

**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Mangsir 2077**

| S.No.   | Date       | Branch          | Location          | Sample taken | Turbidity     | Colour        | P <sup>H</sup> | E.C.        | Total Alkalinity | Total Hardness | Total Iron     | Total Ammonia | Chloride   | F.R.C.         | Total Coliforms         | Remarks      |
|---|------------|-----------------|-------------------|--------------|---------------|---------------|----------------|-------------|------------------|----------------|----------------|---------------|------------|----------------|-------------------------|--------------|
|   |            |                 |                   |              | (NTU)         | (TCU)         |                | µs/cm       | mg/l             | mg/l           | mg/l           | mg/l          | mg/l       | mg/l           | /100ml                  |              |
| <b>National Drinking Water Quality Standard (NDWQS)</b> |            |                 |                   |              | <b>5 (10)</b> | <b>5 (15)</b> | <b>6.5-8.5</b> | <b>1500</b> |                  | <b>500</b>     | <b>0.3 (3)</b> | <b>1.5</b>    | <b>250</b> | <b>0.1-0.2</b> | <b>0 in 95% Samples</b> |              |
| 1   | 2077/08/01 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 37          | 12               | 12             | 0.1            | 0.02          | 3.84       | 0.5            | 0                       | Satisfactory |
| 2   | 2077/08/02 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 42          | 14               | 14             | 0.1            | 0.02          | 5.76       | 0.5            | 0                       | Satisfactory |
| 3   | 2077/08/03 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 38          | 14               | 12             | 0.1            | 0.02          | 5.76       | 0.4            | 0                       | Satisfactory |
| 4   | 2077/08/03 | Lalitpur        | Sainbu W.T.P.     | Treated      | Clear/<5      | <5            | 7.9            | 348         | 100              | 120            | 0.1            | 0.02          | 7.68       | 0.6            | 0                       | Satisfactory |
| 5   | 2077/08/03 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 288         | 66               | 54             | 0.3            | 1.7           | 11.52      | 0.2            | 0                       | Satisfactory |
| 6   | 2077/08/03 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/<5      | <5            | 7.1            | 45          | 14               | 14             | 0.1            | 0.02          | 7.86       | 0.3            | 0                       | Satisfactory |
| 7   | 2077/08/04 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 44          | 16               | 14             | 0.1            | 0.02          | 5.76       | 0.4            | 0                       | Satisfactory |
| 8   | 2077/08/04 | Lalitpur        | Sainbu W.T.P.     | Treated      | Clear/<5      | <5            | 8.0            | 336         | 96               | 118            | 0.1            | 0.02          | 5.76       | 0.6            | 0                       | Satisfactory |
| 9   | 2077/08/04 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 290         | 62               | 56             | 0.3            | 1.6           | 15.36      | 0.3            | 0                       | Satisfactory |
| 10  | 2077/08/04 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/<5      | <5            | 7.5            | 44          | 16               | 14             | 0.1            | 0.02          | 5.76       | 0.2            | 0                       | Satisfactory |
| 11  | 2077/08/05 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 58          | 18               | 16             | 0.1            | 0.02          | 5.76       | 0.5            | 0                       | Satisfactory |
| 12  | 2077/08/05 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 283         | 60               | 54             | 0.3            | 1.6           | 13.44      | 0.3            | 0                       | Satisfactory |
| 13  | 2077/08/05 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/<5      | <5            | 7.6            | 47          | 18               | 14             | 0.1            | 0.02          | 7.86       | 0.8            | 0                       | Satisfactory |
| 14  | 2077/08/06 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 55          | 18               | 16             | 0.1            | 0.02          | 5.76       | 0.5            | 0                       | Satisfactory |
| 15  | 2077/08/07 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 64          | 24               | 20             | 0.1            | 0.02          | 5.76       | 0.6            | 0                       | Satisfactory |
| 16  | 2077/08/07 | Lalitpur        | Sainbu W.T.P.     | Treated      | Clear/<5      | <5            | 8.1            | 330         | 94               | 118            | 0.1            | 0.02          | 5.76       | 0.7            | 0                       | Satisfactory |
| 17  | 2077/08/07 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 277         | 60               | 52             | 0.3            | 1.6           | 7.68       | 0.4            | 0                       | Satisfactory |
| 18  | 2077/08/07 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/<5      | <5            | 7.3            | 40          | 16               | 14             | 0.1            | 0.02          | 5.76       | 0.1            | 0                       | Satisfactory |
| 19  | 2077/08/08 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 62          | 22               | 20             | 0.1            | 0.02          | 5.76       | 0.5            | 0                       | Satisfactory |
| 20  | 2077/08/08 | Lalitpur        | Sainbu W.T.P.     | Treated      | Clear/<5      | <5            | 7.9            | 344         | 100              | 120            | 0.1            | 0.02          | 5.76       | 0.7            | 0                       | Satisfactory |
| 21  | 2077/08/08 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 281         | 62               | 54             | 0.3            | 1.6           | 9.6        | 0.1            | 0                       | Satisfactory |
| 22  | 2077/08/08 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/5       | <5            | 7.2            | 41          | 16               | 14             | 0.1            | 0.02          | 5.76       | 0.1            | 0                       | Satisfactory |
| 23  | 2077/08/09 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 60          | 22               | 18             | 0.1            | 0.02          | 5.76       | 0.5            | 0                       | Satisfactory |
| 24  | 2077/08/09 | Lalitpur        | Sainbu W.T.P.     | Treated      | Clear/<5      | <5            | 7.9            | 343         | 100              | 120            | 0.1            | 0.02          | 5.76       | 0.7            | 0                       | Satisfactory |
| 25  | 2077/08/09 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 280         | 62               | 58             | 0.3            | 1.6           | 11.52      | 0.1            | 0                       | Satisfactory |
| 26  | 2077/08/09 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/9       | <5            | 7.1            | 57          | 16               | 14             | 0.3            | 0.02          | 5.76       | 0.4            | 0                       | Satisfactory |
| 27  | 2077/08/10 | Maharajgunj     | Bansbari WTP      | Treated      | Clear/<5      | <5            | 7.1            | 64          | 24               | 18             | 0.1            | 0.02          | 5.76       | 0.5            | 0                       | Satisfactory |
| 28  | 2077/08/10 | Madhyapur Thimi | Bode WTP          | Treated      | Clear/<5      | <5            | 6.9            | 291         | 66               | 54             | 0.3            | 1.6           | 13.44      | 0.2            | 0                       | Satisfactory |
| 29  | 2077/08/10 | Mahankalchaur   | Mahankalchaur WTP | Treated      | Clear/9       | <5            | 6.9            | 69          | 16               | 20             | 0.3            | 0.02          | 5.76       | 0.3            | 0                       | Satisfactory |

|    |            |                 |                   |         |          |    |     |     |     |     |     |      |       |     |   |              |
|----|------------|-----------------|-------------------|---------|----------|----|-----|-----|-----|-----|-----|------|-------|-----|---|--------------|
| 30 | 2077/08/11 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 53  | 18  | 16  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 31 | 2077/08/11 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 7.9 | 355 | 104 | 122 | 0.1 | 0.02 | 7.68  | 0.8 | 0 | Satisfactory |
| 32 | 2077/08/11 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 289 | 68  | 52  | 0.3 | 1.6  | 19.2  | 0.3 | 0 | Satisfactory |
| 33 | 2077/08/11 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/9  | <5 | 6.9 | 66  | 22  | 20  | 0.3 | 0.02 | 5.76  | 0.6 | 0 | Satisfactory |
| 34 | 2077/08/12 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 61  | 22  | 18  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 35 | 2077/08/12 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 7.9 | 331 | 94  | 118 | 0.1 | 0.02 | 5.76  | 0.8 | 0 | Satisfactory |
| 36 | 2077/08/12 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 291 | 68  | 56  | 0.3 | 1.6  | 15.36 | 0.4 | 0 | Satisfactory |
| 37 | 2077/08/12 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/7  | <5 | 6.7 | 50  | 18  | 14  | 0.3 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |
| 38 | 2077/08/13 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 38  | 14  | 12  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 39 | 2077/08/14 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 64  | 24  | 20  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 40 | 2077/08/14 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 8.2 | 357 | 106 | 124 | 0.1 | 0.02 | 7.68  | 0.8 | 0 | Satisfactory |
| 41 | 2077/08/14 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 314 | 66  | 66  | 0.3 | 1.6  | 28.88 | 0.4 | 0 | Satisfactory |
| 42 | 2077/08/14 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 7.2 | 53  | 16  | 14  | 0.1 | 0.02 | 7.68  | 0.8 | 0 | Satisfactory |
| 43 | 2077/08/15 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 65  | 24  | 20  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 44 | 2077/08/15 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 286 | 66  | 58  | 0.3 | 1.6  | 11.52 | 0.1 | 0 | Satisfactory |
| 45 | 2077/08/15 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/7  | <5 | 7.2 | 68  | 22  | 18  | 0.1 | 0.02 | 9.6   | 0.5 | 0 | Satisfactory |
| 46 | 2077/08/16 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 52  | 18  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 47 | 2077/08/16 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 7.8 | 347 | 100 | 120 | 0.1 | 0.02 | 7.68  | 0.6 | 0 | Satisfactory |
| 48 | 2077/08/16 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 286 | 66  | 60  | 0.3 | 1.6  | 19.2  | 0.2 | 0 | Satisfactory |
| 49 | 2077/08/16 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/8  | <5 | 7.1 | 49  | 16  | 14  | 0.2 | 0.02 | 7.68  | 0.2 | 0 | Satisfactory |
| 50 | 2077/08/17 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 54  | 20  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 51 | 2077/08/17 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 287 | 66  | 60  | 0.3 | 1.6  | 11.52 | 0.4 | 0 | Satisfactory |
| 52 | 2077/08/17 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/7  | <5 | 7.1 | 57  | 18  | 14  | 0.3 | 0.02 | 7.68  | 0.6 | 0 | Satisfactory |
| 53 | 2077/08/18 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 53  | 20  | 16  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 54 | 2077/08/18 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 8.0 | 342 | 98  | 120 | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 55 | 2077/08/18 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 293 | 68  | 60  | 0.3 | 1.6  | 11.52 | 0.2 | 0 | Satisfactory |
| 56 | 2077/08/18 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/5  | <5 | 7.1 | 50  | 16  | 12  | 0.1 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |
| 57 | 2077/08/19 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 55  | 22  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 58 | 2077/08/19 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 56  | 22  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 59 | 2077/08/19 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 284 | 64  | 58  | 0.3 | 1.6  | 11.52 | 0.3 | 0 | Satisfactory |
| 60 | 2077/08/19 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 7.2 | 48  | 18  | 14  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 61 | 2077/08/20 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 51  | 20  | 16  | 0.1 | 0.02 | 5.76  | 0.6 | 0 | Satisfactory |
| 62 | 2077/08/21 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 54  | 20  | 16  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 63 | 2077/08/21 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 7.8 | 350 | 102 | 112 | 0.1 | 0.02 | 7.68  | 0.8 | 0 | Satisfactory |
| 64 | 2077/08/21 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 276 | 62  | 58  | 0.3 | 1.6  | 9.6   | 0.1 | 0 | Satisfactory |
| 65 | 2077/08/21 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 7.3 | 51  | 18  | 14  | 0.1 | 0.02 | 5.76  | 0.2 | 0 | Satisfactory |
| 66 | 2077/08/22 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 55  | 22  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 67 | 2077/08/22 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 8.0 | 329 | 96  | 118 | 0.1 | 0.02 | 5.76  | 0.8 | 0 | Satisfactory |
| 68 | 2077/08/22 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 273 | 60  | 56  | 0.3 | 1.7  | 5.76  | 0.2 | 0 | Satisfactory |
| 69 | 2077/08/22 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 6.9 | 49  | 16  | 14  | 0.1 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |

|    |            |                 |                   |         |          |    |     |     |     |     |     |      |       |     |   |              |
|----|------------|-----------------|-------------------|---------|----------|----|-----|-----|-----|-----|-----|------|-------|-----|---|--------------|
| 70 | 2077/08/23 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 54  | 22  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 71 | 2077/08/23 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 7.9 | 341 | 100 | 120 | 0.1 | 0.02 | 5.76  | 0.6 | 0 | Satisfactory |
| 72 | 2077/08/23 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 280 | 62  | 58  | 0.3 | 1.7  | 7.68  | 0.1 | 0 | Satisfactory |
| 73 | 2077/08/23 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 6.9 | 59  | 18  | 14  | 0.1 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |
| 74 | 2077/08/24 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 64  | 24  | 20  | 0.1 | 0.02 | 5.76  | 0.2 | 0 | Satisfactory |
| 75 | 2077/08/24 | Lalitpur        | Sainbu W.T.P.     | Treated | Clear/<5 | <5 | 7.9 | 336 | 96  | 118 | 0.1 | 0.02 | 5.76  | 0.8 | 0 | Satisfactory |
| 76 | 2077/08/24 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 289 | 66  | 52  | 0.3 | 1.6  | 9.6   | 0.3 | 0 | Satisfactory |
| 77 | 2077/08/24 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 6.7 | 45  | 14  | 12  | 0.1 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |
| 78 | 2077/08/25 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 42  | 16  | 14  | 0.1 | 0.02 | 3.84  | 0.1 | 0 | Satisfactory |
| 79 | 2077/08/25 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.2 | 290 | 66  | 54  | 0.3 | 1.6  | 9.6   | 0.3 | 0 | Satisfactory |
| 80 | 2077/08/25 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/7  | <5 | 7.1 | 60  | 20  | 18  | 0.3 | 0.02 | 9.6   | 0.8 | 0 | Satisfactory |
| 81 | 2077/08/26 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 62  | 22  | 18  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 82 | 2077/08/26 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 269 | 62  | 54  | 0.3 | 1.6  | 9.6   | 0.2 | 0 | Satisfactory |
| 83 | 2077/08/26 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 7.2 | 61  | 20  | 16  | 0.1 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |
| 84 | 2077/08/27 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 58  | 22  | 16  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 85 | 2077/08/28 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.4 | 64  | 24  | 18  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 86 | 2077/08/28 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 244 | 60  | 42  | 0.3 | 1.7  | 5.76  | 0.1 | 0 | Satisfactory |
| 87 | 2077/08/28 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/5  | <5 | 7.3 | 71  | 22  | 16  | 0.1 | 0.02 | 9.6   | 0.8 | 0 | Satisfactory |
| 88 | 2077/08/29 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 58  | 22  | 16  | 0.1 | 0.02 | 5.76  | 0.5 | 0 | Satisfactory |
| 89 | 2077/08/29 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 7.1 | 245 | 60  | 42  | 0.3 | 1.7  | 5.76  | 0.1 | 0 | Satisfactory |
| 90 | 2077/08/29 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 6.7 | 43  | 16  | 14  | 0.1 | 0.02 | 5.76  | 0.1 | 0 | Satisfactory |
| 91 | 2077/08/30 | Maharajgunj     | Bansbari WTP      | Treated | Clear/<5 | <5 | 7.1 | 54  | 20  | 16  | 0.1 | 0.02 | 5.76  | 0.4 | 0 | Satisfactory |
| 92 | 2077/08/30 | Madhyapur Thimi | Bode WTP          | Treated | Clear/<5 | <5 | 6.9 | 245 | 60  | 42  | 0.3 | 1.6  | 11.52 | 0.2 | 0 | Satisfactory |
| 93 | 2077/08/30 | Mahankalchaur   | Mahankalchaur WTP | Treated | Clear/<5 | <5 | 7.1 | 54  | 16  | 14  | 0.1 | 0.02 | 7.68  | 0.4 | 0 | Satisfactory |