

KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Asar 2079

S.No.	Date	Branch	Location	Sample taken	Appearance	Turbidity	Colour	Temp eratur	P ^H	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammoni	Chlorid e	F.R.C.	Total Coliforms	Remarks	
						(NTU)	(TCU)			µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	100/ml		
Units																			
National Drinking Water Quality Standard (NDWQS)						5.00	5		6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.2	0 in 95% Samples		
1	2079/03/01	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.51	<5	23.1	7.0	283.0	90	110	0.10	0.02	10.0	0.87	0	Satisfactory	
2	2079/03/01	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	5.00	<5	21.0	7.2	85.5	20	22	0.20	0.02	8.0	0.14	0	Satisfactory	
3	2079/03/01	Mahankalchaur	Mahankalchaur W.T.P.(2:30 pm	Treated	Clear	4.90	<5	24.0	7.3	99.7	20	22	0.20	0.02	8.0	0.20	0	Satisfactory	
4	2079/03/01	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	0.90	<5	23.0	7.5	108.0	14	20	0.20	0.02	6.0	0.20	0	Satisfactory	
5	2079/03/01	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.30	<5	25.0	6.8	261.2	60	52	0.30	1.80	9.6	0.20	0	Satisfactory	
6	2079/03/01	Maharajgunj	Bansbari W.T.P.	Treated	Clear	4.20	<5	22.0	6.7	57.0	20	18	0.10	0.02	7.7	0.43	0	Satisfactory	
7	2079/03/02	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.41	<5	23.4	7.1	256.0	78	106	0.10	0.02	8.0	0.67	0	Satisfactory	
8	2079/03/02	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	3.34	<5	22.0	7.5	72.2	20	18	0.10	0.02	8.0	0.20	0	Satisfactory	
9	2079/03/02	Mahankalchaur	Mahankalchaur W.T.P.(12:30 pm	Treated	Clear	3.10	<5	21.0	7.7	68.4	20	22	0.10	0.02	8.0	0.52	0	Satisfactory	
10	2079/03/02	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	3.36	<5	22.0	7.0	75.0	20	22	0.10	0.02	8.0	0.27	0	Satisfactory	
11	2079/03/02	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	4.30	<5	23.0	7.4	69.0	20	22	0.10	0.02	8.0	0.31	0	Satisfactory	
12	2079/03/02	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.10	<5	24.0	6.8	263.8	58	52	0.30	1.70	9.6	0.20	0	Satisfactory	
13	2079/03/02	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.73	<5	22.0	6.8	48.3	16	16	0.10	0.02	7.7	0.61	0	Satisfactory	
14	2079/03/03	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.67	<5	23.5	6.9	279.0	88	108	0.10	0.02	10.0	0.71	0	Satisfactory	
15	2079/03/03	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	4.14	<5	26.0	7.1	67.0	24	22	0.10	0.02	8.0	0.20	0	Satisfactory	
16	2079/03/03	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm	Treated	Clear	3.30	<5	27.0	7.1	71.5	24	26	0.10	0.02	8.0	0.10	0	Satisfactory	
17	2079/03/03	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	3.10	<5	25.0	7.4	67.8	20	18	0.10	0.02	6.0	0.20	0	Satisfactory	
18	2079/03/03	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.20	<5	24.0	6.8	286.0	64	56	0.30	1.70	11.5	0.43	0	Satisfactory	
19	2079/03/03	Maharajgunj	Bansbari W.T.P.	Treated	Clear	1.73	<5	23.0	6.8	52.7	16	16	0.10	0.02	7.7	0.52	0	Satisfactory	
20	2079/03/04	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.43	<5	22.0	6.8	54.0	16	16	0.10	0.02	7.7	0.63	0	Satisfactory	
21	2079/03/05	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.06	<5	23.6	6.9	259.0	78	106	0.10	0.02	8.0	0.84	0	Satisfactory	
22	2079/03/05	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	4.03	<5	21.0	7.2	65.9	20	18	0.10	0.02	8.0	0.45	0	Satisfactory	
23	2079/03/05	Mahankalchaur	Mahankalchaur W.T.P.(2:30 pm	Treated	Clear	3.98	<5	28.0	7.2	66.8	20	18	0.10	0.02	8.0	0.20	0	Satisfactory	
24	2079/03/05	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	3.98	<5	20.0	7.2	89.8	20	22	0.10	0.02	8.0	0.80	0	Satisfactory	
25	2079/03/05	Maharajgunj	Bansbari W.T.P.	Treated	Clear	1.10	<5	22.0	6.8	57.5	16	16	0.10	0.02	7.7	0.54	0	Satisfactory	
26	2079/03/06	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.24	<5	23.7	7.2	280.0	88	108	0.10	0.02	10.0	0.63	0	Satisfactory	
27	2079/03/06	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	5.00	<5	23.0	7.8	114.7	20	18	0.10	0.02	8.0	0.34	0	Satisfactory	
28	2079/03/06	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	3.26	<5	20.0	7.1	91.8	20	18	0.10	0.02	8.0	0.80	0	Satisfactory	
29	2079/03/06	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	3.60	<5	23.0	7.1	84.2	20	18	0.10	0.02	8.0	0.78	0	Satisfactory	
30	2079/03/06	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.90	<5	25.0	6.9	321.0	66	62	0.30	1.50	19.2	0.80	0	Satisfactory	
31	2079/03/06	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.16	<5	22.0	6.8	48.4	16	14	0.10	0.02	7.7	0.52	0	Satisfactory	
32	2079/03/07	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.16	<5	24.1	7.1	265.0	86	106	0.10	0.02	8.0	0.67	0	Satisfactory	
33	2079/03/07	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	3.49	<5	21.0	7.9	79.6	20	18	0.10	0.02	8.0	0.39	0	Satisfactory	
34	2079/03/07	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	2.95	<5	21.0	7.3	72.9	20	18	0.10	0.02	8.0	0.68	0	Satisfactory	

35	2079/03/07	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	2.82	<5	21.0	7.3	71.2	20	18	0.10	0.02	8.0	0.57	0	Satisfactory
36	2079/03/07	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.13	<5	23.0	7.0	51.0	16	16	0.10	0.02	7.7	0.64	0	Satisfactory
37	2079/03/08	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.31	<5	24.2	7.0	271.0	80	106	0.10	0.02	10.0	0.89	0	Satisfactory
38	2079/03/08	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	24.0	7.6	72.7	12	16	0.10	0.02	8.0	0.20	0	Satisfactory
39	2079/03/08	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.85	<5	26.0	7.3	80.5	12	16	0.10	0.02	8.0	0.47	0	Satisfactory
40	2079/03/08	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	1.24	<5	26.0	7.3	100.0	22	20	0.10	0.02	8.0	0.20	0	Satisfactory
41	2079/03/08	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.72	<5	24.0	6.8	294.7	64	58	0.30	1.50	13.4	0.20	0	Satisfactory
42	2079/03/08	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.14	<5	22.0	6.9	60.2	20	18	0.10	0.02	7.7	0.83	0	Satisfactory
43	2079/03/09	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.13	<5	24.1	7.3	279.0	80	106	0.10	0.02	10.0	0.20	0	Satisfactory
44	2079/03/09	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	22.0	7.1	63.0	12	16	0.10	0.02	8.0	0.20	0	Satisfactory
45	2079/03/09	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	22.0	7.2	62.6	12	16	0.10	0.02	8.0	0.49	0	Satisfactory
46	2079/03/09	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	24.0	8.0	57.4	18	20	0.20	0.02	8.0	0.60	0	Satisfactory
47	2079/03/09	Mahankalchaur	Mahankalchaur W.T.P.	Treated	Clear	5.00	<5	27.0	7.3	60.1	12	16	0.10	0.02	8.0	0.18	0	Satisfactory
48	2079/03/09	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.10	<5	24.0	6.7	256.5	58	50	0.30	1.70	9.6	0.20	0	Satisfactory
49	2079/03/09	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.26	<5	23.0	6.9	57.1	20	18	0.10	0.02	7.7	0.80	0	Satisfactory
50	2079/03/10	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.34	<5	24.6	7.5	299.0	82	114	0.10	0.02	14.0	0.80	0	Satisfactory
51	2079/03/10	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	3.77	<5	22.0	6.9	66.4	14	16	0.10	0.02	8.0	0.56	0	Satisfactory
52	2079/03/10	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	3.20	<5	28.0	7.5	71.6	14	16	0.10	0.02	8.0	0.52	0	Satisfactory
53	2079/03/10	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.82	<5	24.0	7.0	274.0	60	52	0.30	1.60	9.6	0.14	0	Satisfactory
54	2079/03/10	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.52	<5	21.0	7.1	58.3	20	18	0.10	0.02	7.7	0.80	0	Satisfactory
55	2079/03/11	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.10	<5	25.0	7.0	272.4	60	52	0.30	1.70	13.4	0.42	0	Satisfactory
56	2079/03/11	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.48	<5	22.0	6.8	49.3	16	16	0.10	0.02	7.7	0.80	0	Satisfactory
57	2079/03/12	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.25	<5	24.5	7.9	331.0	86	120	0.10	0.02	22.0	0.80	0	Satisfactory
58	2079/03/12	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	21.0	7.3	75.2	14	18	0.10	0.02	10.0	0.80	0	Satisfactory
59	2079/03/12	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	22.0	7.9	59.5	18	20	0.10	0.02	8.0	0.49	0	Satisfactory
60	2079/03/12	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.90	<5	22.0	6.8	290.3	60	58	0.30	1.70	9.6	0.73	0	Satisfactory
61	2079/03/12	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	22.0	7.3	56.7	18	20	0.10	0.02	8.0	0.80	0	Satisfactory
62	2079/03/12	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.94	<5	25.0	6.8	290.3	64	56	0.30	1.70	11.5	0.80	0	Satisfactory
63	2079/03/12	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.83	<5	23.0	6.7	53.7	16	16	0.10	0.02	7.7	0.62	0	Satisfactory
64	2079/03/13	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.16	<5	24.6	7.5	285.0	82	110	0.10	0.02	16.0	0.80	0	Satisfactory
65	2079/03/13	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	24.0	7.3	58.1	18	20	0.10	0.02	8.0	0.80	0	Satisfactory
66	2079/03/13	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	22.0	7.1	58.2	12	14	0.10	0.02	8.0	0.80	0	Satisfactory
67	2079/03/13	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	4.50	<5	22.0	6.7	54.5	12	14	0.10	0.02	8.0	0.72	0	Satisfactory
68	2079/03/13	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.00	<5	25.0	6.8	285.1	62	54	0.30	1.70	11.5	0.81	0	Satisfactory
69	2079/03/13	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.54	<5	22.0	6.9	59.6	20	18	0.10	0.02	7.7	0.80	0	Satisfactory
70	2079/03/14	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.79	<5	25.3	7.5	276.0	80	110	0.10	0.02	10.0	0.80	0	Satisfactory
71	2079/03/14	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.30	<5	25.0	6.5	292.0	62	58	0.30	1.70	9.6	0.30	0	Satisfactory
72	2079/03/14	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	4.80	<5	25.0	7.1	52.1	16	20	0.10	0.02	8.0	0.84	0	Satisfactory
73	2079/03/14	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.50	<5	21.0	7.7	74.6	18	20	0.10	0.02	8.0	0.30	0	Satisfactory
74	2079/03/14	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	1.85	<5	21.0	7.4	62.0	18	20	0.10	0.02	8.0	0.40	0	Satisfactory
75	2079/03/14	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.10	<5	25.0	6.9	278.8	62	52	0.30	1.50	11.5	0.32	0	Satisfactory
76	2079/03/14	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.43	<5	21.0	6.8	46.2	16	14	0.10	0.02	7.7	0.72	0	Satisfactory
77	2079/03/15	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.65	<5	25.5	7.5	292.0	84	114	0.10	0.02	12.0	0.80	0	Satisfactory
78	2079/03/15	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	3.10	<5	21.0	7.3	52.8	14	16	0.10	0.02	8.0	0.83	0	Satisfactory
79	2079/03/15	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.10	<5	22.0	7.2	55.3	14	16	0.10	0.02	8.0	0.80	0	Satisfactory
80	2079/03/15	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	21.0	7.2	70.2	18	20	0.10	0.02	8.0	0.80	0	Satisfactory
81	2079/03/15	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.86	<5	24.0	6.9	286.6	65	56	0.30	1.80	18.0	0.10	0	Satisfactory
83	2079/03/16	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.36	<5	25.6	7.4	284.0	82	112	0.10	0.02	10.0	0.89	0	Satisfactory
84	2079/03/16	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	21.0	6.8	66.8	18	20	0.20	0.02	8.0	0.19	0	Satisfactory

85	2079/03/16	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	5.00	<5	21.0	6.7	66.4	18	20	0.20	0.02	8.0	0.43	0	Satisfactory
86	2079/03/16	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	21.0	7.6	128.2	22	26	0.10	0.02	10.0	0.80	0	Satisfactory
87	2079/03/16	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	21.0	7.7	62.7	18	20	0.10	0.02	8.0	0.30	0	Satisfactory
88	2079/03/16	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.90	<5	24.0	6.9	301.0	64	62	0.20	1.70	11.5	0.80	0	Satisfactory
89	2079/03/16	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.62	<5	20.0	6.6	44.6	14	14	0.10	0.02	7.7	0.80	0	Satisfactory
90	2079/03/17	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.14	<5	25.5	7.6	289.0	82	116	0.10	0.02	12.0	0.77	0	Satisfactory
91	2079/03/17	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	2.83	<5	21.0	7.6	54.4	12	14	0.10	0.02	6.0	0.47	0	Satisfactory
92	2079/03/17	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	2.76	<5	21.0	7.6	54.4	12	14	0.10	0.02	6.0	0.45	0	Satisfactory
93	2079/03/17	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	2.81	<5	22.0	7.6	56.1	12	14	0.10	0.02	6.0	0.80	0	Satisfactory
94	2079/03/17	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.80	<5	24.0	6.8	277.5	62	52	0.20	1.60	9.6	0.35	0	Satisfactory
95	2079/03/17	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.35	<5	22.0	6.9	45.2	14	14	0.10	0.02	7.7	0.74	0	Satisfactory
96	2079/03/18	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	4.20	<5	22.0	7.5	50.3	12	14	0.10	0.02	8.0	0.94	0	Satisfactory
97	2079/03/18	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.10	<5	22.0	7.6	57.2	12	14	0.10	0.02	8.0	0.52	0	Satisfactory
98	2079/03/18	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.98	<5	24.0	6.7	277.3	62	52	0.20	1.60	11.5	0.50	0	Satisfactory
99	2079/03/18	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.46	<5	20.0	7.1	46.0	16	14	0.10	0.02	7.7	0.73	0	Satisfactory
100	2079/03/19	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	22.0	8.5	103.1	26	28	0.10	0.02	8.0	0.56	0	Satisfactory
101	2079/03/19	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.02	<5	21.0	7.7	50.6	12	14	0.10	0.02	8.0	0.66	0	Satisfactory
102	2079/03/19	Madhyapur Thimi	Bode W.T.P.(10:30am)	Treated	Clear	2.30	<5	24.0	6.9	275.2	62	52	0.30	1.60	11.5	0.19	0	Satisfactory
103	2079/03/19	Madhyapur Thimi	Bode W.T.P.(2:30pm)	Treated	Clear	2.20	<5	24.0	6.8	276.0	60	52	0.30	1.60	11.5	0.80	0	Satisfactory
104	2079/03/19	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.47	<5	21.0	7.1	55.3	16	18	0.10	0.02	3.8	0.80	0	Satisfactory
108	2079/03/19	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.50	<5	22.0	6.9	58.3	16	16	0.10	0.02	7.7	0.67	0	Satisfactory
109	2079/03/20	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	22.0	7.8	77.1	14	16	0.10	0.02	8.0	0.69	0	Satisfactory
110	2079/03/20	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	5.00	<5	23.0	7.8	79.6	14	16	0.10	0.02	8.0	0.80	0	Satisfactory
112	2079/03/20	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	23.0	7.8	82.6	16	20	0.10	0.02	8.0	0.70	0	Satisfactory
113	2079/03/20	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	23.0	7.7	73.2	14	16	0.10	0.02	8.0	0.40	0	Satisfactory
111	2079/03/20	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.53	<5	25.0	6.8	44.4	8	10	0.10	0.02	6.0	0.81	0	Satisfactory
114	2079/03/20	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.96	<5	25.0	6.7	274.8	60	52	0.20	1.50	11.5	0.86	0	Satisfactory
115	2079/03/20	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.51	<5	22.0	6.8	40.2	14	14	0.10	0.02	7.7	0.76	0	Satisfactory
116	2079/03/21	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	1.82	<5	22.0	7.6	63.4	14	16	0.10	0.02	8.0	0.85	0	Satisfactory
117	2079/03/21	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	3.74	<5	22.0	7.7	61.6	14	16	0.10	0.02	8.0	0.87	0	Satisfactory
118	2079/03/21	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	1.55	<5	23.0	7.5	61.1	14	16	0.10	0.02	6.0	0.66	0	Satisfactory
119	2079/03/21	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	2.12	<5	21.0	7.3	53.1	14	18	0.10	0.02	6.0	0.78	0	Satisfactory
120	2079/03/21	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.90	<5	25.0	7.1	289.9	62	54	0.20	1.50	11.5	0.44	0	Satisfactory
121	2079/03/21	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.28	<5	21.0	6.7	44.7	14	14	0.10	0.02	7.7	0.80	0	Satisfactory
122	2079/03/22	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	24.0	7.2	79.0	14	16	0.10	0.02	8.0	0.80	0	Satisfactory
123	2079/03/22	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	4.32	<5	26.0	7.4	71.0	14	16	0.10	0.02	6.0	0.35	0	Satisfactory
124	2079/03/22	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	26.0	7.4	60.0	14	16	0.10	0.02	8.0	0.10	0	Satisfactory
125	2079/03/22	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	2.10	<5	22.0	7.4	68.4	16	18	0.10	0.02	6.0	0.89	0	Satisfactory
126	2079/03/22	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.90	<5	26.0	6.9	268.0	58	50	0.20	1.50	11.5	0.16	0	Satisfactory
127	2079/03/22	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.47	<5	24.0	6.6	59.7	16	14	0.10	0.02	7.7	0.87	0	Satisfactory
128	2079/03/23	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	22.0	8.1	75.2	14	16	0.10	0.02	8.0	0.45	0	Satisfactory
129	2079/03/23	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	5.00	<5	22.0	6.9	53.0	14	16	0.10	0.02	8.0	0.19	0	Satisfactory
130	2079/03/23	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	22.0	7.2	58.0	14	16	0.10	0.02	8.0	0.64	0	Satisfactory
131	2079/03/23	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	2.36	<5	22.0	7.2	58.2	14	16	0.10	0.02	6.0	0.56	0	Satisfactory
132	2079/03/23	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.10	<5	26.0	7.1	294.0	62	54	0.30	1.50	9.6	0.40	0	Satisfactory
133	2079/03/23	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.54	<5	24.0	6.6	53.2	16	16	0.10	0.02	9.6	0.87	0	Satisfactory
134	2079/03/24	Mahankalchaur	Mahankalchaur W.T.P.(10:30am)	Treated	Clear	5.00	<5	21.0	7.1	57.9	14	16	0.30	0.02	4.0	0.67	0	Satisfactory
135	2079/03/24	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm)	Treated	Clear	5.00	<5	25.0	7.2	66.6	14	16	0.10	0.02	8.0	0.78	0	Satisfactory
136	2079/03/24	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	22.0	7.2	67.1	14	16	0.10	0.02	8.0	0.67	0	Satisfactory

137	2079/03/24	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.60	<5	26.0	6.8	276.7	60	52	0.30	1.50	13.4	0.52	0	Satisfactory
138	2079/03/24	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.58	<5	21.0	6.7	47.7	16	14	0.10	0.02	7.7	0.80	0	Satisfactory
139	2079/03/25	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	5.00	<5	21.0	7.3	65.2	14	16	0.10	0.02	8.0	0.22	0	Satisfactory
140	2079/03/25	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm	Treated	Clear	5.00	<5	23.0	7.2	66.1	14	16	0.10	0.02	8.0	0.88	0	Satisfactory
141	2079/03/25	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	25.0	7.2	67.0	14	16	0.10	0.02	8.0	0.75	0	Satisfactory
142	2079/03/25	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.46	<5	21.0	6.7	48.1	16	14	0.10	0.02	7.7	0.75	0	Satisfactory
143	2079/03/26	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	5.00	<5	22.0	7.2	64.3	14	16	0.10	0.02	8.0	0.67	0	Satisfactory
144	2079/03/26	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.80	<5	22.0	7.3	62.4	14	16	0.10	0.02	8.0	0.17	0	Satisfactory
145	2079/03/26	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	4.50	<5	22.0	7.3	63.2	14	16	0.10	0.02	8.0	0.69	0	Satisfactory
146	2079/03/26	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.22	<5	21.0	6.7	39.4	14	14	0.10	0.02	7.7	0.87	0	Satisfactory
147	2079/03/27	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.18	<5	26.2	7.7	293.0	84	114	0.10	0.02	12.0	0.76	0	Satisfactory
148	2079/03/27	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	4.80	<5	21.0	6.9	48.9	12	14	0.10	0.02	6.0	0.18	0	Satisfactory
149	2079/03/27	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm	Treated	Clear	4.30	<5	21.0	7.4	60.9	16	14	0.10	0.02	8.0	0.52	0	Satisfactory
150	2079/03/27	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.52	<5	22.0	7.2	60.8	14	16	0.10	0.02	8.0	0.44	0	Satisfactory
151	2079/03/27	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	21.0	7.4	58.2	14	16	0.10	0.02	8.0	0.28	0	Satisfactory
152	2079/03/27	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.60	<5	26.0	6.8	270.0	58	52	0.30	1.50	11.5	0.32	0	Satisfactory
153	2079/03/27	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.38	<5	20.0	6.6	43.0	14	14	0.10	0.02	7.7	0.76	0	Satisfactory
154	2079/03/28	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.18	<5	26.3	7.7	276.0	80	110	0.10	0.02	10.0	0.56	0	Satisfactory
155	2079/03/28	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	3.56	<5	23.0	7.6	72.0	14	16	0.10	0.02	8.0	0.80	0	Satisfactory
156	2079/03/28	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	4.20	<5	23.0	7.5	73.2	14	16	0.10	0.02	8.0	0.80	0	Satisfactory
157	2079/03/28	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	4.10	<5	22.0	7.6	72.0	14	16	0.10	0.02	8.0	0.80	0	Satisfactory
158	2079/03/28	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	0.91	<5	26.0	6.7	292.4	62	54	0.30	1.50	15.4	0.80	0	Satisfactory
159	2079/03/28	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.14	<5	23.0	6.6	38.3	12	14	0.10	0.02	7.7	0.76	0	Satisfactory
160	2079/03/29	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	5.00	<5	22.0	7.4	44.0	12	10	0.10	0.02	8.0	0.60	0	Satisfactory
161	2079/03/29	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm	Treated	Clear	5.00	<5	23.0	7.3	43.5	12	10	0.10	0.02	8.0	0.72	0	Satisfactory
162	2079/03/29	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	23.0	7.3	43.8	12	10	0.10	0.02	8.0	0.36	0	Satisfactory
163	2079/03/29	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	5.00	<5	23.0	7.9	58.2	14	16	0.10	0.02	8.0	0.70	0	Satisfactory
165	2079/03/29	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.30	<5	26.0	6.8	284.3	62	52	0.20	1.50	9.6	0.21	0	Satisfactory
166	2079/03/29	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.18	<5	24.0	6.9	43.7	14	14	0.10	0.02	9.6	0.80	0	Satisfactory
167	2079/03/30	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	3.64	<5	22.0	7.5	62.8	12	14	0.10	0.02	8.0	0.78	0	Satisfactory
168	2079/03/30	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm	Treated	Clear	2.84	<5	23.0	7.5	63.0	12	14	0.10	0.02	8.0	0.84	0	Satisfactory
169	2079/03/30	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	2.96	<5	23.0	7.6	63.7	12	14	0.10	0.02	8.0	0.67	0	Satisfactory
170	2079/03/30	Mahankalchaur	Mahankalchaur W.T.P.(4:30pm)	Treated	Clear	2.70	<5	28.0	7.9	69.3	14	16	0.10	0.02	8.0	0.74	0	Satisfactory
171	2079/03/30	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.50	<5	26.0	6.8	264.6	58	50	0.20	1.50	9.6	0.20	0	Satisfactory
172	2079/03/30	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.24	<5	23.0	6.9	37.6	12	12	0.10	0.02	7.7	0.37	0	Satisfactory
173	2079/03/31	Mahankalchaur	Mahankalchaur W.T.P.(10:30am	Treated	Clear	5.00	<5	24.0	7.2	47.6	12	14	0.10	0.02	8.0	0.10	0	Satisfactory
174	2079/03/31	Mahankalchaur	Mahankalchaur W.T.P.(12:30pm	Treated	Clear	5.00	<5	24.0	7.4	43.8	14	16	0.10	0.02	8.0	0.13	0	Satisfactory
175	2079/03/31	Mahankalchaur	Mahankalchaur W.T.P.(2:30pm)	Treated	Clear	5.00	<5	24.0	7.4	61.3	14	16	0.10	0.02	8.0	0.70	0	Satisfactory
176	2079/03/31	Madhyapur Thimi	Bode W.T.P.	Treated	Clear	1.20	<5	26.0	6.7	295.7	64	56	0.20	1.50	19.2	0.82	0	Satisfactory
177	2079/03/31	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.42	<5	23.0	6.9	39.2	12	14	0.10	0.02	7.7	0.68	0	Satisfactory
178	2079/3/32	Maharajgunj	Bansbari W.T.P.	Treated	Clear	0.32	<5	23.0	6.8	38.4	12	14	0.10	0.02	7.7	0.72	0	Satisfactory