

**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Jestha 2079**

S.No.	Date	Branch	Location	Sample taken	Turbidity	Colour	P <sup>H</sup>	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
Units					(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	/100ml	
National Drinking Water Quality Standard (NDWQS)					5 (10)	5 (15)	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.2	0 in 95% Samples	
1	2079/02/01	Maharajgunj	Bansbari WTP	Treated	0.95	<5	7.1	72	24	24	0.1	0.02	5.76	0.4	0	Satisfactory
2	2079/02/01	Madhyapur Thimi	Bode WTP	Treated	1.20	<5	6.9	312	66	64	0.3	1.7	13.44	0.3	0	Satisfactory
3	2079/02/01	Mahankalchaur	Mahankalchaur WTP	Treated	0.76	<5	7.7	69	20	22	0.1	0.02	6.00	0.3	0	Satisfactory
4	2079/02/01	Maharajgunj	Bansbari Inlet	Treated	1.61	<5	7.5	74	22	30	0.1	0.02	5.76	0.21	0	Satisfactory
5	2079/02/01	Maharajgunj	Bansbari Outlet	Treated	2.06	<5	7.5	75	22	30	0.1	0.02	5.76	0.32	0	Satisfactory
6	2079/02/01	Maharajgunj	Panipokhari Inlet	Treated	2.16	<5	7.5	75	22	30	0.1	0.02	5.76	0.18	0	Satisfactory
7	2079/02/01	Maharajgunj	Panipokhari Outlet	Treated	2.45	<5	7.5	76	22	30	0.1	0.02	5.76	0.26	0	Satisfactory
8	2079/02/01	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.30	<5	7.5	90	24	28	0.1	0.02	6.00	0.5	0	Satisfactory
9	2079/02/01	Mahankalchaur	Mahankalchaur Melamchi outlet	Treated	0.84	<5	7.7	88	24	28	0.1	0.02	6.00	0.4	0	Satisfactory
10	2079/02/01	Chhetrapati	Balaju inlet	Treated	2.88	<5	7.4	101	24	28	0.1	0.02	6.00	0.42	0	Satisfactory
11	2079/02/01	Kirtipur	Kirtipur SRT	Treated	1.50	<5	7.6	103	24	28	0.1	0.02	6.00	0.26	0	Satisfactory
12	2079/02/01	Baneshwar	Minbhawan SRT	Treated	0.39	<5	7.8	92	24	28	0.1	0.02	6.00	0.26	0	Satisfactory
13	2079/02/01	Lalitpur	Khumaltar SRT	Treated	1.16	<5	7.5	89	24	28	0.1	0.02	6.00	0.19	0	Satisfactory
14	2079/02/01	Tripureshwar	Anamnagar SRT	Treated	0.48	<5	7.5	99	24	28	0.1	0.02	6.00	0.14	0	Satisfactory
15	2079/02/01	Madhyapur Thimi	Tigani SRT	Treated	0.90	<5	7.4	78	20	26	0.1	0.02	5.76	0.1	0	Satisfactory
16	2079/02/01	Maharajgunj	Bansbari inlet	Treated	1.61	<5	7.5	74	24	30	0.1	0.02	5.76	0.21	0	Satisfactory
17	2079/02/01	Maharajgunj	Bansbari Outlet	Treated	2.06	<5	7.5	75	24	30	0.1	0.02	5.76	0.32	0	Satisfactory
18	2079/02/01	Maharajgunj	Panipokhari inlet	Treated	2.16	<5	7.5	75	24	30	0.1	0.02	5.76	0.18	0	Satisfactory
19	2079/02/01	Maharajgunj	Panipokhari Outlet	Treated	2.45	<5	7.5	76	24	30	0.1	0.02	5.76	0.26	0	Satisfactory
20	2079/02/02	Maharajgunj	Bansbari WTP	Treated	0.66	<5	7.1	69	24	24	0.1	0.02	5.76	0.4	0	Satisfactory
21	2079/02/02	Madhyapur Thimi	Bode WTP	Treated	1.30	<5	6.9	332	70	66	0.3	1.7	19.20	0.8	0	Satisfactory
22	2079/02/02	Mahankalchaur	Mahankalchaur WTP	Treated	0.74	<5	7.9	81	22	24	0.1	0.02	6.00	0.1	0	Satisfactory
23	2079/02/02	Maharajgunj	Bansbari Inlet	Treated	0.93	<5	7.5	74	22	30	0.1	0.02	5.76	0.23	0	Satisfactory
24	2079/02/02	Maharajgunj	Bansbari Outlet	Treated	1.04	<5	7.5	75	22	30	0.1	0.02	5.76	0.33	0	Satisfactory
25	2079/02/02	Maharajgunj	Panipokhari Inlet	Treated	1.24	<5	7.6	75	22	30	0.1	0.02	5.76	0.27	0	Satisfactory
26	2079/02/02	Maharajgunj	Panipokhari Outlet	Treated	1.16	<5	7.5	76	22	30	0.1	0.02	5.76	0.26	0	Satisfactory
27	2079/02/02	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.15	<5	7.9	91	24	32	0.1	0.02	6.00	0.41	0	Satisfactory
28	2079/02/02	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.30	<5	7.9	100	24	30	0.1	0.02	6.00	0.38	0	Satisfactory
29	2079/02/02	Chhetrapati	Balaju inlet	Treated	0.63	<5	7.7	93	24	30	0.1	0.02	6.00	0.41	0	Satisfactory
30	2079/02/02	Kirtipur	Kirtipur SRT	Treated	0.65	<5	7.8	99	24	30	0.1	0.02	6.00	0.17	0	Satisfactory
31	2079/02/02	Baneshwar	Minbhawan SRT	Treated	0.71	<5	7.7	92	24	30	0.1	0.02	6.00	0.17	0	Satisfactory

32	2079/02/02	Lalitpur	Khumaltar SRT	Treated	0.56	<5	7.3	93	24	30	0.1	0.02	6.00	0.32	0	Satisfactory
33	2079/02/02	Madhyapur Thimi	Tigani SRT	Treated	0.20	<5	7.5	76	20	30	0.1	0.02	3.84	0.14	0	Satisfactory
34	2079/02/02	Maharajgunj	Bansbari inlet	Treated	0.93	<5	7.5	74	22	30	0.1	0.02	5.76	0.23	0	Satisfactory
35	2079/02/02	Maharajgunj	Bansbari Outlet	Treated	1.04	<5	7.5	75	22	30	0.1	0.02	5.76	0.33	0	Satisfactory
36	2079/02/02	Maharajgunj	Panipokhari inlet	Treated	1.24	<5	7.6	75	22	30	0.1	0.02	5.76	0.27	0	Satisfactory
37	2079/02/02	Maharajgunj	Panipokhari Outlet	Treated	1.16	<5	7.5	76	22	30	0.1	0.02	5.76	0.26	0	Satisfactory
38	2079/02/02	Tripureshwar	Anamnagar SRT	Treated	0.71	<5	7.4	90	24	32	0.1	0.02	6.00	0.17	0	Satisfactory
39	2079/02/03	Maharajgunj	Bansbari WTP	Treated	1.76	<5	7.1	72	24	26	0.1	0.02	5.76	0.3	0	Satisfactory
40	2079/02/03	Madhyapur Thimi	Bode WTP	Treated	1.50	<5	6.8	287	64	58	0.3	1.7	9.60	0.1	0	Satisfactory
41	2079/02/03	Lalitpur	Sainbu WTP	Treated	3.18	<5	7.1	251	78	110	0.1	0.02	7.68	0.5	0	Satisfactory
42	2079/02/03	Mahankalchaur	Mahankalchaur WTP	Treated	7.30	<5	7.6	76	12	18	0.1	0.02	8.00	0.3	0	Satisfactory
43	2079/02/03	Maharajgunj	Panipokhari Inlet	Treated	5.11	<5	7.6	75	22	28	0.1	0.02	5.76	0.24	0	Satisfactory
44	2079/02/03	Maharajgunj	Panipokhari Outlet	Treated	4.43	<5	7.6	74	22	28	0.1	0.02	5.76	0.18	0	Satisfactory
45	2079/02/03	Maharajgunj	Bansbari Inlet	Treated	4.52	<5	7.6	74	22	28	0.1	0.02	5.76	0.42	0	Satisfactory
46	2079/02/03	Maharajgunj	Bansbari Outlet	Treated	3.68	<5	7.6	73	22	28	0.1	0.02	5.76	0.37	0	Satisfactory
47	2079/02/03	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.01	<5	7.7	87	20	30	0.1	0.02	6.00	0.45	0	Satisfactory
48	2079/02/03	Kirtipur	Kirtipur SRT	Treated	0.70	<5	7.9	97	22	30	0.1	0.02	8.00	0.39	0	Satisfactory
49	2079/02/03	Chhetrapati	Balaju inlet	Treated	4.84	<5	7.9	100	24	28	0.1	0.02	6.00	0.35	0	Satisfactory
50	2079/02/03	Tripureshwar	Anamnagar SRT	Treated	0.49	<5	7.5	97	22	30	0.1	0.02	6.00	0.21	0	Satisfactory
51	2079/02/03	Baneshwar	Minbhawan SRT	Treated	0.81	<5	7.7	90	24	30	0.1	0.02	6.00	0.34	0	Satisfactory
52	2079/02/03	Lalitpur	Khumaltar SRT	Treated	0.48	<5	7.6	94	24	30	0.1	0.02	6.00	0.54	0	Satisfactory
53	2079/02/03	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.20	<5	7.4	88	20	30	0.1	0.02	6.00	0.54	0	Satisfactory
54	2079/02/03	Madhyapur Thimi	Tigani SRT	Treated	0.50	<5	7.1	75	18	26	0.1	0.02	5.76	0.13	0	Satisfactory
55	2079/02/03	Maharajgunj	Panipokhari inlet	Treated	5.10	<5	7.6	75	22	28	0.1	0.02	5.76	0.24	0	Satisfactory
56	2079/02/03	Maharajgunj	Panipokhari Outlet	Treated	4.40	<5	7.6	74	22	28	0.1	0.02	5.76	0.18	0	Satisfactory
57	2079/02/03	Maharajgunj	Bansbari inlet	Treated	4.52	<5	7.6	74	22	28	0.1	0.02	5.76	0.42	0	Satisfactory
58	2079/02/03	Maharajgunj	Bansbari Outlet	Treated	3.68	<5	7.5	74	22	28	0.1	0.02	5.76	0.37	0	Satisfactory
59	2079/02/03	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.96	<5	7.4	93	22	32	0.1	0.02	6.00	0.5	0	Satisfactory
60	2079/02/04	Maharajgunj	Bansbari WTP	Treated	0.78	<5	7.1	65	24	20	0.1	0.02	5.76	0.3	0	Satisfactory
61	2079/02/04	Madhyapur Thimi	Bode WTP	Treated	1.80	<5	6.9	293	66	62	0.3	1.8	11.52	0.1	0	Satisfactory
62	2079/02/04	Lalitpur	Sainbu WTP	Treated	1.66	<5	7.3	250	78	110	0.1	0.02	7.68	0.7	0	Satisfactory
63	2079/02/04	Mahankalchaur	Mahankalchaur WTP	Treated	5.20	<5	6.9	88	22	26	0.1	0.02	6.00	0.4	0	Satisfactory
64	2079/02/04	Maharajgunj	Bansbari Inlet	Treated	1.27	<5	7.6	78	22	28	0.1	0.02	5.76	0.27	0	Satisfactory
65	2079/02/04	Maharajgunj	Bansbari Outlet	Treated	1.19	<5	7.6	74	22	28	0.1	0.02	5.76	0.25	0	Satisfactory
66	2079/02/04	Maharajgunj	Panipokhari Inlet	Treated	2.78	<5	7.6	76	22	28	0.1	0.02	5.76	0.34	0	Satisfactory
67	2079/02/04	Maharajgunj	Panipokhari Outlet	Treated	2.30	<5	7.6	76	22	28	0.1	0.02	5.76	0.42	0	Satisfactory
68	2079/02/04	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.79	<5	7.7	85	20	22	0.1	0.02	6.00	0.2	0	Satisfactory
69	2079/02/04	Kirtipur	Kirtipur SRT	Treated	0.81	<5	7.8	97	22	26	0.1	0.02	6.00	0.27	0	Satisfactory
70	2079/02/04	Chhetrapati	Balaju inlet	Treated	0.93	<5	7.4	91	20	22	0.1	0.02	6.00	0.29	0	Satisfactory
71	2079/02/04	Tripureshwar	Anamnagar SRT	Treated	0.72	<5	7.3	92	24	30	0.1	0.02	6.00	0.1	0	Satisfactory
72	2079/02/04	Lalitpur	Khumaltar SRT	Treated	3.26	<5	7.4	94	24	30	0.1	0.02	6.00	0.28	0	Satisfactory

73	2079/02/04	Baneshwar	Minbhawan SRT	Treated	0.64	<5	7.2	91	22	26	0.1	0.02	6.00	0.1	0	Satisfactory
74	2079/02/04	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.82	<5	7.3	89	14	18	0.1	0.02	6.00	0.41	0	Satisfactory
75	2079/02/04	Madhyapur Thimi	Tigani SRT	Treated	0.60	<5	7.2	75	20	26	0.1	0.02	3.84	0.22	0	Satisfactory
76	2079/02/04	Maharajgunj	Bansbari inlet	Treated	1.27	<5	7.6	74	22	28	0.1	0.02	5.76	0.27	0	Satisfactory
77	2079/02/04	Maharajgunj	Bansbari Outlet	Treated	1.19	<5	7.6	74	22	28	0.1	0.02	5.76	0.25	0	Satisfactory
78	2079/02/04	Maharajgunj	Panipokhari inlet	Treated	2.78	<5	7.6	76	22	28	0.1	0.02	5.76	0.34	0	Satisfactory
79	2079/02/04	Maharajgunj	Panipokhari Outlet	Treated	2.30	<5	7.6	76	22	28	0.1	0.02	5.76	0.42	0	Satisfactory
80	2079/02/04	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	2.10	<5	7.2	90	24	26	0.1	0.02	6.00	0.6	0	Satisfactory
81	2079/02/04	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	3.90	<5	7.4	91	24	26	0.1	0.02	6.00	0.6	0	Satisfactory
82	2079/02/05	Maharajgunj	Bansbari WTP	Treated	0.46	<5	7.3	62	24	20	0.1	0.02	5.76	0.3	0	Satisfactory
83	2079/02/05	Madhyapur Thimi	Bode WTP	Treated	1.50	<5	6.8	298	66	64	0.3	1.8	11.52	0.4	0	Satisfactory
84	2079/02/05	Lalitpur	Sainbu WTP	Treated	3.41	<5	7.2	248	76	108	0.1	0.02	7.68	0.8	0	Satisfactory
85	2079/02/05	Mahankalchaur	Mahankalchaur WTP	Treated	3.70	<5	7.1	69	14	20	0.1	0.02	10.00	0.2	0	Satisfactory
86	2079/02/05	Maharajgunj	Bansbari Inlet	Treated	0.77	<5	7.7	74	22	30	0.1	0.02	5.76	0.71	0	Satisfactory
87	2079/02/05	Maharajgunj	Bansbari Outlet	Treated	0.58	<5	7.7	75	22	30	0.1	0.02	5.76	0.60	0	Satisfactory
88	2079/02/05	Maharajgunj	Panipokhari Inlet	Treated	0.93	<5	7.6	74	22	30	0.1	0.02	5.76	0.36	0	Satisfactory
89	2079/02/05	Maharajgunj	Panipokhari Outlet	Treated	0.69	<5	7.6	74	22	30	0.1	0.02	5.76	0.24	0	Satisfactory
90	2079/02/05	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.26	<5	7.7	97	22	28	0.1	0.02	8.00	0.59	0	Satisfactory
91	2079/02/05	Chhetrapati	Balaju inlet	Treated	1.52	<5	7.8	94	20	26	0.1	0.02	6.00	0.1	0	Satisfactory
92	2079/02/05	Kirtipur	Kirtipur SRT	Treated	0.94	<5	7.9	103	22	28	0.1	0.02	6.00	0.25	0	Satisfactory
93	2079/02/05	Baneshwar	Minbhawan SRT	Treated	1.24	<5	7.6	113	22	28	0.1	0.02	8.00	0.59	0	Satisfactory
94	2079/02/05	Lalitpur	Khumaltar SRT	Treated	1.95	<5	7.2	94	20	26	0.1	0.02	6.00	0.38	0	Satisfactory
95	2079/02/05	Tripureshwar	Anamnagar SRT	Treated	0.66	<5	7.2	95	20	26	0.1	0.02	6.00	0.2	0	Satisfactory
96	2079/02/05	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.80	<5	7.1	95	20	26	0.1	0.02	6.00	0.5	0	Satisfactory
97	2079/02/05	Madhyapur Thimi	Tigani SRT	Treated	0.40	<5	7.3	77	20	28	0.1	0.02	3.84	0.16	0	Satisfactory
98	2079/02/05	Maharajgunj	Bansbari inlet	Treated	0.77	<5	7.7	74	22	30	0.1	0.02	5.76	0.71	0	Satisfactory
99	2079/02/05	Maharajgunj	Bansbari Outlet	Treated	0.58	<5	7.7	75	22	30	0.1	0.02	5.76	0.6	0	Satisfactory
100	2079/02/05	Maharajgunj	Panipokhari inlet	Treated	0.93	<5	7.6	74	22	30	0.1	0.02	5.76	0.36	0	Satisfactory
101	2079/02/05	Maharajgunj	Panipokhari Outlet	Treated	0.69	<5	7.6	74	22	30	0.1	0.02	5.76	0.24	0	Satisfactory
102	2079/02/05	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	1.56	<5	7.4	95	22	26	0.1	0.02	6.00	0.25	0	Satisfactory
103	2079/02/06	Maharajgunj	Bansbari WTP	Treated	1.07	<5	7.0	59	22	18	0.1	0.02	5.76	0.3	0	Satisfactory
104	2079/02/06	Madhyapur Thimi	Bode WTP	Treated	1.30	<5	6.9	291	64	58	0.3	1.8	9.60	0.1	0	Satisfactory
105	2079/02/06	Lalitpur	Sainbu WTP	Treated	1.34	<5	6.9	265	76	116	0.1	0.02	11.50	0.5	0	Satisfactory
106	2079/02/06	Mahankalchaur	Mahankalchaur WTP	Treated	1.60	<5	7.2	88	18	20	0.1	0.02	8.00	0.6	0	Satisfactory
107	2079/02/06	Maharajgunj	Bansbari Inlet	Treated	1.35	<5	7.7	73	22	28	0.1	0.02	5.76	0.25	0	Satisfactory
108	2079/02/06	Maharajgunj	Bansbari Outlet	Treated	1.31	<5	7.7	73	22	28	0.1	0.02	5.76	0.22	0	Satisfactory
109	2079/02/06	Maharajgunj	Panipokhari Inlet	Treated	1.51	<5	7.6	73	22	28	0.1	0.02	5.76	0.31	0	Satisfactory
110	2079/02/06	Maharajgunj	Panipokhari Outlet	Treated	1.03	<5	7.6	74	22	28	0.1	0.02	5.76	0.29	0	Satisfactory
111	2079/02/06	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.83	<5	7.9	91	20	30	0.1	0.02	8.00	0.45	0	Satisfactory
112	2079/02/06	Chhetrapati	Balaju inlet	Treated	0.85	<5	7.9	91	20	28	0.1	0.02	6.00	0.41	0	Satisfactory
113	2079/02/06	Kirtipur	Kirtipur SRT	Treated	1.51	<5	8.0	97	22	30	0.1	0.02	4.00	0.28	0	Satisfactory

114	2079/02/06	Baneshwar	Minbhawan SRT	Treated	1.26	<5	8.1	92	20	28	0.1	0.02	6.00	0.13	0	Satisfactory
115	2079/02/06	Tripureshwar	Anamnagar SRT	Treated	0.70	<5	8.0	91	20	28	0.1	0.02	6.00	0.3	0	Satisfactory
116	2079/02/06	Lalitpur	Khumaltar SRT	Treated	0.85	<5	7.9	92	20	28	0.1	0.02	6.00	0.45	0	Satisfactory
117	2079/02/06	Madhyapur Thimi	Tigani SRT	Treated	0.50	<5	7.3	74	20	26	0.1	0.02	3.84	0.31	0	Satisfactory
118	2079/02/06	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.83	<5	8.2	94	20	30	0.1	0.02	6.00	0.35	0	Satisfactory
119	2079/02/06	Maharajgunj	Bansbari inlet	Treated	1.35	<5	7.7	73	22	28	0.1	0.02	5.76	0.25	0	Satisfactory
120	2079/02/06	Maharajgunj	Bansbari Outlet	Treated	1.31	<5	7.7	73	22	28	0.1	0.02	5.76	0.22	0	Satisfactory
121	2079/02/06	Maharajgunj	Panipokhari inlet	Treated	1.51	<5	7.6	73	22	28	0.1	0.02	5.76	0.31	0	Satisfactory
122	2079/02/06	Maharajgunj	Panipokhari Outlet	Treated	1.03	<5	7.6	74	22	28	0.1	0.02	5.76	0.29	0	Satisfactory
123	2079/02/06	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.85	<5	7.8	93	20	30	0.1	0.02	8.00	0.2	0	Satisfactory
124	2079/02/07	Maharajgunj	Bansbari WTP	Treated	0.46	<5	7.1	56	22	18	0.1	0.02	5.76	0.4	0	Satisfactory
125	2079/02/07	Madhyapur Thimi	Bode WTP	Treated	1.20	<5	6.8	288	62	56	0.3	1.8	5.76	0.3	0	Satisfactory
126	2079/02/07	Mahankalchaur	Mahankalchaur WTP	Treated	4.28	<5	7.4	92	14	18	0.1	0.02	8.00	0.4	0	Satisfactory
127	2079/02/07	Maharajgunj	Bansbari Inlet	Treated	1.17	<5	7.6	75	22	30	0.1	0.02	5.76	0.46	0	Satisfactory
128	2079/02/07	Maharajgunj	Bansbari Outlet	Treated	0.87	<5	7.6	74	22	30	0.1	0.02	5.76	0.38	0	Satisfactory
129	2079/02/07	Maharajgunj	Panipokhari Inlet	Treated	1.40	<5	7.7	76	22	30	0.1	0.02	5.76	0.52	0	Satisfactory
130	2079/02/07	Maharajgunj	Panipokhari Outlet	Treated	1.07	<5	7.6	75	22	30	0.1	0.02	5.76	0.43	0	Satisfactory
131	2079/02/07	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.84	<5	7.7	95	22	28	0.1	0.02	6.00	0.38	0	Satisfactory
132	2079/02/07	Chhetrapati	Balaju inlet	Treated	1.10	<5	7.8	96	22	30	0.1	0.02	6.00	0.29	0	Satisfactory
133	2079/02/07	Kirtipur	Kirtipur SRT	Treated	1.20	<5	7.9	97	22	30	0.1	0.02	6.00	0.13	0	Satisfactory
134	2079/02/07	Lalitpur	Khumaltar SRT	Treated	1.60	<5	7.6	97	24	32	0.1	0.02	6.00	0.2	0	Satisfactory
135	2079/02/07	Tripureshwar	Anamnagar SRT	Treated	1.40	<5	7.9	96	22	30	0.1	0.02	6.00	0.32	0	Satisfactory
136	2079/02/07	Baneshwar	Minbhawan SRT	Treated	0.81	<5	7.9	93	24	32	0.1	0.02	6.00	0.17	0	Satisfactory
137	2079/02/07	Mahankalchaur	Mahankalchaur Melamchi outlet	Treated	1.10	<5	7.8	91	24	30	0.1	0.02	6.00	0.53	0	Satisfactory
138	2079/02/07	Maharajgunj	Bansbari inlet	Treated	1.20	<5	7.6	75	22	30	0.1	0.02	5.76	0.46	0	Satisfactory
139	2079/02/07	Maharajgunj	Bansbari Outlet	Treated	0.90	<5	7.6	74	22	30	0.1	0.02	5.76	0.38	0	Satisfactory
140	2079/02/07	Maharajgunj	Panipokhari inlet	Treated	1.40	<5	7.6	76	22	30	0.1	0.02	5.76	0.52	0	Satisfactory
141	2079/02/07	Maharajgunj	Panipokhari Outlet	Treated	1.07	<5	7.6	75	22	30	0.1	0.02	5.76	0.49	0	Satisfactory
142	2079/02/07	Madhyapur Thimi	Tigani SRT	Treated	0.70	<5	7.2	80	20	32	0.1	0.02	3.84	0.1	0	Satisfactory
143	2079/02/07	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.44	<5	7.6	92	22	30	0.1	0.02	6.00	0.44	0	Satisfactory
144	2079/02/08	Maharajgunj	Bansbari WTP	Treated	1.13	<5	7.1	61	24	22	0.1	0.02	5.76	0.4	0	Satisfactory
145	2079/02/08	Madhyapur Thimi	Bode WTP	Treated	1.60	<5	6.8	296	66	62	0.3	1.8	9.60	0.1	0	Satisfactory
146	2079/02/08	Mahankalchaur	Mahankalchaur WTP	Treated	3.92	<5	7.5	58	14	16	0.1	0.02	6.00	0.5	0	Satisfactory
147	2079/02/08	Maharajgunj	Bansbari Inlet	Treated	2.91	<5	7.6	76	22	30	0.1	0.02	5.76	0.66	0	Satisfactory
148	2079/02/08	Maharajgunj	Bansbari Outlet	Treated	2.76	<5	7.5	76	22	30	0.1	0.02	5.76	0.62	0	Satisfactory
149	2079/02/08	Maharajgunj	Panipokhari Inlet	Treated	3.93	<5	7.5	75	22	30	0.1	0.02	5.76	0.53	0	Satisfactory
150	2079/02/08	Maharajgunj	Panipokhari Outlet	Treated	3.65	<5	7.5	77	22	30	0.1	0.02	5.76	0.58	0	Satisfactory
151	2079/02/08	Madhyapur Thimi	Tigani SRT	Treated	0.40	<5	7.2	80	20	32	0.1	0.02	3.84	0.1	0	Satisfactory
152	2079/02/08	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.56	<5	7.6	95	22	32	0.1	0.02	6.00	0.71	0	Satisfactory
153	2079/02/08	Chhetrapati	Balaju inlet	Treated	0.72	<5	7.7	97	22	32	0.1	0.02	6.00	0.53	0	Satisfactory
154	2079/02/08	Mahankalchaur	Mahankalchaur Melamchi outlet	Treated	0.81	<5	7.5	83	20	30	0.1	0.02	6.00	0.45	0	Satisfactory

155	2079/02/08	Kirtipur	Kirtipur SRT	Treated	1.10	<5	7.9	95	22	30	0.1	0.02	6.00	0.32	0	Satisfactory
156	2079/02/08	Baneshwar	Minbhawan SRT	Treated	1.90	<5	7.8	94	22	30	0.1	0.02	6.00	0.55	0	Satisfactory
157	2079/02/08	Lalitpur	Khumaltar SRT	Treated	0.84	<5	7.8	101	26	34	0.1	0.02	6.00	0.54	0	Satisfactory
158	2079/02/08	Tripureshwar	Anamnagar SRT	Treated	0.96	<5	7.9	96	22	30	0.1	0.02	6.00	0.54	0	Satisfactory
159	2079/02/08	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.60	<5	7.7	95	22	32	0.1	0.02	6.00	0.54	0	Satisfactory
160	2079/02/09	Maharajgunj	Bansbari WTP	Treated	1.40	<5	7.3	70	24	26	0.1	0.02	5.76	0.3	0	Satisfactory
161	2079/02/09	Madhyapur Thimi	Bode WTP	Treated	1.80	<5	6.8	330	70	66	0.3	1.7	19.20	0.8	0	Satisfactory
162	2079/02/09	Lalitpur	Sainbu WTP	Treated	1.58	<5	6.8	269	86	120	0.1	0.02	15.36	0.8	0	Satisfactory
163	2079/02/09	Mahankalchaur	Mahankalchaur WTP	Treated	0.51	<5	7.5	58	14	16	0.1	0.02	6.00	0.5	0	Satisfactory
164	2079/02/09	Maharajgunj	Bansbari Inlet	Treated	3.74	<5	7.6	78	22	30	0.1	0.02	5.76	0.53	0	Satisfactory
165	2079/02/09	Maharajgunj	Bansbari Outlet	Treated	3.17	<5	7.5	78	22	30	0.1	0.02	5.76	0.58	0	Satisfactory
166	2079/02/09	Maharajgunj	Panipokhari Inlet	Treated	3.93	<5	7.6	78	22	30	0.1	0.02	5.76	0.49	0	Satisfactory
167	2079/02/09	Maharajgunj	Panipokhari Outlet	Treated	3.50	<5	7.6	79	22	30	0.1	0.02	5.76	0.73	0	Satisfactory
168	2079/02/09	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.56	<5	7.6	95	22	32	0.1	0.02	6.00	0.71	0	Satisfactory
169	2079/02/09	Chhetrapati	Balaju inlet	Treated	0.72	<5	7.7	97	22	32	0.1	0.02	6.00	0.53	0	Satisfactory
170	2079/02/09	Mahankalchaur	Mahankalchaur Melamchi outlet	Treated	0.81	<5	7.5	83	20	30	0.1	0.02	6.00	0.45	0	Satisfactory
171	2079/02/09	Kirtipur	Kirtipur SRT	Treated	1.10	<5	7.9	95	22	30	0.1	0.02	6.00	0.32	0	Satisfactory
172	2079/02/09	Baneshwar	Minbhawan SRT	Treated	1.90	<5	7.8	94	22	30	0.1	0.02	6.00	0.55	0	Satisfactory
173	2079/02/09	Lalitpur	Khumaltar SRT	Treated	0.84	<5	7.8	101	26	34	0.1	0.02	6.00	0.54	0	Satisfactory
174	2079/02/09	Tripureshwar	Anamnagar SRT	Treated	0.96	<5	7.9	96	22	30	0.1	0.02	6.00	0.54	0	Satisfactory
175	2079/02/09	Mahankalchaur	Mahankalchaur WTP	Treated	1.90	<5	7.6	80	20	18	0.1	0.02	6.00	0.54	0	Satisfactory
176	2079/02/09	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.60	<5	7.7	95	22	32	0.1	0.02	6.00	0.54	0	Satisfactory
177	2079/02/10	Maharajgunj	Bansbari WTP	Treated	1.16	<5	7.4	56	22	20	0.1	0.02	5.76	0.4	0	Satisfactory
178	2079/02/10	Madhyapur Thimi	Bode WTP	Treated	1.50	<5	6.8	317	68	64	0.3	1.7	19.20	0.7	0	Satisfactory
179	2079/02/10	Lalitpur	Sainbu WTP	Treated	1.65	<5	7.1	236	78	116	0.1	0.02	9.60	0.5	0	Satisfactory
180	2079/02/10	Mahankalchaur	Mahankalchaur WTP	Treated	1.23	<5	7.5	58	14	16	0.1	0.02	6.00	0.5	0	Satisfactory
181	2079/02/10	Maharajgunj	Panipokhari Inlet	Treated	2.62	<5	7.6	76	24	30	0.1	0.02	5.76	0.56	0	Satisfactory
182	2079/02/10	Maharajgunj	Panipokhari Outlet	Treated	2.50	<5	7.5	79	24	30	0.1	0.02	5.76	0.52	0	Satisfactory
183	2079/02/10	Madhyapur Thimi	Tigani SRT	Treated	1.70	<5	7.1	92	20	34	0.1	0.02	3.84	0.14	0	Satisfactory
184	2079/02/10	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.56	<5	7.6	95	22	32	0.1	0.02	6.00	0.71	0	Satisfactory
185	2079/02/10	Chhetrapati	Balaju inlet	Treated	0.72	<5	7.7	97	22	32	0.1	0.02	6.00	0.53	0	Satisfactory
186	2079/02/10	Mahankalchaur	Mahankalchaur Melamchi outlet	Treated	0.81	<5	7.5	83	20	30	0.1	0.02	6.00	0.45	0	Satisfactory
187	2079/02/10	Kirtipur	Kirtipur SRT	Treated	1.10	<5	7.9	95	22	30	0.1	0.02	6.00	0.32	0	Satisfactory
188	2079/02/10	Baneshwar	Minbhawan SRT	Treated	1.90	<5	7.8	94	22	30	0.1	0.02	6.00	0.55	0	Satisfactory
189	2079/02/10	Lalitpur	Khumaltar SRT	Treated	0.84	<5	7.8	101	26	34	0.1	0.02	6.00	0.54	0	Satisfactory
190	2079/02/10	Tripureshwar	Anamnagar SRT	Treated	0.96	<5	7.9	96	22	30	0.1	0.02	6.00	0.54	0	Satisfactory
191	2079/02/10	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.60	<5	7.7	95	22	32	0.1	0.02	6.00	0.54	0	Satisfactory
192	2079/02/11	Maharajgunj	Bansbari WTP	Treated	1.02	<5	7.2	57	22	20	0.1	0.02	5.76	0.4	0	Satisfactory
193	2079/02/11	Madhyapur Thimi	Bode WTP	Treated	1.80	<5	6.8	320	68	64	0.3	1.7	19.20	0.6	0	Satisfactory
194	2079/02/11	Lalitpur	Sainbu WTP	Treated	3.07	<5	7.2	251	78	106	0.1	0.02	7.68	0.8	0	Satisfactory
195	2079/02/11	Mahankalchaur	Mahankalchaur WTP	Treated	1.86	<5	7.4	65	14	18	0.1	0.02	6.00	0.1	0	Satisfactory

196	2079/02/11	Maharajgunj	Bansbari Inlet	Treated	1.97	<5	7.5	77	22	30	0.1	0.02	5.76	0.37	0	Satisfactory
197	2079/02/11	Maharajgunj	Bansbari Outlet	Treated	1.76	<5	7.5	76	22	30	0.1	0.02	5.76	0.50	0	Satisfactory
198	2079/02/11	Maharajgunj	Panipokhari Inlet	Treated	2.26	<5	7.5	77	22	30	0.1	0.02	5.76	0.45	0	Satisfactory
199	2079/02/11	Maharajgunj	Panipokhari Outlet	Treated	2.16	<5	7.5	78	22	30	0.1	0.02	5.76	0.59	0	Satisfactory
200	2079/02/11	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.79	<5	7.7	85	20	22	0.1	0.02	6.00	0.2	0	Satisfactory
201	2079/02/11	Kirtipur	Kirtipur SRT	Treated	0.81	<5	7.8	97	22	26	0.1	0.02	6.00	0.27	0	Satisfactory
202	2079/02/11	Chhetrapati	Balaju inlet	Treated	0.93	<5	7.4	91	20	22	0.1	0.02	6.00	0.29	0	Satisfactory
203	2079/02/11	Tripureshwar	Anamnagar SRT	Treated	0.72	<5	7.3	92	24	30	0.1	0.02	6.00	0.1	0	Satisfactory
204	2079/02/11	Lalitpur	Khumaltar SRT	Treated	3.26	<5	7.4	94	24	30	0.1	0.02	6.00	0.28	0	Satisfactory
205	2079/02/11	Baneshwar	Minbhawan SRT	Treated	0.64	<5	7.2	91	22	26	0.1	0.02	6.00	0.1	0	Satisfactory
206	2079/02/11	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	0.82	<5	7.3	89	14	18	0.1	0.02	6.00	0.41	0	Satisfactory
207	2079/02/11	Madhyapur Thimi	Tigani SRT	Treated	0.60	<5	7.2	75	20	26	0.1	0.02	3.84	0.22	0	Satisfactory
208	2079/02/11	Maharajgunj	Bansbari inlet	Treated	1.27	<5	7.6	74	22	28	0.1	0.02	5.76	0.27	0	Satisfactory
209	2079/02/11	Maharajgunj	Bansbari Outlet	Treated	1.19	<5	7.6	74	22	28	0.1	0.02	5.76	0.25	0	Satisfactory
210	2079/02/11	Maharajgunj	Panipokhari inlet	Treated	2.78	<5	7.6	76	22	28	0.1	0.02	5.76	0.34	0	Satisfactory
211	2079/02/11	Maharajgunj	Panipokhari Outlet	Treated	2.30	<5	7.6	76	22	28	0.1	0.02	5.76	0.42	0	Satisfactory
212	2079/02/12	Maharajgunj	Bansbari WTP	Treated	0.83	<5	7.1	57	20	16	0.1	0.02	5.76	0.4	0	Satisfactory
213	2079/02/12	Madhyapur Thimi	Bode WTP	Treated	1.10	<5	6.9	287	62	54	0.3	1.8	9.60	0.1	0	Satisfactory
214	2079/02/12	Lalitpur	Sainbu WTP	Treated	2.51	<5	7.3	254	78	110	0.1	0.02	7.68	0.5	0	Satisfactory
215	2079/02/12	Maharajgunj	Bansbari Inlet	Treated	2.48	<5	7.6	78	22	30	0.1	0.02	5.76	0.47	0	Satisfactory
216	2079/02/12	Maharajgunj	Bansbari Outlet	Treated	2.26	<5	7.5	77	22	30	0.1	0.02	5.76	0.33	0	Satisfactory
217	2079/02/12	Maharajgunj	Panipokhari Inlet	Treated	2.71	<5	7.6	79	22	30	0.1	0.02	5.76	0.46	0	Satisfactory
218	2079/02/12	Maharajgunj	Panipokhari Outlet	Treated	2.53	<5	7.5	77	22	30	0.1	0.02	5.76	0.51	0	Satisfactory
219	2079/02/12	Madhyapur Thimi	Tigani SRT	Treated	0.40	<5	7.4	85	20	32	0.1	0.02	3.84	0.38	0	Satisfactory
220	2079/02/12	Lalitpur	Khumaltar SRT	Treated	1.26	<5	7.2	109	22	34	0.1	0.02	6.00	0.1	0	Satisfactory
221	2079/02/12	Tripureshwar	Anamnagar SRT	Treated	0.79	<5	7.3	110	22	34	0.1	0.02	6.00	0.8	0	Satisfactory
222	2079/02/13	Maharajgunj	Bansbari WTP	Treated	0.62	<5	6.9	60	22	18	0.1	0.02	5.76	0.3	0	Satisfactory
223	2079/02/13	Madhyapur Thimi	Bode WTP	Treated	1.90	<5	6.8	296	62	56	0.3	1.8	9.60	0.4	0	Satisfactory
224	2079/02/13	Lalitpur	Sainbu WTP	Treated	2.55	<5	7.4	259	84	116	0.1	0.02	9.60	0.8	0	Satisfactory
225	2079/02/13	Mahankalchaur	Mahankalchaur WTP	Treated	2.32	<5	7.5	73	14	20	0.3	0.02	8.00	0.3	0	Satisfactory
226	2079/02/13	Maharajgunj	Bansbari Inlet	Treated	0.93	<5	7.6	77	24	30	0.1	0.02	5.76	0.45	0	Satisfactory
227	2079/02/13	Maharajgunj	Bansbari Outlet	Treated	0.83	<5	7.5	77	24	30	0.1	0.02	5.76	0.43	0	Satisfactory
228	2079/02/13	Maharajgunj	Panipokhari Inlet	Treated	1.01	<5	7.5	76	24	30	0.1	0.02	5.76	0.41	0	Satisfactory
229	2079/02/13	Maharajgunj	Panipokhari Outlet	Treated	0.77	<5	7.6	78	24	30	0.1	0.02	5.76	0.52	0	Satisfactory
230	2079/02/13	Kirtipur	Kirtipur SRT	Treated	0.88	<5	6.5	98	22	30	0.1	0.02	6.00	0.37	0	Satisfactory
231	2079/02/13	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	0.53	<5	6.8	92	20	30	0.1	0.02	6.00	0.72	0	Satisfactory
232	2079/02/13	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	5.77	<5	6.5	85	22	30	0.1	0.02	6.00	0.41	0	Satisfactory
233	2079/02/13	Chhetrapati	Balaju inlet	Treated	0.90	<5	6.9	97	22	30	0.1	0.02	6.00	0.47	0	Satisfactory
234	2079/02/13	Tripureshwar	Anamnagar SRT	Treated	0.48	<5	6.9	96	20	30	0.1	0.02	6.00	0.54	0	Satisfactory
235	2079/02/13	Lalitpur	Khumaltar SRT	Treated	0.84	<5	6.8	97	22	30	0.1	0.02	6.00	0.45	0	Satisfactory
236	2079/02/13	Baneshwar	Minbhawan SRT	Treated	0.50	<5	6.9	94	20	30	0.1	0.02	6.00	0.44	0	Satisfactory

237	2079/02/13	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	0.39	<5	7.1	93	22	30	0.1	0.02	6.00	0.62	0	Satisfactory
238	2079/02/13	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	4.55	<5	7.1	87	22	30	0.1	0.02	6.00	0.59	0	Satisfactory
239	2079/02/13	Maharajgunj	Bansbari inlet	Treated	0.93	<5	7.6	77	24	30	0.1	0.02	5.76	0.45	0	Satisfactory
240	2079/02/13	Maharajgunj	Bansbari Outlet	Treated	0.83	<5	7.5	77	24	30	0.1	0.02	5.76	0.43	0	Satisfactory
241	2079/02/13	Maharajgunj	Panipokhari inlet	Treated	1.01	<5	7.5	76	24	30	0.1	0.02	5.76	0.41	0	Satisfactory
242	2079/02/13	Maharajgunj	Panipokhari Outlet	Treated	0.77	<5	7.6	78	24	30	0.1	0.02	5.76	0.52	0	Satisfactory
243	2079/02/13	Madhyapur Thimi	Tigani SRT	Treated	0.38	<5	7.4	81	20	32	0.1	0.02	3.84	0.2	0	Satisfactory
244	2079/02/13	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	2.00	<5	6.7	95	20	28	0.1	0.02	6.00	0.2	0	Satisfactory
245	2079/02/13	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	5.10	<5	6.5	107	24	32	0.1	0.02	6.00	0.8	0	Satisfactory
246	2079/02/14	Maharajgunj	Bansbari WTP	Treated	0.54	<5	7.2	54	18	16	0.1	0.02	5.76	0.4	0	Satisfactory
247	2079/02/14	Madhyapur Thimi	Bode WTP	Treated	1.30	<5	6.8	292	62	56	0.3	1.7	11.52	0.3	0	Satisfactory
248	2079/02/14	Mahankalchaur	Mahankalchaur WTP	Treated	2.67	<5	6.7	64	14	20	0.1	0.02	6.00	0.8	0	Satisfactory
249	2079/02/14	Maharajgunj	Panipokhari Inlet	Treated	1.03	<5	7.5	76	24	30	0.1	0.02	5.76	0.57	0	Satisfactory
250	2079/02/14	Maharajgunj	Panipokhari Outlet	Treated	0.84	<5	7.5	77	24	30	0.1	0.02	5.76	0.49	0	Satisfactory
251	2079/02/14	Maharajgunj	Bansbari Inlet	Treated	0.74	<5	7.5	76	24	28	0.1	0.02	5.76	0.46	0	Satisfactory
252	2079/02/14	Lalitpur	Khumaltar SRT	Treated	1.14	<5	7.0	99	20	28	0.1	0.02	6.00	0.57	0	Satisfactory
253	2079/02/14	Tripureshwar	Anamnagar SRT	Treated	0.94	<5	7.6	106	22	30	0.1	0.02	6.00	0.4	0	Satisfactory
254	2079/02/14	Kirtipur	Kirtipur SRT	Treated	1.17	<5	7.4	103	22	30	0.1	0.02	6.00	0.39	0	Satisfactory
255	2079/02/14	Chhetrapati	Balaju inlet	Treated	0.80	<5	7.6	102	22	30	0.1	0.02	6.00	0.6	0	Satisfactory
256	2079/02/14	Baneshwar	Minbhawan SRT	Treated	0.75	<5	7.7	116	22	30	0.1	0.02	6.00	0.29	0	Satisfactory
257	2079/02/14	Madhyapur Thimi	Tigani SRT	Treated	0.30	<5	7.5	78	20	32	0.1	0.02	3.84	0.12	0	Satisfactory
258	2079/02/14	Maharajgunj	Bansbari inlet	Treated	0.74	<5	7.5	76	24	30	0.1	0.02	5.76	0.46	0	Satisfactory
259	2079/02/14	Maharajgunj	Bansbari Outlet	Treated	0.71	<5	7.5	76	24	30	0.1	0.02	5.76	0.23	0	Satisfactory
260	2079/02/14	Maharajgunj	Panipokhari inlet	Treated	1.09	<5	7.5	76	24	30	0.1	0.02	5.76	0.57	0	Satisfactory
261	2079/02/14	Maharajgunj	Panipokhari Outlet	Treated	0.84	<5	7.5	77	24	30	0.1	0.02	5.76	0.49	0	Satisfactory
262	2079/02/15	Maharajgunj	Bansbari WTP	Treated	0.50	<5	6.9	49	14	14	0.1	0.02	5.76	0.4	0	Satisfactory
263	2079/02/15	Madhyapur Thimi	Bode WTP	Treated	2.00	<5	6.8	294	62	56	0.3	1.7	13.44	0.3	0	Satisfactory
264	2079/02/15	Mahankalchaur	Mahankalchaur WTP	Treated	4.44	<5	8.0	68	18	20	0.1	0.02	6.00	0.7	0	Satisfactory
265	2079/02/15	Maharajgunj	Bansbari Inlet	Treated	9.68	<5	7.2	75	22	30	0.1	0.02	5.76	0.30	0	Satisfactory
266	2079/02/15	Madhyapur Thimi	Tigani SRT	Treated	0.30	<5	7.5	78	20	32	0.1	0.02	3.84	0.12	0	Satisfactory
267	2079/02/15	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	0.71	<5	7.8	93	22	30	0.1	0.02	6.00	0.49	0	Satisfactory
268	2079/02/15	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	0.81	<5	7.5	84	22	28	0.1	0.02	6.00	0.28	0	Satisfactory
269	2079/02/15	Kirtipur	Kirtipur SRT	Treated	1.40	<5	7.4	105	26	36	0.1	0.02	6.00	0.24	0	Satisfactory
270	2079/02/15	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	0.98	<5	8.1	97	24	30	0.1	0.02	6.00	0.54	0	Satisfactory
271	2079/02/16	Maharajgunj	Bansbari WTP	Treated	0.34	<5	6.9	49	16	14	0.1	0.02	5.76	0.4	0	Satisfactory
272	2079/02/16	Madhyapur Thimi	Bode WTP	Treated	1.40	<5	6.9	299	62	58	0.3	1.7	15.36	0.1	0	Satisfactory
273	2079/02/16	Lalitpur	Sainbu WTP	Treated	1.31	<5	7.2	260	84	118	0.1	0.02	9.60	0.8	0	Satisfactory
274	2079/02/16	Mahankalchaur	Mahankalchaur WTP	Treated	4.20	<5	7.4	84	16	20	0.1	0.02	3.84	0.5	0	Satisfactory
275	2079/02/16	Mahankalchaur	Mahankalchaur WTP	Treated	3.80	<5	7.2	89	16	20	0.1	0.02	6.00	0.4	0	Satisfactory
276	2079/02/16	Maharajgunj	Bansbari Inlet	Treated	1.27	<5	7.3	72	20	30	0.1	0.02	5.76	0.45	0	Satisfactory
277	2079/02/16	Maharajgunj	Bansbari Outlet	Treated	2.66	<5	7.3	72	20	30	0.1	0.02	5.76	0.29	0	Satisfactory

278	2079/02/16	Madhyapur Thimi	Tigani SRT	Treated	3.61	<5	7.3	83	20	32	0.1	0.02	3.84	0.19	0	Satisfactory
279	2079/02/16	Maharajgunj	Bansbari inlet	Treated	9.68	<5	7.2	72	22	30	0.1	0.02	5.76	0.3	0	Satisfactory
280	2079/02/16	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	6.20	<5	7.3	88	24	30	0.1	0.02	6.00	0.36	0	Satisfactory
281	2079/02/16	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	2.71	<5	7.2	80	24	30	0.1	0.02	6.00	0.35	0	Satisfactory
282	2079/02/16	Tripureshwar	Anamnagar SRT	Treated	2.69	<5	7.5	89	22	30	0.1	0.02	4.00	0.1	0	Satisfactory
283	2079/02/16	Baneshwar	Minbhawan SRT	Treated	1.90	<5	7.5	92	24	34	0.1	0.02	8.00	0.42	0	Satisfactory
284	2079/02/16	Lalitpur	Khumaltar SRT	Treated	1.80	<5	7.3	89	22	30	0.1	0.02	12.00	0.22	0	Satisfactory
285	2079/02/16	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	3.72	<5	7.3	88	20	30	0.1	0.02	6.00	0.12	0	Satisfactory
286	2079/02/16	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	2.64	<5	7.5	85	14	22	0.1	0.02	6.00	0.16	0	Satisfactory
287	2079/02/16	Maharajgunj	Bansbari inlet	Treated	1.27	<5	7.3	72	20	30	0.1	0.02	5.76	0.45	0	Satisfactory
288	2079/02/16	Maharajgunj	Bansbari Outlet	Treated	2.66	<5	7.3	72	20	30	0.1	0.02	5.76	0.29	0	Satisfactory
289	2079/02/16	Mahankalchaur	Mahankalchaur melamchi inlet	Treated	5.80	<5	7.1	88	20	30	0.1	0.02	6.00	0.11	0	Satisfactory
290	2079/02/16	Mahankalchaur	Mahankalchaur melamchi outlet	Treated	6.40	<5	7.2	88	20	32	0.1	0.02	6.00	0.24	0	Satisfactory
291	2079/02/17	Maharajgunj	Bansbari WTP	Treated	0.44	<5	6.9	55	20	16	0.1	0.02	5.76	0.4	0	Satisfactory
292	2079/02/17	Lalitpur	Sainbu WTP	Treated	1.73	<5	6.9	245	78	108	0.1	0.02	7.68	0.8	0	Satisfactory
293	2079/02/17	Mahankalchaur	Mahankalchaur WTP	Treated	1.30	<5	7.5	76	12	16	0.1	0.02	8.00	0.4	0	Satisfactory
294	2079/02/17	Madhyapur Thimi	Tigani SRT	Treated	1.00	<5	7.1	92	22	28	0.1	0.02	6.00	0.62	0	Satisfactory
295	2079/02/18	Maharajgunj	Bansbari WTP	Treated	0.72	<5	6.9	71	20	22	0.1	0.02	5.76	0.3	0	Satisfactory
296	2079/02/18	Madhyapur Thimi	Bode WTP	Treated	1.20	<5	6.8	283	62	56	0.3	1.8	9.60	0.2	0	Satisfactory
297	2079/02/18	Lalitpur	Sainbu WTP	Treated	3.06	<5	7.1	256	78	108	0.1	0.02	7.68	0.5	0	Satisfactory
298	2079/02/18	Mahankalchaur	Mahankalchaur WTP	Treated	1.60	<5	7.1	53	12	16	0.1	0.02	6.00	0.7	0	Satisfactory
299	2079/02/18	Madhyapur Thimi	Tigani SRT	Treated	2.90	<5	7.3	89	20	34	0.1	0.02	3.84	0.12	0	Satisfactory
300	2079/02/19	Maharajgunj	Bansbari WTP	Treated	0.40	<5	6.9	73	22	22	0.1	0.02	5.76	0.5	0	Satisfactory
301	2079/02/19	Madhyapur Thimi	Bode WTP	Treated	1.30	<5	6.7	279	60	56	0.3	1.8	9.60	0.2	0	Satisfactory
302	2079/02/19	Lalitpur	Sainbu WTP	Treated	1.86	<5	7.0	249	76	106	0.1	0.02	7.68	0.8	0	Satisfactory
303	2079/02/19	Mahankalchaur	Mahankalchaur WTP	Treated	1.30	<5	6.6	75	14	20	0.1	0.02	6.00	0.6	0	Satisfactory
304	2079/02/20	Maharajgunj	Bansbari WTP	Treated	0.23	<5	6.9	61	20	20	0.1	0.02	5.76	0.5	0	Satisfactory
305	2079/02/20	Madhyapur Thimi	Bode WTP	Treated	1.20	<5	6.7	274	60	54	0.3	1.8	9.60	0.1	0	Satisfactory
306	2079/02/20	Lalitpur	Sainbu WTP	Treated	1.34	<5	7.5	270	82	108	0.1	0.02	9.60	0.5	0	Satisfactory
307	2079/02/20	Mahankalchaur	Mahankalchaur WTP	Treated	1.60	<5	6.6	70	14	24	0.1	0.02	8.00	0.2	0	Satisfactory
308	2079/02/21	Maharajgunj	Bansbari WTP	Treated	0.47	<5	6.9	61	22	20	0.1	0.02	5.76	0.5	0	Satisfactory
309	2079/02/21	Mahankalchaur	Mahankalchaur WTP	Treated	1.30	<5	7.6	60	14	18	0.1	0.02	8.00	0.2	0	Satisfactory
310	2079/02/22	Maharajgunj	Bansbari WTP	Treated	0.48	<5	6.9	66	24	20	0.1	0.02	5.76	0.4	0	Satisfactory
311	2079/02/22	Mahankalchaur	Mahankalchaur WTP	Treated	1.60	<5	7.3	81	14	16	0.1	0.02	8.00	0.8	0	Satisfactory
312	2079/02/23	Maharajgunj	Bansbari WTP	Treated	0.67	<5	6.9	56	18	16	0.1	0.02	5.76	0.4	0	Satisfactory
313	2079/02/23	Madhyapur Thimi	Bode WTP	Treated	0.88	<5	6.9	306	66	62	0.3	1.7	9.60	0.8	0	Satisfactory
314	2079/02/23	Lalitpur	Sainbu WTP	Treated	1.61	<5	7.0	249	74	106	0.1	0.02	7.68	0.8	0	Satisfactory
315	2079/02/23	Mahankalchaur	Mahankalchaur WTP	Treated	4.28	<5	7.4	77	16	16	0.1	0.02	6.00	0.1	0	Satisfactory
316	2079/02/24	Maharajgunj	Bansbari WTP	Treated	0.20	<5	6.8	60	20	16	0.1	0.02	5.76	0.4	0	Satisfactory
317	2079/02/24	Madhyapur Thimi	Bode WTP	Treated	0.96	<5	6.7	281	60	56	0.3	1.8	9.60	0.5	0	Satisfactory
318	2079/02/24	Lalitpur	Sainbu WTP	Treated	3.06	<5	6.8	245	76	104	0.1	0.02	7.68	0.8	0	Satisfactory



319	2079/02/24	Mahankalchaur	Mahankalchaur WTP	Treated	3.92	<5	6.9	85	18	18	0.1	0.02	8.00	0.3	0	Satisfactory
320	2079/02/25	Maharajgunj	Bansbari WTP	Treated	1.14	<5	6.8	61	20	18	0.1	0.02	5.76	0.4	0	Satisfactory
321	2079/02/25	Madhyapur Thimi	Bode WTP	Treated	0.91	<5	6.7	286	64	56	0.3	1.8	9.60	0.6	0	Satisfactory
322	2079/02/25	Lalitpur	Sainbu WTP	Treated	2.01	<5	6.9	280	86	104	0.1	0.02	7.68	0.8	0	Satisfactory
323	2079/02/25	Mahankalchaur	Mahankalchaur WTP	Treated	4.13	<5	6.9	61	14	18	0.1	0.02	6.00	0.4	0	Satisfactory
324	2079/02/26	Maharajgunj	Bansbari WTP	Treated	0.48	<5	6.8	65	20	20	0.1	0.02	7.68	0.4	0	Satisfactory
325	2079/02/26	Lalitpur	Sainbu WTP	Treated	1.41	<5	6.9	278	86	110	0.1	0.02	9.60	0.7	0	Satisfactory
326	2079/02/26	Mahankalchaur	Mahankalchaur WTP	Treated	4.46	<5	7.4	61	16	18	0.1	0.02	6.00	0.4	0	Satisfactory
327	2079/02/27	Maharajgunj	Bansbari WTP	Treated	0.17	<5	6.9	62	22	18	0.1	0.02	7.68	0.4	0	Satisfactory
328	2079/02/27	Lalitpur	Sainbu WTP	Treated	1.23	<5	6.8	286	90	116	0.1	0.02	11.50	0.8	0	Satisfactory
329	2079/02/27	Mahankalchaur	Mahankalchaur WTP	Treated	3.78	<5	7.3	61	14	18	0.1	0.02	6.00	0.4	0	Satisfactory
330	2079/02/28	Maharajgunj	Bansbari WTP	Treated	0.32	<5	6.9	62	22	18	0.1	0.02	7.68	0.5	0	Satisfactory
331	2079/02/28	Mahankalchaur	Mahankalchaur WTP	Treated	3.52	<5	7.4	61	16	18	0.1	0.02	8.00	0.4	0	Satisfactory
332	2079/02/29	Maharajgunj	Bansbari WTP	Treated	0.11	<5	6.9	64	22	18	0.1	0.02	7.68	0.5	0	Satisfactory
333	2079/02/30	Maharajgunj	Bansbari WTP	Treated	0.21	<5	6.9	57	20	18	0.1	0.02	5.76	0.3	0	Satisfactory
334	2079/02/30	Lalitpur	Sainbu WTP	Treated	2.24	<5	7.2	263	80	104	0.1	0.02	7.68	0.7	0	Satisfactory
335	2079/02/30	Mahankalchaur	Mahankalchaur WTP	Treated	4.00	<5	7.5	59	18	20	0.1	0.02	6.00	0.4	0	Satisfactory
336	2079/02/31	Maharajgunj	Bansbari WTP	Treated	0.32	<5	6.9	57	20	16	0.1	0.02	7.68	0.4	0	Satisfactory
337	2079/02/31	Lalitpur	Sainbu WTP	Treated	2.84	<5	6.9	271	82	106	0.1	0.02	7.68	0.7	0	Satisfactory
338	2079/02/31	Mahankalchaur	Mahankalchaur WTP	Treated	4.00	<5	7.5	112	20	22	0.1	0.02	8.00	0.4	0	Satisfactory