

KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur WTP
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
 Baisakh 2080

S.No.	Date	Time	Branch	Location	Sample taken	Appearance	Turbidity	Colour	p ^H	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
Units							(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100ml	
National Drinking Water Quality Standard (NDWQS) 2079							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2080/01/01	7:44am	Bhaktapur	Katunje SRT	Treated	Clear	0.34	<5	6.9	105	20	28	0.1	0.02	6	0.4	0	Satisfactory
2	2080/01/01	10:30am	Sundarijal	Sundarijal WTP	Treated	Clear	0.22	<5	7.8	74	22	18	0.1	0.02	6	0.5	0	Satisfactory
3	2080/01/01	2:00pm	Sundarijal	Sundarijal WTP	Treated	Clear	0.47	<5	7.8	75	22	18	0.1	0.02	6	0.4	0	Satisfactory
4	2080/01/01	12:00pm	Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	7.9	79	22	18	0.1	0.02	6	0.4	0	Satisfactory
5	2080/01/01	10:00am	Maharajgunj	Bansbari In	Treated	Clear	0.18	<5	7.8	78	28	32	0.1	0.02	6	0.3	0	Satisfactory
6	2080/01/01	10:10am	Maharajgunj	Bansbari Out	Treated	Clear	0.14	<5	7.7	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
7	2080/01/01	10:55am	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	71	22	28	0.1	0.02	6	0.4	0	Satisfactory
8	2080/01/01	3:10pm	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	69	22	28	0.1	0.02	6	0.4	0	Satisfactory
9	2080/01/02	8:00am	Kirtipur	Kirtipur SRT	Treated	Clear	0.13	<5	7.6	104	22	28	0.1	0.02	6	0.3	0	Satisfactory
10	2080/01/02	8:30am	Tripureshwor	Anamnagar SRT	Treated	Clear	1.37	<5	7.6	105	22	28	0.1	0.02	6	0.5	0	Satisfactory
11	2080/01/02	7:30am	Lalitpur	Khumaltar SRT	Treated	Clear	2.10	<5	7.6	106	22	28	0.1	0.02	6	0.2	0	Satisfactory
12	2080/01/02	7:00am	Baneshwor	Minbhawan SRT	Treated	Clear	0.10	<5	7.7	105	24	28	0.1	0.02	6	0.4	0	Satisfactory
13	2080/01/02	8:44am	Maharajgunj	Panipokhari inlet	Treated	Clear	0.54	<5	7.7	106	24	28	0.1	0.02	6	0.3	0	Satisfactory
14	2080/01/02	8:45am	Maharajgunj	Panipokhari outlet	Treated	Clear	0.62	<5	7.8	106	24	28	0.1	0.02	6	0.3	0	Satisfactory
15	2080/01/02	10:00am	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.5	61	14	16	0.1	0.02	6	0.1	0	Satisfactory
16	2080/01/02	10:00am	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.45	<5	7.5	103	22	28	0.1	0.02	6	0.1	0	Satisfactory
17	2080/01/02	6:24am	Bhaktapur	Katunje SRT	Treated	Clear	0.33	<5	7.8	107	24	28	0.1	0.02	6	0.2	0	Satisfactory
18	2080/01/02	10:00am	Sundarijal	Sundarijal WTP	Treated	Clear	0.15	<5	7.9	77	22	18	0.1	0.02	6	0.3	0	Satisfactory
19	2080/01/02	3:00pm	Sundarijal	Sundarijal WTP	Treated	Clear	0.72	<5	7.9	83	22	18	0.1	0.02	6	0.3	0	Satisfactory
20	2080/01/02	10:50am	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	68	22	28	0.1	0.02	6	0.4	0	Satisfactory
21	2080/01/02	11:45am	Maharajgunj	Bansbari In	Treated	Clear	0.14	<5	8.1	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
22	2080/01/02	11:55am	Maharajgunj	Bansbari Out	Treated	Clear	0.11	<5	8.0	79	28	32	0.1	0.02	6	0.1	0	Satisfactory
23	2080/01/02	3:10pm	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	67	22	28	0.1	0.02	6	0.4	0	Satisfactory
24	2080/01/03	11:30am	Madhyapur Thimi	Bode WTP	Treated	Clear	1.27	<5	7.1	269	68	56	0.3	1.7	10	0.1	0	Satisfactory
25	2080/01/03	10:00am	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.95	<5	7.2	82	28	36	0.1	0.02	4	0.1	0	Satisfactory
26	2080/01/03	10:00am	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.38	<5	7.5	59	14	16	0.1	0.02	6	0.1	0	Satisfactory
27	2080/01/03	10:00am	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.37	<5	7.7	98	22	26	0.1	0.02	6	0.3	0	Satisfactory
28	2080/01/03	12:00pm	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.45	<5	7.7	73	14	16	0.1	0.02	6	1.0	0	Satisfactory
29	2080/01/03	12:00pm	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.45	<5	7.9	101	24	28	0.1	0.02	6	0.2	0	Satisfactory
30	2080/01/03	2:15pm	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.50	<5	7.8	73	14	16	0.1	0.02	6	1.0	0	Satisfactory
31	2080/01/03	2:15pm	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.42	<5	7.8	101	24	28	0.1	0.02	6	0.3	0	Satisfactory

32	2080/01/03	12:10pm	Kirtipur	Kirtipur SRT	Treated	Clear	0.44	<5	7.8	105	24	28	0.1	0.02	6	0.4	0	Satisfactory
33	2080/01/03	11:50am	Lalitpur	Khumaltar SRT	Treated	Clear	0.10	<5	7.5	105	22	28	0.1	0.02	6	0.1	0	Satisfactory
34	2080/01/03	10:45am	Tripureshwor	Anamnagar SRT	Treated	Clear	0.12	<5	7.8	103	24	28	0.1	0.02	6	0.4	0	Satisfactory
35	2080/01/03	11:15am	Baneshwor	Minbhawan SRT	Treated	Clear	0.10	<5	7.8	103	24	28	0.1	0.02	6	0.2	0	Satisfactory
36	2080/01/03	1:40pm	Chettrapati	Balaju SRT	Treated	Clear	1.51	<5	7.8	104	24	28	0.1	0.02	6	0.2	0	Satisfactory
37	2080/01/03	3:45pm	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.8	85	16	18	0.1	0.02	4	1.0	0	Satisfactory
38	2080/01/03	3:45pm	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.74	<5	7.8	98	24	26	0.1	0.02	6	0.6	0	Satisfactory
39	2080/01/03	6:56am	Bhaktapur	Katunje SRT	Treated	Clear	0.20	<5	7.8	106	24	28	0.1	0.02	6	0.2	0	Satisfactory
40	2080/01/03	11:30pm	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.02	<5	7.9	360	56	136	0.1	0.02	16	0.8	0	Satisfactory
41	2080/01/03	10:00am	Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	8.1	78	22	18	0.1	0.02	6	0.6	0	Satisfactory
42	2080/01/03	12:45pm	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	8.0	78	22	18	0.1	0.02	6	0.6	0	Satisfactory
43	2080/01/03	3:45pm	Sundarijal	Sundarijal WTP	Treated	Clear	0.25	<5	7.9	78	22	18	0.1	0.02	6	0.3	0	Satisfactory
44	2080/01/03	10:00am	Maharajgunj	Bansbari In	Treated	Clear	0.32	<5	7.9	76	28	32	0.1	0.02	6	0.2	0	Satisfactory
45	2080/01/03	10:10am	Maharajgunj	Bansbari Out	Treated	Clear	0.26	<5	7.9	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
46	2080/01/03	10:45am	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.8	73	24	28	0.1	0.02	6	0.5	0	Satisfactory
47	2080/01/03	1:10pm	Maharajgunj	Panipokhari In	Treated	Clear	0.16	<5	8.1	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
48	2080/01/03	1:20am	Maharajgunj	Panipokhari Out	Treated	Clear	0.13	<5	8.0	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
49	2080/01/03	3:10pm	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.8	70	24	26	0.1	0.02	6	0.4	0	Satisfactory
50	2080/01/04	11:00am	Madhyapur Thimi	Bode WTP	Treated	Clear	1.14	<5	6.9	266	68	56	0.3	1.7	10	1.0	0	Satisfactory
51	2080/01/04	01:30:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.29	<5	6.9	269	68	56	0.3	1.8	10	0.1	0	Satisfactory
52	2080/01/04	03:40:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.28	<5	6.9	267	68	56	0.3	1.8	10	0.1	0	Satisfactory
53	2080/01/04	10:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.89	<5	7.2	93	30	38	0.1	0.02	4	0.1	0	Satisfactory
54	2080/01/04	10:00AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.3	61	14	16	0.1	0.02	6	0.1	0	Satisfactory
55	2080/01/04	10:00AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.34	<5	7.6	101	22	28	0.1	0.02	6	0.3	0	Satisfactory
56	2080/01/04	6:42AM	Bhaktapur	Katunje SRT	Treated	Clear	0.19	<5	7.7	103	22	28	0.1	0.02	6	0.3	0	Satisfactory
57	2080/01/04	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.02	<5	7.3	71	14	16	0.1	0.02	6	0.1	0	Satisfactory
58	2080/01/04	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.39	<5	7.6	101	22	28	0.1	0.02	6	0.2	0	Satisfactory
59	2080/01/04	2:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.49	<5	7.9	70	14	16	0.1	0.02	6	0.6	0	Satisfactory
60	2080/01/04	2:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.58	<5	7.9	102	24	28	0.1	0.02	6	0.3	0	Satisfactory
61	2080/01/04	11:05AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.10	<5	8.0	106	24	30	0.1	0.02	6	0.2	0	Satisfactory
62	2080/01/04	10:50AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.15	<5	8.0	103	24	30	0.1	0.02	6	0.2	0	Satisfactory
63	2080/01/04	11:35AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.36	<5	8.1	106	26	30	0.1	0.02	6	0.2	0	Satisfactory
64	2080/01/04	12:30PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.20	<5	8.0	104	24	30	0.1	0.02	6	0.5	0	Satisfactory
65	2080/01/04	3:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.51	<5	7.9	71	14	16	0.1	0.02	6	0.5	0	Satisfactory
66	2080/01/04	3:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.48	<5	7.9	102	24	30	0.1	0.02	6	0.3	0	Satisfactory
67	2080/01/04	10:30am	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.04	<5	8.0	370	60	140	0.1	0.02	18	0.9	0	Satisfactory
68	2080/01/04	9:30AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.27	<5	8.0	77	22	18	0.1	0.02	6	0.2	0	Satisfactory
69	2080/01/04	12:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.49	<5	7.8	76	22	18	0.1	0.02	6	0.2	0	Satisfactory
70	2080/01/04	4:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	7.9	79	22	18	0.1	0.02	6	0.3	0	Satisfactory
71	2080/01/04	10:35AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.8	68	24	28	0.1	0.02	6	0.4	0	Satisfactory
72	2080/01/04	1:45PM	Maharajgunj	Panipokhari In	Treated	Clear	0.26	<5	8.0	77	28	34	0.1	0.02	6	0.3	0	Satisfactory
73	2080/01/04	1:55PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.22	<5	8.0	79	28	34	0.1	0.02	6	0.2	0	Satisfactory
74	2080/01/04	2:35PM	Maharajgunj	Bansbari In	Treated	Clear	0.15	<5	7.8	78	28	34	0.1	0.02	6	0.4	0	Satisfactory
75	2080/01/04	2:45PM	Maharajgunj	Bansbari Out	Treated	Clear	0.11	<5	7.8	80	28	34	0.1	0.02	6	0.2	0	Satisfactory
76	2080/01/04	3:15PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.8	71	24	28	0.1	0.02	6	0.4	0	Satisfactory
77	2080/01/05	11:00AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.32	<5	6.9	280	70	58	0.3	1.8	12	0.7	0	Satisfactory

78	2080/01/05	01:40:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.26	<5	6.9	285	72	60	0.3	1.8	14	0.9	0	Satisfactory
79	2080/01/05	03:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.29	<5	6.9	284	72	56	0.3	1.8	14	0.9	0	Satisfactory
80	2080/01/05	09:30:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.78	<5	7.2	93	30	38	0.1	0.02	4	0.1	0	Satisfactory
81	2080/01/05	10:00AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.49	<5	7.7	66	18	20	0.1	0.02	6	0.1	0	Satisfactory
82	2080/01/05	10:00AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.65	<5	7.8	95	24	26	0.1	0.02	6	0.2	0	Satisfactory
83	2080/01/05	8:10AM	Bhaktapur	Katunje SRT	Treated	Clear	0.20	<5	7.8	103	24	28	0.1	0.02	6	0.3	0	Satisfactory
84	2080/01/05	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.48	<5	7.7	69	18	20	0.1	0.02	6	0.2	0	Satisfactory
85	2080/01/05	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.15	<5	7.8	100	24	28	0.1	0.02	6	0.6	0	Satisfactory
86	2080/01/05	2:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.44	<5	7.8	77	18	20	0.1	0.02	6	1.0	0	Satisfactory
87	2080/01/05	2:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.16	<5	7.9	100	24	26	0.1	0.02	6	0.2	0	Satisfactory
88	2080/01/05	3:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.45	<5	7.5	75	18	20	0.1	0.02	6	1.0	0	Satisfactory
89	2080/01/05	3:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.20	<5	7.7	100	22	28	0.1	0.02	6	0.2	0	Satisfactory
90	2080/01/05	1:40:PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.71	<5	7.3	101	22	28	0.1	0.02	6	0.2	0	Satisfactory
91	2080/01/05	2:15PM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.69	<5	7.6	102	22	28	0.1	0.02	6	0.2	0	Satisfactory
92	2080/01/05	10:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.30	<5	7.9	79	22	18	0.1	0.02	6	0.2	0	Satisfactory
93	2080/01/05	12:30PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.31	<5	8.1	78	22	18	0.1	0.02	6	0.2	0	Satisfactory
94	2080/01/05	3:30PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.93	<5	8.0	80	22	18	0.1	0.02	6	0.1	0	Satisfactory
95	2080/01/05	10:30AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.8	69	24	28	0.1	0.02	6	0.3	0	Satisfactory
96	2080/01/05	10:35AM	Maharajgunj	Bansbari In	Treated	Clear	0.62	<5	7.8	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
97	2080/01/05	10:40AM	Maharajgunj	Bansbari Out	Treated	Clear	0.32	<5	7.8	76	28	32	0.1	0.02	6	0.1	0	Satisfactory
98	2080/01/05	12:45PM	Maharajgunj	Panipokhari In	Treated	Clear	0.43	<5	8.0	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
99	2080/01/05	12:50PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.38	<5	8.0	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
100	2080/01/05	3:10PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.8	69	24	28	0.1	0.02	6	0.3	0	Satisfactory
101	2080/01/06	10:30AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.53	<5	7.4	63	18	20	0.1	0.02	6	0.1	0	Satisfactory
102	2080/01/06	10:30AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.47	<5	7.5	101	22	28	0.1	0.02	6	0.4	0	Satisfactory
103	2080/01/06	11:00AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.56	<5	7.5	100	22	26	0.1	0.02	6	0.1	0	Satisfactory
104	2080/01/06	12:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.83	<5	7.6	52	14	16	0.1	0.02	6	0.7	0	Satisfactory
105	2080/01/06	12:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.33	<5	7.5	73	22	26	0.1	0.02	6	0.3	0	Satisfactory
106	2080/01/06	6:52AM	Bhaktapur	Katunje SRT	Treated	Clear	0.36	<5	7.7	76	22	26	0.1	0.02	6	0.2	0	Satisfactory
107	2080/01/06	2:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.36	<5	7.8	52	14	16	0.1	0.02	6	0.9	0	Satisfactory
108	2080/01/06	2:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.33	<5	8.1	46	26	24	0.1	0.02	6	0.4	0	Satisfactory
109	2080/01/06	10:55AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.32	<5	7.8	74	24	24	0.1	0.02	6	0.1	0	Satisfactory
110	2080/01/06	10:40AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.17	<5	7.9	74	24	24	0.1	0.02	6	0.3	0	Satisfactory
111	2080/01/06	11:25AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.39	<5	7.8	80	24	24	0.1	0.02	6	0.1	0	Satisfactory
112	2080/01/06	11:55AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.31	<5	7.7	77	22	24	0.1	0.02	6	0.1	0	Satisfactory
113	2080/01/06	4:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.40	<5	7.2	50	14	16	0.1	0.02	6	0.8	0	Satisfactory
114	2080/01/06	4:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.42	<5	7.4	72	22	24	0.1	0.02	6	0.4	0	Satisfactory
115	2080/01/06	11:35AM	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.17	<5	8.0	366	62	134	0.1	0.02	8	0.9	0	Satisfactory
116	2080/01/06	10:00AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	8.0	79	22	18	0.1	0.02	6	0.1	0	Satisfactory
117	2080/01/06	12:30PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.63	<5	8.0	80	22	18	0.1	0.02	6	0.2	0	Satisfactory
118	2080/01/06	4:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.48	<5	7.9	77	22	18	0.1	0.02	6	0.4	0	Satisfactory
119	2080/01/06	10:15AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.9	75	26	30	0.1	0.02	6	0.3	0	Satisfactory
120	2080/01/06	10:25AM	Maharajgunj	Bansbari In	Treated	Clear	0.52	<5	7.9	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
121	2080/01/06	10:35AM	Maharajgunj	Bansbari Out	Treated	Clear	0.48	<5	7.8	77	28	32	0.1	0.02	6	0.1	0	Satisfactory
122	2080/01/06	2:05PM	Maharajgunj	Panipokhari In	Treated	Clear	0.81	<5	7.8	78	28	34	0.1	0.02	6	0.2	0	Satisfactory
123	2080/01/06	2:15PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.67	<5	7.7	79	28	34	0.1	0.02	6	0.2	0	Satisfactory

124	2080/01/06	3:20PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.8	72	24	30	0.1	0.02	6	0.3	0	Satisfactory
125	2080/01/07	11:30:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.90	<5	6.9	286	84	76	0.3	1.7	16	1.0	0	Satisfactory
126	2080/01/07	01:30:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.93	<5	6.9	291	86	78	0.3	1.7	16	1.0	0	Satisfactory
127	2080/01/07	03:50:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.04	<5	6.9	312	86	78	0.3	1.7	16	1.0	0	Satisfactory
128	2080/01/07	09:30:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.64	<5	7.2	81	28	36	0.1	0.02	4	0.1	0	Satisfactory
129	2080/01/07	10:00AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.6	55	20	12	0.1	0.02	6	0.1	0	Satisfactory
130	2080/01/07	10:00AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.20	<5	7.7	72	22	26	0.1	0.02	6	0.2	0	Satisfactory
131	2080/01/07	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.3	64	18	12	0.1	0.02	6	1.0	0	Satisfactory
132	2080/01/07	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.48	<5	7.8	74	22	26	0.1	0.02	6	0.3	0	Satisfactory
133	2080/01/07	2:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.34	<5	8.1	67	20	12	0.1	0.02	6	1.0	0	Satisfactory
134	2080/01/07	2:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.14	<5	8.0	74	26	24	0.1	0.02	6	0.2	0	Satisfactory
135	2080/01/07	11:05AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.10	<5	8.0	76	24	26	0.1	0.02	6	0.3	0	Satisfactory
136	2080/01/07	11:20AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.29	<5	8.0	81	24	26	0.1	0.02	6	0.1	0	Satisfactory
137	2080/01/07	12:30PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.34	<5	7.9	77	24	26	0.1	0.02	6	0.3	0	Satisfactory
138	2080/01/07	1:40:PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.26	<5	8.0	77	24	26	0.1	0.02	6	0.2	0	Satisfactory
139	2080/01/07	3:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.9	67	20	12	0.1	0.02	6	1.0	0	Satisfactory
140	2080/01/07	3:00pm	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.18	<5	7.6	72	22	26	0.1	0.02	6	0.2	0	Satisfactory
141	2080/01/07	11:30am	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.35	<5	8.0	374	62	136	0.1	0.02	10	0.8	0	Satisfactory
142	2080/01/07	9:30AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	7.8	78	22	18	0.1	0.02	6	0.1	0	Satisfactory
143	2080/01/07	12:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.9	75	22	18	0.1	0.02	6	0.2	0	Satisfactory
144	2080/01/07	4:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.9	78	22	18	0.1	0.02	6	0.3	0	Satisfactory
145	2080/01/07	10:10AM	Maharajgunj	Bansbari In	Treated	Clear	0.32	<5	7.7	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
146	2080/01/07	10:25AM	Maharajgunj	Bansbari Out	Treated	Clear	0.22	<5	7.7	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
147	2080/01/07	10:50AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	74	26	30	0.1	0.02	6	0.3	0	Satisfactory
148	2080/01/07	1:35PM	Maharajgunj	Panipokhari In	Treated	Clear	0.46	<5	7.9	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
149	2080/01/07	1:45PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.42	<5	7.9	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
150	2080/01/07	3:10PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	76	24	28	0.1	0.02	6	0.3	0	Satisfactory
151	2080/01/08	11:20AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.57	<5	7.0	285	84	76	0.3	1.7	14	1.0	0	Satisfactory
152	2080/01/08	2:30PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.90	<5	7.0	290	84	76	0.3	1.7	14	1.0	0	Satisfactory
153	2080/01/08	09:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.95	<5	7.1	93	30	36	0.1	0.02	4	0.3	0	Satisfactory
154	2080/01/08	10:00AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.3	53	20	12	0.1	0.02	6	0.1	0	Satisfactory
155	2080/01/08	10:00AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.36	<5	7.7	71	22	26	0.1	0.02	6	0.2	0	Satisfactory
156	2080/01/08	11:05AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.11	<5	7.7	74	22	26	0.1	0.02	6	0.1	0	Satisfactory
157	2080/01/08	10:50AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.15	<5	7.7	74	22	26	0.1	0.02	6	0.4	0	Satisfactory
158	2080/01/08	7:03AM	Bhaktapur	Katunje SRT	Treated	Clear	0.20	<5	7.6	77	22	26	0.1	0.02	6	0.1	0	Satisfactory
159	2080/01/08	8:00AM	Bhaktapur	Katunje SRT	Treated	Clear	0.11	<5	7.3	78	22	26	0.1	0.02	6	0.1	0	Satisfactory
160	2080/01/08	9:00AM	Bhaktapur	Tigani SRT	Treated	Clear	0.95	<5	7.3	93	20	28	0.1	0.02	6	0.3	0	Satisfactory
161	2080/01/08	12:20PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.29	<5	7.9	58	20	12	0.1	0.02	6	0.4	0	Satisfactory
162	2080/01/08	12:20PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.88	<5	8.1	74	26	26	0.1	0.02	6	0.3	0	Satisfactory
163	2080/01/08	2:00PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.07	<5	7.0	59	20	12	0.1	0.02	6	1.0	0	Satisfactory
164	2080/01/08	2:00PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.21	<5	7.5	72	22	26	0.1	0.02	6	0.3	0	Satisfactory
165	2080/01/08	10:00AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	8.0	79	22	18	0.1	0.02	6	0.3	0	Satisfactory
166	2080/01/08	2:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.63	<5	8.0	78	22	18	0.1	0.02	6	0.2	0	Satisfactory
167	2080/01/08	4:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.83	<5	7.9	76	22	18	0.1	0.02	6	0.1	0	Satisfactory
168	2080/01/08	10:20AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	73	24	30	0.1	0.02	6	0.3	0	Satisfactory
169	2080/01/08	10:25AM	Maharajgunj	Bansbari In	Treated	Clear	0.26	<5	7.8	76	28	32	0.1	0.02	6	0.2	0	Satisfactory

170	2080/01/08	10:35AM	Maharajgunj	Bansbari Out	Treated	Clear	0.22	<5	7.8	76	28	32	0.1	0.02	6	0.2	0	Satisfactory
171	2080/01/08	12:35PM	Maharajgunj	Panipokhari In	Treated	Clear	0.16	<5	8.1	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
172	2080/01/08	12:50PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.13	<5	8.0	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
173	2080/01/09	10:40AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.81	<5	7.0	79	22	18	0.1	0.02	6	0.2	0	Satisfactory
174	2080/01/09	2:30PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	8.0	78	22	18	0.1	0.02	6	0.2	0	Satisfactory
175	2080/01/09	4:00PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.9	77	22	18	0.1	0.02	6	0.2	0	Satisfactory
176	2080/01/09	10:10AM	Maharajgunj	Bansbari In	Treated	Clear	0.18	<5	8.2	76	28	32	0.1	0.02	6	0.2	0	Satisfactory
177	2080/01/09	10:20AM	Maharajgunj	Bansbari Out	Treated	Clear	0.14	<5	8.2	76	28	32	0.1	0.02	6	0.2	0	Satisfactory
178	2080/01/09	10:55AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	73	26	28	0.1	0.02	6	0.3	0	Satisfactory
179	2080/01/09	3:00PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	69	24	28	0.1	0.02	6	0.3	0	Satisfactory
180	2080/01/10	11:45AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.61	<5	6.9	300	88	78	0.3	1.6	16	1.0	0	Satisfactory
181	2080/01/10	2:20PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.86	<5	6.9	303	90	80	0.3	1.6	16	1.0	0	Satisfactory
182	2080/01/10	4:00PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.79	<5	6.9	301	88	82	0.3	1.6	16	1.0	0	Satisfactory
183	2080/01/10	09:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.93	<5	7.2	110	32	36	0.2	0.96	4	0.1	0	Satisfactory
184	2080/01/10	10:30:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.88	<5	7.7	44	20	12	0.1	0.02	6	0.1	0	Satisfactory
185	2080/01/10	10:30:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.35	<5	7.8	71	24	26	0.1	0.02	6	0.3	0	Satisfactory
186	2080/01/10	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.43	<5	7.4	50	20	12	0.1	0.02	4	1.0	0	Satisfactory
187	2080/01/10	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.59	<5	7.8	71	22	26	0.1	0.02	6	0.4	0	Satisfactory
188	2080/01/10	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.57	<5	7.4	51	20	12	0.1	0.02	6	1.0	0	Satisfactory
189	2080/01/10	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.51	<5	7.3	72	22	26	0.1	0.02	6	0.6	0	Satisfactory
190	2080/01/10	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.38	<5	7.2	42	20	12	0.1	0.02	6	1.0	0	Satisfactory
191	2080/01/10	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.31	<5	7.3	74	22	26	0.1	0.02	6	0.7	0	Satisfactory
192	2080/01/10	02:30:00 PM	Chetrapati	Balaju SRT	Treated	Clear	0.36	<5	7.8	70	24	26	0.1	0.02	6	0.2	0	Satisfactory
193	2080/01/10	11:58:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.39	<5	7.2	72	22	26	0.1	0.02	6	0.1	0	Satisfactory
194	2080/01/10	01:05:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.33	<5	7.6	74	22	26	0.1	0.02	6	0.3	0	Satisfactory
195	2080/01/10	12:40:00 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.65	<5	7.7	76	22	26	0.1	0.02	6	0.1	0	Satisfactory
196	2080/01/10	11:45:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.26	<5	7.8	70	24	26	0.1	0.02	6	0.2	0	Satisfactory
197	2080/01/10	11:20am	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.02	<5	8.0	372	62	138	0.1	0.02	10	0.9	0	Satisfactory
198	2080/01/10	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.24	<5	7.9	79	22	18	0.1	0.02	6	0.1	0	Satisfactory
199	2080/01/10	01:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	7.9	78	22	18	0.1	0.02	6	0.2	0	Satisfactory
200	2080/01/10	04:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.32	<5	8.1	79	22	18	0.1	0.02	6	0.5	0	Satisfactory
201	2080/01/10	10:30:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	73	24	28	0.1	0.02	6	0.5	0	Satisfactory
202	2080/01/10	10:40:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.34	<5	8.0	77	28	32	0.1	0.02	6	0.2	0	Satisfactory
203	2080/01/10	10:50:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.26	<5	8.0	76	28	32	0.1	0.02	6	0.2	0	Satisfactory
204	2080/01/10	02:00:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.22	<5	8.1	78	28	32	0.1	0.02	6	0.2	0	Satisfactory
205	2080/01/10	02:10:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.18	<5	8.1	78	28	32	0.1	0.02	6	0.1	0	Satisfactory
206	2080/01/10	03:15:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	8.0	74	26	30	0.1	0.02	6	0.5	0	Satisfactory
207	2080/01/11	11:20:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.22	<5	6.9	317	90	82	0.3	1.7	16	0.8	0	Satisfactory
208	2080/01/11	02:20:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.14	<5	6.9	310	90	82	0.3	1.7	20	1.0	0	Satisfactory
209	2080/01/11	04:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.18	<5	6.9	311	90	82	0.3	1.7	20	1.0	0	Satisfactory
210	2080/01/11	09:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.45	<5	7.0	113	34	40	0.2	0.96	4	0.1	0	Satisfactory
211	2080/01/11	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.70	<5	8.0	61	20	12	0.1	0.02	6	0.1	0	Satisfactory
212	2080/01/11	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.78	<5	7.7	66	22	26	0.1	0.02	6	0.14	0	Satisfactory
213	2080/01/11	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.40	<5	8.1	66	20	12	0.1	0.02	6	0.1	0	Satisfactory
214	2080/01/11	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.23	<5	8.2	80	26	24	0.1	0.02	6	0.2	0	Satisfactory
215	2080/01/11	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.92	<5	7.2	59	20	12	0.1	0.02	6	0.65	0	Satisfactory

216	2080/01/11	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.36	<5	7.6	71	22	26	0.1	0.02	6	0.28	0	Satisfactory
217	2080/01/11	10:55:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.10	<5	7.7	69	22	24	0.1	0.02	6	0.39	0	Satisfactory
218	2080/01/11	11:10:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.50	<5	7.6	71	22	24	0.1	0.02	6	0.12	0	Satisfactory
219	2080/01/11	12:15:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.23	<5	7.7	70	22	24	0.1	0.02	6	0.23	0	Satisfactory
220	2080/01/11	11:50:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.30	<5	7.6	72	22	24	0.1	0.02	6	0.14	0	Satisfactory
221	2080/01/11	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.91	<5	7.4	59	20	12	0.1	0.02	6	0.54	0	Satisfactory
222	2080/01/11	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.38	<5	7.6	71	22	24	0.1	0.02	6	0.25	0	Satisfactory
223	2080/01/11	11:30:00 AM	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.71	<5	8.0	411	64	140	0.1	0.02	14	1	0	Satisfactory
224	2080/01/11	09:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	8.1	76	22	18	0.1	0.02	6	0.24	0	Satisfactory
225	2080/01/11	12:45:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.28	<5	7.9	77	22	18	0.1	0.02	6	0.21	0	Satisfactory
226	2080/01/11	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	8.0	78	22	18	0.1	0.02	6	0.34	0	Satisfactory
227	2080/01/11	10:30:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	73	24	28	0.1	0.02	6	0.24	0	Satisfactory
228	2080/01/11	10:35:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.33	<5	8.2	77	28	32	0.1	0.02	6	0.13	0	Satisfactory
229	2080/01/11	10:40:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.27	<5	8.1	77	28	32	0.1	0.02	6	0.1	0	Satisfactory
230	2080/01/11	01:30:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.40	<5	8.3	76	28	32	0.1	0.02	6	0.14	0	Satisfactory
231	2080/01/11	01:45:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.37	<5	8.2	77	28	32	0.1	0.02	6	0.11	0	Satisfactory
232	2080/01/11	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	75	26	30	0.1	0.02	6	0.23	0	Satisfactory
233	2080/01/12	11:15:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.68	<5	6.9	279	90	82	0.3	1.7	16	0.57	0	Satisfactory
234	2080/01/12	2:00pm	Madhyapur Thimi	Bode WTP	Treated	Clear	0.73	<5	6.9	283	88	82	0.3	1.7	16	0.89	0	Satisfactory
235	2080/01/12	10:40:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.50	<5	7.3	79	26	38	0.1	0.02	4	0.13	0	Satisfactory
236	2080/01/12	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.80	<5	7.6	50	20	12	0.1	0.02	6	0.1	0	Satisfactory
237	2080/01/12	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.34	<5	7.6	66	22	26	0.1	0.02	6	0.16	0	Satisfactory
238	2080/01/12	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.70	<5	7.6	57	20	12	0.1	0.02	6	1	0	Satisfactory
239	2080/01/12	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.39	<5	7.3	72	22	24	0.1	0.02	6	0.12	0	Satisfactory
240	2080/01/12	10:40:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.19	<5	7.5	75	22	26	0.1	0.02	6	0.22	0	Satisfactory
241	2080/01/12	11:00:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.30	<5	7.5	74	22	26	0.1	0.02	6	0.16	0	Satisfactory
242	2080/01/12	11:30:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.09	<5	7.6	75	22	26	0.1	0.02	6	0.2	0	Satisfactory
243	2080/01/12	12:00:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.10	<5	7.4	74	22	26	0.1	0.02	6	0.38	0	Satisfactory
244	2080/01/12	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.74	<5	8.0	64	20	12	0.1	0.02	6	0.97	0	Satisfactory
245	2080/01/12	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.37	<5	8.0	74	24	26	0.1	0.02	6	0.41	0	Satisfactory
246	2080/01/12	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.64	<5	8.0	64	20	12	0.1	0.02	6	0.89	0	Satisfactory
247	2080/01/12	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.40	<5	8.0	74	24	26	0.1	0.02	6	0.45	0	Satisfactory
248	2080/01/12	10:25am	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.74	<5	7.8	406	62	138	0.1	0.02	10	0.67	0	Satisfactory
249	2080/01/12	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.26	<5	7.8	77	22	18	0.1	0.02	6	0.31	0	Satisfactory
250	2080/01/12	12:45:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.96	<5	7.7	64	18	16	0.1	0.02	6	0.17	0	Satisfactory
251	2080/01/12	03:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.7	68	18	16	0.1	0.02	6	0.21	0	Satisfactory
252	2080/01/12	10:00:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.14	<5	8.3	76	28	32	0.1	0.02	6	0.16	0	Satisfactory
253	2080/01/12	10:10:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.11	<5	8.2	76	28	32	0.1	0.02	6	0.14	0	Satisfactory
254	2080/01/12	10:50:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	74	24	28	0.1	0.02	6	0.27	0	Satisfactory
255	2080/01/12	01:10:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.26	<5	8.2	77	28	32	0.1	0.02	6	0.21	0	Satisfactory
256	2080/01/12	01:25:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.20	<5	8.2	78	28	32	0.1	0.02	6	0.19	0	Satisfactory
257	2080/01/12	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	75	26	30	0.1	0.02	6	0.26	0	Satisfactory
258	2080/01/13	11:30:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.29	<5	7.1	273	88	80	0.3	1.7	16	0.99	0	Satisfactory
259	2080/01/13	02:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.28	<5	7.0	280	90	82	0.3	1.7	16	1	0	Satisfactory
260	2080/01/13	02:30:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.26	<5	7.1	279	88	82	0.3	1.7	16	1	0	Satisfactory
261	2080/01/13	10:30:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.15	<5	7.4	85	26	38	0.1	0.02	4	0.1	0	Satisfactory

262	2080/01/13	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.85	<5	7.5	55	20	10	0.1	0.02	6	0.07	0	Satisfactory
263	2080/01/13	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.31	<5	7.6	74	22	26	0.1	0.02	6	0.27	0	Satisfactory
264	2080/01/13	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.55	<5	7.5	56	20	10	0.1	0.02	6	0.05	0	Satisfactory
265	2080/01/13	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.14	<5	7.8	74	24	26	0.1	0.02	6	0.25	0	Satisfactory
266	2080/01/13	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.55	<5	7.9	59	20	10	0.1	0.02	6	0.5	0	Satisfactory
267	2080/01/13	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.55	<5	8.0	75	26	24	0.1	0.02	6	0.16	0	Satisfactory
268	2080/01/13	10:55:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.43	<5	7.9	76	24	26	0.1	0.02	6	0.12	0	Satisfactory
269	2080/01/13	11:05:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.11	<5	8.0	79	24	26	0.1	0.02	6	0.13	0	Satisfactory
270	2080/01/13	11:30:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.94	<5	7.7	82	22	26	0.1	0.02	6	0.05	0	Satisfactory
271	2080/01/13	12:15:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.14	<5	7.8	77	24	26	0.1	0.02	6	0.15	0	Satisfactory
272	2080/01/13	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.9	59	20	10	0.1	0.02	6	0.48	0	Satisfactory
273	2080/01/13	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.32	<5	8.0	75	24	26	0.1	0.02	6	0.2	0	Satisfactory
274	2080/01/13	10:20am	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.19	<5	7.9	408	62	136	0.1	0.02	10	0.98	0	Satisfactory
275	2080/01/13	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.49	<5	7.8	64	18	16	0.1	0.02	6	0.1	0	Satisfactory
276	2080/01/13	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.8	61	18	16	0.1	0.02	6	0.1	0	Satisfactory
277	2080/01/13	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	7.9	69	18	16	0.1	0.02	6	0.21	0	Satisfactory
278	2080/01/13	10:50:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	74	16	30	0.1	0.02	6	0.34	0	Satisfactory
279	2080/01/13	11:45:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.35	<5	7.8	78	28	32	0.1	0.02	6	0.13	0	Satisfactory
280	2080/01/13	11:55:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.27	<5	7.8	78	28	32	0.1	0.02	6	0.11	0	Satisfactory
281	2080/01/13	02:00:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.38	<5	8.1	78	28	32	0.1	0.02	6	0.16	0	Satisfactory
282	2080/01/13	02:10:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.32	<5	8.1	79	28	32	0.1	0.02	6	0.2	0	Satisfactory
283	2080/01/13	03:20:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	75	26	32	0.1	0.02	6	0.3	0	Satisfactory
284	2080/01/14	10:30:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.42	<5	7.0	292	84	78	0.3	1.7	16	0.8	0	Satisfactory
285	2080/01/14	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.5	50	20	10	0.1	0.02	6	0.1	0	Satisfactory
286	2080/01/14	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.18	<5	7.6	72	22	26	0.1	0.02	6	0.21	0	Satisfactory
287	2080/01/14	10:40:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.08	<5	8.0	77	24	26	0.1	0.02	6	0.41	0	Satisfactory
288	2080/01/14	10:55:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1.47	<5	7.9	78	24	26	0.1	0.02	6	0.22	0	Satisfactory
289	2080/01/14	12:15:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.49	<5	7.6	76	22	26	0.1	0.02	6	0.22	0	Satisfactory
290	2080/01/14	11:10:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.36	<5	8.0	81	24	26	0.1	0.02	6	0.19	0	Satisfactory
291	2080/01/14	10:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.10	<5	7.5	73	22	26	0.1	0.02	6	0.2	0	Satisfactory
292	2080/01/14	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.5	60	20	10	0.1	0.02	6	1	0	Satisfactory
293	2080/01/14	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.36	<5	7.7	78	22	26	0.1	0.02	6	0.14	0	Satisfactory
294	2080/01/14	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.14	<5	8.2	68	20	10	0.1	0.02	6	1	0	Satisfactory
295	2080/01/14	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	8.0	76	24	26	0.1	0.02	6	0.34	0	Satisfactory
296	2080/01/14	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.98	<5	8.0	68	20	10	0.1	0.02	6	1	0	Satisfactory
297	2080/01/14	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.24	<5	7.9	75	22	26	0.1	0.02	6	0.32	0	Satisfactory
298	2080/01/14	11:05am	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.52	<5	8.1	418	64	140	0.1	0.02	12	0.84	0	Satisfactory
299	2080/01/14	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.69	<5	7.8	63	18	16	0.1	0.02	6	0.32	0	Satisfactory
300	2080/01/14	02:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	7.9	64	18	16	0.1	0.02	6	0.16	0	Satisfactory
301	2080/01/14	04:15:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.8	64	18	16	0.1	0.02	6	0.27	0	Satisfactory
302	2080/01/14	10:35:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	73	24	28	0.1	0.02	6	0.32	0	Satisfactory
303	2080/01/14	10:50:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.18	<5	7.8	77	28	32	0.1	0.02	6	0.18	0	Satisfactory
304	2080/01/14	10:55:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.14	<5	7.8	77	28	32	0.1	0.02	6	0.15	0	Satisfactory
305	2080/01/14	11:50:00 AM	Maharajgunj	Panipokhari In	Treated	Clear	0.22	<5	7.9	78	28	32	0.1	0.02	6	0.16	0	Satisfactory
306	2080/01/14	11:55:00 AM	Maharajgunj	Panipokhari Out	Treated	Clear	0.17	<5	7.8	79	28	32	0.1	0.02	6	0.13	0	Satisfactory
307	2080/01/14	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	75	26	30	0.1	0.02	6	0.29	0	Satisfactory

308	2080/01/15	11:00:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.20	<5	7.1	291	90	82	0.3	1.7	20	1	0	Satisfactory
309	2080/01/15	02:15:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.30	<5	7.1	282	90	82	0.3	1.7	20	1	0	Satisfactory
310	2080/01/15	10:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.08	<5	7.3	82	26	36	0.1	0.02	4	0.1	0	Satisfactory
311	2080/01/15	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.4	61	20	10	0.1	0.02	6	0.1	0	Satisfactory
312	2080/01/15	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.51	<5	7.6	71	22	26	0.1	0.02	6	0.18	0	Satisfactory
313	2080/01/15	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.47	<5	7.4	66	20	10	0.1	0.02	6	0.6	0	Satisfactory
314	2080/01/15	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.53	<5	7.6	75	22	26	0.1	0.02	6	0.27	0	Satisfactory
315	2080/01/15	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.73	<5	7.5	70	20	10	0.1	0.02	6	1	0	Satisfactory
316	2080/01/15	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.19	<5	7.1	77	20	24	0.1	0.02	6	0.28	0	Satisfactory
317	2080/01/15	12:55:00 PM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.89	<5	7.9	76	24	24	0.1	0.02	6	0.46	0	Satisfactory
318	2080/01/15	11:05:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1.19	<5	7.9	75	24	24	0.1	0.02	6	0.25	0	Satisfactory
319	2080/01/15	11:30:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.95	<5	7.9	83	24	24	0.1	0.02	6	0.29	0	Satisfactory
320	2080/01/15	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.9	63	18	16	0.1	0.02	6	0.1	0	Satisfactory
321	2080/01/15	01:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.8	60	18	16	0.1	0.02	6	0.21	0	Satisfactory
322	2080/01/15	03:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.9	61	18	16	0.1	0.02	6	0.14	0	Satisfactory
323	2080/01/15	10:25:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.53	<5	8.0	77	28	32	0.1	0.02	6	0.16	0	Satisfactory
324	2080/01/15	10:35:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.45	<5	8.0	77	28	32	0.1	0.02	6	0.1	0	Satisfactory
325	2080/01/15	10:55:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.9	75	26	30	0.1	0.02	6	0.34	0	Satisfactory
326	2080/01/15	11:10:00 AM	Maharajgunj	Panipokhari In	Treated	Clear	0.32	<5	8.1	80	28	32	0.1	0.02	6	0.13	0	Satisfactory
327	2080/01/15	11:20:00 AM	Maharajgunj	Panipokhari Out	Treated	Clear	0.27	<5	8.0	80	28	32	0.1	0.02	6	0.11	0	Satisfactory
328	2080/01/15	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	7.9	76	26	30	0.1	0.02	6	0.28	0	Satisfactory
329	2080/01/16	10:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.30	<5	7.9	69	18	16	0.1	0.02	6	0.21	0	Satisfactory
330	2080/01/16	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.9	70	18	16	0.1	0.02	6	0.22	0	Satisfactory
331	2080/01/16	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	7.9	69	18	16	0.1	0.02	6	0.24	0	Satisfactory
332	2080/01/16	10:50:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.8	74	24	28	0.1	0.02	6	0.35	0	Satisfactory
333	2080/01/16	12:50:00 PM	Maharajgunj	Bansbari In	Treated	Clear	0.63	<5	7.9	78	28	32	0.1	0.02	6	0.33	0	Satisfactory
334	2080/01/16	12:55:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	0.52	<5	7.9	78	28	32	0.1	0.02	6	0.29	0	Satisfactory
335	2080/01/16	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.43	<5	7.9	73	24	28	0.1	0.02	6	0.31	0	Satisfactory
336	2080/01/17	11:15:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.89	<5	7.0	321	90	86	0.3	1.7	16	0.56	0	Satisfactory
337	2080/01/17	02:15:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.78	<5	7.0	310	90	86	0.3	1.7	20	0.88	0	Satisfactory
338	2080/01/17	03:30:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.74	<5	7.0	313	90	86	0.3	1.7	20	0.9	0	Satisfactory
339	2080/01/17	10:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.23	<5	7.2	102	28	38	0.1	0.02	4	0.1	0	Satisfactory
340	2080/01/17	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.71	<5	7.4	56	20	10	0.1	0.02	6	0.25	0	Satisfactory
341	2080/01/17	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.81	<5	7.4	72	22	24	0.1	0.02	6	0.21	0	Satisfactory
342	2080/01/17	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.19	<5	7.7	61	20	10	0.1	0.02	6	0.57	0	Satisfactory
343	2080/01/17	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.05	<5	7.9	75	24	22	0.1	0.02	6	0.33	0	Satisfactory
344	2080/01/17	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.34	<5	7.5	56	20	10	0.1	0.02	6	0.44	0	Satisfactory
345	2080/01/17	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.95	<5	7.4	71	22	24	0.1	0.02	6	0.28	0	Satisfactory
346	2080/01/17	10:45:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.01	<5	7.7	74	22	24	0.1	0.02	6	0.34	0	Satisfactory
347	2080/01/17	11:10:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.08	<5	7.8	71	24	22	0.1	0.02	6	0.26	0	Satisfactory
348	2080/01/17	11:30:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	7.8	75	24	22	0.1	0.02	6	0.23	0	Satisfactory
349	2080/01/17	12:42:00 PM	Chettrapati	Balaju SRT	Treated	Clear	1.30	<5	7.8	73	24	22	0.1	0.02	6	0.26	0	Satisfactory
350	2080/01/17	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.44	<5	7.5	56	20	10	0.1	0.02	6	0.49	0	Satisfactory
351	2080/01/17	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.96	<5	7.6	71	22	24	0.1	0.02	6	0.22	0	Satisfactory
352	2080/01/17	09:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	7.9	70	18	16	0.1	0.02	6	0.35	0	Satisfactory
353	2080/01/17	12:45:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.9	63	18	16	0.1	0.02	6	0.11	0	Satisfactory

354	2080/01/17	03:45:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.8	63	18	16	0.1	0.02	6	0.23	0	Satisfactory
355	2080/01/17	10:45:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.6	74	24	28	0.1	0.02	6	0.32	0	Satisfactory
356	2080/01/17	11:35:00 AM	Maharajgunj	Panipokhari In	Treated	Clear	0.34	<5	8.2	77	28	32	0.1	0.02	6	0.13	0	Satisfactory
357	2080/01/17	11:45:00 AM	Maharajgunj	Panipokhari Out	Treated	Clear	0.22	<5	8.2	78	28	32	0.1	0.02	6	0.1	0	Satisfactory
358	2080/01/17	12:50:00 PM	Maharajgunj	Bansbari In	Treated	Clear	0.26	<5	8.2	77	28	32	0.1	0.02	6	0.25	0	Satisfactory
359	2080/01/17	12:55:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	0.18	<5	8.1	77	28	32	0.1	0.02	6	0.22	0	Satisfactory
360	2080/01/17	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.9	76	26	30	0.1	0.02	6	0.3	0	Satisfactory
361	2080/01/18	06:40:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.15	<5	7.6	74	22	24	0.1	0.02	6	0.55	0	Satisfactory
362	2080/01/18	07:30:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.1	74	22	24	0.1	0.02	6	0.21	0	Satisfactory
363	2080/01/18	07:00:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	7.4	74	22	24	0.1	0.02	6	0.3	0	Satisfactory
364	2080/01/18	08:00:00 AM	Chettrapati	Balaju SRT	Treated	Clear	1.15	<5	7.6	74	22	24	0.1	0.02	6	0.16	0	Satisfactory
365	2080/01/18	08:30:00 AM	Maharajgunj	Panipokhari inlet	Treated	Clear	0.77	<5	7.4	74	22	24	0.1	0.02	6	0.23	0	Satisfactory
366	2080/01/18	08:30:00 AM	Maharajgunj	Panipokhari Outlet	Treated	Clear	0.73	<5	7.3	73	22	24	0.1	0.02	6	0.29	0	Satisfactory
367	2080/01/18	08:30:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.27	<5	6.9	58	20	10	0.1	0.02	6	0.12	0	Satisfactory
368	2080/01/18	08:30:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.16	<5	7.1	72	22	24	0.1	0.02	6	0.12	0	Satisfactory
369	2080/01/18	11:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.59	<5	7.9	63	18	16	0.1	0.02	6	0.24	0	Satisfactory
370	2080/01/18	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	8.0	70	18	16	0.1	0.02	6		0	Satisfactory
371	2080/01/18	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	8.0	69	18	16	0.1	0.02	6	0.26	0	Satisfactory
372	2080/01/18	10:35:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	72	24	28	0.1	0.02	6	0.33	0	Satisfactory
373	2080/01/18	01:50:00 PM	Maharajgunj	Bansbari In	Treated	Clear	0.13	<5	8.2	78	28	32	0.1	0.02	6	0.25	0	Satisfactory
374	2080/01/18	01:55:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	0.10	<5	8.1	77	28	32	0.1	0.02	6	0.17	0	Satisfactory
375	2080/01/18	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	73	24	28	0.1	0.02	6	0.26	0	Satisfactory
376	2080/01/19	11:50:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.13	<5	6.8	372	92	72	0.3	1.6	20	1	0	Satisfactory
377	2080/01/19	02:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.14	<5	6.8	375	92	72	0.3	1.6	20	1	0	Satisfactory
378	2080/01/19	04:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.06	<5	6.7	369	92	72	0.3	1.6	20	1	0	Satisfactory
379	2080/01/19	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.37	<5	7.3	54	20	10	0.1	0.02	6	0.1	0	Satisfactory
380	2080/01/19	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.84	<5	7.6	72	22	24	0.1	0.02	6	0.12	0	Satisfactory
381	2080/01/19	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.48	<5	7.4	64	20	10	0.1	0.02	6	0.76	0	Satisfactory
382	2080/01/19	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.04	<5	7.1	73	22	24	0.1	0.02	6	0.35	0	Satisfactory
383	2080/01/19	10:55:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.52	<5	7.8	75	24	26	0.1	0.02	6	0.15	0	Satisfactory
384	2080/01/19	11:10:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.36	<5	7.7	73	24	26	0.1	0.02	6	0.1	0	Satisfactory
385	2080/01/19	11:55:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.12	<5	7.7	75	24	26	0.1	0.02	6	0.1	0	Satisfactory
386	2080/01/19	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.27	<5	7.5	63	20	10	0.1	0.02	6	0.98	0	Satisfactory
387	2080/01/19	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.27	<5	7.8	73	24	26	0.1	0.02	6	0.15	0	Satisfactory
388	2080/01/19	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.05	<5	7.5	63	20	10	0.1	0.02	6	0.96	0	Satisfactory
389	2080/01/19	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.33	<5	7.8	72	24	26	0.1	0.02	6	0.14	0	Satisfactory
390	2080/01/19	09:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	8.1	69	18	16	0.1	0.02	6	0.44	0	Satisfactory
391	2080/01/19	12:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.9	63	18	16	0.1	0.02	6	0.1	0	Satisfactory
392	2080/01/19	03:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	1.03	<5	7.9	67	18	16	0.1	0.02	6	0.19	0	Satisfactory
393	2080/01/19	10:20:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	75	26	30	0.1	0.02	6	0.41	0	Satisfactory
394	2080/01/19	10:30:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.16	<5	8.0	78	28	32	0.1	0.02	6	0.11	0	Satisfactory
395	2080/01/19	10:45:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.13	<5	7.9	79	28	32	0.1	0.02	6	0.1	0	Satisfactory
396	2080/01/19	01:35:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.47	<5	8.3	79	28	32	0.1	0.02	6	0.14	0	Satisfactory
397	2080/01/19	01:45:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.44	<5	8.2	80	28	32	0.1	0.02	6	0.1	0	Satisfactory
398	2080/01/19	03:15:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.9	76	28	32	0.1	0.02	6	0.28	0	Satisfactory
399	2080/01/20	11:30:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.59	<5	6.9	341	90	64	0.3	1.6	14	0.27	0	Satisfactory

400	2080/01/20	02:15:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.72	<5	6.9	339	90	64	0.3	1.6	14	0.58	0	Satisfactory
401	2080/01/20	03:40:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.04	<5	6.9	355	90	66	0.3	1.6	16	0.8	0	Satisfactory
402	2080/01/20	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.4	61	20	10	0.1	0.02	6	0.24	0	Satisfactory
403	2080/01/20	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.25	<5	7.3	70	20	24	0.1	0.02	6	0.33	0	Satisfactory
404	2080/01/20	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.60	<5	7.5	65	22	10	0.1	0.02	6	1	0	Satisfactory
405	2080/01/20	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.31	<5	7.2	70	20	24	0.1	0.02	6	0.45	0	Satisfactory
406	2080/01/20	11:00:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.49	<5	7.6	73	22	26	0.1	0.02	6	0.24	0	Satisfactory
407	2080/01/20	10:45:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.02	<5	7.4	72	22	26	0.1	0.02	6	0.29	0	Satisfactory
408	2080/01/20	10:15:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	7.6	77	22	26	0.1	0.02	6	0.23	0	Satisfactory
409	2080/01/20	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.78	<5	7.5	66	20	10	0.1	0.02	6	1	0	Satisfactory
410	2080/01/20	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.23	<5	7.6	70	22	24	0.1	0.02	6	0.41	0	Satisfactory
411	2080/01/20	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.40	<5	7.5	67	20	10	0.1	0.02	6	1	0	Satisfactory
412	2080/01/20	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.23	<5	7.6	71	22	24	0.1	0.02	6	0.27	0	Satisfactory
413	2080/01/20	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.47	<5	8.0	62	18	16	0.1	0.02	6	0.2	0	Satisfactory
414	2080/01/20	11:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.9	68	18	16	0.1	0.02	6	0.24	0	Satisfactory
415	2080/01/20	03:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.87	<5	8.0	66	18	16	0.1	0.02	6	0.31	0	Satisfactory
416	2080/01/20	10:25:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.44	<5	7.9	74	24	28	0.1	0.02	6	0.28	0	Satisfactory
417	2080/01/20	10:30:00 AM	Maharajgunj	Bansbari In	Treated	Clear	2.04	<5	7.9	78	28	32	0.1	0.02	6	0.23	0	Satisfactory
418	2080/01/20	10:45:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.81	<5	7.9	78	28	32	0.1	0.02	6	0.11	0	Satisfactory
419	2080/01/20	02:00:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	1.85	<5	7.8	79	28	32	0.1	0.02	6	0.21	0	Satisfactory
420	2080/01/20	02:25:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	1.87	<5	7.9	80	28	32	0.1	0.02	6	0.1	0	Satisfactory
421	2080/01/20	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.9	75	26	30	0.1	0.02	6	0.29	0	Satisfactory
422	2080/01/21	11:00:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.76	<5	6.9	317	88	64	0.3	1.6	16	0.62	0	Satisfactory
423	2080/01/21	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.13	<5	7.4	60	20	8	0.1	0.02	6	0.1	0	Satisfactory
424	2080/01/21	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.18	<5	7.5	71	22	24	0.1	0.02	6	0.13	0	Satisfactory
425	2080/01/21	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	7.7	62	20	10	0.1	0.02	6	1	0	Satisfactory
426	2080/01/21	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.39	<5	7.7	72	22	24	0.1	0.02	6	0.32	0	Satisfactory
427	2080/01/21	12:00:00 PM	Baneshwor	Minbhawan SRT	Treated	Clear	0.48	<5	7.7	75	24	26	0.1	0.02	6	0.12	0	Satisfactory
428	2080/01/21	10:50:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.99	<5	7.7	76	24	26	0.1	0.02	6	0.19	0	Satisfactory
429	2080/01/21	11:30:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	1.34	<5	7.6	73	22	26	0.1	0.02	6	0.18	0	Satisfactory
430	2080/01/21	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	6.9	57	18	10	0.1	0.02	6	1	0	Satisfactory
431	2080/01/21	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.21	<5	7.6	72	22	24	0.1	0.02	6	0.2	0	Satisfactory
432	2080/01/21	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.30	<5	7.0	57	20	10	0.1	0.02	6	1	0	Satisfactory
433	2080/01/21	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.23	<5	7.6	73	22	24	0.1	0.02	6	0.19	0	Satisfactory
434	2080/01/21	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.94	<5	7.8	67	18	16	0.1	0.02	6	0.18	0	Satisfactory
435	2080/01/21	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	1.10	<5	7.9	66	18	16	0.1	0.02	6	0.34	0	Satisfactory
436	2080/01/21	03:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.9	65	18	16	0.1	0.02	6	0.18	0	Satisfactory
437	2080/01/21	10:30:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.35	<5	7.7	72	24	30	0.1	0.02	6	0.27	0	Satisfactory
438	2080/01/21	10:40:00 AM	Maharajgunj	Bansbari In	Treated	Clear	1.35	<5	7.9	76	28	32	0.1	0.02	6	0.12	0	Satisfactory
439	2080/01/21	10:55:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	1.22	<5	7.8	76	28	32	0.1	0.02	6	0.1	0	Satisfactory
440	2080/01/21	02:35:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	1.70	<5	7.9	76	28	32	0.1	0.02	6	0.28	0	Satisfactory
441	2080/01/21	02:45:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	1.65	<5	7.9	76	28	32	0.1	0.02	6	0.11	0	Satisfactory
442	2080/01/21	03:15:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.45	<5	7.7	73	24	30	0.1	0.02	6	0.26	0	Satisfactory
443	2080/01/22	08:45:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.96	<5	7.9	76	24	26	0.1	0.02	6	0.19	0	Satisfactory
444	2080/01/22	08:50:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.91	<5	8.0	74	24	26	0.1	0.02	6	0.13	0	Satisfactory
445	2080/01/22	09:05:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.12	<5	7.9	76	24	26	0.1	0.02	6	0.22	0	Satisfactory

446	2080/01/22	10:30:00 AM	Chettrapati	Balaju SRT	Treated	Clear	2.15	<5	8.0	74	24	26	0.1	0.02	6	0.24	0	Satisfactory
447	2080/01/22	11:00:00 AM	Maharajgunj	Panipokhari Inlet	Treated	Clear	2.19	<5	8.1	75	26	24	0.1	0.02	6	0.16	0	Satisfactory
448	2080/01/22	11:00:00 AM	Maharajgunj	Panipokhari Outlet	Treated	Clear	1.80	<5	8.0	73	26	24	0.1	0.02	6	0.37	0	Satisfactory
449	2080/01/22	11:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.13	<5	7.4	55	20	10	0.1	0.02	6	0.38	0	Satisfactory
450	2080/01/22	11:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.51	<5	7.5	73	22	26	0.1	0.02	6	0.47	0	Satisfactory
451	2080/01/22	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.96	<5	7.8	65	18	16	0.1	0.02	6	0.14	0	Satisfactory
452	2080/01/22	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.84	<5	8.0	66	18	16	0.1	0.02	6	0.13	0	Satisfactory
453	2080/01/22	03:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.79	<5	8.0	64	18	16	0.1	0.02	6	0.24	0	Satisfactory
454	2080/01/22	10:50:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.47	<5	7.8	72	24	30	0.1	0.02	6	0.35	0	Satisfactory
455	2080/01/22	01:45:00 PM	Maharajgunj	Bansbari In	Treated	Clear	0.93	<5	7.9	74	26	32	0.1	0.02	6	0.41	0	Satisfactory
456	2080/01/22	01:55:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	0.87	<5	7.9	75	26	32	0.1	0.02	6	0.27	0	Satisfactory
457	2080/01/22	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.62	<5	7.9	72	24	30	0.1	0.02	6	0.26	0	Satisfactory
458	2080/01/23	10:35:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.40	<5	7.7	55	20	28	0.1	0.02	6	0.35	0	Satisfactory
459	2080/01/23	10:50:00 AM	Maharajgunj	Bansbari In	Treated	Clear	1.07	<5	7.9	71	22	30	0.1	0.02	6	0.27	0	Satisfactory
460	2080/01/23	12:45:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	1.03	<5	7.9	71	22	30	0.1	0.02	6	0.23	0	Satisfactory
461	2080/01/23	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.43	<5	7.8	68	22	28	0.1	0.02	6	0.29	0	Satisfactory
462	2080/01/23	06:35:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.39	<5	7.9	74	24	26	0.1	0.02	6	0.12	0	Satisfactory
463	2080/01/23	07:10:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.38	<5	8.0	75	24	26	0.1	0.02	6	0.3	0	Satisfactory
464	2080/01/23	07:30:00 AM	Chettrapati	Balaju SRT	Treated	Clear	5.00	<5	8.1	74	26	26	0.1	0.02	6	0.18	0	Satisfactory
465	2080/01/23	07:10:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.59	<5	7.9	75	24	26	0.1	0.02	6	0.18	0	Satisfactory
466	2080/01/23	07:45:00 AM	Maharajgunj	Panipokhari Inlet	Treated	Clear	3.85	<5	7.9	75	24	26	0.1	0.02	6	0.17	0	Satisfactory
467	2080/01/23	07:45:00 AM	Maharajgunj	Panipokhari Outlet	Treated	Clear	4.66	<5	7.8	77	24	26	0.1	0.02	6	0.22	0	Satisfactory
468	2080/01/23	11:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.71	<5	7.8	55	20	10	0.1	0.02	6	0.29	0	Satisfactory
469	2080/01/23	11:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.68	<5	7.9	69	24	22	0.1	0.02	6	0.49	0	Satisfactory
470	2080/01/23	11:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	2.40	<5	7.9	63	18	16	0.1	0.02	6	0.27	0	Satisfactory
471	2080/01/23	02:30:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	2.10	<5	7.9	66	18	16	0.1	0.02	6	0.21	0	Satisfactory
472	2080/01/23	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	2.60	<5	7.8	65	18	16	0.1	0.02	6	0.23	0	Satisfactory
473	2080/01/24	10:50:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.7	69	22	28	0.1	0.02	6	0.31	0	Satisfactory
474	2080/01/24	11:10:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.37	<5	7.6	71	22	30	0.1	0.02	6	0.1	0	Satisfactory
475	2080/01/24	11:20:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.32	<5	7.6	71	22	30	0.1	0.02	6	0.1	0	Satisfactory
476	2080/01/24	01:45:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.34	<5	8.1	74	24	32	0.1	0.02	6	0.1	0	Satisfactory
477	2080/01/24	01:55:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.28	<5	8.0	75	24	32	0.1	0.02	6	0.1	0	Satisfactory
478	2080/01/24	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	67	22	28	0.1	0.02	6	0.28	0	Satisfactory
479	2080/01/24	11:40:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.64	<5	7.2	301	94	80	0.3	1.7	14	0.5	0	Satisfactory
480	2080/01/24	02:20:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.63	<5	7.2	281	94	72	0.3	1.7	14	0.38	0	Satisfactory
481	2080/01/24	04:30:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.64	<5	7.2	291	94	76	0.3	1.7	20	1	0	Satisfactory
482	2080/01/24	11:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	4.70	<5	7.5	81	26	36	0.1	0.02	4	0.1	0	Satisfactory
483	2080/01/24	11:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.32	<5	7.6	61	20	10	0.1	0.02	6	1	0	Satisfactory
484	2080/01/24	11:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.98	<5	7.6	70	22	24	0.1	0.02	6	0.43	0	Satisfactory
485	2080/01/24	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.42	<5	7.5	54	20	10	0.1	0.02	6	0.79	0	Satisfactory
486	2080/01/24	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.33	<5	7.4	52	22	20	0.1	0.02	6	0.47	0	Satisfactory
487	2080/01/24	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.49	<5	7.8	64	20	10	0.1	0.02	6	0.53	0	Satisfactory
488	2080/01/24	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.81	<5	7.9	68	24	22	0.1	0.02	6	0.29	0	Satisfactory
489	2080/01/24	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.43	<5	7.6	64	20	10	0.1	0.02	6	0.56	0	Satisfactory
490	2080/01/24	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.75	<5	7.8	66	24	22	0.1	0.02	6	0.27	0	Satisfactory
491	2080/01/24	10:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	1.26	<5	7.9	67	18	16	0.1	0.02	6	0.1	0	Satisfactory

492	2080/01/24	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	1.02	<5	8.2	65	18	16	0.1	0.02	6	0.11	0	Satisfactory
493	2080/01/24	03:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	8.1	67	18	16	0.1	0.02	6	0.17	0	Satisfactory
494	2080/01/25	11:20:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.85	<5	7.0	254	80	62	0.3	1.6	12	0.1	0	Satisfactory
495	2080/01/25	04:20:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.31	<5	6.9	290	80	72	0.3	1.6	18	0.45	0	Satisfactory
496	2080/01/25	03:50:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.19	<5	6.9	355	90	84	0.3	1.6	20	1	0	Satisfactory
497	2080/01/25	11:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.60	<5	7.5	73	26	34	0.1	0.02	4	0.1	0	Satisfactory
498	2080/01/25	11:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.5	48	20	10	0.2	0.02	6	0.15	0	Satisfactory
499	2080/01/25	11:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.61	<5	7.6	69	22	22	0.1	0.02	6	0.24	0	Satisfactory
500	2080/01/25	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5.00	<5	7.6	53	20	10	0.1	0.02	6	0.12	0	Satisfactory
501	2080/01/25	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.4	49	20	10	0.1	0.02	6	0.33	0	Satisfactory
502	2080/01/25	12:02:00 PM	Lalitpur	Khumaltar SRT	Treated	Clear	2.27	<5	7.7	81	22	26	0.1	0.02	6	0.1	0	Satisfactory
503	2080/01/25	10:45:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.22	<5	7.8	69	24	24	0.1	0.02	6	0.33	0	Satisfactory
504	2080/01/25	11:10:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.83	<5	7.7	73	22	26	0.1	0.02	6	0.1	0	Satisfactory
505	2080/01/25	11:45:00 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.88	<5	7.9	72	24	26	0.1	0.02	6	0.23	0	Satisfactory
506	2080/01/25	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.79	<5	8.0	58	20	10	0.1	0.02	6	0.7	0	Satisfactory
507	2080/01/25	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.44	<5	7.0	69	20	22	0.1	0.02	6	0.39	0	Satisfactory
508	2080/01/25	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.23	<5	7.8	64	20	10	0.1	0.02	6	0.75	0	Satisfactory
509	2080/01/25	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.98	<5	7.5	71	22	26	0.1	0.02	6	0.61	0	Satisfactory
510	2080/01/25	10:30:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.96	<5	7.7	69	18	16	0.1	0.02	6	0.1	0	Satisfactory
511	2080/01/25	03:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	2.36	<5	7.7	68	18	16	0.1	0.02	6	0.1	0	Satisfactory
512	2080/01/25	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	7.9	68	18	16	0.1	0.02	6	0.13	0	Satisfactory
513	2080/01/25	10:55:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.7	71	22	28	0.1	0.02	6	0.27	0	Satisfactory
514	2080/01/25	01:00:00 PM	Maharajgunj	Bansbari In	Treated	Clear	0.81	<5	7.7	75	26	32	0.1	0.02	6	0.14	0	Satisfactory
515	2080/01/25	01:10:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	0.77	<5	7.6	76	26	32	0.1	0.02	6	0.11	0	Satisfactory
516	2080/01/25	02:25:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	1.17	<5	8.0	76	26	32	0.1	0.02	6	0.15	0	Satisfactory
517	2080/01/25	02:35:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	1.13	<5	7.9	75	26	32	0.1	0.02	6	0.12	0	Satisfactory
518	2080/01/25	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.7	71	24	28	0.1	0.02	6	0.34	0	Satisfactory
519	2080/01/26	11:00:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.18	<5	6.9	269	80	70	0.3	1.6	18	0.24	0	Satisfactory
520	2080/01/26	04:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.98	<5	6.9	308	94	76	0.3	1.6	18		0	Satisfactory
521	2080/01/26	03:50:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.20	<5	6.9	293	92	74	0.3	1.6	16	0.23	0	Satisfactory
522	2080/01/26	10:30:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.97	<5	7.5	78	26	34	0.1	0.02	4	0.1	0	Satisfactory
523	2080/01/26	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.32	<5	7.3	51	20	10	0.1	0.02	6	0.1	0	Satisfactory
524	2080/01/26	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.55	<5	7.5	70	22	24	0.1	0.02	6	0.34	0	Satisfactory
525	2080/01/26	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.58	<5	7.2	59	20	10	0.1	0.02	6	1	0	Satisfactory
526	2080/01/26	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.30	<5	7.3	71	22	24	0.1	0.02	6	0.15	0	Satisfactory
527	2080/01/26	10:40:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.10	<5	7.5	72	22	24	0.1	0.02	6	0.23	0	Satisfactory
528	2080/01/26	11:35:00 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.86	<5	7.7	72	22	24	0.1	0.02	6	0.44	0	Satisfactory
529	2080/01/26	11:00:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.81	<5	7.6	73	22	24	0.1	0.02	6	0.26	0	Satisfactory
530	2080/01/26	12:00:00 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.82	<5	7.8	74	22	24	0.1	0.02	6	0.22	0	Satisfactory
531	2080/01/26	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.64	<5	7.5	64	20	10	0.1	0.02	6	1	0	Satisfactory
532	2080/01/26	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.35	<5	7.6	67	22	22	0.1	0.02	6	0.3	0	Satisfactory
533	2080/01/26	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.58	<5	7.5	64	20	10	0.1	0.02	6	1	0	Satisfactory
534	2080/01/26	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.35	<5	7.2	69	22	20	0.1	0.02	6	0.29	0	Satisfactory
535	2080/01/26	11:14:00 AM	Bhaktapur	Katunje SRT	Treated	Clear	5.00	<5	7.8	99	24	26	0.2	0.02	6	0.1	0	Satisfactory
536	2080/01/26	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	1.13	<5	8.1	65	18	16	0.1	0.02	6	0.21	0	Satisfactory
537	2080/01/26	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	1.09	<5	7.7	66	18	16	0.1	0.02	6	0.38	0	Satisfactory

538	2080/01/26	03:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.95	<5	7.6	67	18	16	0.1	0.02	6	0.31	0	Satisfactory
539	2080/01/26	10:10:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	7.7	68	24	28	0.1	0.02	6	0.32	0	Satisfactory
540	2080/01/26	10:15:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.74	<5	7.7	74	26	30	0.1	0.02	6	0.15	0	Satisfactory
541	2080/01/26	10:20:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.67	<5	7.7	74	26	30	0.1	0.02	6	0.12	0	Satisfactory
542	2080/01/26	02:50:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	7.7	73	26	28	0.1	0.02	6	0.26	0	Satisfactory
543	2080/01/26	03:00:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	1.06	<5	7.6	75	26	30	0.1	0.02	6	0.14	0	Satisfactory
544	2080/01/26	03:15:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	1.02	<5	7.6	75	26	30	0.1	0.02	6	0.11	0	Satisfactory
545	2080/01/27	10:30:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.99	<5	6.9	260	80	72	0.3	1.6	20	1	0	Satisfactory
546	2080/01/27	02:15:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.90	<5	6.9	280	82	78	0.3	1.6	20	1	0	Satisfactory
547	2080/01/27	04:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.96	<5	6.9	286	82	78	0.3	1.6	20	0.94	0	Satisfactory
548	2080/01/27	10:15:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.96	<5	7.6	92	28	38	0.1	0.02	4	0.26	0	Satisfactory
549	2080/01/27	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.17	<5	7.6	53	20	10	0.1	0.02	6	0.15	0	Satisfactory
550	2080/01/27	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.68	<5	7.9	70	24	20	0.1	0.02	6	0.45	0	Satisfactory
551	2080/01/27	06:18:00 AM	Bhaktapur	Katunje SRT	Treated	Clear	0.60	<5	7.7	73	22	24	0.1	0.02	6	0.19	0	Satisfactory
552	2080/01/27	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.04	<5	6.8	59	20	10	0.1	0.02	6	1	0	Satisfactory
553	2080/01/27	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.39	<5	7.3	70	22	20	0.1	0.02	6	0.15	0	Satisfactory
554	2080/01/27	10:40:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.60	<5	8.0	75	24	22	0.1	0.02	6	0.29	0	Satisfactory
555	2080/01/27	11:30:00 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.91	<5	8.0	75	24	22	0.1	0.02	6	0.39	0	Satisfactory
556	2080/01/27	10:55:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.22	<5	8.0	73	24	22	0.1	0.02	6	0.3	0	Satisfactory
557	2080/01/27	12:06:00 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.49	<5	8.0	73	24	22	0.1	0.02	6	0.16	0	Satisfactory
558	2080/01/27	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.78	<5	7.6	63	20	10	0.1	0.02	6	1	0	Satisfactory
559	2080/01/27	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.22	<5	7.5	70	22	20	0.1	0.02	6	0.38	0	Satisfactory
560	2080/01/27	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.79	<5	7.6	63	20	10	0.1	0.02	6	1	0	Satisfactory
561	2080/01/27	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.22	<5	7.8	70	22	20	0.1	0.02	6	0.38	0	Satisfactory
562	2080/01/27	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	1.77	<5	7.8	71	18	16	0.1	0.02	6	0.1	0	Satisfactory
563	2080/01/27	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.85	<5	7.9	68	18	16	0.1	0.02	6	0.32	0	Satisfactory
564	2080/01/27	03:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.99	<5	7.8	64	18	16	0.1	0.02	6	0.31	0	Satisfactory
565	2080/01/27	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	7.9	66	18	16	0.1	0.02	6	0.32	0	Satisfactory
566	2080/01/27	10:55:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.7	69	24	28	0.1	0.02	6	0.3	0	Satisfactory
567	2080/01/27	11:10:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.75	<5	7.9	74	26	30	0.1	0.02	6	0.14	0	Satisfactory
568	2080/01/27	11:20:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.52	<5	7.9	75	26	30	0.1	0.02	6	0.11	0	Satisfactory
569	2080/01/27	12:45:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	0.34	<5	8.1	75	26	30	0.1	0.02	6	0.1	0	Satisfactory
570	2080/01/27	12:55:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	0.26	<5	8.1	75	26	30	0.1	0.02	6	0.1	0	Satisfactory
571	2080/01/27	02:55:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.36	<5	7.7	71	24	28	0.1	0.02	6	0.32	0	Satisfactory
572	2080/01/28	10:50:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.83	<5	7.2	254	80	66	0.3	1.6	16	0.72	0	Satisfactory
573	2080/01/28	02:30:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.95	<5	7.1	270	80	72	0.3	1.6	16	0.85	0	Satisfactory
574	2080/01/28	04:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.97	<5	7.1	266	80	72	0.3	1.6	20	0.81	0	Satisfactory
575	2080/01/28	10:15:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.57	<5	7.2	105	50	46	0.3	1.5	6	1	0	Satisfactory
576	2080/01/28	10:30:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.16	<5	7.4	57	20	10	0.1	0.02	6	0.44	0	Satisfactory
577	2080/01/28	10:30:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.68	<5	7.8	70	22	22	0.1	0.02	6	0.16	0	Satisfactory
578	2080/01/28	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.23	<5	7.4	65	20	10	0.1	0.02	6	1	0	Satisfactory
579	2080/01/28	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.39	<5	7.4	65	22	20	0.1	0.02	6	0.1	0	Satisfactory
580	2080/01/28	12:00:00 PM	Bhaktapur	Katunje SRT	Treated	Clear	0.05	<5	7.9	73	24	20	0.1	0.02	6	0.1	0	Satisfactory
581	2080/01/28	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.6	71	20	10	0.1	0.02	6	1	0	Satisfactory
582	2080/01/28	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.09	<5	7.7	69	22	20	0.1	0.02	6	0.19	0	Satisfactory
583	2080/01/28	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.7	72	20	10	0.1	0.02	6	1	0	Satisfactory

584	2080/01/28	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.08	<5	7.7	68	22	20	0.1	0.02	6	0.2	0	Satisfactory
585	2080/01/28	10:30am	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.81	<5	8.0	375	60	136	0.1	0.02	10	0.81	0	Satisfactory
586	2080/01/28	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.81	<5	8.0	66	18	16	0.1	0.02	6	0.16	0	Satisfactory
587	2080/01/28	01:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	8.1	66	18	16	0.1	0.02	6	0.1	0	Satisfactory
588	2080/01/28	04:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.9	67	18	16	0.1	0.02	6	0.1	0	Satisfactory
589	2080/01/28	5:55PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	69	22	30	0.1	0.02	6	0.31	0	Satisfactory
590	2080/01/28	11:10:00 AM	Maharajgunj	Panipokhari In	Treated	Clear	0.23	<5	8.1	75	26	32	0.1	0.02	6	0.14	0	Satisfactory
591	2080/01/28	11:20:00 AM	Maharajgunj	Panipokhari Out	Treated	Clear	0.17	<5	8.1	76	26	32	0.1	0.02	6	0.11	0	Satisfactory
592	2080/01/28	01:15:00 PM	Maharajgunj	Bansbari In	Treated	Clear	0.14	<5	8.1	75	26	32	0.1	0.02	6	0.1	0	Satisfactory
593	2080/01/28	01:20:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	0.12	<5	8.1	75	26	32	0.1	0.02	6	0.1	0	Satisfactory
594	2080/01/28	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.7	72	24	30	0.1	0.02	6	0.26	0	Satisfactory
595	2080/01/29	11:00:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.98	<5	7.0	270	80	72	0.3	1.6	20	1	0	Satisfactory
596	2080/01/29	02:15:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	0.92	<5	7.0	274	80	72	0.3	1.6	20	1	0	Satisfactory
597	2080/01/29	04:00:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.25	<5	7.0	281	82	74	0.3	1.6	20	1	0	Satisfactory
598	2080/01/29	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.82	<5	7.6	49	20	10	0.1	0.02	6	0.1	0	Satisfactory
599	2080/01/29	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.70	<5	7.7	65	22	20	0.1	0.02	6	0.1	0	Satisfactory
600	2080/01/29	12:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.54	<5	7.8	58	20	10	0.1	0.02	6	0.63	0	Satisfactory
601	2080/01/29	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.43	<5	7.8	70	24	20	0.1	0.02	6	0.43	0	Satisfactory
602	2080/01/29	10:55:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1.67	<5	7.8	75	24	22	0.1	0.02	6	0.18	0	Satisfactory
603	2080/01/29	10:45:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	5.00	<5	7.9	81	24	26	0.1	0.02	6	0.19	0	Satisfactory
604	2080/01/29	10:40:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	3.27	<5	7.9	74	24	20	0.1	0.02	6	0.35	0	Satisfactory
605	2080/01/29	12:05:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.73	<5	7.7	75	22	20	0.1	0.02	6	0.32	0	Satisfactory
606	2080/01/29	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	8.0	65	20	10	0.1	0.02	6	1	0	Satisfactory
607	2080/01/29	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.56	<5	7.1	71	22	20	0.1	0.02	6	0.16	0	Satisfactory
608	2080/01/29	11:35am	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.45	<5	8.0	416	64	138	0.1	0.02	10	0.97	0	Satisfactory
609	2080/01/29	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	1.79	<5	8.2	67	18	16	0.1	0.02	6		0	Satisfactory
610	2080/01/29	01:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	8.1	66	18	16	0.1	0.02	6	0.1	0	Satisfactory
611	2080/01/29	5:55PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.80	<5	7.7	74	24	30	0.1	0.02	6	0.33	0	Satisfactory
612	2080/01/29	10:30:00 AM	Maharajgunj	Bansbari In	Treated	Clear	5.00	<5	8.0	76	28	34	0.1	0.02	6	0.1	0	Satisfactory
613	2080/01/29	10:35:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	5.00	<5	8.0	76	28	34	0.1	0.02	6	0.1	0	Satisfactory
614	2080/01/29	12:15:00 PM	Maharajgunj	Panipokhari In	Treated	Clear	5.00	<5	8.1	75	28	34	0.1	0.02	6	0.1	0	Satisfactory
615	2080/01/29	12:25:00 PM	Maharajgunj	Panipokhari Out	Treated	Clear	5.00	<5	8.0	76	28	34	0.1	0.02	6	0.1	0	Satisfactory
616	2080/01/29	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	2.72	<5	7.8	75	26	30	0.1	0.02	6	0.17	0	Satisfactory
617	2080/01/30	12:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	1.96	<5	8.0	69	18	16	0.1	0.02	6	0.1	0	Satisfactory
618	2080/01/30	05:55:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	7.4	68	22	28	0.1	0.02	6	0.23	0	Satisfactory
619	2080/01/30	03:00:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.4	67	22	28	0.1	0.02	6	0.17	0	Satisfactory
620	2080/01/30	06:00:00 PM	Maharajgunj	Bansbari In	Treated	Clear	4.85	<5	8.2	78	28	32	0.1	0.02	6	0.1	0	Satisfactory
621	2080/01/30	06:10:00 PM	Maharajgunj	Bansbari Out	Treated	Clear	4.93	<5	8.1	78	28	32	0.1	0.02	6	0.1	0	Satisfactory
622	2080/01/31	11:00:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.43	<5	7.2	250	88	62	0.3	1.6	12	0.08	0	Satisfactory
623	2080/01/31	10:00:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.99	<5	7.4	58	20	10	0.1	0.02	6	0.1	0	Satisfactory
624	2080/01/31	10:00:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.71	<5	7.9	71	24	20	0.1	0.02	6	0.1	0	Satisfactory
625	2080/01/31	10:00:00 AM	Bhaktapur	Katunje SRT	Treated	Clear	0.86	<5	8.2	81	26	28	0.1	0.02	6	0.1	0	Satisfactory
626	2080/01/31	10:00:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.47	<5	7.9	72	24	20	0.1	0.02	6	0.16	0	Satisfactory
627	2080/01/31	01:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.91	<5	7.2	66	20	10	0.1	0.02	6	0.94	0	Satisfactory
628	2080/01/31	12:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.22	<5	7.7	68	22	20	0.1	0.02	6	0.13	0	Satisfactory
629	2080/01/31	10:45:00 AM	Tripureshwor	Anamnagar SRT	Treated	Clear	0.98	<5	8.1	74	26	20	0.1	0.02	6	0.19	0	Satisfactory

630	2080/01/31	12:00:00 PM	Kirtipur	Kirtipur SRT	Treated	Clear	1.53	<5	8.1	74	26	22	0.1	0.02	6	0.35	0	Satisfactory
631	2080/01/31	11:30:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	5.00	<5	7.8	74	24	22	0.1	0.02	6	0.39	0	Satisfactory
632	2080/01/31	12:30:00 PM	Chettrapati	Balaju SRT	Treated	Clear	5.00	<5	8.2	73	26	22	0.2	0.02	6	0.36	0	Satisfactory
633	2080/01/31	11:05:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1.48	<5	8.0	73	24	22	0.1	0.02	6	0.22	0	Satisfactory
634	2080/01/31	02:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.96	<5	7.6	68	20	10	0.1	0.02	6	0.57	0	Satisfactory
635	2080/01/31	02:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.00	<5	7.6	69	22	20	0.1	0.02	6	0.23	0	Satisfactory
636	2080/01/31	03:00:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.97	<5	7.5	67	20	10	0.1	0.02	6	0.57	0	Satisfactory
637	2080/01/31	03:00:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.96	<5	7.5	70	22	20	0.1	0.02	6	0.24	0	Satisfactory
638	2080/01/31	11:30am	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.11	<5	8.0	409	62	134	0.1	0.02	10	0.86	0	Satisfactory
639	2080/01/31	10:00:00 AM	Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	8.2	69	18	16	0.1	0.02	6	0.25	0	Satisfactory
640	2080/01/31	12:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.9	64	18	16	0.1	0.02	6	0.17	0	Satisfactory
641	2080/01/31	04:00:00 PM	Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	8.0	63	18	16	0.1	0.02	6	0.2	0	Satisfactory
642	2080/01/31	05:55:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.37	<5	7.4	71	24	28	0.1	0.02	6	0.41	0	Satisfactory
643	2080/01/31	10:30:00 AM	Maharajgunj	Bansbari In	Treated	Clear	0.75	<5	8.1	78	28	32	0.1	0.02	6	0.1	0	Satisfactory
644	2080/01/31	10:40:00 AM	Maharajgunj	Bansbari Out	Treated	Clear	0.52	<5	8.1	77	28	32	0.1	0.02	6	0.1	0	Satisfactory
645	2080/01/31	11:25:00 AM	Maharajgunj	Panipokhari In	Treated	Clear	0.62	<5	7.8	77	28	32	0.1	0.02	6	0.1	0	Satisfactory
646	2080/01/31	11:35:00 AM	Maharajgunj	Panipokhari Out	Treated	Clear	0.73	<5	7.8	77	28	32	0.1	0.02	6	0.1	0	Satisfactory
647	2080/01/31	03:10:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.4	74	24	28	0.1	0.02	6	0.36	0	Satisfactory