



**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Poush 2080**

S.No.	Date	Time	Branch	Location	Sample taken	Appearance	Turbidity (NTU)	Colour (TCU)	p <sup>H</sup>	E.C. (µs/cm)	Total Alkalinity (mg/l)	Total Hardness (mg/l)	Total Iron (mg/l)	Total Ammonia (mg/l)	Chloride (mg/l)	F.R.C. (mg/L)	Total Coliforms (CFU/100mL)	Remarks	
Units →																			
National Drinking Water Quality Standard (NDWQS) →							5	5	6.5-8.5	1500		500.0	0.3(3)	1.5	250.0	0.1-0.5	0 in 95% Samples		
1	2080/9/1	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.36	<5	7.24	51	16	16	0.1	0.02	4.0	0.41	0	Satisfactory	
2	2080/9/1	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.17	51	16	16	0.1	0.02	4.0	0.64	0	Satisfactory	
3	2080/9/1	12:00	Madhyapur Thimi	Bode WTP	Treated	Clear	4.82	<5	7.05	266	82	70	0.3	1.5	16.0	0.53	0	Satisfactory	
4	2080/9/1	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.58	<5	7.02	254	78	68	0.3	1.5	10.0	0.10	0	Satisfactory	
5	2080/9/1	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.25	<5	7.02	253	78	68	0.3	1.5	10.0	0.10	0	Satisfactory	
6	2080/9/1	7:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.66	<5	7.26	35.4	16	18	0.1	0.02	8.0	1.00	0	Satisfactory	
7	2080/9/1	10:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.45	<5	7.59	35.6	16	18	0.1	0.02	8.0	0.86	0	Satisfactory	
8	2080/9/1	12:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.55	<5	7.38	35.4	16	18	0.1	0.02	8.0	0.91	0	Satisfactory	
9	2080/9/1	15:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.58	<5	7.22	35.4	16	18	0.1	0.02	8.0	1.00	0	Satisfactory	
10	2080/9/1	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.19	<5	7.97	53.2	20	16	0.1	0.02	6.0	0.45	0	Satisfactory	
11	2080/9/1	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.66	<5	7.69	56.7	16	16	0.1	0.02	6.0	0.56	0	Satisfactory	
12	2080/9/1	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.81	<5	7.5	60.3	14	16	0.1	0.02	6.0	0.75	0	Satisfactory	
13	2080/9/1	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.34	<5	6.78	65.3	12	14	0.1	0.02	6.0	0.70	0	Satisfactory	
14	2080/9/1	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.84	<5	6.9	51.8	12	14	0.1	0.02	6.0	0.36	0	Satisfactory	
15	2080/9/1	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.10	<5	7.07	51.6	12	14	0.1	0.02	6.0	0.39	0	Satisfactory	
16	2080/9/1	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.64	<5	7.15	54.7	12	14	0.1	0.02	6.0	0.40	0	Satisfactory	
17	2080/9/1	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.46	<5	7.25	58.9	14	16	0.1	0.02	6.0	0.45	0	Satisfactory	
18	2080/9/1	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.48	<5	8.18	385	50	142	0.1	0.02	10.0	0.97	0	Satisfactory	
19	2080/9/2	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.33	48	16	144	0.1	0.02	6.0	0.63	0	Satisfactory	
20	2080/9/2	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.27	51	16	146	0.1	0.02	6.0	0.62	0	Satisfactory	
21	2080/9/2	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.67	<5	7.06	283	94	148	0.3	1.5	16.0	0.30	0	Satisfactory	
22	2080/9/2	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.03	<5	7.1	272	92	136	0.3	1.5	16.0	0.21	0	Satisfactory	
23	2080/9/2	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.39	<5	7.1	272	92	146	0.3	1.5	12.0	0.10	0	Satisfactory	
24	2080/9/2	10:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.62	<5	7.02	37.1	16	18	0.1	0.02	8.0	0.85	0	Satisfactory	
25	2080/9/2	12:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.62	<5	6.96	37.7	16	18	0.1	0.02	8.0	0.92	0	Satisfactory	
26	2080/9/2	15:00	New Sundarrijal	Sundarrijal WTP	Treated	Clear	0.63	<5	6.98	38.0	16	18	0.1	0.02	8.0	0.96	0	Satisfactory	
27	2080/9/2	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.45	<5	8.04	392	56	144	0.1	0.02	10.0	0.87	0	Satisfactory	
28	2080/9/3	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.21	52	16	134	0.1	0.02	4.0	0.51	0	Satisfactory	

29	2080/9/3	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.20	48	16	148	0.1	0.02	6.0	0.71	0	Satisfactory
30	2080/9/3	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.92	<5	7.1	278	94	134	0.3	1.5	16.0	0.35	0	Satisfactory
31	2080/9/3	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.24	<5	7.09	272	94	146	0.3	1.5	16.0	0.23	0	Satisfactory
32	2080/9/3	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.41	<5	7.08	273	94	142	0.3	1.5	14.0	0.10	0	Satisfactory
33	2080/9/3	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.11	<5	6.71	39.2	14	18	0.1	0.02	8.0	1.00	0	Satisfactory
34	2080/9/3	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.91	<5	6.89	38.3	14	18	0.1	0.02	8.0	1.00	0	Satisfactory
35	2080/9/3	15:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	6.66	36.5	14	18	0.1	0.02	8.0	1.00	0	Satisfactory
36	2080/9/3	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.33	<5	6.97	55	10	16	0.1	0.02	6.0	0.28	0	Satisfactory
37	2080/9/3	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.05	<5	7.32	55.4	14	16	0.1	0.02	6.0	0.23	0	Satisfactory
38	2080/9/3	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.11	<5	7.27	60.9	14	16	0.1	0.02	6.0	0.30	0	Satisfactory
39	2080/9/3	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.15	<5	7.13	63.9	12	16	0.1	0.02	6.0	0.34	0	Satisfactory
40	2080/9/3	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.24	<5	7.95	405	60	146	0.1	0.02	10.0	0.93	0	Satisfactory
41	2080/9/4	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.22	51	16	148	0.1	0.02	6.0	0.54	0	Satisfactory
42	2080/9/4	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.24	59	16	136	0.1	0.02	6.0	0.48	0	Satisfactory
43	2080/9/4	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.30	<5	7.01	261	92	16	0.3	1.5	14.0	0.25	0	Satisfactory
44	2080/9/4	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.70	<5	7.02	265	92	68	0.3	1.5	14.0	0.14	0	Satisfactory
45	2080/9/4	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.72	<5	6.99	260	88	68	0.3	1.5	14.0	0.18	0	Satisfactory
46	2080/9/4	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	6.8	36.9	14	18	0.1	0.02	8.0	1.00	0	Satisfactory
47	2080/9/4	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.09	35.6	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
48	2080/9/4	15:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.2	36.2	18	18	0.1	0.02	8.0	1.00	0	Satisfactory
49	2080/9/4	17:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.16	37.1	18	18	0.1	0.02	8.0	1.00	0	Satisfactory
50	2080/9/4	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	6.7	53.8	8	12	0.1	0.02	6.0	0.31	0	Satisfactory
51	2080/9/4	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.56	53.7	16	16	0.1	0.02	6.0	0.32	0	Satisfactory
52	2080/9/4	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.30	<5	7.01	61.5	10	16	0.1	0.02	6.0	0.64	0	Satisfactory
53	2080/9/4	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.33	<5	7.12	54.1	12	16	0.1	0.02	6.0	0.87	0	Satisfactory
54	2080/9/4	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.42	<5	8.08	393	58	148	0.1	0.02	10.0	0.96	0	Satisfactory
55	2080/9/5	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.26	<5	7.23	48	16	16	0.1	0.02	6.0	0.51	0	Satisfactory
56	2080/9/5	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	45	16	16	0.1	0.02	4.0	0.48	0	Satisfactory
57	2080/9/5	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.20	<5	7.06	263	92	16	0.3	1.5	14.0	0.10	0	Satisfactory
58	2080/9/5	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.87	<5	7.02	268	92	68	0.3	1.5	16.0	0.21	0	Satisfactory
59	2080/9/5	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.91	<5	7.02	266	92	68	0.3	1.5	14.0	0.14	0	Satisfactory
60	2080/9/5	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.14	<5	7.13	33.4	18	18	0.1	0.02	8.0	0.24	0	Satisfactory
61	2080/9/5	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	7.27	33.6	18	18	0.1	0.02	8.0	0.27	0	Satisfactory
62	2080/9/5	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	6.6	35.7	14	18	0.1	0.02	8.0	0.50	0	Satisfactory
63	2080/9/5	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	6.6	35.8	14	18	0.1	0.02	8.0	0.80	0	Satisfactory
64	2080/9/5	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.73	<5	6.6	35.9	14	18	0.1	0.02	8.0	0.65	0	Satisfactory
65	2080/9/5	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.68	<5	7.81	51.6	18	16	0.1	0.02	6.0	0.45	0	Satisfactory
66	2080/9/5	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.71	<5	7.91	53.3	20	16	0.1	0.02	6.0	0.41	0	Satisfactory
67	2080/9/5	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.23	<5	7.89	58.4	20	16	0.1	0.02	6.0	0.70	0	Satisfactory
68	2080/9/5	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.10	<5	7.58	57.2	16	16	0.1	0.02	6.0	0.52	0	Satisfactory
69	2080/9/5	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.34	<5	7.97	387	58	136	0.1	0.02	10.0	0.75	0	Satisfactory
70	2080/9/6	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	46	16	16	0.1	0.02	6.0	0.52	0	Satisfactory
71	2080/9/6	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	54	16	16	0.1	0.02	6.0	0.64	0	Satisfactory

72	2080/9/6	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.79	<5	7.2	262	92	16	0.3	1.5	12.0	0.10	0	Satisfactory
73	2080/9/6	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.71	<5	7.15	260	92	68	0.3	1.5	16.0	0.23	0	Satisfactory
74	2080/9/6	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.95	<5	7.15	266	92	60	0.3	1.5	16.0	0.21	0	Satisfactory
75	2080/9/6	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	6.97	36.2	14	18	0.1	0.02	8.0	0.32	0	Satisfactory
76	2080/9/6	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.83	<5	7.03	37.3	14	18	0.1	0.02	8.0	1.00	0	Satisfactory
77	2080/9/6	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.79	<5	6.51	37.9	12	18	0.1	0.02	8.0	1.00	0	Satisfactory
78	2080/9/6	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.72	<5	6.57	37.6	10	18	0.1	0.02	8.0	1.00	0	Satisfactory
79	2080/9/6	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	6.5	37.1	10	18	0.1	0.02	8.0	1.00	0	Satisfactory
80	2080/9/6	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.50	<5	6.5	36.9	10	18	0.1	0.02	8.0	1.00	0	Satisfactory
81	2080/9/6	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	2.80	<5	6.5	37.8	10	18	0.1	0.02	8.0	1.00	0	Satisfactory
82	2080/9/6	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.2	53	12	16	0.1	0.02	6.0	0.30	0	Satisfactory
83	2080/9/6	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.83	<5	7.53	53.3	16	16	0.1	0.02	6.0	0.37	0	Satisfactory
84	2080/9/6	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.17	<5	7.55	55.3	16	16	0.1	0.02	6.0	0.27	0	Satisfactory
85	2080/9/7	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.17	52	16	16	0.1	0.02	6.0	0.47	0	Satisfactory
86	2080/9/7	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	49	16	16	0.1	0.02	6.0	0.54	0	Satisfactory
87	2080/9/7	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.79	<5	6.7	37.1	12	18	0.1	0.02	8.0	0.43	0	Satisfactory
88	2080/9/7	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.96	<5	6.5	36.7	12	18	0.1	0.02	8.0	0.22	0	Satisfactory
89	2080/9/7	13:30	New Sundarijal	Sundarijal WTP	Treated	Clear	2.26	<5	7.31	42.2	16	18	0.1	0.02	8.0	0.30	0	Satisfactory
90	2080/9/7	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	2.16	<5	6.5	37.6	12	18	0.1	0.02	8.0	0.19	0	Satisfactory
91	2080/9/8	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.33	51	16	16	0.1	0.02	6.0	0.56	0	Satisfactory
92	2080/9/8	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.31	50	16	16	0.1	0.02	6.0	0.64	0	Satisfactory
93	2080/9/8	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.70	<5	7.14	253	84	16	0.3	1.5	12.0	0.10	0	Satisfactory
94	2080/9/8	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.85	<5	7.1	263	90	68	0.3	1.5	12.0	0.12	0	Satisfactory
95	2080/9/8	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.19	<5	7.1	270	90	60	0.3	1.5	14.0	0.25	0	Satisfactory
96	2080/9/8	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	3.88	<5	7.72	55.9	16	18	0.1	0.02	8.0	0.55	0	Satisfactory
97	2080/9/8	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	3.55	<5	7.21	46.5	16	18	0.1	0.02	8.0	0.14	0	Satisfactory
98	2080/9/8	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.08	<5	6.82	55.5	16	18	0.1	0.02	8.0	0.20	0	Satisfactory
99	2080/9/8	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.08	<5	6.9	49.1	16	18	0.1	0.02	8.0	0.58	0	Satisfactory
100	2080/9/8	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.14	<5	7.35	78.9	14	16	0.1	0.02	6.0	0.37	0	Satisfactory
101	2080/9/8	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.10	<5	7.41	49.5	14	16	0.1	0.02	6.0	0.32	0	Satisfactory
102	2080/9/8	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.06	<5	7.37	50.1	14	16	0.1	0.02	6.0	0.40	0	Satisfactory
103	2080/9/8	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.38	60.8	14	16	0.1	0.02	6.0	0.50	0	Satisfactory
104	2080/9/8	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.22	<5	8.14	407	58	146	0.1	0.02	10.0	0.76	0	Satisfactory
105	2080/9/9	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.33	54	16	14	0.1	0.02	6.0	0.63	0	Satisfactory
106	2080/9/9	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	48	16	14	0.1	0.02	6.0	0.64	0	Satisfactory
107	2080/9/9	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.17	<5	6.5	56.2	12	18	0.1	0.02	8.0	1.00	0	Satisfactory
108	2080/9/9	11:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	7.8	45.2	18	18	0.1	0.02	8.0	1.00	0	Satisfactory
109	2080/9/9	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.2	45.1	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
110	2080/9/10	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.40	<5	7.18	51	16	16	0.1	0.02	6.0	0.58	0	Satisfactory
111	2080/9/10	15:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.24	48	16	16	0.1	0.02	6.0	0.63	0	Satisfactory
112	2080/9/10	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.94	<5	7.39	57.0	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
113	2080/9/10	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	6.9	52.6	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
114	2080/9/10	17:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	7.4	51.0	16	18	0.1	0.02	8.0	1.02	0	Satisfactory
115	2080/9/11	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.17	52	16	14	0.1	0.02	4.0	0.65	0	Satisfactory

116	2080/9/11	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	48	16	14	0.1	0.02	6.0	0.58	0	Satisfactory
117	2080/9/11	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.95	<5	7.02	274	88	14	0.3	1.5	12.0	0.10	0	Satisfactory
118	2080/9/11	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	4.05	<5	7.02	268	86	60	0.3	1.5	12.0	0.10	0	Satisfactory
119	2080/9/11	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.77	<5	7.33	51.8	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
120	2080/9/11	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.84	<5	7.51	58.0	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
121	2080/9/11	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	7.37	62.7	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
122	2080/9/11	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.95	<5	6.5	68.2	12	18	0.1	0.02	8.0	1.00	0	Satisfactory
123	2080/9/11	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.09	<5	6.51	69.4	12	18	0.1	0.02	8.0	1.00	0	Satisfactory
124	2080/9/11	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.38	<5	7.38	60.8	14	12	0.1	0.02	6.0	0.54	0	Satisfactory
125	2080/9/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.50	<5	7.01	57.7	10	16	0.1	0.02	6.0	0.45	0	Satisfactory
126	2080/9/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.48	<5	6.96	59.3	10	12	0.1	0.02	6.0	0.62	0	Satisfactory
127	2080/9/11	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.31	<5	6.95	60.7	10	16	0.1	0.02	6.0	0.71	0	Satisfactory
128	2080/9/11	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.97	<5	8.24	374	58	138	0.1	0.02	8.0	0.81	0	Satisfactory
129	2080/9/12	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.20	55	16	16	0.1	0.02	6.0	0.62	0	Satisfactory
130	2080/9/12	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.12	<5	7.18	63	20	16	0.1	0.02	6.0	0.64	0	Satisfactory
131	2080/9/12	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.64	<5	7.12	265	88	12	0.3	1.5	12.0	0.10	0	Satisfactory
132	2080/9/12	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.44	<5	7.1	269	88	68	0.3	1.5	14.0	0.10	0	Satisfactory
133	2080/9/12	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.22	<5	7.11	262	86	60	0.3	1.5	14.0	0.14	0	Satisfactory
134	2080/9/12	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	7.31	69.7	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
135	2080/9/12	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.79	<5	7.3	82.4	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
136	2080/9/12	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.84	<5	7.3	90.3	16	18	0.1	0.02	8.0	1.05	0	Satisfactory
137	2080/9/12	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.69	<5	7.36	81.9	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
138	2080/9/12	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.55	<5	6.6	77.3	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
139	2080/9/12	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.48	<5	6.75	79.2	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
140	2080/9/12	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.51	<5	7.13	57.7	12	12	0.1	0.02	6.0	0.52	0	Satisfactory
141	2080/9/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.91	<5	7.17	53.5	12	12	0.1	0.02	6.0	0.75	0	Satisfactory
142	2080/9/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.01	<5	7.31	55.4	14	16	0.1	0.02	6.0	0.45	0	Satisfactory
143	2080/9/12	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.01	<5	8.03	78.6	20	16	0.1	0.02	10.0	2.37	0	Satisfactory
144	2080/9/12	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.22	<5	8.11	381	56	132	0.1	0.02	10.0	0.97	0	Satisfactory
145	2080/9/13	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.23	57	18	16	0.1	0.02	6.0	0.60	0	Satisfactory
146	2080/9/13	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	56	18	16	0.1	0.02	4.0	0.65	0	Satisfactory
147	2080/9/13	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.95	<5	7.07	262	86	16	0.3	1.5	12.0	0.10	0	Satisfactory
148	2080/9/13	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.87	<5	7.03	261	86	68	0.3	1.5	10.0	0.11	0	Satisfactory
149	2080/9/13	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.70	<5	7.02	262	86	60	0.3	1.5	10.0	0.10	0	Satisfactory
150	2080/9/13	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.43	<5	7.59	73.3	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
151	2080/9/13	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.59	81.8	16	18	0.1	0.02	8.0	1.00	0	Satisfactory
152	2080/9/13	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.84	92.0	16	18	0.1	0.02	8.0	0.81	0	Satisfactory
153	2080/9/13	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	8.22	80.9	18	18	0.1	0.02	8.0	0.68	0	Satisfactory
154	2080/9/13	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.95	<5	7.03	93.7	16	18	0.1	0.02	8.0	0.84	0	Satisfactory
155	2080/9/13	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	6.65	87.8	12	18	0.1	0.02	8.0	1.03	0	Satisfactory
156	2080/9/13	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.81	<5	7.19	53.3	12	16	0.1	0.02	6.0	0.63	0	Satisfactory
157	2080/9/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.71	<5	7.25	53.6	14	16	0.1	0.02	6.0	0.45	0	Satisfactory
158	2080/9/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.33	<5	7.21	51.1	12	16	0.1	0.02	6.0	0.53	0	Satisfactory
160	2080/9/14	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.17	49	16	16	0.1	0.02	6.0	0.52	0	Satisfactory

161	2080/9/14	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	52	16	16	0.1	0.02	6.0	0.65	0	Satisfactory
162	2080/9/14	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	4.25	<5	7.43	87.9	16	18	0.1	0.02	8.0	0.06	0	Satisfactory
163	2080/9/14	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	6.82	81.6	12	18	0.1	0.02	8.0	0.96	0	Satisfactory
164	2080/9/14	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.01	<5	7.33	92.5	16	18	0.1	0.02	8.0	0.69	0	Satisfactory
165	2080/9/14	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.29	92.5	16	18	0.1	0.02	8.0	0.63	0	Satisfactory
166	2080/9/15	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	7.24	54	16	16	0.1	0.02	6.0	0.51	0	Satisfactory
167	2080/9/15	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	48	16	16	0.1	0.02	6.0	0.53	0	Satisfactory
168	2080/9/15	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.79	111.3	16	18	0.1	0.02	10.0	0.82	0	Satisfactory
169	2080/9/15	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	8.19	114.4	18	18	0.1	0.02	10.0	0.62	0	Satisfactory
170	2080/9/15	11:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	8	113.6	18	18	0.1	0.02	10.0	0.32	0	Satisfactory
171	2080/9/15	17:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.9	114.7	16	18	0.1	0.02	10.0	0.31	0	Satisfactory
172	2080/9/16	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.21	47	16	16	0.1	0.02	6.0	0.64	0	Satisfactory
173	2080/9/16	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.24	56	16	16	0.1	0.02	6.0	0.57	0	Satisfactory
174	2080/9/16	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.38	<5	7.14	261	88	16	0.3	1.5	12.0	0.20	0	Satisfactory
175	2080/9/16	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.42	<5	7.1	260	88	68	0.3	1.5	16.0	0.37	0	Satisfactory
176	2080/9/16	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.91	<5	7.07	263	88	60	0.3	1.5	12.0	0.10	0	Satisfactory
177	2080/9/16	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.74	124.9	14	18	0.1	0.02	12.0	0.49	0	Satisfactory
178	2080/9/16	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	8.4	126.2	18	18	0.1	0.02	12.0	0.56	0	Satisfactory
179	2080/9/16	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.10	<5	8.2	126.2	18	18	0.1	0.02	12.0	0.10	0	Satisfactory
180	2080/9/16	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.79	<5	8.15	126.0	18	18	0.1	0.02	12.0	0.10	0	Satisfactory
181	2080/9/16	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	8.17	126.5	18	18	0.1	0.02	12.0	0.10	0	Satisfactory
182	2080/9/16	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	8.17	123.1	18	18	0.1	0.02	12.0	0.10	0	Satisfactory
183	2080/9/16	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.40	<5	7.59	123.0	14	18	0.1	0.02	12.0	0.10	0	Satisfactory
184	2080/9/16	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.13	<5	7.29	66.1	14	16	0.1	0.02	6.0	0.52	0	Satisfactory
185	2080/9/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	6.98	63.2	10	16	0.1	0.02	6.0	0.22	0	Satisfactory
186	2080/9/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	7.28	73.6	14	16	0.1	0.02	6.0	0.90	0	Satisfactory
187	2080/9/16	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.18	<5	7.19	76.7	18	16	0.1	0.02	6.0	0.87	0	Satisfactory
188	2080/9/16	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.26	<5	8.11	382	52	154	0.1	0.02	10.0	0.79	0	Satisfactory
189	2080/9/17	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.23	55	16	16	0.1	0.02	6.0	0.62	0	Satisfactory
190	2080/9/17	14:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.30	48	16	14	0.1	0.02	6.0	0.54	0	Satisfactory
191	2080/9/17	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.34	<5	6.96	257	84	58	0.3	1.5	12.0	0.10	0	Satisfactory
192	2080/9/17	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.17	<5	6.95	256	84	68	0.3	1.5	10.0	0.10	0	Satisfactory
193	2080/9/17	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.62	<5	6.95	261	84	60	0.3	1.5	12.0	0.10	0	Satisfactory
194	2080/9/17	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.04	<5	7.88	130.8	16	18	0.1	0.02	14.0	0.60	0	Satisfactory
195	2080/9/17	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	8.01	130.5	16	18	0.1	0.02	14.0	0.50	0	Satisfactory
196	2080/9/17	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	8.15	127.5	16	18	0.1	0.02	14.0	0.10	0	Satisfactory
197	2080/9/17	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.22	<5	8.3	138.0	18	18	0.1	0.02	16.0	0.10	0	Satisfactory
198	2080/9/17	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	8.16	128.6	16	18	0.1	0.02	14.0	0.10	0	Satisfactory
199	2080/9/17	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.29	<5	7.92	129.6	16	18	0.1	0.02	14.0	0.15	0	Satisfactory
200	2080/9/17	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.32	<5	7.34	130.2	16	18	0.1	0.02	14.0	0.27	0	Satisfactory
201	2080/9/17	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	7.2	68.2	24	14	0.1	0.02	6.0	0.71	0	Satisfactory
202	2080/9/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.00	<5	7.4	73.5	24	14	0.1	0.02	6.0	0.84	0	Satisfactory
203	2080/9/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.43	79.4	18	14	0.1	0.02	6.0	0.75	0	Satisfactory
204	2080/9/17	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.42	83.4	18	14	0.1	0.02	6.0	0.77	0	Satisfactory



205	2080/9/17	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.17	<5	7.97	361	50	144	0.1	0.02	10.0	0.98	0	Satisfactory
206	2080/9/18	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.31	62	24	16	0.1	0.02	6.0	0.38	0	Satisfactory
207	2080/9/18	14:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.26	66	24	16	0.1	0.02	6.0	0.40	0	Satisfactory
208	2080/9/18	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.80	<5	6.96	255	84	16	0.3	1.5	12.0	0.10	0	Satisfactory
209	2080/9/18	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.55	<5	6.94	252	84	68	0.3	1.5	12.0	0.10	0	Satisfactory
210	2080/9/18	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.50	<5	6.92	251	84	60	0.3	1.5	12.0	0.12	0	Satisfactory
211	2080/9/18	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	7.66	130.1	16	18	0.1	0.02	14.0	0.43	0	Satisfactory
212	2080/9/18	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	8.2	130.9	18	18	0.1	0.02	14.0	0.65	0	Satisfactory
213	2080/9/18	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.38	<5	8.21	132.4	18	18	0.1	0.02	14.0	0.46	0	Satisfactory
214	2080/9/18	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.72	<5	8.2	131.3	18	18	0.1	0.02	14.0	0.43	0	Satisfactory
215	2080/9/18	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.83	<5	8.4	146.3	18	18	0.1	0.02	18.0	0.64	0	Satisfactory
216	2080/9/18	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.29	<5	7.31	80.1	24	10	0.1	0.02	6.0	0.78	0	Satisfactory
217	2080/9/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	7.36	83	30	10	0.1	0.02	6.0	0.75	0	Satisfactory
218	2080/9/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.39	87.1	28	10	0.1	0.02	6.0	0.73	0	Satisfactory
219	2080/9/18	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.29	<5	7.38	84.5	32	10	0.1	0.02	6.0	0.70	0	Satisfactory
220	2080/9/19	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.06	76	28	12	0.1	0.02	6.0	0.36	0	Satisfactory
221	2080/9/19	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.08	84	32	12	0.2	0.02	6.0	0.45	0	Satisfactory
222	2080/9/19	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.67	<5	7.05	265	88	16	0.3	1.5	12.0	0.40	0	Satisfactory
223	2080/9/19	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.27	<5	7.1	270	90	74	0.3	1.5	12.0	0.46	0	Satisfactory
224	2080/9/19	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.23	<5	7.24	61.9	18	16	0.1	0.02	6.0	0.67	0	Satisfactory
225	2080/9/19	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.63	61.5	16	16	0.1	0.02	6.0	0.76	0	Satisfactory
226	2080/9/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.74	<5	7.52	63.7	22	16	0.1	0.02	6.0	0.46	0	Satisfactory
227	2080/9/19	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	7.5	68.5	24	16	0.1	0.02	6.0	0.64	0	Satisfactory
228	2080/9/19	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.31	<5	7.93	385	56	134	0.1	0.02	10.0	0.89	0	Satisfactory
229	2080/9/20	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.10	97	46	18	0.2	0.02	6.0	0.41	0	Satisfactory
230	2080/9/20	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.13	64	24	16	0.1	0.02	6.0	0.53	0	Satisfactory
231	2080/9/20	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.00	<5	6.98	262	88	16	0.3	1.5	12.0	0.10	0	Satisfactory
232	2080/9/20	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.07	<5	7.02	266	90	66	0.3	1.5	10.0	0.16	0	Satisfactory
233	2080/9/20	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.43	<5	7.35	69.9	26	16	0.1	0.02	6.0	0.44	0	Satisfactory
234	2080/9/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.53	<5	7.3	66	14	16	0.1	0.02	6.0	0.43	0	Satisfactory
235	2080/9/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.36	<5	7.39	76.4	26	16	0.1	0.02	6.0	0.67	0	Satisfactory
236	2080/9/20	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.26	<5	7.89	390	58	146	0.1	0.02	10.0	0.92	0	Satisfactory
237	2080/9/21	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.14	60	20	12	0.1	0.02	6.0	0.54	0	Satisfactory
238	2080/9/21	13:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.13	53	18	12	0.1	0.02	6.0	0.46	0	Satisfactory
239	2080/9/22	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	7.10	52	16	16	0.1	0.02	6.0	0.53	0	Satisfactory
240	2080/9/22	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.13	58	22	16	0.1	0.02	6.0	0.47	0	Satisfactory
241	2080/9/22	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.71	<5	7.1	274	90	16	0.3	1.5	16.0	0.52	0	Satisfactory
242	2080/9/22	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.75	<5	7.06	269	90	66	0.3	1.5	16.0	0.28	0	Satisfactory
243	2080/9/22	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	7.34	57.6	22	16	0.1	0.02	8.0	0.59	0	Satisfactory
244	2080/9/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.54	<5	7.1	59.6	16	16	0.1	0.02	6.0	0.89	0	Satisfactory
245	2080/9/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.91	<5	7.3	72.9	24	16	0.1	0.02	6.0	1.31	0	Satisfactory
246	2080/9/22	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.70	<5	7.43	73.1	26	16	0.1	0.02	6.0	0.87	0	Satisfactory
247	2080/9/22	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.31	<5	8.08	337	48	142	0.1	0.02	10.0	0.81	0	Satisfactory
248	2080/9/23	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.07	55	18	16	0.1	0.02	6.0	0.50	0	Satisfactory

249	2080/9/23	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.08	56	18	16	0.1	0.02	6.0	0.52	0	Satisfactory
250	2080/9/23	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.32	<5	6.98	265	88	16	0.3	1.5	16.0	0.51	0	Satisfactory
251	2080/9/23	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.57	<5	7.02	269	90	60	0.3	1.5	16.0	0.63	0	Satisfactory
252	2080/9/23	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.14	<5	7.26	54.4	14	16	0.1	0.02	4.0	0.47	0	Satisfactory
253	2080/9/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.41	58.2	14	16	0.1	0.02	8.0	0.51	0	Satisfactory
254	2080/9/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.81	<5	7.49	68.4	18	16	0.1	0.02	8.0	0.86	0	Satisfactory
255	2080/9/23	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.05	<5	7.64	71.7	26	16	0.1	0.02	8.0	1.03	0	Satisfactory
256	2080/9/23	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.19	<5	8.12	405	60	144	0.1	0.02	12.0	0.95	0	Satisfactory
257	2080/9/24	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.13	53	16	16	0.1	0.02	6.0	0.27	0	Satisfactory
258	2080/9/24	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.13	58	20	16	0.1	0.02	6.0	0.34	0	Satisfactory
259	2080/9/24	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	6.99	270	90	16	0.3	1.5	14.0	0.48	0	Satisfactory
260	2080/9/24	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.20	<5	6.97	266	90	60	0.3	1.5	14.0	0.12	0	Satisfactory
261	2080/9/24	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.51	66	20	16	0.1	0.02	8.0	0.28	0	Satisfactory
262	2080/9/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.70	<5	7.44	69.6	24	16	0.1	0.02	8.0	0.24	0	Satisfactory
263	2080/9/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.30	<5	7.48	73.6	28	16	0.1	0.02	8.0	0.57	0	Satisfactory
264	2080/9/24	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	7.43	76.8	26	16	0.1	0.02	8.0	0.81	0	Satisfactory
265	2080/9/24	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.23	<5	8.17	395	58	138	0.1	0.02	10.0	0.99	0	Satisfactory
266	2080/9/25	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.06	54	16	16	0.1	0.02	6.0	0.31	0	Satisfactory
267	2080/9/25	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.06	53	16	16	0.1	0.02	6.0	0.28	0	Satisfactory
268	2080/9/25	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.79	<5	7.09	273	90	16	0.3	1.5	16.0	0.55	0	Satisfactory
269	2080/9/25	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.58	<5	7.1	269	90	60	0.3	1.5	14.0	0.23	0	Satisfactory
270	2080/9/25	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.08	<5	7.34	58.3	18	16	0.1	0.02	8.0	0.26	0	Satisfactory
271	2080/9/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.84	<5	7.15	62.4	26	16	0.1	0.02	8.0	0.28	0	Satisfactory
272	2080/9/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.66	<5	7.58	81.9	32	16	0.1	0.02	8.0	0.75	0	Satisfactory
273	2080/9/25	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.35	83.2	38	16	0.1	0.02	6.0	0.37	0	Satisfactory
274	2080/9/25	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.57	<5	7.99	409	60	140	0.1	0.02	10.0	0.81	0	Satisfactory
275	2080/9/26	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	7.10	55	16	16	0.1	0.02	6.0	0.35	0	Satisfactory
276	2080/9/26	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.14	54	16	16	0.1	0.02	6.0	0.32	0	Satisfactory
277	2080/9/26	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.17	<5	7.06	268	88	16	0.3	1.5	16.0	0.56	0	Satisfactory
278	2080/9/26	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.56	<5	6.95	249	80	60	0.3	1.5	12.0	0.10	0	Satisfactory
279	2080/9/26	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.53	<5	7.25	58	24	16	0.1	0.02	8.0	0.58	0	Satisfactory
280	2080/9/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.78	<5	6.52	60.7	26	16	0.1	0.02	6.0	0.74	0	Satisfactory
281	2080/9/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.46	<5	7.42	66.5	24	16	0.1	0.02	6.0	0.82	0	Satisfactory
282	2080/9/26	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.53	<5	7.56	70.5	28	16	0.1	0.02	6.0	0.47	0	Satisfactory
283	2080/9/26	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.26	<5	8.12	388	58	136	0.1	0.02	10.0	0.93	0	Satisfactory
284	2080/9/27	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.23	53	16	16	0.1	0.02	6.0	0.51	0	Satisfactory
285	2080/9/27	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	51	16	16	0.1	0.02	6.0	0.54	0	Satisfactory
286	2080/9/28	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.51	52	16	16	0.1	0.02	6.0	0.43	0	Satisfactory
287	2080/9/28	13:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.48	48	16	16	0.1	0.02	6.0	0.45	0	Satisfactory
288	2080/9/29	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.37	<5	7.31	53	16	16	0.1	0.02	6.0	0.53	0	Satisfactory
289	2080/9/29	13:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.26	54	16	16	0.1	0.02	6.0	0.47	0	Satisfactory
290	2080/9/29	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.79	<5	7.05	265	84	60	0.3	1.5	14.0	0.28	0	Satisfactory
291	2080/9/29		Madhyapur Thimi	Bode WTP	Treated	Clear	2.57	<5	7.07	258	82	60	0.3	1.5	14.0	0.12	0	Satisfactory
292	2080/9/29	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.87	<5	7.88	120.0	16	18	0.1	0.02	12.0	0.52	0	Satisfactory

293	2080/9/29	8:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.61	<5	7.89	135.3	16	18	0.1	0.02	16.0	0.99	0	Satisfactory
294	2080/9/29	10:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	8.2	111.5	18	18	0.1	0.02	10.0	0.38	0	Satisfactory
295	2080/9/29	12:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.97	<5	8.22	130.2	18	18	0.1	0.02	14.0	0.36	0	Satisfactory
296	2080/9/29	14:00	New Sundarijal	Sundarijal WTP	Treated	Clear	1.10	<5	8.24	129.7	18	18	0.1	0.02	16.0	0.32	0	Satisfactory
297	2080/9/29	16:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.74	<5	8.34	148.1	18	18	0.1	0.02	18.0	0.78	0	Satisfactory
298	2080/9/29	18:00	New Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	7.77	130.2	14	18	0.1	0.02	16.0	0.59	0	Satisfactory
299	2080/9/29	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.73	<5	7.17	77.9	30	22	0.1	0.02	8.0	0.37	0	Satisfactory
300	2080/9/29	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.07	<5	7.27	79.8	28	22	0.1	0.02	6.0	0.59	0	Satisfactory
301	2080/9/29	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.48	<5	7.59	83.1	34	22	0.1	0.02	6.0	0.52	0	Satisfactory
302	2080/9/29	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.61	<5	7.83	93.1	38	26	0.1	0.02	8.0	1.31	0	Satisfactory
303	2080/9/29	11:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.26	<5	8.2	391	58	140	0.1	0.02	10.0	0.77	0	Satisfactory