



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Falgun 2080

S.No.	Date	Time	Branch	Location	Sample taken	Appearance	Turbidity	Colour	pH	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks	
						(NTU)	(TCU)			µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml		
Units →																			
National Drinking Water Quality Standard (NDWQS) →							5	5.00	6.5-8.5	1500		500.0	0.3(3)	1.5	250	0.1-0.5	0 in 95% Samples		
1	2080/11/01	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.69	<5	7.90	72.4	26	22	0.1	0.02	6	0.55	0	Satisfactory	
2	2080/11/01	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	7.70	71.4	24	22	0.1	0.02	6	0.82	0	Satisfactory	
3	2080/11/01	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.80	72.6	24	22	0.1	0.02	6	0.88	0	Satisfactory	
4	2080/11/01	11:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.8	<5	7.05	74.0	24	32	0.1	0.02	6	0.51	0	Satisfactory	
5	2080/11/01	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.95	55.0	18	16	0.1	0.02	6	0.31	0	Satisfactory	
6	2080/11/01	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.25	<5	8.24	366.0	48	134	0.1	0.02	8	0.74	0	Satisfactory	
7	2080/11/01	10:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.95	<5	7.42	79.2	24	22	0.1	0.02	6	0.67	0	Satisfactory	
8	2080/11/01	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.88	<5	7.91	50.1	20	12	0.1	0.02	4	0.75	0	Satisfactory	
9	2080/11/01	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.64	76.8	26	22	0.1	0.02	6	0.22	0	Satisfactory	
10	2080/11/01	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.84	80.3	28	26	0.1	0.02	6	0.28	0	Satisfactory	
11	2080/11/01	11:25	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.14	<5	7.41	47.7	14	10	0.1	0.02	4	0.9	0	Satisfactory	
12	2080/11/01	15:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.52	<5	7.44	76.4	24	20	0.1	0.02	6	0.99	0	Satisfactory	
13	2080/11/01	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.63	<5	7.72	78.4	26	22	0.1	0.02	6	0.47	0	Satisfactory	
14	2080/11/02	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.48	<5	7.21	72.2	22	22	0.1	0.02	6	0.99	0	Satisfactory	
15	2080/11/02	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.68	69.5	24	22	0.1	0.02	6	0.97	0	Satisfactory	
16	2080/11/02	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.47	<5	7.67	71.5	24	22	0.1	0.02	6	0.78	0	Satisfactory	
17	2080/11/02	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.86	70.0	24	22	0.1	0.02	6	0.7	0	Satisfactory	
18	2080/11/02	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.5	<5	7.84	72.0	24	22	0.1	0.02	6	0.68	0	Satisfactory	
19	2080/11/02	10:30	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.12	<5	7.48	69.3	22	32	0.1	0.02	4	0.1	0	Satisfactory	
20	2080/11/02	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.16	<5	7.28	108.8	36	48	0.3	1.12	18	0.65	0	Satisfactory	
21	2080/11/02	10:55	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.8	<5	7.01	71.0	24	32	0.1	0.02	6	0.12	0	Satisfactory	
22	2080/11/02	13:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.6	<5	6.92	73.0	24	32	0.1	0.02	6	0.12	0	Satisfactory	
23	2080/11/02	14:50	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.6	<5	6.92	73.0	24	32	0.1	0.02	6	0.78	0	Satisfactory	
24	2080/11/02	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.92	63.0	20	22	0.1	0.02	6	0.32	0	Satisfactory	
25	2080/11/02	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.24	<5	7.98	374.0	56	132	0.1	0.02	8	0.9	0	Satisfactory	
26	2080/11/02	11:30	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.26	<5	7.74	77.1	28	24	0.1	0.02	4	0.16	0	Satisfactory	
27	2080/11/02	13:30	Chhetrapati	Balaju Reservoir	Treated	Clear	0.68	<5	7.56	85.5	26	24	0.1	0.02	6	0.46	0	Satisfactory	
28	2080/11/02	8:00	Bhaktapur	Katunje Reservoir	Treated	Clear	0.86	<5	7.58	78.9	26	22	0.1	0.02	4	0.33	0	Satisfactory	

29	2080/11/02	12:00	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.25	<5	7.44	77.7	24	22	0.1	0.02	4	0.18	0	Satisfactory
30	2080/11/02	12:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.53	<5	7.66	46.2	16	10	0.1	0.02	4	0.52	0	Satisfactory
31	2080/11/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.69	49.7	18	14	0.1	0.02	4	0.72	0	Satisfactory
32	2080/11/02	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.62	49.0	16	12	0.1	0.02	4	0.49	0	Satisfactory
33	2080/11/02	11:50	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.22	<5	7.74	78.4	28	24	0.1	0.02	4	0.13	0	Satisfactory
34	2080/11/02	12:15	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.25	<5	7.59	77.5	26	22	0.1	0.02	4	0.9	0	Satisfactory
35	2080/11/02	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.31	<5	7.66	74.4	28	20	0.1	0.02	4	0.29	0	Satisfactory
36	2080/11/02	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.01	<5	7.61	78.5	26	22	0.1	0.02	4	0.79	0	Satisfactory
37	2080/11/02	11:50	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.22	<5	7.74	78.4	28	24	0.1	0.02	4	0.13	0	Satisfactory
38	2080/11/03	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.55	<5	7.21	71.1	22	22	0.1	0.02	6	0.42	0	Satisfactory
39	2080/11/03	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	7.32	71.5	24	22	0.1	0.02	6	0.55	0	Satisfactory
40	2080/11/03	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	7.40	71.9	24	22	0.1	0.02	6	0.9	0	Satisfactory
41	2080/11/03	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.81	<5	7.48	70.4	24	22	0.1	0.02	6	0.68	0	Satisfactory
42	2080/11/03	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	7.62	71.7	24	22	0.1	0.02	6	0.98	0	Satisfactory
43	2080/11/03	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.60	70.1	24	22	0.1	0.02	6	0.43	0	Satisfactory
44	2080/11/03	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.50	71.0	24	22	0.1	0.02	6	0.44	0	Satisfactory
45	2080/11/03	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.17	<5	7.16	295.0	88	76	0.76	1.5	18	0.91	0	Satisfactory
46	2080/11/03	11:00	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.11	<5	7.50	71.5	22	32	0.1	0.02	4	0.1	0	Satisfactory
47	2080/11/03	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.75	<5	7.30	163.0	42	52	0.3	1.5	12	0.86	0	Satisfactory
48	2080/11/03	11:00	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	7.02	72.0	24	32	0.1	0.02	6	0.12	0	Satisfactory
49	2080/11/03	14:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	1.1	<5	6.94	73.0	24	32	0.1	0.02	6	0.27	0	Satisfactory
50	2080/11/03	15:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.9	<5	6.96	74.0	24	32	0.1	0.02	6	0.99	0	Satisfactory
51	2080/11/03	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.93	59.0	20	22	0.1	0.02	4	0.43	0	Satisfactory
52	2080/11/03	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.89	<5	7.86	404.0	60	136	0.1	0.02	10	0.85	0	Satisfactory
53	2080/11/03	11:55	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.24	<5	7.46	79.7	26	22	0.1	0.02	4	0.46	0	Satisfactory
54	2080/11/03	10:30	Bhaktapur	Katunje Reservoir	Treated	Clear	1.12	<5	7.84	82.0	28	26	0.1	0.02	4	0.42	0	Satisfactory
55	2080/11/03	12:50	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.33	<5	7.61	80.6	26	24	0.1	0.02	4	0.2	0	Satisfactory
56	2080/11/03	10:30	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.38	<5	7.75	86.8	28	26	0.1	0.02	6	0.18	0	Satisfactory
57	2080/11/03	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.79	46.0	16	12	0.1	0.02	4	0.22	0	Satisfactory
58	2080/11/03	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.92	<5	7.65	45.9	18	12	0.1	0.02	4	0.39	0	Satisfactory
59	2080/11/03	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.43	<5	7.50	49.4	16	10	0.1	0.02	4	0.32	0	Satisfactory
60	2080/11/03	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.08	<5	7.70	48.2	18	10	0.1	0.02	4	0.31	0	Satisfactory
61	2080/11/03	12:10	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.38	<5	7.57	77.8	26	22	0.1	0.02	4	0.1	0	Satisfactory
62	2080/11/03	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.8	<5	7.74	79.1	28	24	0.1	0.02	4	0.34	0	Satisfactory
63	2080/11/03	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.2	<5	7.41	78.9	24	22	0.1	0.02	4	0.88	0	Satisfactory
64	2080/11/03	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.49	<5	7.66	79.3	28	24	0.1	0.02	4	0.26	0	Satisfactory
65	2080/11/03	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.65	<5	7.59	74.8	26	22	0.1	0.02	4	0.3	0	Satisfactory
66	2080/11/03	12:10	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.38	<5	7.57	77.8	26	22	0.1	0.02	4	0.1	0	Satisfactory
67	2080/11/04	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	7.52	72.3	24	22	0.1	0.02	6	0.42	0	Satisfactory
68	2080/11/04	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	7.61	72.0	24	22	0.1	0.02	6	0.56	0	Satisfactory
69	2080/11/04	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.38	<5	7.43	71.3	24	22	0.1	0.02	6	0.5	0	Satisfactory
70	2080/11/04	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.42	71.1	24	22	0.1	0.02	6	0.66	0	Satisfactory
71	2080/11/04	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.52	72.4	24	22	0.1	0.02	6	0.92	0	Satisfactory

72	2080/11/04	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.54	71.7	24	22	0.1	0.02	6	0.9	0	Satisfactory
73	2080/11/04	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.36	<5	7.18	290.0	88	72	0.76	1.5	18	0.43	0	Satisfactory
74	2080/11/04	10:15	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	1.22	<5	7.50	71.1	22	32	0.1	0.02	4	0.6	0	Satisfactory
75	2080/11/04	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.98	<5	7.15	181.0	44	56	0.3	1.3	18	0.56	0	Satisfactory
76	2080/11/04	11:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.7	<5	6.97	70.0	24	30	0.1	0.02	6	0.12	0	Satisfactory
77	2080/11/04	13:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.6	<5	6.92	71.0	24	32	0.1	0.02	6	0.12	0	Satisfactory
78	2080/11/04	14:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.5	<5	6.94	72.0	24	32	0.1	0.02	6	0.12	0	Satisfactory
79	2080/11/04	10:44	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.91	58.0	20	22	0.1	0.02	6	0.51	0	Satisfactory
80	2080/11/04	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.31	<5	8.06	397.0	56	138	0.1	0.02	10	0.81	0	Satisfactory
81	2080/11/04	11:05	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.71	<5	7.62	79.5	26	24	0.1	0.02	4	0.23	0	Satisfactory
82	2080/11/04	12:45	Chhetrapati	Balaju Reservoir	Treated	Clear	0.65	<5	7.44	104.8	24	28	0.1	0.02	6	0.68	0	Satisfactory
83	2080/11/04	10:30	Bhaktapur	Katunje Reservoir	Treated	Clear	1.36	<5	7.46	83.6	26	24	0.1	0.02	4	0.9	0	Satisfactory
84	2080/11/04	12:10	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.3	<5	7.41	80.2	24	26	0.1	0.02	4	0.15	0	Satisfactory
85	2080/11/04	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.29	<5	7.54	84.1	26	24	0.1	0.02	4	0.12	0	Satisfactory
86	2080/11/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.44	<5	7.87	48.8	18	14	0.1	0.02	4	0.57	0	Satisfactory
87	2080/11/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.95	49.5	20	10	0.1	0.02	4	0.51	0	Satisfactory
88	2080/11/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.50	51.0	16	14	0.1	0.02	4	0.56	0	Satisfactory
89	2080/11/04	13:20	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.39	<5	7.42	78.2	24	22	0.1	0.02	4	0.28	0	Satisfactory
90	2080/11/04	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.41	<5	7.57	81.1	26	24	0.1	0.02	4	0.49	0	Satisfactory
91	2080/11/04	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.76	<5	7.81	79.4	28	24	0.1	0.02	4	0.53	0	Satisfactory
92	2080/11/04	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.73	<5	7.42	76.8	24	20	0.1	0.02	4	0.23	0	Satisfactory
93	2080/11/04	13:20	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.39	<5	7.42	78.2	24	22	0.1	0.02	4	0.28	0	Satisfactory
94	2080/11/05	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.73	<5	7.60	70.1	24	22	0.1	0.02	6	0.56	0	Satisfactory
95	2080/11/05	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.70	71.0	24	22	0.1	0.02	6	0.56	0	Satisfactory
96	2080/11/05	13:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.60	70.1	24	22	0.1	0.02	6	0.66	0	Satisfactory
97	2080/11/05	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.70	71.0	24	22	0.1	0.02	6	0.56	0	Satisfactory
98	2080/11/05	14:40	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	6.98	73.0	24	32	0.1	0.02	6	0.73	0	Satisfactory
99	2080/11/05	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.91	56.0	18	20	0.1	0.02	6	0.42	0	Satisfactory
100	2080/11/05	12:40	Tripureshwar	Anamnagar Reservoir	Treated	Clear	1.37	<5	7.76	79.5	28	24	0.1	0.02	4	0.2	0	Satisfactory
101	2080/11/05	13:35	Chhetrapati	Balaju Reservoir	Treated	Clear	0.9	<5	7.78	103.2	28	26	0.1	0.02	6	0.37	0	Satisfactory
102	2080/11/05	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	2.17	<5	7.88	84.2	30	28	0.1	0.02	4	0.56	0	Satisfactory
103	2080/11/05	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.26	<5	7.97	78.7	30	24	0.1	0.02	4	0.12	0	Satisfactory
104	2080/11/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.18	<5	7.76	51.2	20	14	0.1	0.02	4	0.3	0	Satisfactory
105	2080/11/05	11:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.96	80.8	30	26	0.1	0.02	4	0.22	0	Satisfactory
106	2080/11/05	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.68	<5	7.90	80.6	30	26	0.1	0.02	4	0.11	0	Satisfactory
107	2080/11/05	11:30	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.35	<5	7.96	80.8	30	26	0.1	0.02	4	0.22	0	Satisfactory
108	2080/11/06	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	7.60	70.7	24	22	0.1	0.02	6	0.37	0	Satisfactory
109	2080/11/06	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.52	71.5	24	22	0.1	0.02	6	0.57	0	Satisfactory
110	2080/11/06	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	7.48	72.0	24	22	0.1	0.02	6	0.9	0	Satisfactory
111	2080/11/06	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.43	70.3	24	22	0.1	0.02	6	0.17	0	Satisfactory
112	2080/11/06	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.41	71.1	24	22	0.1	0.02	6	0.42	0	Satisfactory
113	2080/11/06	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.41	72.0	24	22	0.1	0.02	6	0.9	0	Satisfactory
114	2080/11/06	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.62	<5	7.41	71.4	24	22	0.1	0.02	6	0.89	0	Satisfactory
115	2080/11/06	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.31	<5	7.2	302.0	88	78	0.76	1.3	18	0.66	0	Satisfactory

116	2080/11/06	10:30	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.3	<5	7.6	72.0	22	32	0.1	0.02	4	0.1	0	Satisfactory
117	2080/11/06	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.81	<5	7.24	114.0	38	50	0.3	1.4	18	0.52	0	Satisfactory
118	2080/11/06	10:55	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	7.05	71.0	24	30	0.1	0.02	6	0.10	0	Satisfactory
119	2080/11/06	13:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	7.02	72.0	24	32	0.1	0.02	6	0.10	0	Satisfactory
120	2080/11/06	14:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.5	<5	6.92	73.0	24	32	0.1	0.02	6	0.71	0	Satisfactory
121	2080/11/06	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.94	54.0	18	18	0.1	0.02	6	0.34	0	Satisfactory
122	2080/11/06	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.44	<5	7.97	395.0	56	138	0.1	0.02	10	0.97	0	Satisfactory
123	2080/11/06	11:25	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.48	<5	7.64	86.0	26	24	0.1	0.02	4	0.33	0	Satisfactory
124	2080/11/06	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	1.33	<5	7.56	84.1	26	28	0.1	0.02	4	0.15	0	Satisfactory
125	2080/11/06	12:20	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.6	<5	7.58	87.5	26	24	0.1	0.02	4	0.18	0	Satisfactory
126	2080/11/06	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.65	<5	7.45	80.3	26	28	0.1	0.02	4	0.25	0	Satisfactory
127	2080/11/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.94	<5	7.74	51.8	24	22	0.1	0.02	4	0.68	0	Satisfactory
128	2080/11/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.04	<5	7.6	48.8	16	12	0.1	0.02	4	0.43	0	Satisfactory
129	2080/11/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.61	47.1	16	12	0.1	0.02	4	0.43	0	Satisfactory
130	2080/11/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.62	51.1	16	12	0.1	0.02	4	0.39	0	Satisfactory
131	2080/11/06	11:40	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.61	<5	7.41	81.5	24	22	0.1	0.02	4	0.1	0	Satisfactory
132	2080/11/06	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.62	<5	7.9	80.1	30	24	0.1	0.02	4	0.94	0	Satisfactory
133	2080/11/06	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.57	<5	7.41	89.8	24	26	0.1	0.02	4	0.97	0	Satisfactory
134	2080/11/06	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.87	<5	7.45	82.5	26	24	0.1	0.02	4	0.63	0	Satisfactory
135	2080/11/06	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.62	<5	7.69	84.2	28	24	0.1	0.02	4	0.26	0	Satisfactory
136	2080/11/06	11:40	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.61	<5	7.41	81.5	24	22	0.1	0.02	4	0.1	0	Satisfactory
137	2080/11/07	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.41	70.8	24	22	0.1	0.02	6	0.35	0	Satisfactory
138	2080/11/07	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.41	70.6	24	22	0.1	0.02	6	0.47	0	Satisfactory
139	2080/11/07	11:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.41	70.2	24	22	0.1	0.02	6	0.73	0	Satisfactory
140	2080/11/07	13:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.48	<5	7.32	70.6	24	22	0.1	0.02	6	0.89	0	Satisfactory
141	2080/11/07	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.61	70.6	24	22	0.1	0.02	6	0.55	0	Satisfactory
142	2080/11/07	15:00	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	6.88	74.0	24	32	0.1	0.02	6	0.77	0	Satisfactory
143	2080/11/07	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.91	59.0	20	22	0.1	0.02	6	0.43	0	Satisfactory
144	2080/11/07	13:55	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.18	<5	7.48	81.6	24	28	0.1	0.02	4	0.28	0	Satisfactory
145	2080/11/07	14:30	Chhetrapati	Balaju Reservoir	Treated	Clear	0.56	<5	7.47	101.0	26	30	0.1	0.02	4	0.12	0	Satisfactory
146	2080/11/07	7:45	Bhaktapur	Katunje Reservoir	Treated	Clear	0.62	<5	8.16	82.8	32	26	0.1	0.02	4	0.15	0	Satisfactory
147	2080/11/07	12:55	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.38	<5	7.39	83.8	24	28	0.1	0.02	4	0.12	0	Satisfactory
148	2080/11/07	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.58	<5	7.64	49.4	16	12	0.1	0.02	4	0.28	0	Satisfactory
149	2080/11/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.81	<5	7.84	44.2	18	14	0.1	0.02	4	0.45	0	Satisfactory
150	2080/11/07	13:40	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.22	<5	7.41	80.1	24	28	0.1	0.02	4	0.48	0	Satisfactory
151	2080/11/07	16:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.37	<5	7.38	78.9	24	28	0.1	0.02	4	0.8	0	Satisfactory
152	2080/11/07	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.58	<5	7.78	78.5	28	26	0.1	0.02	4	0.36	0	Satisfactory
153	2080/11/07	13:40	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.22	<5	7.41	80.1	24	28	0.1	0.02	4	0.48	0	Satisfactory
154	2080/11/08	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.49	<5	7.56	77.0	24	22	0.1	0.02	6	0.4	0	Satisfactory
155	2080/11/08	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.62	71.9	24	22	0.1	0.02	6	0.46	0	Satisfactory
156	2080/11/08	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	8.12	87.0	26	22	0.1	0.02	6	0.88	0	Satisfactory
157	2080/11/08	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	8.27	70.2	26	22	0.1	0.02	6	0.94	0	Satisfactory
158	2080/11/08	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.69	<5	8.19	72.2	26	22	0.1	0.02	6	0.9	0	Satisfactory
159	2080/11/08	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.78	74.8	24	22	0.1	0.02	6	0.6	0	Satisfactory

160	2080/11/08	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.77	71.1	24	22	0.1	0.02	6	0.75	0	Satisfactory
161	2080/11/08	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.54	<5	7.1	273.0	82	66	0.76	1.5	12	0.1	0	Satisfactory
162	2080/11/08	10:20	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.1	<5	7.58	72.1	22	32	0.1	0.02	4	0.1	0	Satisfactory
163	2080/11/08	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.77	<5	7.1	140.3	40	50	0.3	1.5	12	0.1	0	Satisfactory
164	2080/11/08	10:50	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.5	<5	6.92	71.0	24	32	0.1	0.02	6	0.10	0	Satisfactory
165	2080/11/08	13:15	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	6.86	73.0	24	32	0.1	0.02	6	0.10	0	Satisfactory
166	2080/11/08	15:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.2	<5	6.85	74.0	24	32	0.1	0.02	6	0.75	0	Satisfactory
167	2080/11/08	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.94	63.0	20	24	0.1	0.02	6	0.52	0	Satisfactory
168	2080/11/08	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.61	<5	7.89	370.0	50	136	0.1	0.02	8	0.79	0	Satisfactory
169	2080/11/08	11:10	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.31	<5	8.06	79.3	30	22	0.1	0.02	4	0.2	0	Satisfactory
170	2080/11/08	8:45	Bhaktapur	Katunje Reservoir	Treated	Clear	0.58	<5	8.09	84.7	32	26	0.1	0.02	4	0.25	0	Satisfactory
171	2080/11/08	12:20	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.55	<5	8.09	80.1	30	26	0.1	0.02	4	0.18	0	Satisfactory
172	2080/11/08	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.65	<5	8.25	84.7	32	28	0.1	0.02	4	0.12	0	Satisfactory
173	2080/11/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.52	<5	8.08	45.8	20	14	0.1	0.02	4	0.57	0	Satisfactory
174	2080/11/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.69	<5	8.19	47.5	18	12	0.1	0.02	4	0.54	0	Satisfactory
175	2080/11/08	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.98	64.7	24	14	0.1	0.02	4	0.9	0	Satisfactory
176	2080/11/08	11:25	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	8.2	78.1	32	24	0.1	0.02	4	0.19	0	Satisfactory
177	2080/11/08	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.35	<5	8.01	79.5	30	24	0.1	0.02	4	0.9	0	Satisfactory
178	2080/11/08	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.87	<5	8.19	82.3	32	26	0.1	0.02	4	0.9	0	Satisfactory
179	2080/11/08	15:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	2.68	<5	8.11	83.7	32	26	0.1	0.02	4	0.9	0	Satisfactory
180	2080/11/08	11:25	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.2	<5	8.2	78.1	32	24	0.1	0.02	4	0.19	0	Satisfactory
181	2080/11/09	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.68	73.2	24	22	0.1	0.02	6	0.9	0	Satisfactory
182	2080/11/09	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.58	70.6	24	22	0.1	0.02	6	0.58	0	Satisfactory
183	2080/11/09	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.29	<5	7.52	71.0	24	22	0.1	0.02	6	0.58	0	Satisfactory
184	2080/11/09	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.71	<5	7.38	70.9	24	22	0.1	0.02	6	0.48	0	Satisfactory
185	2080/11/09	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.4	<5	7.45	73.2	24	22	0.1	0.02	6	0.9	0	Satisfactory
186	2080/11/09	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.61	71.3	24	22	0.1	0.02	6	0.84	0	Satisfactory
187	2080/11/09	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.62	72.9	24	22	0.1	0.02	6	0.92	0	Satisfactory
188	2080/11/09	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.52	<5	7.2	292.0	88	72	0.76	1.5	18	0.64	0	Satisfactory
189	2080/11/09	10:30	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.22	<5	7.43	72.5	22	32	0.1	0.02	4	0.1	0	Satisfactory
190	2080/11/09	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.93	<5	7.26	210.0	56	54	0.3	1.4	14	0.54	0	Satisfactory
191	2080/11/09	10:55	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	7.04	73.0	24	32	0.1	0.02	6	0.13	0	Satisfactory
192	2080/11/09	13:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	6.93	74.0	26	32	0.1	0.02	6	0.13	0	Satisfactory
193	2080/11/09	16:00	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.2	<5	6.95	76.0	26	32	0.1	0.02	6	0.77	0	Satisfactory
194	2080/11/09	11:35	Maharajgunj	Panipokhari Reservoir	Treated	Clear	0.4	<5	6.97	75.0	24	32	0.1	0.02	6	0.38	0	Satisfactory
195	2080/11/09	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.94	62.0	22	24	0.1	0.02	6	0.42	0	Satisfactory
196	2080/11/09	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.51	<5	7.98	399.0	58	138	0.1	0.02	10	0.9	0	Satisfactory
197	2080/11/09	11:00	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.64	<5	7.72	77.6	28	24	0.1	0.02	4	0.27	0	Satisfactory
198	2080/11/09	13:15	Chhetrapati	Balaju Reservoir	Treated	Clear	1.24	<5	7.71	99.6	28	26	0.1	0.02	4	0.1	0	Satisfactory
199	2080/11/09	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.27	<5	7.79	80.6	30	26	0.1	0.02	4	0.72	0	Satisfactory
200	2080/11/09	12:10	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.68	<5	7.56	78.2	26	24	0.1	0.02	4	0.18	0	Satisfactory
201	2080/11/09	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.55	<5	7.82	78.2	28	24	0.1	0.02	4	0.12	0	Satisfactory
202	2080/11/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.94	49.1	18	12	0.1	0.02	4	0.72	0	Satisfactory
203	2080/11/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.85	<5	7.98	50.2	20	14	0.1	0.02	4	0.69	0	Satisfactory

204	2080/11/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.57	67.7	20	18	0.1	0.02	4	0.9	0	Satisfactory
205	2080/11/09	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.33	<5	7.9	65.3	22	14	0.1	0.02	4	0.95	0	Satisfactory
206	2080/11/09	11:10	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.75	76.5	28	24	0.1	0.02	4	0.1	0	Satisfactory
207	2080/11/09	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.04	<5	7.72	80.5	28	24	0.1	0.02	4	0.46	0	Satisfactory
208	2080/11/09	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.75	<5	7.75	82.7	18	14	0.1	0.02	4	0.32	0	Satisfactory
209	2080/11/09	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.62	<5	7.61	77.4	26	22	0.1	0.02	4	0.11	0	Satisfactory
210	2080/11/09	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.46	<5	7.88	80.5	30	26	0.1	0.02	4	0.92	0	Satisfactory
211	2080/11/09	11:10	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.56	<5	7.75	76.5	28	24	0.1	0.02	4	0.1	0	Satisfactory
212	2080/11/10	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.27	<5	7.5	71.2	24	22	0.1	0.02	6	0.41	0	Satisfactory
213	2080/11/10	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.4	<5	7.52	71.4	24	22	0.1	0.02	6	0.51	0	Satisfactory
214	2080/11/10	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.33	<5	7.51	74.0	24	22	0.1	0.02	6	0.9	0	Satisfactory
215	2080/11/10	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.49	71.9	24	22	0.1	0.02	6	0.62	0	Satisfactory
216	2080/11/10	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.37	<5	7.7	71.2	24	22	0.1	0.02	6	0.36	0	Satisfactory
217	2080/11/10	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	7.89	74.2	24	22	0.1	0.02	6	0.9	0	Satisfactory
218	2080/11/10	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.38	<5	7.72	76.2	24	22	0.1	0.02	6	0.21	0	Satisfactory
219	2080/11/10	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.35	<5	7.01	302	88	72	0.76	1.4	14	0.19	0	Satisfactory
220	2080/11/10	9:45	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.67	<5	7.56	77.6	22	34	0.1	0.02	4	0.1	0	Satisfactory
221	2080/11/10	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.2	<5	7.3	110	38	50	0.3	1.4	16	0.38	0	Satisfactory
222	2080/11/10	11:55	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.6	<5	6.90	73	26	32	0.1	0.02	6	0.18	0	Satisfactory
223	2080/11/10	13:40	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.5	<5	6.91	74	26	32	0.1	0.02	6	0.18	0	Satisfactory
224	2080/11/10	15:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.7	<5	6.83	74	26	32	0.1	0.02	6	0.23	0	Satisfactory
225	2080/11/10	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.93	61	22	22	0.1	0.02	6	0.49	0	Satisfactory
226	2080/11/10	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.94	<5	7.95	409	60	140	0.1	0.02	10	0.88	0	Satisfactory
227	2080/11/10	10:50	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.61	<5	7.45	78.8	26	24	0.1	0.02	4	0.15	0	Satisfactory
228	2080/11/10	10:00	Bhaktapur	Katunje Reservoir	Treated	Clear	0.61	<5	7.97	84.1	30	26	0.1	0.02	4	0.9	0	Satisfactory
229	2080/11/10	11:40	Lalitpur	Khumaltar Reservoir	Treated	Clear	1.12	<5	7.79	83.1	28	26	0.1	0.02	4	0.18	0	Satisfactory
230	2080/11/10	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.68	<5	7.78	72.8	28	24	0.1	0.02	4	0.12	0	Satisfactory
231	2080/11/10	11:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.88	<5	7.97	46.3	20	14	0.1	0.02	4	0.52	0	Satisfactory
232	2080/11/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.64	<5	7.92	44.6	18	12	0.1	0.02	4	0.52	0	Satisfactory
233	2080/11/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.97	44.8	18	12	0.1	0.02	4	0.45	0	Satisfactory
234	2080/11/10	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.03	<5	8.03	47.5	20	14	0.1	0.02	4	0.53	0	Satisfactory
235	2080/11/10	11:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.5	78.6	26	24	0.1	0.02	4	0.43	0	Satisfactory
236	2080/11/10	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.65	<5	7.75	83.6	28	26	0.1	0.02	4	0.57	0	Satisfactory
237	2080/11/10	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.32	<5	7.89	81	30	28	0.1	0.02	4	0.9	0	Satisfactory
238	2080/11/10	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.85	<5	7.88	79.9	30	24	0.1	0.02	4	0.24	0	Satisfactory
239	2080/11/10	15:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.1	<5	7.84	78.5	28	24	0.1	0.02	4	0.54	0	Satisfactory
240	2080/11/10	11:05	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.65	<5	7.5	78.6	26	24	0.1	0.02	4	0.43	0	Satisfactory
241	2080/11/11	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.3	<5	8.41	73	24	22	0.1	0.02	6	0.38	0	Satisfactory
242	2080/11/11	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.3	<5	8.15	74.5	24	22	0.1	0.02	6	0.9	0	Satisfactory
243	2080/11/11	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.4	<5	8.3	73.9	24	22	0.1	0.02	6	0.9	0	Satisfactory
244	2080/11/11	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.97	<5	7.74	71.2	24	22	0.1	0.02	6	0.96	0	Satisfactory
245	2080/11/11	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.24	74.1	24	22	0.1	0.02	6	0.9	0	Satisfactory
246	2080/11/11	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.38	<5	7.26	72.6	24	22	0.1	0.02	6	0.49	0	Satisfactory
247	2080/11/11	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.7	<5	7.21	74.5	24	22	0.1	0.02	6	0.82	0	Satisfactory

248	2080/11/11	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.43	<5	7.15	305	90	72	0.76	1.5	16	0.37	0	Satisfactory
249	2080/11/11	10:00	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.34	<5	7.5	72.4	22	32	0.1	0.02	4	0.1	0	Satisfactory
250	2080/11/11	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.45	<5	7.3	117	40	52	0.3	1.4	16	0.24	0	Satisfactory
251	2080/11/11	10:40	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	7.05	75	26	32	0.1	0.02	6	0.54	0	Satisfactory
252	2080/11/11	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	6.91	63	24	24	0.1	0.02	6	0.44	0	Satisfactory
253	2080/11/11	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.97	<5	7.97	370	48	134	0.1	0.02	8	0.83	0	Satisfactory
254	2080/11/11	11:15	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.75	<5	8.08	82.9	30	28	0.1	0.02	4	0.23	0	Satisfactory
255	2080/11/11	11:15	Chhetrapati	Balaju Reservoir	Treated	Clear	1.66	<5	7.92	113.4	30	28	0.1	0.02	4	0.1	0	Satisfactory
256	2080/11/11	8:10	Bhaktapur	Katunje Reservoir	Treated	Clear	0.63	<5	7.82	84.4	28	24	0.1	0.02	4	0.68	0	Satisfactory
257	2080/11/11	11:15	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.97	<5	7.9	78	30	24	0.1	0.02	4	0.18	0	Satisfactory
258	2080/11/11	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.65	<5	7.79	78.3	28	24	0.1	0.02	4	0.12	0	Satisfactory
259	2080/11/11	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.75	<5	8.02	83.4	30	26	0.4	0.02	4	0.22	0	Satisfactory
260	2080/11/11	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.25	<5	8.01	48.2	20	12	0.1	0.02	4	0.76	0	Satisfactory
261	2080/11/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.02	<5	7.93	48.9	20	12	0.1	0.02	4	0.5	0	Satisfactory
262	2080/11/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.16	<5	7.87	49.1	18	12	0.1	0.02	4	0.54	0	Satisfactory
263	2080/11/11	11:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.67	<5	7.96	80.8	20	26	0.1	0.02	4	0.1	0	Satisfactory
264	2080/11/11	10:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.46	<5	7.94	44.2	20	12	0.1	0.02	4	0.92	0	Satisfactory
265	2080/11/11	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.6	<5	7.95	81.2	30	26	0.1	0.02	4	0.9	0	Satisfactory
266	2080/11/11	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.8	<5	7.8	78.5	28	24	0.1	0.02	4	0.11	0	Satisfactory
267	2080/11/11	11:15	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.67	<5	7.96	80.8	20	26	0.1	0.02	4	0.1	0	Satisfactory
268	2080/11/12	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.4	<5	7.18	72.8	24	22	0.1	0.02	6	0.42	0	Satisfactory
269	2080/11/12	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.28	<5	7.07	74.7	24	22	0.1	0.02	6	0.9	0	Satisfactory
270	2080/11/12	11:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.5	73.2	24	22	0.1	0.02	6	0.62	0	Satisfactory
271	2080/11/12	13:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.32	<5	7.24	75	24	22	0.1	0.02	6	0.9	0	Satisfactory
272	2080/11/12	15:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.5	<5	7.03	74.2	24	22	0.1	0.02	6	0.9	0	Satisfactory
273	2080/11/12	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.13	72.9	24	22	0.1	0.02	6	0.51	0	Satisfactory
274	2080/11/12	15:25	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	6.92	77	26	32	0.1	0.02	6	0.92	0	Satisfactory
275	2080/11/12	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.95	43	22	22	0.1	0.02	6	0.37	0	Satisfactory
276	2080/11/12	12:55	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.58	<5	8.07	83.8	30	26	0.1	0.02	4	0.66	0	Satisfactory
277	2080/11/12	13:25	Chhetrapati	Balaju Reservoir	Treated	Clear	2.51	<5	8.09	99.5	30	28	0.1	0.02	4	0.35	0	Satisfactory
278	2080/11/12	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.88	<5	7.9	83.1	30	26	0.1	0.02	4	0.21	0	Satisfactory
279	2080/11/12	11:55	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.35	<5	8.05	83.8	30	26	0.1	0.02	4	0.29	0	Satisfactory
280	2080/11/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.92	49.8	22	12	0.1	0.02	4	0.32	0	Satisfactory
281	2080/11/12	12:35	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	8.1	83.8	30	26	0.1	0.02	4	0.25	0	Satisfactory
282	2080/11/12	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.85	<5	7.96	83.5	30	28	0.1	0.02	4	0.65	0	Satisfactory
283	2080/11/12	12:35	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.72	<5	8.1	83.8	30	26	0.1	0.02	4	0.25	0	Satisfactory
284	2080/11/13	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.4	<5	7.56	75.2	24	22	0.1	0.02	6	0.43	0	Satisfactory
285	2080/11/13	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.44	75.4	24	22	0.1	0.02	6	0.9	0	Satisfactory
286	2080/11/13	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.27	<5	7.3	73.5	24	22	0.1	0.02	6	0.55	0	Satisfactory
287	2080/11/13	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.53	73.1	24	22	0.1	0.02	6	0.28	0	Satisfactory
288	2080/11/13	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.23	<5	7.59	76.34	24	22	0.1	0.02	6	0.18	0	Satisfactory
289	2080/11/13	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.52	<5	7.72	76.2	24	22	0.1	0.02	6	0.64	0	Satisfactory
290	2080/11/13	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.85	75.5	24	22	0.1	0.02	6	0.32	0	Satisfactory
291	2080/11/13	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.84	<5	7.1	297	88	72	0.76	1.5	14	0.32	0	Satisfactory

292	2080/11/13	10:30	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.15	<5	7.5	74.8	22	34	0.1	0.02	4	0.1	0	Satisfactory
293	2080/11/13	11:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	6.88	74	24	32	0.1	0.02	6	0.12	0	Satisfactory
294	2080/11/13	13:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	6.87	75	26	32	0.1	0.02	6	0.12	0	Satisfactory
295	2080/11/13	15:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	6.91	79	26	32	0.1	0.02	6	0.86	0	Satisfactory
296	2080/11/13	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.87	60	22	22	0.1	0.02	6	0.52	0	Satisfactory
297	2080/11/13	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.76	<5	7.81	386	56	136	0.1	0.02	10	0.97	0	Satisfactory
298	2080/11/13	11:15	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.67	<5	7.83	81.3	28	28	0.1	0.02	4	0.41	0	Satisfactory
299	2080/11/13	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.63	<5	7.87	82.5	28	26	0.1	0.02	4	0.15	0	Satisfactory
300	2080/11/13	12:10	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.42	<5	7.85	82.8	30	28	0.1	0.02	4	0.24	0	Satisfactory
301	2080/11/13	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.68	<5	7.8	82.4	30	26	0.1	0.02	4	0.2	0	Satisfactory
302	2080/11/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.86	<5	7.77	45.7	18	12	0.1	0.02	4	0.79	0	Satisfactory
303	2080/11/13	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.44	<5	8.06	48.1	20	12	0.1	0.02	4	0.57	0	Satisfactory
304	2080/11/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.68	45.4	18	14	0.1	0.02	4	0.55	0	Satisfactory
305	2080/11/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.19	<5	7.81	47.4	18	14	0.1	0.02	4	0.45	0	Satisfactory
306	2080/11/13	11:40	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.44	<5	7.87	80.8	30	28	0.1	0.02	4	0.45	0	Satisfactory
307	2080/11/13	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.75	<5	7.7	84.4	28	26	0.1	0.02	4	0.9	0	Satisfactory
308	2080/11/13	12:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.5	<5	7.91	79.1	30	24	0.1	0.02	4	0.34	0	Satisfactory
309	2080/11/13	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.59	<5	7.82	80.8	28	26	0.1	0.02	4	0.37	0	Satisfactory
310	2080/11/13	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.39	<5	7.75	82.2	28	26	0.1	0.02	4	0.83	0	Satisfactory
311	2080/11/13	11:40	Baneshwor	Min Bhawan Reservoir	Treated	Clear	1.44	<5	7.87	80.8	30	28	0.1	0.02	4	0.45	0	Satisfactory
312	2080/11/14	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.9	74.91	24	22	0.1	0.02	6	0.42	0	Satisfactory
313	2080/11/14	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.79	<5	8.01	75.7	24	22	0.1	0.02	6	0.9	0	Satisfactory
314	2080/11/14	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.64	73.3	24	22	0.1	0.02	6	0.9	0	Satisfactory
315	2080/11/14	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.5	<5	7.65	73.5	24	22	0.1	0.02	6	0.71	0	Satisfactory
316	2080/11/14	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.74	<5	7.81	72.81	24	22	0.1	0.02	6	0.68	0	Satisfactory
317	2080/11/14	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.51	74.17	24	22	0.1	0.02	6	0.81	0	Satisfactory
318	2080/11/14	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.5	<5	7.52	74.21	24	22	0.1	0.02	6	0.32	0	Satisfactory
319	2080/11/14	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.38	<5	7.1	306	90	72	0.76	1.5	16	0.62	0	Satisfactory
320	2080/11/14	12:30	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.16	<5	7.6	79.6	24	34	0.1	0.02	4	0.84	0	Satisfactory
321	2080/11/14	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.19	<5	7.28	113	40	52	0.3	1.4	16	0.36	0	Satisfactory
322	2080/11/14	11:15	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.4	<5	6.91	76	26	32	0.1	0.02	6	0.12	0	Satisfactory
323	2080/11/14	13:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.2	<5	6.84	76	26	32	0.1	0.02	6	0.12	0	Satisfactory
324	2080/11/14	14:45	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	6.90	78	26	32	0.1	0.02	6	0.99	0	Satisfactory
325	2080/11/14	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.93	65	22	24	0.1	0.02	6	0.54	0	Satisfactory
326	2080/11/14	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.47	<5	7.86	376	54	134	0.1	0.02	8	0.71	0	Satisfactory
327	2080/11/14	11:20	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.7	<5	7.8	81.9	28	26	0.1	0.02	4	0.21	0	Satisfactory
328	2080/11/14	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.27	<5	7.84	82.9	28	26	0.1	0.02	4	0.26	0	Satisfactory
329	2080/11/14	12:30	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.75	<5	7.76	82.3	28	26	0.1	0.02	4	0.18	0	Satisfactory
330	2080/11/14	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.52	<5	7.77	82.8	28	26	0.1	0.02	4	0.2	0	Satisfactory
331	2080/11/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.9	46.2	18	14	0.1	0.02	4	0.59	0	Satisfactory
332	2080/11/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.58	<5	7.76	46.4	18	12	0.1	0.02	4	0.58	0	Satisfactory
333	2080/11/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.82	<5	7.52	46.7	16	14	0.1	0.02	4	0.9	0	Satisfactory
334	2080/11/14	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.64	46	16	14	0.1	0.02	4	0.32	0	Satisfactory
335	2080/11/14	11:35	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	7.72	80.2	28	26	0.1	0.02	4	0.27	0	Satisfactory

336	2080/11/14	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.45	<5	7.75	81.3	28	26	0.1	0.02	4	0.48	0	Satisfactory
337	2080/11/14	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.89	<5	7.67	80.5	28	26	0.1	0.02	4	0.6	0	Satisfactory
338	2080/11/14	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.94	<5	8.05	90.7	30	28	0.1	0.02	4	0.56	0	Satisfactory
339	2080/11/14	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.76	<5	7.77	75.8	28	26	0.1	0.02	4	0.46	0	Satisfactory
340	2080/11/14	11:35	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.63	<5	7.72	80.2	28	26	0.1	0.02	4	0.27	0	Satisfactory
341	2080/11/15	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.76	72.8	24	22	0.1	0.02	6	0.38	0	Satisfactory
342	2080/11/15	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.56	75.4	24	22	0.1	0.02	6	0.9	0	Satisfactory
343	2080/11/15	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	7.81	72.8	24	22	0.1	0.02	6	0.91	0	Satisfactory
344	2080/11/15	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.72	<5	7.88	73.4	24	22	0.1	0.02	6	0.71	0	Satisfactory
345	2080/11/15	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.19	<5	7.44	73.2	24	22	0.1	0.02	6	0.74	0	Satisfactory
346	2080/11/15	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.77	<5	7.25	72.7	24	22	0.1	0.02	6	0.76	0	Satisfactory
347	2080/11/15	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.91	<5	7.65	74.6	24	22	0.1	0.02	6	0.9	0	Satisfactory
348	2080/11/15	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.54	<5	7.24	316	92	76	0.76	1.5	16	0.74	0	Satisfactory
349	2080/11/15	16:00	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.33	<5	7.4	74	22	34	0.1	0.02	4	0.61	0	Satisfactory
350	2080/11/15	10:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.2	<5	6.95	75	26	32	0.1	0.02	6	0.45	0	Satisfactory
351	2080/11/15	14:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	7.06	75	26	32	0.1	0.02	6	0.22	0	Satisfactory
352	2080/11/15	15:05	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	7.03	76	26	32	0.1	0.02	6	0.98	0	Satisfactory
353	2080/11/15	11:45	Maharajgunj	Panipokhari Reservoir	Treated	Clear	0.2	<5	7.07	75	26	32	0.1	0.02	6	0.46	0	Satisfactory
354	2080/11/15	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.92	61	22	24	0.1	0.02	6	0.51	0	Satisfactory
355	2080/11/15	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.77	<5	7.88	401	60	138	0.1	0.02	10	0.86	0	Satisfactory
356	2080/11/15	13:10	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.38	<5	7.78	85.4	28	28	0.1	0.02	4	0.3	0	Satisfactory
357	2080/11/15	12:10	Chhetrapati	Balaju Reservoir	Treated	Clear	0.48	<5	7.67	87.8	28	26	0.1	0.02	4	0.1	0	Satisfactory
358	2080/11/15	8:15	Bhaktapur	Katunje Reservoir	Treated	Clear	2.49	<5	7.27	80.9	24	26	0.1	0.02	4	0.15	0	Satisfactory
359	2080/11/15	13:00	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.87	<5	7.54	87.2	26	28	0.1	0.02	4	0.18	0	Satisfactory
360	2080/11/15	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.62	<5	7.66	76.7	28	24	0.1	0.02	4	0.12	0	Satisfactory
361	2080/11/15	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.27	<5	7.69	48.8	16	12	0.1	0.02	4	0.38	0	Satisfactory
362	2080/11/15	12:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.12	<5	7.16	47.5	12	14	0.1	0.02	4	0.21	0	Satisfactory
363	2080/11/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.59	<5	7.66	46.6	18	14	0.1	0.02	4	0.35	0	Satisfactory
364	2080/11/15	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.35	<5	7.85	52.8	18	14	0.1	0.02	4	0.8	0	Satisfactory
365	2080/11/15	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.95	<5	8.14	45.2	20	14	0.1	0.02	4	0.63	0	Satisfactory
366	2080/11/15	11:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.45	<5	7.89	83.4	30	26	0.1	0.02	4	0.26	0	Satisfactory
367	2080/11/15	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.2	<5	7.65	74.1	28	24	0.1	0.02	4	0.51	0	Satisfactory
368	2080/11/15	12:15	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.3	<5	7.26	83.2	24	28	0.1	0.02	4	0.95	0	Satisfactory
369	2080/11/15	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.98	<5	7.73	83.4	18	26	0.1	0.02	4	0.83	0	Satisfactory
370	2080/11/15	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.55	<5	7.83	86.1	28	26	0.1	0.02	4	0.76	0	Satisfactory
371	2080/11/15	10:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.35	<5	7.98	76.2	30	24	0.1	0.02	4	0.11	0	Satisfactory
372	2080/11/15	11:00	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.45	<5	7.89	83.4	30	26	0.1	0.02	4	0.26	0	Satisfactory
373	2080/11/16	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.76	<5	7.37	71	24	22	0.1	0.02	6	0.31	0	Satisfactory
374	2080/11/16	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.71	<5	7.39	71.8	24	22	0.1	0.02	6	0.9	0	Satisfactory
375	2080/11/16	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.77	<5	7.39	70.8	24	22	0.1	0.02	6	0.9	0	Satisfactory
376	2080/11/16	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.89	<5	7.9	72	24	22	0.1	0.02	6	0.62	0	Satisfactory
377	2080/11/16	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	7.01	71.4	24	22	0.1	0.02	6	0.71	0	Satisfactory
378	2080/11/16	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.6	<5	7.02	71.4	24	22	0.1	0.02	6	0.2	0	Satisfactory
379	2080/11/16	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.85	<5	7.14	73	24	22	0.1	0.02	6	0.19	0	Satisfactory

380	2080/11/16	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.2	<5	7.1	293	88	72	0.76	1.5	14	0.24	0	Satisfactory
381	2080/11/16	16:15	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.37	<5	7.4	78.6	22	34	0.1	0.02	4	0.68	0	Satisfactory
382	2080/11/16	10:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.3	<5	7.02	74	24	32	0.1	0.02	6	0.37	0	Satisfactory
383	2080/11/16	13:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.7	<5	6.95	75	24	32	0.1	0.02	6	0.24	0	Satisfactory
384	2080/11/16	15:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	4.8	<5	6.90	73	24	32	0.1	0.02	6	0.60	0	Satisfactory
385	2080/11/16	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.95	64	24	26	0.1	0.02	6	0.35	0	Satisfactory
386	2080/11/16	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.41	<5	7.99	398	58	136	0.1	0.02	10	0.97	0	Satisfactory
387	2080/11/16	11:00	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.36	<5	7.55	78.4	26	26	0.1	0.02	4	0.33	0	Satisfactory
388	2080/11/16	10:20	Bhaktapur	Katunje Reservoir	Treated	Clear	0.68	<5	7.72	79.8	28	24	0.1	0.02	4	0.25	0	Satisfactory
389	2080/11/16	12:00	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.61	<5	7.48	81.2	26	28	0.1	0.02	4	0.18	0	Satisfactory
390	2080/11/16	9:30	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.75	<5	7.73	77.2	28	24	0.1	0.02	4	0.12	0	Satisfactory
391	2080/11/16	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.16	45.8	12	16	0.1	0.02	4	0.46	0	Satisfactory
392	2080/11/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.3	43.7	14	10	0.1	0.02	4	0.5	0	Satisfactory
393	2080/11/16	15:45	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.08	<5	7.49	48.6	16	14	0.1	0.02	4	0.37	0	Satisfactory
394	2080/11/16	11:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.85	<5	7.46	76.2	26	24	0.1	0.02	4	0.41	0	Satisfactory
395	2080/11/16	12:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.72	<5	7.42	77.6	24	22	0.1	0.02	4	0.96	0	Satisfactory
396	2080/11/16	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.08	<5	7.49	78.7	26	24	0.1	0.02	4	0.92	0	Satisfactory
397	2080/11/16	15:45	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	2.17	<5	7.47	79.9	26	24	0.1	0.02	4	0.67	0	Satisfactory
398	2080/11/16	11:15	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.85	<5	7.46	76.2	26	24	0.1	0.02	4	0.41	0	Satisfactory
399	2080/11/17	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.6	<5	7.74	72.5	24	22	0.1	0.02	6	0.1	0	Satisfactory
400	2080/11/17	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.73	73.4	24	22	0.1	0.02	6	0.1	0	Satisfactory
401	2080/11/17	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.72	<5	7.81	70.5	24	22	0.1	0.02	6	0.1	0	Satisfactory
402	2080/11/17	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.93	<5	7.3	70.7	24	22	0.1	0.02	6	0.1	0	Satisfactory
403	2080/11/17	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.14	<5	7.04	71.4	24	22	0.1	0.02	6	0.47	0	Satisfactory
404	2080/11/17	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.91	<5	7.49	72.5	24	22	0.1	0.02	6	0.68	0	Satisfactory
405	2080/11/17	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.91	<5	7.16	73	24	22	0.1	0.02	6	0.51	0	Satisfactory
406	2080/11/17	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.3	<5	7.2	314	90	76	0.76	1.5	14	0.71	0	Satisfactory
407	2080/11/17	7:00	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.23	<5	7.4	75	22	34	0.1	0.02	4	0.1	0	Satisfactory
408	2080/11/17	10:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	1.4	<5	6.94	72	24	32	0.1	0.02	6	0.67	0	Satisfactory
409	2080/11/17	13:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	1.2	<5	7.03	74	24	32	0.1	0.02	6	0.28	0	Satisfactory
410	2080/11/17	15:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	1.0	<5	7.04	71	24	32	0.1	0.02	6	0.28	0	Satisfactory
411	2080/11/17	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	6.93	63	24	26	0.1	0.02	6	0.10	0	Satisfactory
412	2080/11/17	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.21	<5	7.85	406	60	138	0.1	0.02	10	0.81	0	Satisfactory
413	2080/11/17	11:40	Tripureshwar	Anamnagar Reservoir	Treated	Clear	1.09	<5	7.75	81.7	28	26	0.1	0.02	4	0.28	0	Satisfactory
414	2080/11/17	11:00	Chhetrapati	Balaju Reservoir	Treated	Clear	1.34	<5	7.62	81.2	26	28	0.1	0.02	4	0.1	0	Satisfactory
415	2080/11/17	10:00	Bhaktapur	Katunje Reservoir	Treated	Clear	0.35	<5	7.63	80.6	26	28	0.1	0.02	4	0.15	0	Satisfactory
416	2080/11/17	10:00	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.72	<5	7.78	81.4	28	26	0.1	0.02	4	0.12	0	Satisfactory
417	2080/11/17	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.64	45.9	16	14	0.1	0.02	4	0.3	0	Satisfactory
418	2080/11/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.55	<5	7.63	45.8	16	12	0.1	0.02	4	0.52	0	Satisfactory
419	2080/11/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.37	<5	7.79	46.6	18	12	0.1	0.02	4	0.23	0	Satisfactory
420	2080/11/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.05	<5	7.76	50.5	16	14	0.1	0.02	4	0.66	0	Satisfactory
421	2080/11/17	11:55	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.49	78.8	26	24	0.1	0.02	4	0.1	0	Satisfactory
422	2080/11/17	10:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.17	<5	7.73	78.4	28	24	0.1	0.02	4	0.12	0	Satisfactory
423	2080/11/17	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.73	<5	7.65	77.7	16	24	0.1	0.02	4	0.11	0	Satisfactory

424	2080/11/17	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.28	<5	7.79	79.8	28	24	0.1	0.02	4	0.11	0	Satisfactory
425	2080/11/17	15:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	1.21	<5	7.75	77	28	24	0.1	0.02	4	0.32	0	Satisfactory
426	2080/11/17	11:55	Baneshwor	Min Bhawan Reservoir	Treated	Clear	1.1	<5	7.49	78.8	26	24	0.1	0.02	4	0.1	0	Satisfactory
427	2080/11/18	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.69	<5	7.61	70.3	24	22	0.1	0.02	6	0.9	0	Satisfactory
428	2080/11/18	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.08	71.4	24	22	0.1	0.02	6	0.5	0	Satisfactory
429	2080/11/18	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.84	72.4	24	22	0.1	0.02	6	0.9	0	Satisfactory
430	2080/11/18	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.25	71.9	24	22	0.1	0.02	6	0.64	0	Satisfactory
431	2080/11/18	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.27	<5	7.23	72.3	24	22	0.1	0.02	6	0.77	0	Satisfactory
432	2080/11/18	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.52	<5	7.1	297	88	72	0.76	1.5	14	0.38	0	Satisfactory
433	2080/11/18	10:30	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.4	<5	7.4	71.9	22	32	0.1	0.02	4	0.1	0	Satisfactory
434	2080/11/18	10:35	Maharajgunj	Bansbari Reservoir	Treated	Clear	1.5	<5	6.91	72	24	32	0.1	0.02	6	0.28	0	Satisfactory
435	2080/11/18	14:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.2	<5	6.84	73	24	32	0.1	0.02	6	0.71	0	Satisfactory
436	2080/11/18	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.91	62	22	24	0.1	0.02	6	0.10	0	Satisfactory
437	2080/11/18	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.14	<5	7.86	401	62	138	0.1	0.02	8	0.84	0	Satisfactory
438	2080/11/18	11:30	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.28	<5	7.65	82.8	28	26	0.1	0.02	4	0.35	0	Satisfactory
439	2080/11/18	9:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.5	<5	7.62	66.1	26	28	0.1	0.02	4	0.29	0	Satisfactory
440	2080/11/18	8:30	Bhaktapur	Katunje Reservoir	Treated	Clear	0.4	<5	7.5	48	26	28	0.1	0.02	6	0.32	0	Satisfactory
441	2080/11/18	12:55	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.45	<5	7.7	87.3	28	26	0.1	0.02	4	0.18	0	Satisfactory
442	2080/11/18	9:30	Kirtipur	Kirtipur Reservoir	Treated	Clear	0.45	<5	7.74	83.5	28	26	0.1	0.02	4	0.12	0	Satisfactory
443	2080/11/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.92	<5	8.11	46.3	20	14	0.1	0.02	4	0.24	0	Satisfactory
444	2080/11/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.16	<5	7.63	50.2	16	14	0.1	0.02	4	0.67	0	Satisfactory
445	2080/11/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.86	<5	7.68	49	18	12	0.1	0.02	4	0.57	0	Satisfactory
446	2080/11/18	11:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.42	<5	7.6	81.4	26	28	0.1	0.02	4	0.1	0	Satisfactory
447	2080/11/18	10:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.5	<5	7.72	46.3	28	26	0.1	0.02	4	0.27	0	Satisfactory
448	2080/11/18	12:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.49	<5	7.65	83.6	28	30	0.1	0.02	4	0.35	0	Satisfactory
449	2080/11/18	14:00	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.35	<5	7.65	84.5	28	26	0.1	0.02	4	0.9	0	Satisfactory
450	2080/11/18	11:30	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.42	<5	7.6	81.4	26	28	0.1	0.02	4	0.1	0	Satisfactory
451	2080/11/19	11:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.33	<5	7.64	71	24	22	0.1	0.02	6	0.41	0	Satisfactory
452	2080/11/19	13:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.76	<5	7.03	73.4	24	22	0.1	0.02	6	0.9	0	Satisfactory
453	2080/11/19	15:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	7.78	72.1	24	22	0.1	0.02	6	0.86	0	Satisfactory
454	2080/11/19	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.55	<5	7.57	71	24	22	0.1	0.02	6	0.47	0	Satisfactory
455	2080/11/19	16:35	Maharajgunj	Bansbari Reservoir	Treated	Clear	0.5	<5	7.02	72	24	32	0.1	0.02	6	0.37	0	Satisfactory
456	2080/11/19	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	6.93	56	18	22	0.1	0.02	6	0.32	0	Satisfactory
457	2080/11/19	13:20	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.49	<5	7.35	86	24	28	0.1	0.02	4	0.47	0	Satisfactory
458	2080/11/19	13:50	Chhetrapati	Balaju Reservoir	Treated	Clear	1.06	<5	7.71	86.9	28	26	0.1	0.02	4	0.58	0	Satisfactory
459	2080/11/19	10:00	Bhaktapur	Katunje Reservoir	Treated	Clear	1.42	<5	7.69	84.8	28	26	0.1	0.02	6	0.15	0	Satisfactory
460	2080/11/19	13:50	Lalitpur	Khumaltar Reservoir	Treated	Clear	0.74	<5	7.57	88.9	26	28	0.1	0.02	4	0.38	0	Satisfactory
461	2080/11/19	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.79	<5	7.61	48.2	16	12	0.1	0.02	4	0.43	0	Satisfactory
462	2080/11/19	13:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.46	86.5	26	28	0.1	0.02	4	0.64	0	Satisfactory
463	2080/11/19	6:30	Mahankalchaur	Mahankalchaur Reservoir	Treated	Clear	0.53	<5	7.16	83.3	22	28	0.1	0.02	4	0.86	0	Satisfactory
464	2080/11/19	13:05	Baneshwor	Min Bhawan Reservoir	Treated	Clear	0.5	<5	7.46	86.5	26	28	0.1	0.02	4	0.64	0	Satisfactory
465	2080/11/20	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.53	72.8	24	22	0.1	0.02	6	0.35	0	Satisfactory
466	2080/11/20	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.62	71.54	24	22	0.1	0.02	6	0.45	0	Satisfactory
467	2080/11/20	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.84	<5	7.62	70.91	24	22	0.1	0.02	6	0.84	0	Satisfactory

468	2080/11/20	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.09	70.8	24	22	0.1	0.02	6	0.43	0	Satisfactory
469	2080/11/20	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	7.19	72.2	24	22	0.1	0.02	6	0.9	0	Satisfactory
470	2080/11/20	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.36	<5	7.15	71.5	24	22	0.1	0.02	6	0.73	0	Satisfactory
471	2080/11/20	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.59	73	24	22	0.1	0.02	6	0.76	0	Satisfactory
472	2080/11/20	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	7.2	304	90	74	0.76	1.5	16	0.4	0	Satisfactory
473	2080/11/20	15:45	Madhyapur Thimi	Tigani Reservoir	Treated	Clear	0.36	<5	7.4	73	22	34	0.1	0.02	4	0.22	0	Satisfactory
474	2080/11/20	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.27	<5	7.28	157	42	50	0.3	1.5	12	0.46	0	Satisfactory
475	2080/11/20	10:25	Maharajgunj	Bansbari Reservoir	Treated	Clear	3.1	<5	7.03	71	24	32	0.1	0.02	6	0.12	0	Satisfactory
476	2080/11/20	14:10	Maharajgunj	Bansbari Reservoir	Treated	Clear	1.4	<5	6.95	73	24	32	0.1	0.02	6	0.36	0	Satisfactory
477	2080/11/20	15:20	Maharajgunj	Bansbari Reservoir	Treated	Clear	2.2	<5	7.05	74	24	32	0.1	0.02	6	0.91	0	Satisfactory
478	2080/11/20	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	6.92	63	20	24	0.1	0.02	6	0.44	0	Satisfactory
479	2080/11/20	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.81	<5	7.96	383	58	136	0.1	0.02	8	0.94	0	Satisfactory
480	2080/11/20	12:40	Tripureshwar	Anamnagar Reservoir	Treated	Clear	0.52	<5	7.84	80.6	30	28	0.1	0.02	6	0.2	0	Satisfactory