



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Magh 2080

S.No.	Date	Time	Branch	Location	Sample taken	Appearance	Turbidity	Colour	pH	E.C.	Total Alkalinity	Total Hardn	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
						(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/L	CFU/100ml	
National Drinking Water Quality Standard (NDWQS)							5	5.00	6.5-8.5	1500		500.0	0.3(3)	1.5	250.0	0.1-0.5	0 in 95% Samples	
1	2080/10/01	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.3	53	16	16	0.1	0.02	6	0.5	0	Satisfactory
2	2080/10/01	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	48	16	16	0.1	0.02	6	0.5	0	Satisfactory
3	2080/10/01	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	8.1	148	44	48	0.1	0.02	8	0.9	0	Satisfactory
4	2080/10/01	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.43	<5	8.5	150	44	48	0.1	0.02	8	0.7	0	Satisfactory
5	2080/10/01	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	8.5	146	44	48	0.1	0.02	8	0.1	0	Satisfactory
6	2080/10/01	13:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.79	<5	8.5	146	44	48	0.1	0.02	8	0.5	0	Satisfactory
7	2080/10/01	15:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.90	<5	8.5	147	44	48	0.1	0.02	8	0.5	0	Satisfactory
8	2080/10/01	16:30	Sundarijal	Sundarijal WTP	Treated	Clear	0.99	<5	8.5	117	36	48	0.1	0.02	6	0.4	0	Satisfactory
9	2080/10/01	18:30	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	8.5	112	36	44	0.1	0.02	6	0.5	0	Satisfactory
10	2080/10/02	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.84	<5	7.2	68	22	24	0.1	0.02	6	0.2	0	Satisfactory
11	2080/10/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.5	67	22	24	0.1	0.02	6	0.1	0	Satisfactory
12	2080/10/02	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.6	79	26	24	0.1	0.02	6	0.7	0	Satisfactory
13	2080/10/02	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.78	<5	7.8	100	30	30	0.1	0.02	4	0.1	0	Satisfactory
14	2080/10/02	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.44	<5	7.7	75	24	22	0.1	0.02	6	0.5	0	Satisfactory
15	2080/10/02	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.86	<5	6.8	102.8	32	28	0.1	0.02	6	0.7	0	Satisfactory
16	2080/10/02	11:50	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.18	<5	8.1	119	32	26	0.1	0.02	10	0.2	0	Satisfactory
17	2080/10/02	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	1.84	<5	8.0	100	30	46	0.1	0.02	6	0.1	0	Satisfactory
18	2080/10/02	12:15	Baneshwor	Min Bhawan SRT	Treated	Clear	1.13	<5	8.0	118.8	40	36	0.1	0.02	8	0.2	0	Satisfactory
19	2080/10/02	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	2.07	<5	8.3	116	36	34	0.1	0.02	8	0.1	0	Satisfactory
20	2080/10/02	11:00	Baneshwor	Anamnagar SRT	Treated	Clear	1.28	<5	8.1	133.6	44	40	0.1	0.02	8	0.6	0	Satisfactory
21	2080/10/02	11:25	Chhetrapati	Balaju SRT	Treated	Clear	1.23	<5	8.2	156.3	52	44	0.1	0.02	10	0.5	0	Satisfactory
22	2080/10/02	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	7.3	43	14	14	0.1	0.02	6	0.5	0	Satisfactory
23	2080/10/02	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	39	14	12	0.1	0.02	6	0.5	0	Satisfactory
24	2080/10/02	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.88	<5	7.1	255	80	60	0.3	1.5	12	0.1	0	Satisfactory
25	2080/10/02	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.94	<5	7.1	260	80	60	0.3	1.5	14	0.2	0	Satisfactory
26	2080/10/02	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.11	<5	8.1	403	60	146	0.1	0.02	10	1.0	0	Satisfactory
27	2080/10/02	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.93	<5	8.4	99	32	44	0.1	0.02	6	1.0	0	Satisfactory
28	2080/10/02	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.77	<5	8.4	76	20	26	0.1	0.02	6	0.9	0	Satisfactory
29	2080/10/02	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.96	<5	8.3	76	20	26	0.1	0.02	4	0.6	0	Satisfactory
30	2080/10/02	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.92	<5	8.2	64	18	20	0.1	0.02	4	0.1	0	Satisfactory
31	2080/10/02	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.85	<5	8.1	65	18	20	0.1	0.02	4	0.6	0	Satisfactory

32	2080/10/02	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.9	63	18	20	0.1	0.02	4	0.3	0	Satisfactory
33	2080/10/02	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.3	64	18	20	0.1	0.02	4	0.8	0	Satisfactory
34	2080/10/02	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	4.13	<5	7.2	209	66	52	0.76	1.5	12	0.1	0	Satisfactory
35	2080/10/03	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.34	<5	7.2	72	24	22	0.1	0.02	6	0.6	0	Satisfactory
36	2080/10/03	10:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	2.58	<5	7.2	94	32	28	0.1	0.02	8	0.7	0	Satisfactory
37	2080/10/03	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.18	<5	7.7	83	28	24	0.1	0.02	6	0.5	0	Satisfactory
38	2080/10/03	12:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	2.85	<5	7.4	94	34	30	0.1	0.02	8	0.9	0	Satisfactory
39	2080/10/03	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.30	<5	7.6	33	32	28	0.1	0.02	6	0.6	0	Satisfactory
40	2080/10/03	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	1.46	<5	7.9	107	42	36	0.1	0.02	8	0.9	0	Satisfactory
41	2080/10/03	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.43	<5	7.4	85	28	24	0.1	0.02	6	0.5	0	Satisfactory
42	2080/10/03	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	1.33	<5	7.5	95	34	28	0.1	0.02	6	0.9	0	Satisfactory
43	2080/10/03	11:10	Baneshwor	Anamnagar SRT	Treated	Clear	5.00	<5	7.9	103.8	34	32	0.2	0.02	6	0.3	0	Satisfactory
44	2080/10/03	12:20	Baneshwor	Min Bhawan SRT	Treated	Clear	4.99	<5	8.2	98.2	34	30	0.1	0.02	26	0.2	0	Satisfactory
45	2080/10/03	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	3.24	<5	8.4	188	54	40	0.1	0.02	12	0.3	0	Satisfactory
46	2080/10/03	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	4.73	<5	7.8	101	54	46	0.1	0.02	6	0.2	0	Satisfactory
47	2080/10/03	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	42	14	14	0.1	0.02	6	0.4	0	Satisfactory
48	2080/10/03	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	41	14	14	0.1	0.02	6	0.5	0	Satisfactory
49	2080/10/03	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.70	<5	7.1	261	82	60	0.3	1.5	14	0.2	0	Satisfactory
50	2080/10/03	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.59	<5	7.1	264	82	60	0.3	1.5	14	0.2	0	Satisfactory
51	2080/10/03	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.06	<5	8.0	398	58	136	0.1	0.02	10	0.9	0	Satisfactory
52	2080/10/03	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.9	63	18	20	0.1	0.02	4	0.5	0	Satisfactory
53	2080/10/03	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.49	<5	7.8	64	18	20	0.1	0.02	4	1.0	0	Satisfactory
54	2080/10/03	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.9	64	18	20	0.1	0.02	4	0.8	0	Satisfactory
55	2080/10/03	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.83	<5	8.0	65	18	20	0.1	0.02	4	0.5	0	Satisfactory
56	2080/10/03	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.89	<5	7.5	61	18	20	0.1	0.02	4	0.9	0	Satisfactory
57	2080/10/03	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.1	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
58	2080/10/03	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	6.6	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
59	2080/10/03	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.50	<5	7.3	68	22	30	0.1	0.02	4	0.1	0	Satisfactory
60	2080/10/03	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	5.00	<5	7.3	72	26	32	0.2	0.02	6	0.1	0	Satisfactory
61	2080/10/03	11:55	Maharajgunj	Panipokhari SRT	Treated	Clear	5.00	<5	7.2	73	26	32	0.2	0.02	6	0.1	0	Satisfactory
62	2080/10/03	15:05	Maharajgunj	Bansbari SRT	Treated	Clear	5.00	<5	7.3	72	26	32	0.1	0.02	6	0.6	0	Satisfactory
63	2080/10/04	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.37	<5	7.1	58	18	14	0.1	0.02	8	0.4	0	Satisfactory
64	2080/10/04	10:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.28	<5	7.3	96	38	30	0.1	0.02	8	0.9	0	Satisfactory
65	2080/10/04	9:30	Bhaktapur	Katunje SRT	Treated	Clear	5.00	<5	7.1	97.8	38	30	0.1	0.02	8	0.7	0	Satisfactory
66	2080/10/04	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.90	<5	8.3	175	48	34	0.1	0.02	10	0.3	0	Satisfactory
67	2080/10/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.48	<5	7.7	56	16	14	0.1	0.02	6	0.4	0	Satisfactory
68	2080/10/04	12:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	1.03	<5	7.4	92	30	28	0.1	0.02	8	0.7	0	Satisfactory
69	2080/10/04	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.38	<5	7.8	79	32	26	0.1	0.02	8	0.9	0	Satisfactory
70	2080/10/04	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.59	<5	7.8	94	34	30	0.1	0.02	8	0.9	0	Satisfactory
71	2080/10/04	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.57	<5	7.8	90	18	24	0.1	0.02	8	0.9	0	Satisfactory
72	2080/10/04	4:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.89	<5	8.1	94	34	30	0.1	0.02	8	0.9	0	Satisfactory
73	2080/10/04	11:00	Baneshwor	Anamnagar SRT	Treated	Clear	4.44	<5	8.0	96.3	34	30	0.1	0.02	6	0.1	0	Satisfactory
74	2080/10/04	11:45	Chhetrapati	Balaju SRT	Treated	Clear	3.10	<5	8.0	95.4	34	30	0.1	0.02	6	0.2	0	Satisfactory
75	2080/10/04	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	4.33	<5	8.5	164	34	56	0.1	0.02	10	0.3	0	Satisfactory
76	2080/10/04	1:10	Lalitpur	Khumaltar SRT	Treated	Clear	3.83	<5	7.7	103	38	32	0.1	0.02	6	0.2	0	Satisfactory
77	2080/10/04	2:00	Baneshwor	Min Bhawan SRT	Treated	Clear	2.30	<5	7.5	94.6	34	30	0.1	0.02	6	0.5	0	Satisfactory

78	2080/10/04	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	49	16	16	0.1	0.02	6	0.5	0	Satisfactory
79	2080/10/04	13:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	43	14	14	0.1	0.02	6	0.5	0	Satisfactory
80	2080/10/04	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.05	<5	7.1	272	82	66	0.3	1.5	20	0.8	0	Satisfactory
81	2080/10/04	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.14	<5	7.1	267	82	64	0.3	1.5	16	0.3	0	Satisfactory
82	2080/10/04	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.48	<5	8.1	407	60	142	0.1	0.02	10	1.0	0	Satisfactory
83	2080/10/04	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	7.4	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
84	2080/10/04	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.55	<5	7.9	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
85	2080/10/04	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	7.9	64	18	20	0.1	0.02	4	0.7	0	Satisfactory
86	2080/10/04	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	7.7	62	18	20	0.1	0.02	4	0.2	0	Satisfactory
87	2080/10/04	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.83	<5	7.7	61	18	20	0.1	0.02	4	0.4	0	Satisfactory
88	2080/10/04	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.50	<5	7.1	61	18	20	0.1	0.02	4	0.5	0	Satisfactory
89	2080/10/04	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.43	<5	6.7	61	18	20	0.1	0.02	4	0.5	0	Satisfactory
90	2080/10/04	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.63	<5	7.2	67	22	30	0.1	0.02	4	0.1	0	Satisfactory
91	2080/10/04	12:20	Maharajgunj	Bansbari SRT	Treated	Clear	3.71	<5	7.2	71	24	32	0.1	0.02	6	0.3	0	Satisfactory
92	2080/10/04	14:15	Maharajgunj	Panipokhari SRT	Treated	Clear	5.00	<5	7.2	86	28	34	0.1	0.02	6	0.2	0	Satisfactory
93	2080/10/05	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.30	<5	7.5	73	26	22	0.1	0.02	8	0.8	0	Satisfactory
94	2080/10/05	7:00	Bhaktapur	Katunje SRT	Treated	Clear	4.82	<5	7.8	96.7	38	28	0.1	0.02	6	0.8	0	Satisfactory
95	2080/10/05	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	7.6	77	28	26	0.1	0.02	6	1.0	0	Satisfactory
96	2080/10/05	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.48	<5	7.7	80	26	24	0.1	0.02	6	1.0	0	Satisfactory
97	2080/10/05	12:30	Mahankalchaur	Melamchi Inlet	Treated	Clear	1.52	<5	7.6	95	30	28	0.1	0.02	8	0.1	0	Satisfactory
98	2080/10/05	11:20	Kirtipur	Kirtipur SRT	Treated	Clear	3.72	<5	8.5	148	46	52	0.1	0.02	10	0.3	0	Satisfactory
99	2080/10/05	10:50	Baneshwor	Anamnagar SRT	Treated	Clear	1.46	<5	7.8	94.7	30	28	0.1	0.02	8	0.2	0	Satisfactory
100	2080/10/05	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.43	<5	7.8	95	30	28	0.1	0.02	8	0.4	0	Satisfactory
101	2080/10/05	12:00	Maharajgunj	Bansbari SRT	Treated	Clear	1.38	<5	7.6	117	40	46	0.1	0.02	2	0.1	0	Satisfactory
102	2080/10/05	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	48	16	16	0.1	0.02	6	0.3	0	Satisfactory
103	2080/10/05	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	37	14	12	0.1	0.02	6	0.5	0	Satisfactory
104	2080/10/05	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.88	<5	7.1	254	80	60	0.3	1.5	12	0.1	0	Satisfactory
105	2080/10/05	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.59	<5	7.1	265	80	62	0.3	1.5	16	0.2	0	Satisfactory
106	2080/10/05	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.05	<5	7.9	408	60	144	0.1	0.02	10	0.9	0	Satisfactory
107	2080/10/05	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.60	<5	7.8	61	18	20	0.1	0.02	4	0.5	0	Satisfactory
108	2080/10/05	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.9	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
109	2080/10/05	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.9	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
110	2080/10/05	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.35	<5	7.8	62	18	20	0.1	0.02	4	1.0	0	Satisfactory
111	2080/10/05	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	3.64	<5	7.8	65	18	20	0.1	0.02	4	0.9	0	Satisfactory
112	2080/10/05	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.6	61	18	20	0.1	0.02	4	0.7	0	Satisfactory
113	2080/10/05	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.49	<5	7.9	60	18	20	0.1	0.02	4	0.2	0	Satisfactory
114	2080/10/05	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	3.10	<5	7.2	63	20	30	0.1	0.02	4	0.1	0	Satisfactory
115	2080/10/05	11:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.67	<5	7.3	73	24	32	0.1	0.02	6	0.5	0	Satisfactory
116	2080/10/05	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.28	<5	7.5	94.1	38	30	0.1	0.02	8	0.6	0	Satisfactory
117	2080/10/05	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.07	<5	7.4	93.1	36	32	0.1	0.02	10	1.0	0	Satisfactory
118	2080/10/05	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.08	<5	8.1	98.5	34	32	0.1	0.02	8	1.0	0	Satisfactory
119	2080/10/06	3:20	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.74	<5	8.0	70	26	24	0.1	0.02	8	0.5	0	Satisfactory
120	2080/10/06	1:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.39	<5	8.4	122	48	24	0.1	0.02	10	0.3	0	Satisfactory
121	2080/10/06	1:50	Chhetrapati	Balaju SRT	Treated	Clear	1.12	<5	7.7	92.4	32	30	0.1	0.02	6	0.1	0	Satisfactory
122	2080/10/06	2:50	Baneshwor	Anamnagar SRT	Treated	Clear	1.54	<5	7.9	97.4	34	30	0.1	0.02	6	0.5	0	Satisfactory
123	2080/10/06	3:05	Baneshwor	Min Bhawan SRT	Treated	Clear	0.48	<5	7.9	96.7	34	32	0.1	0.02	6	0.6	0	Satisfactory
124	2080/10/06	12:50	Lalitpur	Khumaltar SRT	Treated	Clear	1.89	<5	7.9	102	38	34	0.1	0.02	6	0.1	0	Satisfactory

125	2080/10/06	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.17	<5	7.2	68	24	22	0.1	0.02	6	0.8	0	Satisfactory
126	2080/10/06	10:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.01	<5	7.1	90	34	30	0.1	0.02	6	0.1	0	Satisfactory
127	2080/10/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.30	<5	7.4	60	14	12	0.1	0.02	6	0.7	0	Satisfactory
128	2080/10/06	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.10	<5	7.2	63	22	20	0.1	0.02	6	0.9	0	Satisfactory
129	2080/10/06	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.2	44	14	14	0.1	0.02	4	0.1	0	Satisfactory
130	2080/10/06	13:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.2	42	14	14	0.1	0.02	6	0.5	0	Satisfactory
131	2080/10/06	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.50	<5	7.2	61	18	20	0.1	0.02	4	0.6	0	Satisfactory
132	2080/10/06	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.8	63	18	20	0.1	0.02	4	0.8	0	Satisfactory
133	2080/10/06	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	8.1	61	18	20	0.1	0.02	4	0.4	0	Satisfactory
134	2080/10/06	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	2.45	<5	8.0	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
135	2080/10/06	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.82	<5	7.5	60	18	20	0.1	0.02	4	0.2	0	Satisfactory
136	2080/10/06	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.70	<5	7.9	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
137	2080/10/06	11:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.28	<5	7.2	70	24	32	0.1	0.02	6	0.3	0	Satisfactory
138	2080/10/06	3:20	Mahankalchaur	Melamchi Inlet	Treated	clear	0.45	<5	7.4	92.6	32	30	0.1	0.02	8	0.3	0	Satisfactory
139	2080/10/06	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.30	<5	7.6	88.7	32	30	0.1	0.02	6	0.2	0	Satisfactory
140	2080/10/06	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.12	<5	7.3	89.4	34	28	0.1	0.02	8	0.1	0	Satisfactory
141	2080/10/07	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.82	<5	7.1	93.3	32	30	0.1	0.02	6	0.5	0	Satisfactory
142	2080/10/07	7:00	Bhaktapur	Katunje SRT	Treated	Clear	2.07	<5	7.3	90.5	32	30	0.1	0.02	6	0.1	0	Satisfactory
143	2080/10/07	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	3.10	<5	7.8	148	64	58	0.1	0.02	8	0.1	0	Satisfactory
144	2080/10/07	11:00	Baneshwor	Anamnagar SRT	Treated	Clear	0.26	<5	7.3	89.3	34	32	0.1	0.02	6	0.2	0	Satisfactory
145	2080/10/07	11:20	Baneshwor	Min Bhawan SRT	Treated	Clear	0.95	<5	7.5	91.7	34	32	0.1	0.02	6	0.1	0	Satisfactory
146	2080/10/07	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.78	<5	7.5	94	34	32	0.1	0.02	6	0.1	0	Satisfactory
147	2080/10/07	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.10	<5	7.7	66	28	22	0.1	0.02	6	0.8	0	Satisfactory
148	2080/10/07	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.4	41	14	14	0.1	0.02	6	0.5	0	Satisfactory
149	2080/10/07	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.3	42	14	14	0.1	0.02	6	0.5	0	Satisfactory
150	2080/10/07	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.32	<5	7.1	274	82	74	0.3	1.5	20	1.0	0	Satisfactory
151	2080/10/07	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.11	<5	7.1	259	80	62	0.3	1.5	16	0.3	0	Satisfactory
152	2080/10/07	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.27	<5	8.0	357	56	140	0.1	0.02	10	1.0	0	Satisfactory
153	2080/10/07	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.23	<5	7.4	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
154	2080/10/07	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.20	<5	8.0	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
155	2080/10/07	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	2.85	<5	8.3	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
156	2080/10/07	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.07	<5	8.2	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
157	2080/10/07	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	8.1	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
158	2080/10/07	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.73	<5	8.1	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
159	2080/10/07	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.9	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
160	2080/10/07	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.26	<5	7.2	68	22	30	0.1	0.02	4	0.1	0	Satisfactory
161	2080/10/07	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.08	<5	7.6	90.3	30	28	0.1	0.02	6	0.1	0	Satisfactory
162	2080/10/08	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.5	63	18	16	0.1	0.02	6	0.4	0	Satisfactory
163	2080/10/08	8:15	Bhaktapur	Katunje SRT	Treated	Clear	0.61	<5	7.4	91.8	30	28	0.1	0.02	6	0.1	0	Satisfactory
164	2080/10/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.11	<5	8.3	65	22	20	0.1	0.02	6	0.6	0	Satisfactory
165	2080/10/08	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.04	<5	7.9	130	38	30	0.1	0.02	8	0.2	0	Satisfactory
166	2080/10/08	12:30	Baneshwor	Min Bhawan SRT	Treated	Clear	3.88	<5	8.0	94.9	32	30	0.1	0.02	8	0.1	0	Satisfactory
167	2080/10/08	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	1.65	<5	7.8	98	34	32	0.1	0.02	8	0.1	0	Satisfactory
168	2080/10/08	12:00	Chhetrapati	Balaju SRT	Treated	clear	5.00	<5	7.8	95.5	32	30	0.1	0.02	8	0.2	0	Satisfactory
169	2080/10/08	10:45	Baneshwor	Anamnagar SRT	Treated	Clear	4.43	<5	8.0	97.6	32	30	0.1	0.02	8	0.1	0	Satisfactory
170	2080/10/08	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.53	<5	7.9	66	22	20	0.1	0.02	6	0.5	0	Satisfactory
171	2080/10/08	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.62	<5	7.9	63	28	24	0.1	0.02	6	0.4	0	Satisfactory

172	2080/10/08	9:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.3	43	14	14	0.1	0.02	6	0.4	0	Satisfactory
173	2080/10/08	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.01	<5	7.1	250	80	60	0.3	1.5	16	0.3	0	Satisfactory
174	2080/10/08	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.17	<5	7.1	256	82	60	0.3	1.5	16	0.3	0	Satisfactory
175	2080/10/08	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.28	<5	8.0	399	58	136	0.1	0.02	10	0.9	0	Satisfactory
176	2080/10/08	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.7	66	18	20	0.1	0.02	4	0.6	0	Satisfactory
177	2080/10/08	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	8.0	63	18	20	0.1	0.02	4	0.5	0	Satisfactory
178	2080/10/08	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.48	<5	8.2	62	18	20	0.1	0.02	4	0.1	0	Satisfactory
179	2080/10/08	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.37	<5	7.9	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
180	2080/10/08	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.90	<5	8.2	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
181	2080/10/08	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.81	<5	7.2	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
182	2080/10/08	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.40	<5	7.3	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
183	2080/10/08	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.14	<5	7.2	74	22	32	0.1	0.02	4	0.1	0	Satisfactory
184	2080/10/08	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.44	<5	7.1	71	24	32	0.1	0.02	6	0.1	0	Satisfactory
185	2080/10/08	12:50	Maharajgunj	Panipokhari SRT	Treated	Clear	3.34	<5	7.1	73	24	32	0.1	0.02	6	0.1	0	Satisfactory
186	2080/10/08	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.68	<5	7.6	76.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
187	2080/10/08	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.20	<5	7.1	89	32	30	0.1	0.02	6	0.1	0	Satisfactory
188	2080/10/08	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.72	<5	8.0	94.6	32	28	0.1	0.02	8	0.2	0	Satisfactory
189	2080/10/08	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.82	<5	8.0	95.7	34	32	0.1	0.02	8	0.2	0	Satisfactory
190	2080/10/09	10:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.60	<5	8.2	130	30	28	0.1	0.02	8	0.3	0	Satisfactory
191	2080/10/09	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.13	<5	7.3	64	22	20	0.1	0.02	6	0.8	0	Satisfactory
192	2080/10/09	8:00	Bhaktapur	Katunje SRT	Treated	Clear	4.67	<5	7.4	92.3	30	24	0.1	0.02	8	0.3	0	Satisfactory
193	2080/10/09	10:50	Baneshwor	Anamnagar SRT	Treated	Clear	3.80	<5	7.4	94.3	32	26	0.1	0.02	8	0.2	0	Satisfactory
194	2080/10/09	1:40	Lalitpur	Khumaltar SRT	Treated	Clear	4.87	<5	7.5	94	32	26	0.1	0.02	8	0.1	0	Satisfactory
195	2080/10/09	11:03	Baneshwor	Min Bhawan SRT	Treated	Clear	2.96	<5	7.4	94.1	32	26	0.1	0.02	8	0.2	0	Satisfactory
196	2080/10/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.88	<5	7.6	62	22	20	0.1	0.02	6	0.4	0	Satisfactory
197	2080/10/09	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.75	<5	7.6	70	28	22	0.1	0.02	6	0.7	0	Satisfactory
198	2080/10/09	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.26	<5	7.6	74	26	24	0.1	0.02	6	0.7	0	Satisfactory
199	2080/10/09	9:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.1	45	14	14	0.1	0.02	6	0.4	0	Satisfactory
200	2080/10/09	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.2	56	18	18	0.1	0.02	6	0.4	0	Satisfactory
201	2080/10/09	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.99	<5	7.1	284	82	76	0.3	1.5	20	0.8	0	Satisfactory
202	2080/10/09	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.07	<5	7.1	265	80	64	0.3	1.5	14	0.2	0	Satisfactory
203	2080/10/09	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.85	<5	8.1	386	58	136	0.1	0.02	10	0.8	0	Satisfactory
204	2080/10/09	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.1	62	18	20	0.1	0.02	4	0.4	0	Satisfactory
205	2080/10/09	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.91	<5	7.7	64	18	20	0.1	0.02	4	0.1	0	Satisfactory
206	2080/10/09	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.8	61	18	20	0.1	0.02	4	0.2	0	Satisfactory
207	2080/10/09	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	7.9	62	18	20	0.1	0.02	4	1.0	0	Satisfactory
208	2080/10/09	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.76	<5	8.0	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
209	2080/10/09	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	7.5	62	18	20	0.1	0.02	4	1.0	0	Satisfactory
210	2080/10/09	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.86	<5	7.6	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
211	2080/10/09	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.32	<5	7.2	66	22	30	0.1	0.02	4	0.3	0	Satisfactory
212	2080/10/09	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	1.21	<5	6.9	70	24	32	0.1	0.02	6	0.3	0	Satisfactory
213	2080/10/09	14:00	Maharajgunj	Panipokhari SRT	Treated	Clear	1.50	<5	6.8	72	24	32	0.1	0.02	6	0.2	0	Satisfactory
214	2080/10/09	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.74	<5	7.3	95.6	32	28	0.1	0.02	8	0.8	0	Satisfactory
215	2080/10/09	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.66	<5	7.3	59.2	22	20	0.1	0.02	8	0.2	0	Satisfactory
216	2080/10/09	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.7	93.5	32	26	0.1	0.02	8	0.9	0	Satisfactory
217	2080/10/09	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	3.52	<5	7.5	94.1	32	26	0.1	0.02	8	0.9	0	Satisfactory
218	2080/10/10	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.58	<5	7.2	58	22	20	0.1	0.02	6	0.6	0	Satisfactory

219	2080/10/10	9:45	Bhaktapur	Katunje SRT	Treated	Clear	4.52	<5	7.2	95.2	34	26	0.1	0.02	8	0.5	0	Satisfactory
220	2080/10/10	10:00	Bhaktapur	Katunje SRT	Treated	Clear	3.66	<5	7.1	93.5	34	28	0.1	0.02	8	0.3	0	Satisfactory
221	2080/10/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.79	<5	7.5	60	22	18	0.1	0.02	6	0.6	0	Satisfactory
222	2080/10/10	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.08	<5	7.6	65	24	22	0.1	0.02	6	0.9	0	Satisfactory
223	2080/10/10	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.34	<5	7.6	68	26	24	0.1	0.02	6	0.9	0	Satisfactory
224	2080/10/10	11:55	Baneshwor	Anamnagar SRT	Treated	Clear	5.00	<5	7.5	92.6	32	28	0.2	0.02	8	0.1	0	Satisfactory
225	2080/10/10	12:10	Baneshwor	Min Bhawan SRT	Treated	Clear	4.16	<5	7.3	99.5	36	28	0.1	0.02	8	0.2	0	Satisfactory
226	2080/10/10	12:55	Lalitpur	Khumaltar SRT	Treated	Clear	4.95	<5	7.3	98	34	26	0.1	0.02	8	0.2	0	Satisfactory
227	2080/10/10	2:00	Chhetrapati	Balaju SRT	Treated	Clear	5.00	<5	7.1	81.5	32	26	0.1	0.02	8	0.1	0	Satisfactory
228	2080/10/10	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.2	42	14	14	0.1	0.02	6	0.5	0	Satisfactory
229	2080/10/10	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.2	54	16	16	0.1	0.02	6	0.5	0	Satisfactory
230	2080/10/10	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	7.1	263	80	64	0.3	1.5	16	0.5	0	Satisfactory
231	2080/10/10	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.23	<5	7.1	257	80	62	0.3	1.5	12	0.2	0	Satisfactory
232	2080/10/10	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.38	<5	8.1	405	60	138	0.1	0.02	10	0.8	0	Satisfactory
233	2080/10/10	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.3	61	18	20	0.1	0.02	4	0.5	0	Satisfactory
234	2080/10/10	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.49	<5	7.8	63	18	20	0.1	0.02	4	1.0	0	Satisfactory
235	2080/10/10	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	8.1	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
236	2080/10/10	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.55	<5	7.6	64	18	20	0.1	0.02	4	0.9	0	Satisfactory
237	2080/10/10	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.47	<5	7.8	71	18	20	0.1	0.02	4	0.8	0	Satisfactory
238	2080/10/10	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.47	<5	7.1	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
239	2080/10/10	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.84	<5	7.1	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
240	2080/10/10	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.47	<5	7.2	73	22	32	0.1	0.02	4	0.1	0	Satisfactory
241	2080/10/10	12:15	Maharajgunj	Panipokhari SRT	Treated	Clear	1.43	<5	7.5	73	24	32	0.1	0.02	6	0.5	0	Satisfactory
242	2080/10/10	13:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.18	<5	7.1	71	24	32	0.1	0.02	6	0.9	0	Satisfactory
243	2080/10/10	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	3.48	<5	7.4	92.3	32	22	0.1	0.02	8	0.9	0	Satisfactory
244	2080/10/10	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	4.12	<5	7.4	89.6	32	22	0.1	0.02	8	0.3	0	Satisfactory
245	2080/10/10	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	3.99	<5	7.3	92.5	32	22	0.1	0.02	8	0.9	0	Satisfactory
246	2080/10/10	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	4.14	<5	7.5	92.2	32	22	0.1	0.02	8	1.0	0	Satisfactory
247	2080/10/11	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.00	<5	7.3	66	24	22	0.1	0.02	6	0.9	0	Satisfactory
248	2080/10/11	7:00	Bhaktapur	Katunje SRT	Treated	Clear	5.00	<5	7.7	97.0	32	28	0.1	0.02	8	1.0	0	Satisfactory
249	2080/10/11	10:30	Kirtipur	Kirtipur SRT	Treated	Clear	4.25	<5	7.7	95	32	26	0.1	0.02	8	0.2	0	Satisfactory
250	2080/10/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.85	<5	7.6	60	24	20	0.1	0.02	6	0.6	0	Satisfactory
251	2080/10/11	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.70	<5	7.4	62	22	18	0.1	0.02	8	0.6	0	Satisfactory
252	2080/10/11	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.83	<5	7.5	69	24	20	0.1	0.02	6	0.6	0	Satisfactory
253	2080/10/11	3:00	Baneshwor	Anamnagar SRT	Treated	Clear	4.28	<5	7.3	94.2	32	28	0.1	0.02	6	0.8	0	Satisfactory
254	2080/10/11	3:00	Baneshwor	Min Bhawan SRT	Treated	Clear	4.14	<5	7.3	91.5	32	28	0.1	0.02	6	0.2	0	Satisfactory
255	2080/10/11	3:00	Lalitpur	Khumaltar SRT	Treated	Clear	3.92	<5	7.4	95	34	28	0.1	0.02	8	0.2	0	Satisfactory
256	2080/10/11	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.2	46	16	16	0.1	0.02	6	0.5	0	Satisfactory
257	2080/10/11	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	6.9	58	20	22	0.1	0.02	6	0.6	0	Satisfactory
258	2080/10/11	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.54	<5	7.1	267	82	68	0.3	1.5	20	1.0	0	Satisfactory
259	2080/10/11	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.42	<5	7.1	259	80	62	0.3	1.5	14	0.4	0	Satisfactory
260	2080/10/11	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.15	<5	7.9	398	58	136	0.1	0.02	10	1.0	0	Satisfactory
261	2080/10/11	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.76	<5	6.8	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
262	2080/10/11	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.7	64	18	20	0.1	0.02	4	0.9	0	Satisfactory
263	2080/10/11	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.59	<5	7.9	63	18	20	0.1	0.02	4	0.3	0	Satisfactory
264	2080/10/11	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	8.0	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
265	2080/10/11	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.8	62	18	20	0.1	0.02	4	0.9	0	Satisfactory

266	2080/10/11	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.9	61	18	20	0.1	0.02	4	0.3	0	Satisfactory
267	2080/10/11	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.96	<5	7.9	62	18	20	0.1	0.02	4	0.4	0	Satisfactory
268	2080/10/11	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.52	<5	7.2	66	22	30	0.1	0.02	4	0.7	0	Satisfactory
269	2080/10/11	14:00	Maharajgunj	Panipokhari SRT	Treated	Clear	1.13	<5	6.8	72	24	32	0.1	0.02	6	0.4	0	Satisfactory
270	2080/10/11	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.71	<5	6.8	71	24	32	0.1	0.02	6	0.8	0	Satisfactory
271	2080/10/11	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	3.25	<5	7.4	97.8	32	28	0.1	0.02	8	0.9	0	Satisfactory
272	2080/10/11	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	2.50	<5	7.7	92.7	32	24	0.1	0.02	8	0.3	0	Satisfactory
273	2080/10/11	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	4.78	<5	7.5	92.4	32	26	0.1	0.02	8	0.9	0	Satisfactory
274	2080/10/11	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.6	91.9	32	26	0.1	0.02	6	1.0	0	Satisfactory
275	2080/10/12	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.25	<5	7.5	61	20	18	0.1	0.02	6	0.4	0	Satisfactory
276	2080/10/12	8:00	Bhaktapur	Katunje SRT	Treated	Clear	4.17	<5	7.6	88.5	28	24	0.1	0.02	6	0.1	0	Satisfactory
277	2080/10/12	10:00	Baneshwor	Anamnagar SRT	Treated	Clear	5.00	<5	7.8	92.5	30	28	0.1	0.02	6	0.1	0	Satisfactory
278	2080/10/12	10:50	Baneshwor	Min Bhawan SRT	Treated	Clear	4.55	<5	7.8	92.9	28	24	0.1	0.02	6	0.2	0	Satisfactory
279	2080/10/12	10:10	Kirtipur	Kirtipur SRT	Treated	Clear	4.30	<5	7.4	95	34	28	0.1	0.02	6	0.3	0	Satisfactory
280	2080/10/12	10:30	Lalitpur	Khumaltar SRT	Treated	Clear	3.99	<5	7.8	93	30	28	0.1	0.02	8	0.1	0	Satisfactory
281	2080/10/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.8	62	24	20	0.1	0.02	6	0.5	0	Satisfactory
282	2080/10/12	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.70	<5	7.9	66	22	20	0.1	0.02	6	0.6	0	Satisfactory
283	2080/10/12	8:30	Baneshwor	Anamnagar SRT	Treated	Clear	5.00	<5	7.5	94.2	30	28	0.1	0.02	8	0.4	0	Satisfactory
284	2080/10/12	8:15	Baneshwor	Min Bhawan SRT	Treated	Clear	4.81	<5	7.6	91.4	30	28	0.1	0.02	8	0.3	0	Satisfactory
285	2080/10/12	9:30	Chhetrapati	Balaju SRT	Treated	Clear	5.00	<5	7.5	90.5	30	28	0.1	0.02	8	0.3	0	Satisfactory
286	2080/10/12	9:00	Lalitpur	Khumaltar SRT	Treated	Clear	4.41	<5	7.7	96	32	28	0.1	0.02	8	0.1	0	Satisfactory
287	2080/10/12	8:10	Bhaktapur	Katunje SRT	Treated	Clear	5.00	<5	7.5	96.7	30	26	0.1	0.02	8	0.4	0	Satisfactory
288	2080/10/12	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.1	48	16	14	0.1	0.02	6	0.4	0	Satisfactory
289	2080/10/12	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.1	56	18	18	0.1	0.02	6	0.4	0	Satisfactory
290	2080/10/12	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.09	<5	7.1	250	80	60	0.3	1.5	14	0.2	0	Satisfactory
291	2080/10/12	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	7.1	251	80	60	0.3	1.5	14	0.4	0	Satisfactory
292	2080/10/12	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.87	<5	7.9	401	58	134	0.1	0.02	10	1.0	0	Satisfactory
293	2080/10/12	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.3	61	18	20	0.1	0.02	4	0.5	0	Satisfactory
294	2080/10/12	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	8.1	61	18	20	0.1	0.02	4	0.5	0	Satisfactory
295	2080/10/12	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	7.9	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
296	2080/10/12	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.87	<5	8.1	60	18	20	0.1	0.02	4	0.1	0	Satisfactory
297	2080/10/12	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.99	<5	8.1	61	18	20	0.1	0.02	4	0.3	0	Satisfactory
298	2080/10/12	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	7.6	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
299	2080/10/12	18:30	Sundarijal	Sundarijal WTP	Treated	Clear	3.24	<5	6.7	63	18	20	0.1	0.02	4	0.7	0	Satisfactory
300	2080/10/12	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.48	<5	7.3	65	22	30	0.1	0.02	4	0.1	0	Satisfactory
301	2080/10/12	12:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	6.8	70	24	32	0.1	0.02	6	0.2	0	Satisfactory
302	2080/10/12	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.45	<5	6.7	72	24	32	0.1	0.02	6	0.3	0	Satisfactory
303	2080/10/12	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	4.29	<5	7.6	88.7	26	24	0.1	0.02	8	0.1	0	Satisfactory
304	2080/10/12	12:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.9	88	26	24	0.1	0.02	8	0.1	0	Satisfactory
305	2080/10/12	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.8	94.6	34	30	0.2	0.02	8	0.1	0	Satisfactory
306	2080/10/13	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	7.1	46	16	14	0.1	0.02	6	0.3	0	Satisfactory
307	2080/10/13	14:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	6.9	57	18	16	0.1	0.02	6	0.5	0	Satisfactory
308	2080/10/13	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.5	61	18	20	0.1	0.02	4	0.6	0	Satisfactory
309	2080/10/13	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.31	<5	7.2	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
310	2080/10/13	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.91	<5	8.0	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
311	2080/10/13	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.81	<5	7.9	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
312	2080/10/13	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	7.8	62	18	20	0.1	0.02	4	0.7	0	Satisfactory

313	2080/10/13	2:30 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.40	<5	7.2	66	22	30	0.1	0.02	4	0.7	0	Satisfactory
314	2080/10/13	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.65	<5	6.8	72	24	32	0.1	0.02	6	0.9	0	Satisfactory
315	2080/10/14	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.70	<5	7.6	65	20	18	0.1	0.02	6	0.6	0	Satisfactory
316	2080/10/14	8:25	Bhaktapur	Katunje SRT	Treated	Clear	5.00	<5	7.5	51.6	30	28	0.1	0.02	8	0.7	0	Satisfactory
317	2080/10/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.6	64	26	24	0.1	0.02	6	0.8	0	Satisfactory
318	2080/10/14	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.92	<5	7.9	66	24	22	0.1	0.02	6	0.7	0	Satisfactory
319	2080/10/14	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.29	<5	7.8	90	22	20	0.1	0.02	6	0.5	0	Satisfactory
320	2080/10/14	10:30	Chhetrapati	Balaju SRT	Treated	Clear	5.00	<5	7.6	91.1	32	30	0.1	0.02	6	0.3	0	Satisfactory
321	2080/10/14	12:00	Baneshwor	Anamnagar SRT	Treated	Clear	5.00	<5	8.0	89.4	30	28	0.2	0.02	6	0.1	0	Satisfactory
322	2080/10/14	12:15	Baneshwor	Min Bhawan SRT	Treated	Clear	4.99	<5	7.9	93.5	32	30	0.1	0.02	6	0.3	0	Satisfactory
323	2080/10/14	1:20	Lalitpur	Khumaltar SRT	Treated	Clear	4.24	<5	8.0	95	32	30	0.1	0.02	6	0.1	0	Satisfactory
324	2080/10/14	9:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.1	45	14	14	0.1	0.02	6	0.3	0	Satisfactory
325	2080/10/14	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.19	<5	7.1	287	84	74	0.3	1.5	18	0.7	0	Satisfactory
326	2080/10/14	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.23	<5	7.1	257	80	64	0.3	1.5	14	0.3	0	Satisfactory
327	2080/10/14	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.15	<5	8.0	408	60	138	0.1	0.02	10	0.8	0	Satisfactory
328	2080/10/14	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.99	<5	7.8	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
329	2080/10/14	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.84	<5	7.8	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
330	2080/10/14	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.75	<5	7.9	62	18	20	0.1	0.02	4	0.2	0	Satisfactory
331	2080/10/14	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.10	<5	8.0	61	18	20	0.1	0.02	4	0.4	0	Satisfactory
332	2080/10/14	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.46	<5	7.6	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
333	2080/10/14	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.69	<5	8.4	67	18	20	0.1	0.02	4	0.9	0	Satisfactory
334	2080/10/14	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.91	<5	7.8	62	18	20	0.1	0.02	4	0.2	0	Satisfactory
335	2080/10/14	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.64	<5	7.3	65	22	30	0.1	0.02	4	0.1	0	Satisfactory
336	2080/10/14	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.24	<5	6.9	71	24	32	0.1	0.02	6	0.3	0	Satisfactory
337	2080/10/14	10:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.5	91.2	28	22	0.1	0.02	8	0.7	0	Satisfactory
338	2080/10/14	12:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.8	90.3	34	30	0.1	0.02	8	0.9	0	Satisfactory
339	2080/10/14	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.8	91.5	34	30	0.1	0.02	8	0.8	0	Satisfactory
340	2080/10/14	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	4.99	<5	7.8	92.2	30	28	0.1	0.02	8	0.7	0	Satisfactory
341	2080/10/15	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.3	63	22	20	0.1	0.02	6	0.2	0	Satisfactory
342	2080/10/15	6:40	Bhaktapur	Katunje SRT	Treated	Clear	2.30	<5	7.4	91.5	34	32	0.1	0.02	6	0.6	0	Satisfactory
343	2080/10/15	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.98	<5	7.4	92	32	30	0.1	0.02	6	0.3	0	Satisfactory
344	2080/10/15	10:15	Baneshwor	Min Bhawan SRT	Treated	Clear	0.58	<5	7.4	91.3	32	30	0.1	0.02	8	0.4	0	Satisfactory
345	2080/10/15	11:40	Baneshwor	Anamnagar SRT	Treated	Clear	0.32	<5	7.6	92.8	32	30	0.1	0.02	8	0.3	0	Satisfactory
346	2080/10/15	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.5	66	22	20	0.1	0.02	6	0.3	0	Satisfactory
347	2080/10/15	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.5	79	26	22	0.1	0.02	6	0.3	0	Satisfactory
348	2080/10/15	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.61	<5	7.5	67	20	18	0.1	0.02	6	0.1	0	Satisfactory
349	2080/10/15	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	6.9	55	18	16	0.1	0.02	6	0.3	0	Satisfactory
350	2080/10/15	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.52	<5	7.1	260.4	80	66	0.3	1.5	20	1.0	0	Satisfactory
351	2080/10/15	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.95	<5	7.1	258	80	64	0.3	1.5	16	0.6	0	Satisfactory
352	2080/10/15	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.26	<5	7.9	396	58	140	0.1	0.02	10	0.9	0	Satisfactory
353	2080/10/15	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.4	63	18	20	0.1	0.02	4	0.5	0	Satisfactory
354	2080/10/15	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.74	<5	7.1	62	18	20	0.1	0.02	4	1.0	0	Satisfactory
355	2080/10/15	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.9	61	18	20	0.1	0.02	4	0.7	0	Satisfactory
356	2080/10/15	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	8.1	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
357	2080/10/15	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	7.8	61	18	20	0.1	0.02	4	0.8	0	Satisfactory
358	2080/10/15	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.64	<5	7.8	63	18	20	0.1	0.02	4	0.3	0	Satisfactory
359	2080/10/15	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.73	<5	7.5	63	18	20	0.1	0.02	4	0.9	0	Satisfactory

360	2080/10/15	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.83	<5	7.4	67	22	30	0.1	0.02	4	0.1	0	Satisfactory
361	2080/10/15	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1.32	<5	6.8	72	24	32	0.1	0.02	6	0.6	0	Satisfactory
362	2080/10/15	13:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.37	<5	6.9	70	24	32	0.1	0.02	6	0.4	0	Satisfactory
363	2080/10/15	10:30	Mahankalchaur	Melamchi Inlet	Treated	clear	2.01	<5	7.6	76.3	32	30	0.1	0.02	6	0.9	0	Satisfactory
364	2080/10/15	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.20	<5	7.5	91.3	32	28	0.1	0.02	6	0.7	0	Satisfactory
365	2080/10/15	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.22	<5	7.4	92.1	32	28	0.1	0.02	8	0.7	0	Satisfactory
366	2080/10/15	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.27	<5	7.8	95.1	28	24	0.1	0.02	8	1.0	0	Satisfactory
367	2080/10/16	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.66	<5	8.0	53	18	16	0.1	0.02	6	0.3	0	Satisfactory
368	2080/10/16	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.03	<5	7.7	74	26	22	0.1	0.02	6	0.4	0	Satisfactory
369	2080/10/16	8:05	Bhaktapur	Katunje SRT	Treated	Clear	2.72	<5	7.6	85.3	28	24	0.1	0.02	8	0.4	0	Satisfactory
370	2080/10/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	7.6	52	18	16	0.1	0.02	6	0.3	0	Satisfactory
371	2080/10/16	10:30	Baneshwor	Min Bhawan SRT	Treated	Clear	0.50	<5	7.5	72.7	28	24	0.1	0.02	6	0.3	0	Satisfactory
372	2080/10/16	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.62	<5	7.7	75	28	24	0.1	0.02	6	0.5	0	Satisfactory
373	2080/10/16	11:15	Baneshwor	Anamnagar SRT	Treated	Clear	0.35	<5	7.7	72.8	28	24	0.1	0.02	6	0.1	0	Satisfactory
374	2080/10/16	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.66	<5	7.6	48	14	12	0.1	0.02	6	0.4	0	Satisfactory
375	2080/10/16	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.74	<5	7.6	58	20	14	0.1	0.02	6	0.5	0	Satisfactory
376	2080/10/16	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.1	61	20	24	0.1	0.02	6	0.4	0	Satisfactory
377	2080/10/16	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.04	<5	7.1	247	80	60	0.3	1.5	18	0.6	0	Satisfactory
378	2080/10/16	2:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.90	<5	7.1	195	62	50	0.3	1.5	14	0.1	0	Satisfactory
379	2080/10/16	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.18	<5	8.1	408	60	140	0.1	0.02	10	0.8	0	Satisfactory
380	2080/10/16	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.74	<5	7.8	66	18	20	0.1	0.02	4	0.4	0	Satisfactory
381	2080/10/16	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.9	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
382	2080/10/16	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.9	64	18	20	0.1	0.02	4	0.9	0	Satisfactory
383	2080/10/16	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.71	<5	7.9	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
384	2080/10/16	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.8	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
385	2080/10/16	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.7	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
386	2080/10/16	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.38	<5	7.3	62	18	20	0.1	0.02	4	0.3	0	Satisfactory
387	2080/10/16	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.13	<5	7.4	66	22	30	0.1	0.02	4	0.1	0	Satisfactory
388	2080/10/16	2:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.37	<5	7.4	67	22	30	0.1	0.02	4	0.8	0	Satisfactory
389	2080/10/16	15:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.52	<5	7.2	71	24	32	0.1	0.02	6	0.8	0	Satisfactory
390	2080/10/16	10:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.96	<5	7.3	72.8	24	18	0.1	0.02	6	0.7	0	Satisfactory
391	2080/10/16	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.52	<5	7.6	73.4	28	24	0.1	0.02	8	0.7	0	Satisfactory
392	2080/10/16	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.90	<5	7.7	72.1	24	22	0.1	0.02	6	0.6	0	Satisfactory
393	2080/10/16	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.95	<5	7.6	73.5	24	20	0.1	0.02	6	0.7	0	Satisfactory
394	2080/10/17	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.18	<5	7.8	48	14	12	0.1	0.02	6	0.5	0	Satisfactory
395	2080/10/17	7:58	Bhaktapur	Katunje SRT	Treated	Clear	0.89	<5	7.6	75.7	26	22	0.1	0.02	6	0.8	0	Satisfactory
396	2080/10/17	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.65	<5	7.4	75	26	24	0.1	0.02	6	0.4	0	Satisfactory
397	2080/10/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.77	<5	7.5	50	18	14	0.1	0.02	6	0.5	0	Satisfactory
398	2080/10/17	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.77	<5	7.3	49	18	12	0.1	0.02	6	0.5	0	Satisfactory
399	2080/10/17	11:00	Baneshwor	Anamnagar SRT	Treated	Clear	0.49	<5	7.7	73.8	26	20	0.1	0.02	6	0.4	0	Satisfactory
400	2080/10/17	11:15	Baneshwor	Min Bhawan SRT	Treated	Clear	0.52	<5	7.7	73.6	26	20	0.1	0.02	6	0.3	0	Satisfactory
401	2080/10/17	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.78	<5	7.7	75	28	24	0.1	0.02	6	0.3	0	Satisfactory
402	2080/10/17	1:10	Chhetrapati	Balaju SRT	Treated	Clear	1.14	<5	7.8	73.8	26	22	0.1	0.02	6	0.1	0	Satisfactory
403	2080/10/17	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.6	53	20	14	0.1	0.02	6	0.5	0	Satisfactory
404	2080/10/17	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	6.9	48	16	16	0.1	0.02	6	0.4	0	Satisfactory
405	2080/10/17	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.46	<5	7.2	253	80	60	0.3	1.5	18	0.6	0	Satisfactory
406	2080/10/17	3:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.70	<5	7.1	265	80	66	0.3	1.5	14	0.6	0	Satisfactory

407	2080/10/17	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.31	<5	7.9	391	58	136	0.1	0.02	10	0.8	0	Satisfactory
408	2080/10/17	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.99	<5	6.8	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
409	2080/10/17	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.75	<5	7.3	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
410	2080/10/17	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	7.9	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
411	2080/10/17	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.37	<5	7.8	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
412	2080/10/17	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.13	<5	7.8	61	18	20	0.1	0.02	4	0.7	0	Satisfactory
413	2080/10/17	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.9	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
414	2080/10/17	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.45	<5	6.8	62	18	20	0.1	0.02	4	1.0	0	Satisfactory
415	2080/10/17	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.60	<5	7.4	66	22	30	0.1	0.02	4	0.1	0	Satisfactory
416	2080/10/17	15:05	Maharajgunj	Bansbari SRT	Treated	Clear	0.47	<5	7.1	72	24	32	0.1	0.02	6	0.9	0	Satisfactory
417	2080/10/17	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.32	<5	7.8	73.5	26	22	0.1	0.02	6	1.0	0	Satisfactory
418	2080/10/17	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.49	<5	7.5	76.2	26	24	0.1	0.02	6	0.7	0	Satisfactory
419	2080/10/17	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.75	<5	7.5	73.9	26	24	0.1	0.02	6	0.6	0	Satisfactory
420	2080/10/17	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.26	<5	7.7	73.8	26	20	0.1	0.02	6	0.6	0	Satisfactory
421	2080/10/18	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.4	51	16	14	0.1	0.02	6	0.6	0	Satisfactory
422	2080/10/18	8:20	Bhaktapur	Katunje SRT	Treated	Clear	0.86	<5	7.6	75.7	26	24	0.1	0.02	6	0.5	0	Satisfactory
423	2080/10/18	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.5	73	26	24	0.1	0.02	6	0.4	0	Satisfactory
424	2080/10/18	12:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.61	<5	7.6	75	26	24	0.1	0.02	6	1.0	0	Satisfactory
425	2080/10/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.46	<5	7.6	53	20	12	0.1	0.02	6	1.0	0	Satisfactory
426	2080/10/18	11:30	Baneshwor	Anamnagar SRT	Treated	Clear	0.91	<5	7.9	92.2	26	22	0.1	0.02	6	0.4	0	Satisfactory
427	2080/10/18	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.40	<5	7.8	76	26	22	0.1	0.02	6	0.2	0	Satisfactory
428	2080/10/18	11:50	Baneshwor	Min Bhawan SRT	Treated	Clear	0.61	<5	7.8	73.5	26	22	0.1	0.02	6	0.3	0	Satisfactory
429	2080/10/18	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	7.6	63	22	20	0.1	0.02	6	0.8	0	Satisfactory
430	2080/10/18	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.75	<5	7.7	49	14	12	0.1	0.02	6	0.7	0	Satisfactory
431	2080/10/18	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	6.9	45	14	14	0.1	0.02	6	0.3	0	Satisfactory
432	2080/10/18	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.29	<5	7.1	258	80	60	0.3	1.5	14	0.1	0	Satisfactory
433	2080/10/18	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.46	<5	7.3	227	66	54	0.3	1.5	14	0.3	0	Satisfactory
434	2080/10/18	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.16	<5	7.9	387	58	136	0.1	0.02	10	0.9	0	Satisfactory
435	2080/10/18	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.8	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
436	2080/10/18	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.70	<5	7.7	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
437	2080/10/18	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	8.0	64	18	20	0.1	0.02	4	0.9	0	Satisfactory
438	2080/10/18	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.95	<5	7.9	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
439	2080/10/18	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.2	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
440	2080/10/18	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.9	61	18	20	0.1	0.02	4	0.2	0	Satisfactory
441	2080/10/18	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.87	<5	7.7	61	18	20	0.1	0.02	4	0.4	0	Satisfactory
442	2080/10/18	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.38	<5	7.4	65	22	30	0.1	0.02	4	0.1	0	Satisfactory
443	2080/10/18	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.54	<5	7.1	69	24	30	0.1	0.02	6	0.1	0	Satisfactory
444	2080/10/18	13:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.1	72	24	32	0.1	0.02	6	0.1	0	Satisfactory
445	2080/10/18	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.51	<5	7.1	73	24	32	0.1	0.02	6	0.6	0	Satisfactory
446	2080/10/18	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.60	<5	7.5	74.5	26	24	0.1	0.02	6	0.8	0	Satisfactory
447	2080/10/18	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.72	<5	7.6	75.5	26	24	0.1	0.02	6	0.9	0	Satisfactory
448	2080/10/18	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.01	<5	7.7	74.2	26	24	0.1	0.02	6	1.0	0	Satisfactory
449	2080/10/19	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.80	<5	7.6	52	16	14	0.1	0.02	6	0.3	0	Satisfactory
450	2080/10/19	8:30	Bhaktapur	Katunje SRT	Treated	Clear	1.67	<5	7.5	78.4	28	26	0.1	0.02	6	0.4	0	Satisfactory
451	2080/10/19	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.87	<5	7.7	54	16	14	0.1	0.02	6	0.3	0	Satisfactory
452	2080/10/19	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.85	<5	7.5	76	24	20	0.1	0.02	6	0.4	0	Satisfactory
453	2080/10/19	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.32	<5	7.7	71	28	24	0.1	0.02	6	0.1	0	Satisfactory

454	2080/10/19	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.71	<5	7.4	75	24	20	0.1	0.02	6	0.1	0	Satisfactory
455	2080/10/19	11:05	Baneshwor	Anamnagar SRT	Treated	Clear	0.41	<5	7.8	74.8	24	20	0.1	0.02	6	0.1	0	Satisfactory
456	2080/10/19	11:20	Baneshwor	Min Bhawan SRT	Treated	Clear	0.39	<5	7.8	71.7	24	20	0.1	0.02	6	0.2	0	Satisfactory
457	2080/10/19	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.55	<5	7.5	50	16	14	0.1	0.02	6	0.3	0	Satisfactory
458	2080/10/19	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.1	45	14	14	0.1	0.02	6	0.3	0	Satisfactory
459	2080/10/19	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.12	<5	7.2	274	84	62	0.3	1.5	12	0.1	0	Satisfactory
460	2080/10/19	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.46	<5	7.2	260	80	60	0.3	1.5	16	0.3	0	Satisfactory
461	2080/10/19	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.15	<5	7.8	374	54	136	0.1	0.02	8	1.0	0	Satisfactory
462	2080/10/19	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.50	<5	7.1	62	18	20	0.1	0.02	4	0.5	0	Satisfactory
463	2080/10/19	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.2	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
464	2080/10/19	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.60	<5	7.9	65	18	20	0.1	0.02	4	0.9	0	Satisfactory
465	2080/10/19	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.63	<5	7.9	61	18	20	0.1	0.02	4	0.3	0	Satisfactory
466	2080/10/19	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.02	<5	7.8	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
467	2080/10/19	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.93	<5	7.4	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
468	2080/10/19	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	6.7	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
469	2080/10/19	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.32	<5	7.4	83	28	34	0.1	0.02	4	0.1	0	Satisfactory
470	2080/10/19	11:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.38	<5	7.1	69	24	30	0.1	0.02	6	0.1	0	Satisfactory
471	2080/10/19	14:05	Maharajgunj	Bansbari SRT	Treated	Clear	0.48	<5	7.1	71	24	32	0.1	0.02	6	0.6	0	Satisfactory
472	2080/10/19	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.34	<5	7.5	74.8	26	24	0.1	0.02	6	0.6	0	Satisfactory
473	2080/10/19	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.76	<5	7.7	74.6	22	20	0.1	0.02	6	0.9	0	Satisfactory
474	2080/10/19	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.34	<5	7.7	74	26	24	0.1	0.02	6	0.8	0	Satisfactory
475	2080/10/20	4:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.64	<5	7.1	53	16	12	0.1	0.02	6	0.3	0	Satisfactory
476	2080/10/20	12:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.46	<5	7.6	77	26	22	0.1	0.02	6	0.6	0	Satisfactory
477	2080/10/20	12:00	Baneshwor	Anamnagar SRT	Treated	Clear	0.48	<5	7.7	75.9	26	22	0.1	0.02	6	0.1	0	Satisfactory
478	2080/10/20	12:45	Baneshwor	Min Bhawan SRT	Treated	Clear	0.47	<5	7.9	72.1	24	22	0.1	0.02	6	0.3	0	Satisfactory
479	2080/10/20	1:30	Chhetrapati	Balaju SRT	Treated	Clear	0.46	<5	7.9	78.8	26	24	0.1	0.02	6	0.0	0	Satisfactory
480	2080/10/20	7:55	Bhaktapur	Katunje SRT	Treated	Clear	0.49	<5	7.6	77.2	26	24	0.1	0.02	6	0.3	0	Satisfactory
481	2080/10/20	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	6.9	51	16	16	0.1	0.02	6	0.4	0	Satisfactory
482	2080/10/20	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.2	62	18	20	0.1	0.02	4	0.4	0	Satisfactory
483	2080/10/20	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.3	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
484	2080/10/20	11:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.01	<5	7.8	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
485	2080/10/20	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.04	<5	7.9	61	18	20	0.1	0.02	4	0.6	0	Satisfactory
486	2080/10/20	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.94	<5	7.7	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
487	2080/10/20	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.68	<5	8.0	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
488	2080/10/20	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.37	<5	7.2	72	24	32	0.1	0.02	6	0.5	0	Satisfactory
489	2080/10/20	4:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.69	<5	7.3	74.8	26	20	0.1	0.02	6	0.7	0	Satisfactory
490	2080/10/21	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.70	<5	7.5	57	14	12	0.1	0.02	6	0.6	0	Satisfactory
491	2080/10/21	10:00	Bhaktapur	Katunje SRT	Treated	Clear	1.02	<5	7.6	77.5	26	24	0.1	0.02	6	0.3	0	Satisfactory
492	2080/10/21	10:10	Kirtipur	Kirtipur SRT	Treated	Clear	0.42	<5	7.7	76	24	20	0.1	0.02	6	0.4	0	Satisfactory
493	2080/10/21	12:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.55	<5	7.4	75	18	12	0.1	0.02	6	0.6	0	Satisfactory
494	2080/10/21	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.5	50	18	12	0.1	0.02	6	0.4	0	Satisfactory
495	2080/10/21	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.61	<5	7.5	50	16	12	0.1	0.02	6	0.6	0	Satisfactory
496	2080/10/21	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.22	<5	7.6	73	24	22	0.1	0.02	6	0.1	0	Satisfactory
497	2080/10/21	11:40	Baneshwor	Anamnagar SRT	Treated	Clear	0.27	<5	7.8	73.4	24	22	0.1	0.02	6	0.3	0	Satisfactory
498	2080/10/21	11:55	Baneshwor	Min Bhawan SRT	Treated	Clear	0.36	<5	7.7	74	24	22	0.1	0.02	6	0.3	0	Satisfactory
499	2080/10/21	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.1	51	16	16	0.1	0.02	6	0.4	0	Satisfactory
500	2080/10/21	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.04	<5	7.1	276	82	68	0.3	1.5	18	1.0	0	Satisfactory

501	2080/10/21	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.60	<5	7.1	286	82	76	0.3	1.5	20	1.0	0	Satisfactory
502	2080/10/21	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.28	<5	7.9	368	46	134	0.1	0.02	8	1.0	0	Satisfactory
503	2080/10/21	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.1	62	18	20	0.1	0.02	4	0.6	0	Satisfactory
504	2080/10/21	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.13	<5	7.4	61	18	20	0.1	0.02	4	0.9	0	Satisfactory
505	2080/10/21	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	8.0	65	18	20	0.1	0.02	4	0.9	0	Satisfactory
506	2080/10/21	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.50	<5	8.0	62	18	20	0.1	0.02	4	0.8	0	Satisfactory
507	2080/10/21	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.4	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
508	2080/10/21	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	8.0	62	18	20	0.1	0.02	4	0.4	0	Satisfactory
509	2080/10/21	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.02	<5	7.9	61	18	20	0.1	0.02	4	0.1	0	Satisfactory
510	2080/10/21	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.25	<5	7.3	68	22	30	0.1	0.02	4	0.1	0	Satisfactory
511	2080/10/21	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	7.1	71	24	32	0.1	0.02	6	0.5	0	Satisfactory
512	2080/10/21	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.30	<5	7.1	72	24	32	0.1	0.02	6	0.5	0	Satisfactory
513	2080/10/21	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.18	<5	7.6	76.7	24	22	0.1	0.02	6	0.9	0	Satisfactory
514	2080/10/21	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.46	<5	7.5	41.6	24	20	0.1	0.02	6	0.9	0	Satisfactory
515	2080/10/21	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.49	<5	7.5	75.5	28	24	0.1	0.02	6	0.9	0	Satisfactory
516	2080/10/21	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.43	<5	7.6	72.8	24	20	0.1	0.02	6	0.7	0	Satisfactory
517	2080/10/22	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	7.6	48	16	10	0.1	0.02	6	1.0	0	Satisfactory
518	2080/10/22	8:30	Bhaktapur	Katunje SRT	Treated	Clear	0.33	<5	7.6	74.4	28	24	0.1	0.02	6	0.7	0	Satisfactory
519	2080/10/22	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.38	<5	7.6	74	24	20	0.1	0.02	6	0.1	0	Satisfactory
520	2080/10/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.2	50	12	10	0.1	0.02	6	1.0	0	Satisfactory
521	2080/10/22	11:15	Baneshwor	Min Bhawan SRT	Treated	Clear	0.40	<5	7.6	74.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
522	2080/10/22	12:10	Baneshwor	Anamnagar SRT	Treated	Clear	0.54	<5	7.5	74.6	24	22	0.1	0.02	6	0.1	0	Satisfactory
523	2080/10/22	1:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.67	<5	7.5	76	24	22	0.1	0.02	6	0.1	0	Satisfactory
524	2080/10/22	2:00	Chhetrapati	Balaju SRT	Treated	Clear	0.35	<5	7.4	87.3	24	26	0.1	0.02	8	0.2	0	Satisfactory
525	2080/10/22	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	7.6	53	18	12	0.1	0.02	6	1.0	0	Satisfactory
526	2080/10/22	3:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.94	<5	7.6	54	18	12	0.1	0.02	6	0.9	0	Satisfactory
527	2080/10/22	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.1	51	16	16	0.1	0.02	6	0.4	0	Satisfactory
528	2080/10/22	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.28	<5	7.2	282	84	70	0.3	1.5	18	0.7	0	Satisfactory
529	2080/10/22	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.26	<5	7.2	277	84	68	0.3	1.5	16	0.7	0	Satisfactory
530	2080/10/22	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.01	<5	7.9	408	60	144	0.1	0.02	10	1.0	0	Satisfactory
531	2080/10/22	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.66	<5	7.1	65	18	20	0.1	0.02	4	0.5	0	Satisfactory
532	2080/10/22	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.74	<5	7.2	64	18	20	0.1	0.02	4	0.7	0	Satisfactory
533	2080/10/22	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	7.9	64	18	20	0.1	0.02	4	0.8	0	Satisfactory
534	2080/10/22	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	1.03	<5	7.6	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
535	2080/10/22	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.6	61	18	20	0.1	0.02	4	0.7	0	Satisfactory
536	2080/10/22	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.93	<5	7.9	61	18	20	0.1	0.02	4	0.2	0	Satisfactory
537	2080/10/22	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.40	<5	7.5	61	18	20	0.1	0.02	4	0.3	0	Satisfactory
538	2080/10/22	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.26	<5	7.4	69	22	32	0.1	0.02	4	0.1	0	Satisfactory
539	2080/10/22	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.37	<5	7.3	72	24	32	0.1	0.02	6	0.1	0	Satisfactory
540	2080/10/22	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.24	<5	7.1	73	24	32	0.1	0.02	6	0.6	0	Satisfactory
541	2080/10/22	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.52	<5	7.5	75.8	28	24	0.1	0.02	6	0.9	0	Satisfactory
542	2080/10/22	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.77	<5	7.5	74.3	26	22	0.1	0.02	6	0.9	0	Satisfactory
543	2080/10/22	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.48	<5	7.6	75.2	26	22	0.1	0.02	6	0.8	0	Satisfactory
544	2080/10/22	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.59	<5	7.5	77.2	26	30	0.1	0.02	4	0.8	0	Satisfactory
545	2080/10/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.99	<5	7.6	53	14	12	0.1	0.02	4	0.1	0	Satisfactory
546	2080/10/23	8:10	Bhaktapur	Katunje SRT	Treated	Clear	0.69	<5	7.6	75.8	26	22	0.1	0.02	6	0.4	0	Satisfactory
547	2080/10/23	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.97	<5	7.4	56	12	14	0.1	0.02	6	0.6	0	Satisfactory

548	2080/10/23	10:50	Baneshwor	Anamnagar SRT	Treated	Clear	0.90	<5	7.5	76.5	24	18	0.1	0.02	6	0.3	0	Satisfactory
549	2080/10/23	10:20	Baneshwor	Min Bhawan SRT	Treated	Clear	0.70	<5	7.6	72.7	26	20	0.1	0.02	6	0.2	0	Satisfactory
550	2080/10/23	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.95	<5	7.6	76	24	22	0.1	0.02	6	0.2	0	Satisfactory
551	2080/10/23	2:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	0.56	<5	7.6	76	16	22	0.1	0.02	6	0.9	0	Satisfactory
552	2080/10/23	3:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	3.36	<5	7.6	77	26	22	0.1	0.02	6	0.9	0	Satisfactory
553	2080/10/23	12:10	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.34	<5	7.4	44	14	12	0.1	0.02	6	0.3	0	Satisfactory
554	2080/10/23	11:35	Lalitpur	Khumaltar SRT	Treated	Clear	0.73	<5	7.7	75	24	20	0.1	0.02	6	0.1	0	Satisfactory
555	2080/10/23	10:45	Baneshwor	Anamnagar SRT	Treated	Clear	0.47	<5	7.5	73.3	24	20	0.1	0.02	6	0.1	0	Satisfactory
556	2080/10/23	11:00	Baneshwor	Min Bhawan SRT	Treated	Clear	0.72	<5	7.8	74.5	26	20	0.1	0.02	6	0.4	0	Satisfactory
557	2080/10/23	10:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.65	<5	7.7	76	26	20	0.1	0.02	6	0.1	0	Satisfactory
558	2080/10/23	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.1	57	18	18	0.1	0.02	6	0.4	0	Satisfactory
559	2080/10/23	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.03	<5	7.1	302	88	78	0.3	1.5	20	1.0	0	Satisfactory
560	2080/10/23	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.15	<5	7.2	289	86	76	0.3	1.5	20	1.0	0	Satisfactory
561	2080/10/23	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.14	<5	8.0	372	48	138	0.1	0.02	10	0.8	0	Satisfactory
562	2080/10/23	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	2.12	<5	7.4	63	18	20	0.1	0.02	4	0.5	0	Satisfactory
563	2080/10/23	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.7	63	18	20	0.1	0.02	4	0.5	0	Satisfactory
564	2080/10/23	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.51	<5	7.8	64	18	20	0.1	0.02	4	0.9	0	Satisfactory
565	2080/10/23	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.65	<5	7.9	61	18	20	0.1	0.02	4	0.9	0	Satisfactory
566	2080/10/23	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.87	<5	7.8	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
567	2080/10/23	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.90	<5	8.0	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
568	2080/10/23	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.60	<5	7.6	62	18	20	0.1	0.02	4	0.4	0	Satisfactory
569	2080/10/23	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.44	<5	7.3	67	22	30	0.1	0.02	4	0.1	0	Satisfactory
570	2080/10/23	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.72	<5	6.9	70	24	32	0.1	0.02	6	0.1	0	Satisfactory
571	2080/10/23	13:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.57	<5	6.9	72	24	32	0.1	0.02	6	0.1	0	Satisfactory
572	2080/10/23	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.62	<5	6.9	73	24	32	0.1	0.02	6	1.0	0	Satisfactory
573	2080/10/23	11:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.99	<5	7.4	74.4	24	22	0.1	0.02	6	1.0	0	Satisfactory
574	2080/10/23	12:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.54	<5	7.5	78.9	22	18	0.1	0.02	6	0.9	0	Satisfactory
575	2080/10/23	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.51	<5	7.7	74.8	28	22	0.1	0.02	6	0.6	0	Satisfactory
576	2080/10/23	3:00	Mahankalchaur	Melamchi Inlet	Treated	clear	2.00	<5	7.7	75.1	26	22	0.1	0.02	6	0.4	0	Satisfactory
577	2080/10/23	12:10	Mahankalchaur	Melamchi Inlet	Treated	clear	0.98	<5	7.6	77.4	24	22	0.1	0.02	6	0.9	0	Satisfactory
578	2080/10/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.20	<5	8.2	44	14	12	0.1	0.02	6	0.4	0	Satisfactory
579	2080/10/24	8:10	Bhaktapur	Katunje SRT	Treated	Clear	2.83	<5	7.8	75.0	26	22	0.1	0.02	6	0.5	0	Satisfactory
580	2080/10/24	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.83	<5	7.6	53	18	14	0.1	0.02	6	0.5	0	Satisfactory
581	2080/10/24	3:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.97	<5	7.7	54	16	14	0.1	0.02	4	0.5	0	Satisfactory
582	2080/10/24	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.1	55	16	16	0.1	0.02	6	0.4	0	Satisfactory
583	2080/10/24	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.46	<5	7.1	278	84	68	0.3	1.5	14	0.5	0	Satisfactory
584	2080/10/24	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.43	<5	7.1	274	84	68	0.3	1.5	16	0.5	0	Satisfactory
585	2080/10/24	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.01	<5	8.0	384	48	136	0.1	0.02	10	1.0	0	Satisfactory
586	2080/10/24	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.33	<5	8.0	62	18	20	0.1	0.02	4	0.9	0	Satisfactory
587	2080/10/24	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.81	<5	8.0	61	18	20	0.1	0.02	4	0.8	0	Satisfactory
588	2080/10/24	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.42	<5	7.8	63	18	20	0.1	0.02	4	0.9	0	Satisfactory
589	2080/10/24	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.58	<5	8.0	61	18	20	0.1	0.02	4	0.6	0	Satisfactory
590	2080/10/24	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	7.9	62	18	20	0.1	0.02	4	0.7	0	Satisfactory
591	2080/10/24	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.12	<5	7.3	68	22	30	0.1	0.02	4	0.1	0	Satisfactory
592	2080/10/24	3:30 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.15	<5	7.4	70	22	32	0.1	0.02	4	0.8	0	Satisfactory
593	2080/10/24	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.57	<5	7.2	72	24	32	0.1	0.02	6	0.9	0	Satisfactory
594	2080/10/24	10:30	Mahankalchaur	Melamchi Inlet	Treated	clear	1.14	<5	7.8	75	26	22	0.1	0.02	8	0.8	0	Satisfactory

595	2080/10/24	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.61	<5	7.5	74.5	26	32	0.1	0.02	6	0.6	0	Satisfactory
596	2080/10/24	3:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.96	<5	7.7	75.5	26	22	0.1	0.02	6	0.5	0	Satisfactory
597	2080/10/25	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.43	<5	7.6	49	14	14	0.1	0.02	6	0.3	0	Satisfactory
598	2080/10/25	10:00	Bhaktapur	Katunje SRT	Treated	Clear	0.46	<5	7.9	78.3	30	24	0.1	0.02	6	0.4	0	Satisfactory
599	2080/10/25	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.72	<5	7.8	76	28	22	0.1	0.02	6	0.2	0	Satisfactory
600	2080/10/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.9	50	18	16	0.1	0.02	6	0.5	0	Satisfactory
601	2080/10/25	12:30	Baneshwor	Min Bhawan SRT	Treated	Clear	0.98	<5	7.6	74.3	24	22	0.1	0.02	6	0.1	0	Satisfactory
602	2080/10/25	11:30	Chhetrapati	Balaju SRT	Treated	Clear	2.49	<5	7.9	88.4	36	26	0.1	0.02	6	0.1	0	Satisfactory
603	2080/10/25	12:15	Baneshwor	Anamnagar SRT	Treated	Clear	0.42	<5	7.9	73.1	30	28	0.1	0.02	6	0.1	0	Satisfactory
604	2080/10/25	1:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.68	<5	7.9	77	30	28	0.1	0.02	6	0.1	0	Satisfactory
605	2080/10/25	2:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.60	<5	7.6	44	14	12	0.1	0.02	6	0.4	0	Satisfactory
606	2080/10/25	3:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.80	<5	7.9	45	14	12	0.1	0.02	6	0.4	0	Satisfactory
607	2080/10/25	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.1	54	16	16	0.1	0.02	6	0.4	0	Satisfactory
608	2080/10/25	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.23	<5	7.1	267	80	64	0.3	1.5	12	0.1	0	Satisfactory
609	2080/10/25	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.20	<5	7.1	273	82	66	0.3	1.5	16	0.4	0	Satisfactory
610	2080/10/25	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.24	<5	7.8	406	60	142	0.1	0.02	10	0.9	0	Satisfactory
611	2080/10/25	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.41	<5	7.3	63	18	20	0.1	0.02	4	0.4	0	Satisfactory
612	2080/10/25	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.56	<5	7.8	63	18	20	0.1	0.02	4	0.4	0	Satisfactory
613	2080/10/25	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.57	<5	7.7	65	18	20	0.1	0.02	4	0.9	0	Satisfactory
614	2080/10/25	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.67	<5	7.8	71	22	20	0.1	0.02	4	0.9	0	Satisfactory
615	2080/10/25	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.93	<5	7.8	67	20	20	0.1	0.02	4	0.4	0	Satisfactory
616	2080/10/25	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.98	<5	7.9	71	22	20	0.1	0.02	4	0.8	0	Satisfactory
617	2080/10/25	17:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.90	<5	7.9	71	22	20	0.1	0.02	4	0.7	0	Satisfactory
618	2080/10/25	9:45 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.19	<5	7.4	69	22	32	0.1	0.02	4	0.1	0	Satisfactory
619	2080/10/25	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.68	<5	7.1	70	24	30	0.1	0.02	6	0.1	0	Satisfactory
620	2080/10/25	13:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.55	<5	7.1	72	24	32	0.1	0.02	6	0.1	0	Satisfactory
621	2080/10/25	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.43	<5	7.1	73	24	32	0.1	0.02	6	0.5	0	Satisfactory
622	2080/10/25	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.49	<5	7.8	76.6	28	22	0.1	0.02	6	0.4	0	Satisfactory
623	2080/10/25	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	1.10	<5	7.8	77.5	28	24	0.1	0.02	6	0.9	0	Satisfactory
624	2080/10/25	2:30	Mahankalchaur	Melamchi Inlet	Treated	clear	1.23	<5	7.5	74.6	24	22	0.1	0.02	6	0.7	0	Satisfactory
625	2080/10/25	3:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.41	<5	7.7	73.8	26	24	0.1	0.02	6	0.6	0	Satisfactory
626	2080/10/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.43	<5	7.6	42	14	12	0.1	0.02	6	0.5	0	Satisfactory
627	2080/10/26	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.10	<5	7.4	76	24	24	0.1	0.02	6	0.1	0	Satisfactory
628	2080/10/26	6:10	Bhaktapur	Katunje SRT	Treated	Clear	1.70	<5	7.5	75.9	26	24	0.1	0.02	6	0.8	0	Satisfactory
629	2080/10/26	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.53	<5	7.6	50.6	16	14	0.1	0.02	4	0.1	0	Satisfactory
630	2080/10/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.31	<5	7.5	39	16	10	0.1	0.02	4	0.6	0	Satisfactory
631	2080/10/26	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.68	<5	7.6	76	26	22	0.1	0.02	6	0.1	0	Satisfactory
632	2080/10/26	12:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.59	<5	7.7	79	26	22	0.1	0.02	6	0.4	0	Satisfactory
633	2080/10/26	11:00	Baneshwor	Anamnagar SRT	Treated	Clear	0.26	<5	7.8	73.1	28	20	0.1	0.02	6	0.4	0	Satisfactory
634	2080/10/26	11:45	Baneshwor	Min Bhawan SRT	Treated	Clear	0.37	<5	7.7	72.5	28	20	0.1	0.02	6	0.1	0	Satisfactory
635	2080/10/26	2:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.94	<5	7.6	40	14	12	0.1	0.02	6	0.5	0	Satisfactory
636	2080/10/26	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	6.9	56	18	16	0.1	0.02	6	0.3	0	Satisfactory
637	2080/10/26	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.57	<5	7.2	287	86	74	0.3	1.5	16	0.8	0	Satisfactory
638	2080/10/26	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.34	<5	7.9	408	60	140	0.1	0.02	10	0.9	0	Satisfactory
639	2080/10/26	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.46	<5	7.4	73	22	20	0.1	0.02	4	0.8	0	Satisfactory
640	2080/10/26	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	8.0	67	18	20	0.1	0.02	4	0.4	0	Satisfactory
641	2080/10/26	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.26	<5	7.8	69	18	20	0.1	0.02	4	0.7	0	Satisfactory

642	2080/10/26	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.9	68	18	20	0.1	0.02	4	0.9	0	Satisfactory
643	2080/10/26	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.8	70	18	20	0.1	0.02	4	0.7	0	Satisfactory
644	2080/10/26	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	8.0	70	18	20	0.1	0.02	4	0.7	0	Satisfactory
645	2080/10/26	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	7.1	69	24	30	0.1	0.02	6	0.1	0	Satisfactory
646	2080/10/26	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.48	<5	7.1	71	24	32	0.1	0.02	6	0.1	0	Satisfactory
647	2080/10/26	10:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.41	<5	7.2	75.2	24	26	0.1	0.02	6	0.9	0	Satisfactory
648	2080/10/26	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.98	<5	7.4	74	24	26	0.1	0.02	6	0.9	0	Satisfactory
649	2080/10/26	2:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.99	<5	7.7	72.8	26	22	0.1	0.02	6	0.2	0	Satisfactory
650	2080/10/27	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.73	<5	7.8	42	14	12	0.1	0.02	6	0.7	0	Satisfactory
651	2080/10/27	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.46	<5	7.8	82	28	24	0.1	0.02	6	0.4	0	Satisfactory
652	2080/10/27	10:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.40	<5	7.5	77	26	24	0.1	0.02	6	0.4	0	Satisfactory
653	2080/10/27	10:00	Baneshwor	Min Bhawan SRT	Treated	Clear	0.17	<5	7.5	73.6	28	24	0.1	0.02	6	0.3	0	Satisfactory
654	2080/10/27	10:00	Chhetrapati	Balaju SRT	Treated	Clear	0.36	<5	7.8	75.6	18	14	0.1	0.02	6	0.2	0	Satisfactory
655	2080/10/27	10:00	Baneshwor	Anamnagar SRT	Treated	Clear	0.33	<5	7.7	51.5	26	22	0.1	0.02	6	0.4	0	Satisfactory
656	2080/10/27	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	6.9	53	16	16	0.1	0.02	6	0.3	0	Satisfactory
657	2080/10/27	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.61	<5	7.2	72	18	20	0.1	0.02	4	0.5	0	Satisfactory
658	2080/10/27	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.53	<5	7.3	72	18	20	0.1	0.02	4	0.4	0	Satisfactory
659	2080/10/27	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.44	<5	7.7	71	18	20	0.1	0.02	4	0.9	0	Satisfactory
660	2080/10/27	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.48	<5	7.8	70	18	20	0.1	0.02	4	0.5	0	Satisfactory
661	2080/10/27	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.39	<5	7.8	69	18	20	0.1	0.02	4	0.7	0	Satisfactory
662	2080/10/27	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.43	<5	7.7	70	18	20	0.1	0.02	4	0.7	0	Satisfactory
663	2080/10/27	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.38	<5	7.1	72	24	32	0.1	0.02	6	0.5	0	Satisfactory
664	2080/10/27	10:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.36	<5	7.8	76.4	28	24	0.1	0.02	6	0.9	0	Satisfactory
665	2080/10/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.8	65	14	12	0.1	0.02	6	0.6	0	Satisfactory
666	2080/10/28	10:30	Baneshwor	Min Bhawan SRT	Treated	Clear	0.66	<5	7.9	76.3	26	20	0.1	0.02	6	0.2	0	Satisfactory
667	2080/10/28	10:30	Baneshwor	Anamnagar SRT	Treated	Clear	0.58	<5	8.0	75.8	26	20	0.1	0.02	6	0.4	0	Satisfactory
668	2080/10/28	10:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.68	<5	8.0	83	26	24	0.1	0.02	6	0.3	0	Satisfactory
669	2080/10/28	10:30	Bhaktapur	Katunje SRT	Treated	Clear	0.53	<5	7.6	77.4	24	20	0.1	0.02	6	0.1	0	Satisfactory
670	2080/10/28	10:30	Bhaktapur	Katunje SRT	Treated	Clear	1.37	<5	7.6	77.3	24	20	0.1	0.02	6	0.1	0	Satisfactory
671	2080/10/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.8	67	22	16	0.1	0.02	6	0.7	0	Satisfactory
672	2080/10/28	2:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.8	64	16	14	0.1	0.02	6	0.9	0	Satisfactory
673	2080/10/28	3:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.71	<5	7.8	54	18	14	0.1	0.02	6	0.9	0	Satisfactory
674	2080/10/28	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	6.9	57	18	18	0.1	0.02	6	0.4	0	Satisfactory
675	2080/10/28	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.43	<5	7.2	291	86	76	0.3	1.5	14	0.6	0	Satisfactory
676	2080/10/28	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.42	<5	7.2	283	86	72	0.3	1.5	14	0.4	0	Satisfactory
677	2080/10/28	10:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.83	<5	7.9	410	62	142	0.1	0.02	10	1.0	0	Satisfactory
678	2080/10/28	6:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.54	<5	7.5	70	18	20	0.1	0.02	4	0.5	0	Satisfactory
679	2080/10/28	8:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.59	<5	7.3	71	18	20	0.1	0.02	4	0.4	0	Satisfactory
680	2080/10/28	10:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.8	72	18	20	0.1	0.02	4	0.9	0	Satisfactory
681	2080/10/28	12:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.78	<5	7.8	71	18	20	0.1	0.02	4	0.7	0	Satisfactory
682	2080/10/28	14:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.52	<5	7.8	73	18	20	0.1	0.02	4	0.9	0	Satisfactory
683	2080/10/28	16:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.70	<5	7.9	71	18	20	0.1	0.02	4	0.8	0	Satisfactory
684	2080/10/28	18:00	Sundarijal	Sundarijal WTP	Treated	Clear	0.47	<5	7.6	71	18	20	0.1	0.02	4	0.8	0	Satisfactory
685	2080/10/28	11:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.44	<5	7.5	69	22	32	0.1	0.02	4	0.1	0	Satisfactory
686	2080/10/28	11:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.54	<5	7.1	70	24	30	0.1	0.02	6	0.1	0	Satisfactory
687	2080/10/28	13:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.47	<5	6.9	70	24	30	0.1	0.02	6	0.1	0	Satisfactory
688	2080/10/28	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.83	<5	6.9	72	24	32	0.1	0.02	6	0.7	0	Satisfactory

689	2080/10/28	10:30	Mahankalchaur	Melamchi Inlet	Treated	clear	1.11	<5	7.8	77.5	24	20	0.1	0.02	6	0.4	0	Satisfactory
690	2080/10/28	12:00	Mahankalchaur	Melamchi Inlet	Treated	clear	0.93	<5	7.7	74.4	28	24	0.1	0.02	6	0.9	0	Satisfactory
691	2080/10/28	2:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.72	<5	7.4	54.6	24	20	0.1	0.02	6	0.5	0	Satisfactory
692	2080/10/28	3:15	Mahankalchaur	Melamchi Inlet	Treated	clear	1.08	<5	7.6	74.5	26	24	0.1	0.02	6	0.5	0	Satisfactory
693	2080/10/29	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.4	42	14	14	0.1	0.02	6	0.1	0	Satisfactory
694	2080/10/29	10:00	Bhaktapur	Katunje SRT	Treated	Clear	0.35	<5	7.4	78.0	24	14	0.1	0.02	6	0.4	0	Satisfactory
695	2080/10/29	10:00	Mahankalchaur	Melamchi Inlet	Treated	Clear	1.22	<5	7.5	69.6	16	24	0.1	0.02	6	0.6	0	Satisfactory
696	2080/10/29	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.66	<5	7.5	46	16	12	0.1	0.02	6	0.7	0	Satisfactory
697	2080/10/29	1:20	Chhetrapati	Balaju SRT	Treated	Clear	0.22	<5	7.8	76.0	18	14	0.1	0.02	8	0.1	0	Satisfactory
698	2080/10/29	11:50	Baneshwor	Min Bhawan SRT	Treated	Clear	0.83	<5	8.1	74.1	30	22	0.1	0.02	6	0.1	0	Satisfactory
699	2080/10/29	11:30	Baneshwor	Anamnagar SRT	Treated	Clear	0.58	<5	8.1	74.5	30	22	0.1	0.02	6	0.2	0	Satisfactory
700	2080/10/29	12:20	Bhaktapur	Khumaltar SRT	Treated	Clear	0.52	<5	8.3	111	34	28	0.1	0.02	6	0.2	0	Satisfactory
701	2080/10/29	2:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.71	<5	7.8	57	18	12	0.1	0.02	6	1.0	0	Satisfactory
702	2080/10/29	3:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.84	<5	8.0	56	20	16	0.1	0.02	4	0.3	0	Satisfactory
703	2080/10/29	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.65	<5	7.8	76	28	22	0.1	0.02	6	0.1	0	Satisfactory
704	2080/10/29	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	6.9	58	18	18	0.1	0.02	6	0.4	0	Satisfactory
705	2080/10/29	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.53	<5	7.2	289	86	76	0.3	1.5	14	1.0	0	Satisfactory
706	2080/10/29	8:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.34	<5	7.5	69	22	32	0.1	0.02	4	0.2	0	Satisfactory
707	2080/10/29	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.66	<5	7.1	70	24	30	0.1	0.02	6	0.1	0	Satisfactory
708	2080/10/29	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.78	<5	7.1	72	24	30	0.1	0.02	6	0.5	0	Satisfactory
709	2080/10/29	12:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.56	<5	7.1	73.5	28	24	0.1	0.02	4	0.6	0	Satisfactory
710	2080/10/29	2:30	Mahankalchaur	Melamchi Inlet	Treated	clear	0.77	<5	7.7	76.4	26	20	0.1	0.02	6	0.7	0	Satisfactory
711	2080/10/29	3:30	Mahankalchaur	Melamchi Inlet	Treated	clear	1.15	<5	7.8	74.8	28	22	0.1	0.02	4	0.4	0	Satisfactory