



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
 Chaitra 2080

S.No.	Date	Time	Branch	Sampling Location	Sample type	Appearance	Turbidity	Colour	p ^H	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
							(NTU)	(TCU)		µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml	
National Drinking Water Quality Standard (NDWQS)							5	5.00	6.5-8.5	1500		500.0	0.3(3)	1.5	250.0	0.1-0.5 at tap	0 in 95% Samples	
1	2080/12/01	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.0	61	20	22	0.1	0.02	6	0.5	0	Satisfactory
2	2080/12/01	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.3	75	24	32	0.1	0.02	6	0.2	0	Satisfactory
3	2080/12/01	13:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.4	76	24	32	0.1	0.02	6	0.4	0	Satisfactory
4	2080/12/01	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.24	<5	6.8	321	86	76	0.8	1.5	20	0.8	0	Satisfactory
5	2080/12/01	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.84	<5	7.2	167	42	52	0.3	1.5	12	0.7	0	Satisfactory
6	2080/12/01	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.29	<5	7.3	86	24	36	0.1	0.02	4	0.4	0	Satisfactory
7	2080/12/01	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.13	<5	7.6	52.6	18	14	0.1	0.02	4	0.2	0	Satisfactory
8	2080/12/01	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.61	<5	7.8	54.2	22	12	0.1	0.02	4	0.5	0	Satisfactory
9	2080/12/01	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.68	<5	7.7	56.3	22	16	0.1	0.02	4	0.5	0	Satisfactory
10	2080/12/01	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.94	<5	7.6	71.4	18	14	0.1	0.02	4	0.8	0	Satisfactory
11	2080/12/01	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.41	<5	7.6	90.7	26	32	0.1	0.02	6	0.2	0	Satisfactory
12	2080/12/01	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	7.7	92.2	28	26	0.1	0.02	6	0.2	0	Satisfactory
13	2080/12/01	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.98	<5	7.8	93.5	28	26	0.1	0.02	4	0.3	0	Satisfactory
14	2080/12/01	16:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.87	<5	7.6	92.3	26	24	0.1	0.02	4	0.5	0	Satisfactory
15	2080/12/01	10:30	Bhaktapur	Katunje SRT	Treated	Clear	2.1	<5	7.4	92.4	26	24	0.1	0.02	4	0.5	0	Satisfactory
16	2080/12/01	11:00	Baneshwor	Min Bhawan SRT	Treated	Clear	0.5	<5	7.7	91.5	28	26	0.1	0.02	4	0.3	0	Satisfactory
17	2080/12/01	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.95	<5	7.7	94.5	28	26	0.1	0.02	6	0.3	0	Satisfactory
18	2080/12/01	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.38	<5	7.8	92.7	28	26	0.1	0.02	4	0.4	0	Satisfactory
19	2080/12/02	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.1	64	24	28	0.1	0.02	6	0.5	0	Satisfactory
20	2080/12/02	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.4	75	24	32	0.1	0.02	6	0.9	0	Satisfactory
21	2080/12/02	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.3	74	24	32	0.1	0.02	6	0.2	0	Satisfactory
22	2080/12/02	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.14	<5	7.1	298	88	72	0.6	1.5	14	0.2	0	Satisfactory
23	2080/12/02	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.21	<5	7.3	87.3	24	36	0.1	0.02	4	0.4	0	Satisfactory
24	2080/12/02	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.82	<5	7.3	56.1	16	14	0.1	0.02	4	0.3	0	Satisfactory
25	2080/12/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.5	53.7	20	14	0.1	0.02	4	0.6	0	Satisfactory
26	2080/12/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.84	<5	7.4	56.7	16	14	0.1	0.02	4	0.2	0	Satisfactory
27	2080/12/02	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.74	<5	7.5	53.9	24	20	0.1	0.02	4	0.5	0	Satisfactory
28	2080/12/02	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.92	<5	7.3	58.4	24	20	0.1	0.02	4	0.6	0	Satisfactory
29	2080/12/02	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.5	90.1	26	28	0.1	0.02	6	0.6	0	Satisfactory
30	2080/12/02	7:45	Bhaktapur	Katunje SRT	Treated	Clear	1.35	<5	7.4	43.9	28	14	0.1	0.02	4	0.2	0	Satisfactory
31	2080/12/02	11:15	Baneshwor	Min Bhawan SRT	Treated	Clear	0.66	<5	7.7	87.4	28	26	0.1	0.02	4	0.5	0	Satisfactory

32	2080/12/02	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.64	<5	7.6	93.1	26	24	0.1	0.02	4	0.5	0	Satisfactory
33	2080/12/02	13:05	Maharajgunj	Balaju SRT	Treated	Clear	1.53	<5	7.6	94.4	26	28	0.1	0.02	4	0.2	0	Satisfactory
34	2080/12/02	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.95	<5	7.8	92.7	28	26	0.1	0.02	6	0.3	0	Satisfactory
35	2080/12/02	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.94	<5	8.0	421	94	138	0.1	0.02	8	0.9	0	Satisfactory
36	2080/12/02	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.62	<5	7.6	94.8	26	28	0.1	0.02	4	0.1	0	Satisfactory
37	2080/12/03	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.3	75	24	32	0.1	0.02	6	0.6	0	Satisfactory
38	2080/12/03	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.1	57	18	18	0.1	0.02	6	0.5	0	Satisfactory
39	2080/12/03	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.4	75	24	32	0.1	0.02	6	0.4	0	Satisfactory
40	2080/12/03	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.88	<5	7.8	59.2	20	14	0.1	0.02	4	0.3	0	Satisfactory
41	2080/12/03	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.8	93.3	28	26	0.1	0.02	4	0.3	0	Satisfactory
42	2080/12/03	7:25	Bhaktapur	Katunje SRT	Treated	Clear	0.63	<5	7.6	96.1	26	28	0.1	0.02	4	0.5	0	Satisfactory
43	2080/12/03	12:20	Baneshwor	Min Bhawan SRT	Treated	Clear	0.45	<5	7.8	91.7	30	26	0.1	0.02	4	0.3	0	Satisfactory
44	2080/12/03	12:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.54	<5	7.8	93.4	30	26	0.1	0.02	4	0.8	0	Satisfactory
45	2080/12/03	13:35	Maharajgunj	Balaju SRT	Treated	Clear	0.76	<5	7.8	94.1	28	26	0.1	0.02	4	0.9	0	Satisfactory
46	2080/12/03	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.1	<5	7.9	95.2	30	26	0.1	0.02	6	0.3	0	Satisfactory
47	2080/12/03	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	1.03	<5	7.9	94.6	30	26	0.1	0.02	4	0.5	0	Satisfactory
48	2080/12/04	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	7.1	60	22	26	0.1	0.02	6	0.5	0	Satisfactory
49	2080/12/04	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.4	75	24	32	0.1	0.02	6	0.4	0	Satisfactory
50	2080/12/04	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.13	<5	6.8	316	84	68	0.6	1.5	12	0.2	0	Satisfactory
51	2080/12/04	12:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.38	<5	7.3	89.1	24	36	0.1	0.02	4	0.4	0	Satisfactory
52	2080/12/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.75	<5	7.3	51.6	16	14	0.1	0.02	4	0.4	0	Satisfactory
53	2080/12/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.55	<5	7.4	55.6	26	12	0.1	0.02	4	0.7	0	Satisfactory
54	2080/12/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.3	55.4	18	16	0.1	0.02	4	0.8	0	Satisfactory
55	2080/12/04	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.43	<5	7.6	56	18	16	0.1	0.02	4	0.8	0	Satisfactory
56	2080/12/04	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.51	<5	7.4	89.4	24	26	0.1	0.02	4	0.4	0	Satisfactory
57	2080/12/04	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.62	<5	7.5	91.8	26	24	0.1	0.02	4	0.7	0	Satisfactory
58	2080/12/04	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.01	<5	7.3	90.8	24	28	0.1	0.02	4	0.7	0	Satisfactory
59	2080/12/04	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.5	92.4	26	28	0.1	0.02	4	0.7	0	Satisfactory
60	2080/12/04	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.3	93.1	24	26	0.1	0.02	4	0.2	0	Satisfactory
61	2080/12/04	9:00	Baneshwor	Min Bhawan SRT	Treated	Clear	1.16	<5	7.6	90.5	28	24	0.1	0.02	4	0.7	0	Satisfactory
62	2080/12/04	8:45	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.5	92.1	26	28	0.1	0.02	6	0.9	0	Satisfactory
63	2080/12/04	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.6	93.5	26	28	0.1	0.02	6	0.4	0	Satisfactory
64	2080/12/04	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.52	<5	8.2	375	64	138	0.1	0.02	8	1.0	0	Satisfactory
65	2080/12/05	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.1	61	22	24	0.1	0.02	6	0.5	0	Satisfactory
66	2080/12/05	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.3	75	24	32	0.1	0.02	6	0.4	0	Satisfactory
67	2080/12/05	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.5	77	24	32	0.1	0.02	6	0.8	0	Satisfactory
68	2080/12/05	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.81	<5	6.8	352	86	76	0.6	1.5	16	0.3	0	Satisfactory
69	2080/12/05	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.21	<5	7.4	91	24	36	0.1	0.02	4	0.1	0	Satisfactory
70	2080/12/05	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.49	<5	7.6	56	16	14	0.1	0.02	4	0.9	0	Satisfactory
71	2080/12/05	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	8.0	58.2	22	20	0.1	0.02	4	0.8	0	Satisfactory
72	2080/12/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.8	57.2	20	14	0.1	0.02	6	0.5	0	Satisfactory
73	2080/12/05	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.15	<5	7.9	65.7	26	14	0.1	0.02	4	0.4	0	Satisfactory
74	2080/12/05	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.96	<5	7.4	88.5	24	26	0.1	0.02	4	0.6	0	Satisfactory
75	2080/12/05	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.86	<5	7.5	92.2	26	24	0.1	0.02	4	0.4	0	Satisfactory
76	2080/12/05	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.92	<5	7.8	93.5	28	26	0.1	0.02	6	0.5	0	Satisfactory
77	2080/12/05	16:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.51	<5	7.9	91.7	30	28	0.1	0.02	6	0.3	0	Satisfactory

78	2080/12/05	7:32	Bhaktapur	Katunje SRT	Treated	Clear	3.34	<5	7.4	85.7	26	24	0.1	0.02	4	0.6	0	Satisfactory
79	2080/12/05	12:10	Baneshwor	Min Bhawan SRT	Treated	Clear	0.72	<5	7.8	90.5	30	26	0.1	0.02	4	0.3	0	Satisfactory
80	2080/12/05	11:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.51	<5	7.8	90.3	28	26	0.1	0.02	4	0.2	0	Satisfactory
81	2080/12/05	11:10	Maharajgunj	Balaju SRT	Treated	Clear	0.27	<5	7.7	90.7	28	26	0.1	0.02	4	0.5	0	Satisfactory
82	2080/12/05	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.95	<5	7.5	92.3	26	28	0.1	0.02	6	0.3	0	Satisfactory
83	2080/12/05	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.31	<5	7.9	431	100	140	0.1	0.02	10	0.9	0	Satisfactory
84	2080/12/05	13:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.37	<5	7.8	92.5	28	26	0.1	0.02	4	0.3	0	Satisfactory
85	2080/12/06	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	7.1	63	22	24	0.1	0.02	6	0.5	0	Satisfactory
86	2080/12/06	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.4	76	24	32	0.1	0.02	6	0.7	0	Satisfactory
87	2080/12/06	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.4	77	26	32	0.1	0.02	6	0.4	0	Satisfactory
88	2080/12/06	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.63	<5	6.8	362	86	78	0.6	1.5	16	0.5	0	Satisfactory
89	2080/12/06	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.97	<5	7.0	217	50	52	0.3	1.5	12	0.3	0	Satisfactory
90	2080/12/06	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.13	<5	7.4	88.5	24	36	0.1	0.02	4	0.4	0	Satisfactory
91	2080/12/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.23	<5	7.6	58.2	20	12	0.1	0.02	4	0.7	0	Satisfactory
92	2080/12/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.82	<5	7.8	57.9	22	12	0.1	0.02	4	0.9	0	Satisfactory
93	2080/12/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.22	<5	7.8	54.5	18	12	0.1	0.02	4	0.7	0	Satisfactory
94	2080/12/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.86	<5	7.9	55.2	26	14	0.1	0.02	4	0.5	0	Satisfactory
95	2080/12/06	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.85	<5	7.7	91.5	28	26	0.1	0.02	4	0.7	0	Satisfactory
96	2080/12/06	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.04	<5	7.8	92.6	30	28	0.1	0.02	6	0.4	0	Satisfactory
97	2080/12/06	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.33	<5	7.7	92.2	28	26	0.1	0.02	4	0.8	0	Satisfactory
98	2080/12/06	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.73	<5	7.8	94.2	30	28	0.1	0.02	4	0.6	0	Satisfactory
99	2080/12/06	9:30	Bhaktapur	Katunje SRT	Treated	Clear	1.64	<5	8.0	96.8	30	28	0.1	0.02	6	0.6	0	Satisfactory
100	2080/12/06	11:25	Baneshwor	Min Bhawan SRT	Treated	Clear	0.51	<5	7.2	92.6	22	28	0.1	0.02	4	0.5	0	Satisfactory
101	2080/12/06	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.54	<5	7.3	93.4	24	28	0.1	0.02	4	0.6	0	Satisfactory
102	2080/12/06	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.8	95.3	28	26	0.1	0.02	6	0.3	0	Satisfactory
103	2080/12/06	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.12	<5	7.8	427	96	140	0.1	0.02	10	0.8	0	Satisfactory
104	2080/12/06	12:05	Lalitpur	Khumaltar SRT	Treated	Clear	1.15	<5	7.7	97.2	28	30	0.1	0.02	4	0.2	0	Satisfactory
105	2080/12/07	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.7	66	24	28	0.1	0.02	6	0.5	0	Satisfactory
106	2080/12/07	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.3	76	24	32	0.1	0.02	6	0.4	0	Satisfactory
107	2080/12/07	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.1	75	24	32	0.1	0.02	6	0.6	0	Satisfactory
108	2080/12/07	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.68	<5	6.8	363	86	78	0.6	1.5	16	0.9	0	Satisfactory
109	2080/12/07	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.35	<5	7.0	374	90	78	0.8	1.5	16	0.4	0	Satisfactory
110	2080/12/07	15:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.24	<5	7.5	87.8	24	36	0.1	0.02	4	0.4	0	Satisfactory
111	2080/12/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.6	75.4	18	16	0.1	0.02	4	0.5	0	Satisfactory
112	2080/12/07	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.73	<5	7.3	53.4	16	14	0.1	0.02	4	0.4	0	Satisfactory
113	2080/12/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.78	<5	7.8	55.3	16	14	0.1	0.02	4	0.5	0	Satisfactory
114	2080/12/07	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.28	<5	7.7	53.7	16	12	0.1	0.02	4	0.1	0	Satisfactory
115	2080/12/07	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.68	<5	7.6	90.8	16	30	0.1	0.02	4	0.6	0	Satisfactory
116	2080/12/07	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.0	90.3	20	30	0.1	0.02	4	0.5	0	Satisfactory
117	2080/12/07	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.43	<5	7.8	91.7	28	30	0.1	0.02	4	0.7	0	Satisfactory
118	2080/12/07	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.49	<5	7.7	93.1	28	32	0.1	0.02	4	0.5	0	Satisfactory
119	2080/12/07	7:20	Bhaktapur	Katunje SRT	Treated	Clear	0.94	<5	7.5	92.4	26	28	0.1	0.02	4	0.6	0	Satisfactory
120	2080/12/07	12:30	Baneshwor	Min Bhawan SRT	Treated	Clear	0.43	<5	7.6	92.1	26	32	0.1	0.02	4	0.4	0	Satisfactory
121	2080/12/07	13:40	Baneshwor	Min Bhawan SRT	Treated	Clear	1.05	<5	7.7	94.7	30	32	0.1	0.02	4	0.1	0	Satisfactory
122	2080/12/07	12:45	Tripureshwar	Anamnagar SRT	Treated	Clear	0.32	<5	8.0	91.8	30	32	0.1	0.02	4	0.5	0	Satisfactory
123	2080/12/07	13:00	Maharajgunj	Balaju SRT	Treated	Clear	1.41	<5	7.8	93.6	30	28	0.1	0.02	4	0.8	0	Satisfactory
124	2080/12/07	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.7	98.5	28	30	0.1	0.02	4	0.2	0	Satisfactory

125	2080/12/07	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.32	<5	8.0	436	98	140	0.1	0.02	10	0.8	0	Satisfactory
126	2080/12/07	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.52	<5	7.7	92.9	28	32	0.1	0.02	4	0.5	0	Satisfactory
127	2080/12/08	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.1	63	22	26	0.1	0.02	6	0.4	0	Satisfactory
128	2080/12/08	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.4	75	24	32	0.1	0.02	6	0.2	0	Satisfactory
129	2080/12/08	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.1	74	24	32	0.1	0.02	6	0.3	0	Satisfactory
130	2080/12/08	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.12	<5	6.8	330	84	70	0.8	1.5	16	0.5	0	Satisfactory
131	2080/12/08	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.82	<5	6.9	229	50	56	0.3	1.5	12	0.1	0	Satisfactory
132	2080/12/08	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.18	<5	7.5	87.4	24	36	0.1	0.02	4	0.2	0	Satisfactory
133	2080/12/08	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.57	<5	7.6	58.3	16	14	0.1	0.02	4	0.6	0	Satisfactory
134	2080/12/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.59	<5	7.6	58	18	14	0.1	0.02	4	0.5	0	Satisfactory
135	2080/12/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.88	<5	7.7	59.2	16	14	0.1	0.02	4	0.6	0	Satisfactory
136	2080/12/08	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.33	<5	7.9	59.2	16	14	0.1	0.02	4	0.2	0	Satisfactory
137	2080/12/08	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.73	<5	7.7	94.7	28	32	0.1	0.02	4	0.6	0	Satisfactory
138	2080/12/08	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.77	<5	7.7	95.4	28	34	0.1	0.02	4	0.7	0	Satisfactory
139	2080/12/08	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.29	<5	7.7	94.6	28	30	0.1	0.02	4	0.8	0	Satisfactory
140	2080/12/08	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	8.0	91.6	30	28	0.1	0.02	4	0.5	0	Satisfactory
141	2080/12/08	7:30	Bhaktapur	Katunje SRT	Treated	Clear	1.07	<5	7.5	104.5	32	42	0.1	0.02	4	0.6	0	Satisfactory
142	2080/12/08	11:05	Baneshwor	Min Bhawan SRT	Treated	Clear	0.56	<5	7.8	94.4	28	30	0.1	0.02	4	0.3	0	Satisfactory
143	2080/12/08	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.53	<5	7.4	94	24	32	0.1	0.02	4	0.4	0	Satisfactory
144	2080/12/08	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.75	<5	7.8	95.5	30	32	0.1	0.02	4	0.3	0	Satisfactory
145	2080/12/08	12:00	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.0	431	96	138	0.1	0.02	10	1.0	0	Satisfactory
146	2080/12/09	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.7	<5	7.1	67	24	28	0.1	0.02	6	0.5	0	Satisfactory
147	2080/12/09	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.1	<5	7.2	75	24	32	0.1	0.02	6	0.5	0	Satisfactory
148	2080/12/09	11:30	Maharajgunj	Panipokhari SRT	Treated	Clear	1.2	<5	7.1	78	26	34	0.1	0.02	6	0.5	0	Satisfactory
149	2080/12/09	13:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.9	<5	7.2	76	24	32	0.1	0.02	6	0.6	0	Satisfactory
150	2080/12/09	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.31	<5	6.7	332	84	70	0.8	1.5	12	0.2	0	Satisfactory
151	2080/12/09	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.39	<5	6.9	222	50	54	0.3	1.5	12	0.2	0	Satisfactory
152	2080/12/09	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.12	<5	7.3	88.3	24	36	0.1	0.02	4	0.2	0	Satisfactory
153	2080/12/09	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	7.7	61.5	18	16	0.1	0.02	4	0.2	0	Satisfactory
154	2080/12/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.89	<5	7.3	54.8	16	14	0.1	0.02	4	0.2	0	Satisfactory
155	2080/12/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.59	<5	8.0	57.3	20	14	0.1	0.02	4	0.6	0	Satisfactory
156	2080/12/09	10:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.9	94.6	30	34	0.1	0.02	4	0.4	0	Satisfactory
157	2080/12/09	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.6	90.2	26	30	0.1	0.02	4	0.2	0	Satisfactory
158	2080/12/09	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.43	<5	7.9	93.1	30	28	0.1	0.02	4	0.8	0	Satisfactory
159	2080/12/09	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.52	<5	7.9	97.7	30	24	0.1	0.02	4	0.4	0	Satisfactory
160	2080/12/09	11:40	Baneshwor	Min Bhawan SRT	Treated	Clear	0.59	<5	7.7	94.6	28	32	0.1	0.02	4	0.8	0	Satisfactory
161	2080/12/09	11:25	Tripureshwar	Anamnagar SRT	Treated	Clear	1.61	<5	7.4	92.9	20	30	0.1	0.02	4	0.4	0	Satisfactory
162	2080/12/09	8:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.8	95.2	24	20	0.1	0.02	4	0.3	0	Satisfactory
163	2080/12/09	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.29	<5	7.9	440	100	142	0.1	0.02	12	0.9	0	Satisfactory
164	2080/12/09	12:25	Lalitpur	Khumaltar SRT	Treated	Clear	1.16	<5	7.6	92.1	26	30	0.1	0.02	4	0.8	0	Satisfactory
165	2080/12/10	9:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.5	76	24	32	0.1	0.02	6	0.6	0	Satisfactory
166	2080/12/10	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	7.1	61	22	24	0.1	0.02	6	0.5	0	Satisfactory
167	2080/12/10	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.4	77	24	32	0.1	0.02	6	0.5	0	Satisfactory
168	2080/12/10	14:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.2	77.2	14	16	0.1	0.02	4	0.8	0	Satisfactory
169	2080/12/10	14:15	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.67	<5	7.4	93.3	24	28	0.1	0.02	4	0.5	0	Satisfactory
170	2080/12/10	9:30	Bhaktapur	Katunje SRT	Treated	Clear	1.09	<5	7.8	99.1	28	30	0.1	0.02	4	0.8	0	Satisfactory
171	2080/12/10	9:30	Baneshwor	Min Bhawan SRT	Treated	Clear	0.62	<5	7.4	93.3	24	32	0.1	0.02	4	0.7	0	Satisfactory

172	2080/12/10	9:45	Tripureshwar	Anamnagar SRT	Treated	Clear	1.03	<5	7.4	96	24	32	0.1	0.02	4	0.8	0	Satisfactory
173	2080/12/10	12:20	Maharajgunj	Balaju SRT	Treated	Clear	0.86	<5	7.7	94.4	28	26	0.1	0.02	4	0.7	0	Satisfactory
174	2080/12/10	9:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	7.8	95.4	28	26	0.1	0.02	4	0.4	0	Satisfactory
175	2080/12/11	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.4	75	24	32	0.1	0.02	6	0.7	0	Satisfactory
176	2080/12/11	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.1	60	22	24	0.1	0.02	6	0.5	0	Satisfactory
177	2080/12/11	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.4	76	24	32	0.1	0.02	6	0.5	0	Satisfactory
178	2080/12/11	8:28	Bhaktapur	Katunje SRT	Treated	Clear	1.52	<5	7.5	100.7	26	30	0.1	0.02	4	0.4	0	Satisfactory
179	2080/12/12	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.3	76	24	32	0.1	0.02	6	0.7	0	Satisfactory
180	2080/12/12	10:55	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.3	78	26	34	0.1	0.02	6	0.6	0	Satisfactory
181	2080/12/12	11:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.1	49	18	20	0.1	0.02	6	0.3	0	Satisfactory
182	2080/12/12	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.3	75	24	32	0.1	0.02	6	0.2	0	Satisfactory
183	2080/12/12	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.23	<5	6.8	337	84	70	0.8	1.5	16	0.5	0	Satisfactory
184	2080/12/12	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.97	<5	6.8	238	52	56	0.6	1.5	12	0.3	0	Satisfactory
185	2080/12/12	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.08	<5	7.5	91	24	36	0.1	0.02	4	0.2	0	Satisfactory
186	2080/12/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.64	<5	7.7	94.1	20	18	0.1	0.02	4	0.1	0	Satisfactory
187	2080/12/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.78	<5	7.7	78.1	22	20	0.1	0.02	4	0.2	0	Satisfactory
188	2080/12/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.78	<5	7.5	84.2	18	14	0.1	0.02	4	0.3	0	Satisfactory
189	2080/12/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.43	<5	7.7	85.8	20	18	0.1	0.02	4	0.3	0	Satisfactory
190	2080/12/12	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.15	<5	7.7	94.1	28	26	0.1	0.02	4	0.1	0	Satisfactory
191	2080/12/12	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.72	<5	7.9	91.3	30	28	0.1	0.02	4	0.2	0	Satisfactory
192	2080/12/12	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.82	<5	7.8	93.1	28	26	0.1	0.02	4	0.4	0	Satisfactory
193	2080/12/12	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.76	<5	7.9	93.1	30	28	0.1	0.02	4	0.6	0	Satisfactory
194	2080/12/12	7:00	Bhaktapur	Katunje SRT	Treated	Clear	3.71	<5	7.2	96.9	22	28	0.1	0.02	4	0.7	0	Satisfactory
195	2080/12/12	12:00	Baneshwor	Min Bhawan SRT	Treated	Clear	0.68	<5	7.5	91.8	26	28	0.1	0.02	4	0.4	0	Satisfactory
196	2080/12/12	12:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.6	92.9	26	28	0.1	0.02	4	0.6	0	Satisfactory
197	2080/12/12	12:45	Maharajgunj	Balaju SRT	Treated	Clear	0.63	<5	7.6	93.7	26	28	0.1	0.02	4	0.8	0	Satisfactory
198	2080/12/12	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.82	<5	8.2	424	98	140	0.1	0.02	10	0.8	0	Satisfactory
199	2080/12/12	11:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.69	<5	7.6	93.2	26	28	0.1	0.02	4	0.3	0	Satisfactory
200	2080/12/13	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.4	76	24	32	0.1	0.02	6	0.6	0	Satisfactory
201	2080/12/13	13:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.1	70	24	28	0.1	0.02	6	0.5	0	Satisfactory
202	2080/12/13	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	1.3	<5	7.3	77	24	32	0.1	0.02	6	0.3	0	Satisfactory
203	2080/12/13	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.44	<5	6.8	321	84	68	0.8	1.5	12	0.3	0	Satisfactory
204	2080/12/13	15:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.76	<5	7.1	91.6	24	36	0.1	0.02	4	0.7	0	Satisfactory
205	2080/12/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	8.0	58.8	16	14	0.3	0.02	4	0.8	0	Satisfactory
206	2080/12/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.6	70.8	16	14	0.1	0.02	4	0.8	0	Satisfactory
207	2080/12/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.1	92	12	14	0.1	0.02	4	0.3	0	Satisfactory
208	2080/12/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.3	97.5	14	16	0.1	0.02	4	0.8	0	Satisfactory
209	2080/12/13	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.77	<5	8.0	94	30	28	0.1	0.02	4	0.4	0	Satisfactory
210	2080/12/13	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.7	93.4	28	26	0.1	0.02	4	0.5	0	Satisfactory
211	2080/12/13	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.71	<5	7.6	93.4	28	32	0.1	0.02	4	0.7	0	Satisfactory
212	2080/12/13	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.7	92.6	28	32	0.1	0.02	4	0.4	0	Satisfactory
213	2080/12/13	6:30	Bhaktapur	Katunje SRT	Treated	Clear	0.73	<5	7.9	95.7	30	32	0.1	0.02	4	0.5	0	Satisfactory
214	2080/12/13	11:15	Baneshwor	Min Bhawan SRT	Treated	Clear	1.07	<5	7.8	97.6	30	32	0.1	0.02	4	0.8	0	Satisfactory
215	2080/12/13	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	1.01	<5	7.9	95.5	30	32	0.1	0.02	4	0.9	0	Satisfactory
216	2080/12/13	12:00	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.0	437	100	144	0.1	0.02	12	0.8	0	Satisfactory
217	2080/12/13	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	1.8	<5	7.8	100.6	30	32	0.1	0.02	4	0.4	0	Satisfactory
218	2080/12/14	9:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.1	64	22	26	0.1	0.02	6	0.3	0	Satisfactory

219	2080/12/14	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.4	79	26	32	0.1	0.02	6	0.7	0	Satisfactory
220	2080/12/14	15:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.5	77	26	32	0.1	0.02	6	0.6	0	Satisfactory
221	2080/12/14	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.29	<5	6.8	317	84	68	0.8	1.5	10	0.8	0	Satisfactory
222	2080/12/14	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.54	<5	7.2	90.8	24	36	0.1	0.02	4	0.2	0	Satisfactory
223	2080/12/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.55	<5	7.1	69.3	12	14	0.1	0.02	4	0.2	0	Satisfactory
224	2080/12/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.76	<5	6.8	66.2	18	14	0.1	0.02	4	0.4	0	Satisfactory
225	2080/12/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.54	<5	7.2	69.5	14	16	0.1	0.02	4	0.4	0	Satisfactory
226	2080/12/14	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.3	72.7	12	14	0.1	0.02	4	0.2	0	Satisfactory
227	2080/12/14	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.87	<5	7.5	94.3	16	14	0.1	0.02	4	0.3	0	Satisfactory
228	2080/12/14	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.93	<5	7.6	93.5	26	28	0.1	0.02	4	0.3	0	Satisfactory
229	2080/12/14	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.62	<5	7.6	94.3	26	28	0.1	0.02	4	0.5	0	Satisfactory
230	2080/12/14	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.41	<5	7.7	96.6	28	32	0.1	0.02	4	0.5	0	Satisfactory
231	2080/12/14	7:20	Bhaktapur	Katunje SRT	Treated	Clear	1.27	<5	7.6	98.3	28	26	0.1	0.02	4	0.3	0	Satisfactory
232	2080/12/14	11:25	Baneshwor	Min Bhawan SRT	Treated	Clear	0.92	<5	7.3	95.4	22	34	0.1	0.02	4	0.3	0	Satisfactory
233	2080/12/14	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	1.11	<5	7.5	97.3	26	34	0.1	0.02	4	0.5	0	Satisfactory
234	2080/12/14	13:25	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.5	95.4	26	34	0.1	0.02	4	0.6	0	Satisfactory
235	2080/12/14	13:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.65	<5	7.8	96.2	28	32	0.1	0.02	4	0.8	0	Satisfactory
236	2080/12/14	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.71	<5	8.3	396	96	140	0.1	0.02	8	0.9	0	Satisfactory
237	2080/12/14	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.65	<5	7.6	95.5	28	34	0.1	0.02	4	0.8	0	Satisfactory
238	2080/12/15	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.1	60	22	24	0.1	0.02	6	0.3	0	Satisfactory
239	2080/12/15	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	2.4	<5	7.5	82	26	34	0.1	0.02	6	0.3	0	Satisfactory
240	2080/12/15	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	2.2	<5	7.5	81	26	34	0.1	0.02	6	0.5	0	Satisfactory
241	2080/12/15	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.35	<5	6.8	315	82	68	0.8	1.5	10	0.8	0	Satisfactory
242	2080/12/15	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.31	<5	6.8	331	84	70	0.8	1.5	10	0.4	0	Satisfactory
243	2080/12/15	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	5	<5	7.1	95.8	24	38	0.1	0.02	4	0.2	0	Satisfactory
244	2080/12/15	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.0	52.5	12	16	0.1	0.02	4	0.1	0	Satisfactory
245	2080/12/15	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.19	<5	6.9	49.8	12	10	0.1	0.02	4	0.5	0	Satisfactory
246	2080/12/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.32	<5	7.2	52.3	14	16	0.1	0.02	4	0.3	0	Satisfactory
247	2080/12/15	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.0	56.6	16	14	0.1	0.02	4	0.6	0	Satisfactory
248	2080/12/15	10:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	4.66	<5	7.3	81.5	24	26	0.1	0.02	4	0.1	0	Satisfactory
249	2080/12/15	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.87	<5	7.3	82.3	24	28	0.1	0.02	4	0.4	0	Satisfactory
250	2080/12/15	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.38	<5	7.5	84.3	26	24	0.1	0.02	4	0.7	0	Satisfactory
251	2080/12/15	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	4.18	<5	7.4	83.6	24	26	0.1	0.02	4	0.6	0	Satisfactory
252	2080/12/15	7:30	Bhaktapur	Katunje SRT	Treated	Clear	1.42	<5	7.5	81.1	26	28	0.1	0.02	4	0.3	0	Satisfactory
253	2080/12/15	11:10	Baneshwor	Min Bhawan SRT	Treated	Clear	2.16	<5	7.3	84.7	24	26	0.1	0.02	4	0.2	0	Satisfactory
254	2080/12/15	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	2.66	<5	7.1	86.6	22	24	0.1	0.02	4	0.5	0	Satisfactory
255	2080/12/15	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.92	<5	7.8	95.8	28	26	0.1	0.02	4	0.8	0	Satisfactory
256	2080/12/15	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	8.1	444	100	140	0.1	0.02	12	0.7	0	Satisfactory
257	2080/12/15	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	2.34	<5	7.4	85.9	24	26	0.1	0.02	4	0.7	0	Satisfactory
258	2080/12/16	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	2.3	<5	7.6	79	26	34	0.1	0.02	6	0.5	0	Satisfactory
259	2080/12/16	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.1	65	22	26	0.1	0.02	6	0.4	0	Satisfactory
260	2080/12/16	13:30	Maharajgunj	Panipokhari SRT	Treated	Clear	1.9	<5	7.4	78	26	34	0.1	0.02	6	0.4	0	Satisfactory
261	2080/12/16	14:05	Maharajgunj	Bansbari SRT	Treated	Clear	1.9	<5	7.5	77	26	34	0.1	0.02	6	0.4	0	Satisfactory
262	2080/12/16	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.17	<5	6.9	332	86	72	0.8	1.5	16	0.7	0	Satisfactory
263	2080/12/16	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.18	<5	6.8	331	86	72	0.8	1.5	16	0.5	0	Satisfactory
264	2080/12/16	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.46	<5	7.2	92.9	24	38	0.1	0.02	4	0.3	0	Satisfactory
265	2080/12/16	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.93	<5	7.9	42.9	14	12	0.1	0.02	4	0.2	0	Satisfactory

266	2080/12/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.18	<5	7.4	46.7	14	12	0.1	0.02	4	0.4	0	Satisfactory
267	2080/12/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.35	<5	7.4	47.5	14	16	0.1	0.02	4	0.5	0	Satisfactory
268	2080/12/16	10:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.98	<5	7.8	79.5	28	26	0.1	0.02	4	0.2	0	Satisfactory
269	2080/12/16	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.11	<5	7.6	80.5	26	24	0.1	0.02	4	0.6	0	Satisfactory
270	2080/12/16	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.04	<5	7.7	81.1	28	26	0.1	0.02	4	0.4	0	Satisfactory
271	2080/12/16	8:30	Bhaktapur	Katunje SRT	Treated	Clear	2.11	<5	7.7	86.6	28	26	0.1	0.02	4	0.4	0	Satisfactory
272	2080/12/16	12:15	Baneshwor	Min Bhawan SRT	Treated	Clear	1.1	<5	7.8	83.1	28	26	0.1	0.02	4	0.6	0	Satisfactory
273	2080/12/16	12:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.55	<5	7.9	82.3	28	26	0.1	0.02	4	0.7	0	Satisfactory
274	2080/12/16	11:30	Maharajgunj	Balaju SRT	Treated	Clear	1.34	<5	7.6	84.4	26	24	0.1	0.02	4	0.6	0	Satisfactory
275	2080/12/16	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.35	<5	7.5	86.5	26	28	0.1	0.02	4	0.1	0	Satisfactory
276	2080/12/16	12:00	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.2	420	98	138	0.1	0.02	12	1.0	0	Satisfactory
277	2080/12/16	13:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.73	<5	7.5	87.5	24	26	0.1	0.02	4	0.2	0	Satisfactory
278	2080/12/17	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.1	62	22	24	0.1	0.02	6	0.4	0	Satisfactory
279	2080/12/17	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.4	79	26	34	0.1	0.02	6	0.4	0	Satisfactory
280	2080/12/17	13:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.6	69.3	16	14	0.1	0.02	4	0.2	0	Satisfactory
281	2080/12/17	13:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.8	79.6	28	24	0.1	0.02	4	0.4	0	Satisfactory
282	2080/12/17	8:44	Bhaktapur	Katunje SRT	Treated	Clear	3.04	<5	7.3	85.9	24	22	0.1	0.02	4	0.3	0	Satisfactory
283	2080/12/17	13:30	Baneshwor	Min Bhawan SRT	Treated	Clear	2.06	<5	7.7	80.7	28	26	0.1	0.02	4	0.7	0	Satisfactory
284	2080/12/17	13:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.68	<5	7.7	81.3	28	26	0.1	0.02	4	0.5	0	Satisfactory
285	2080/12/17	11:20	Kirtipur	Kirtipur SRT	Treated	Clear	2.17	<5	7.5	84.6	26	24	0.1	0.02	4	0.3	0	Satisfactory
286	2080/12/17	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.6	83.6	26	24	0.1	0.02	4	0.2	0	Satisfactory
287	2080/12/17	13:30	Lalitpur	Khumaltar SRT	Treated	Clear	1.85	<5	7.4	82.5	24	26	0.1	0.02	4	0.4	0	Satisfactory
288	2080/12/18	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.5	76	26	32	0.1	0.02	6	0.5	0	Satisfactory
289	2080/12/18	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.1	64	22	26	0.1	0.02	6	0.4	0	Satisfactory
290	2080/12/18	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	1.0	<5	7.5	77	26	34	0.1	0.02	6	0.3	0	Satisfactory
291	2080/12/18	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.93	<5	6.8	373	86	78	0.8	1.5	16	0.8	0	Satisfactory
292	2080/12/18	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.18	<5	6.9	197	54	52	0.3	1.5	14	0.5	0	Satisfactory
293	2080/12/18	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.06	<5	7.1	89.6	24	38	0.1	0.02	4	0.2	0	Satisfactory
294	2080/12/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.55	<5	7.3	52.1	12	14	0.1	0.02	4	0.3	0	Satisfactory
295	2080/12/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.93	<5	7.3	53.7	14	16	0.1	0.02	4	0.4	0	Satisfactory
296	2080/12/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.64	<5	7.4	50.1	14	16	0.1	0.02	4	0.2	0	Satisfactory
297	2080/12/18	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.68	<5	7.5	54.5	14	16	0.1	0.02	4	0.3	0	Satisfactory
298	2080/12/18	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.85	<5	7.5	78.4	26	24	0.1	0.02	4	0.4	0	Satisfactory
299	2080/12/18	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.41	<5	7.6	78.1	26	24	0.1	0.02	4	0.5	0	Satisfactory
300	2080/12/18	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.15	<5	7.5	77.9	26	24	0.1	0.02	4	0.5	0	Satisfactory
301	2080/12/18	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.49	<5	7.6	78.5	26	24	0.1	0.02	4	0.6	0	Satisfactory
302	2080/12/18	10:30	Bhaktapur	Katunje SRT	Treated	Clear	2.65	<5	7.5	85.1	26	24	0.1	0.02	4	0.3	0	Satisfactory
303	2080/12/18	12:05	Baneshwor	Min Bhawan SRT	Treated	Clear	1.23	<5	7.4	78.5	24	22	0.1	0.02	4	0.3	0	Satisfactory
304	2080/12/18	11:50	Tripureshwar	Anamnagar SRT	Treated	Clear	1.82	<5	7.3	79.2	24	22	0.1	0.02	4	0.4	0	Satisfactory
305	2080/12/18	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.53	<5	8.1	425	98	136	0.1	0.02	12	0.7	0	Satisfactory
306	2080/12/18	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	2.24	<5	7.4	81.1	26	24	0.1	0.02	4	0.2	0	Satisfactory
307	2080/12/19	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	2.9	<5	7.1	63	22	26	0.1	0.02	6	0.3	0	Satisfactory
308	2080/12/19	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.6	77	26	34	0.1	0.02	6	0.9	0	Satisfactory
309	2080/12/19	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.5	79	26	34	0.1	0.02	6	0.5	0	Satisfactory
310	2080/12/19	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.6	77	26	34	0.1	0.02	6	0.5	0	Satisfactory
311	2080/12/19	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.3	<5	6.7	355	84	76	0.8	1.5	16	0.2	0	Satisfactory
312	2080/12/19	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.14	<5	6.9	205	48	54	0.3	1.5	14	0.3	0	Satisfactory

313	2080/12/19	14:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.82	<5	7.4	87.9	24	38	0.1	0.02	4	0.2	0	Satisfactory
314	2080/12/19	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.58	<5	6.5	79.6	10	16	0.1	0.02	4	0.2	0	Satisfactory
315	2080/12/19	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.35	<5	6.7	83.5	12	18	0.1	0.02	4	0.2	0	Satisfactory
316	2080/12/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.21	<5	6.5	79.8	8	18	0.1	0.02	4	0.4	0	Satisfactory
317	2080/12/19	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.23	<5	6.5	85	10	18	0.1	0.02	4	0.4	0	Satisfactory
318	2080/12/19	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.43	<5	7.3	77.9	24	26	0.1	0.02	4	0.2	0	Satisfactory
319	2080/12/19	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.85	<5	7.5	88.9	26	28	0.1	0.02	4	0.2	0	Satisfactory
320	2080/12/19	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.06	<5	7.3	78.2	26	24	0.1	0.02	4	0.2	0	Satisfactory
321	2080/12/19	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.13	<5	7.4	79.2	24	22	0.1	0.02	4	0.2	0	Satisfactory
322	2080/12/19	8:15	Bhaktapur	Katunje SRT	Treated	Clear	1.77	<5	7.5	80.8	26	28	0.1	0.02	4	0.3	0	Satisfactory
323	2080/12/19	12:50	Baneshwor	Min Bhawan SRT	Treated	Clear	1.55	<5	7.5	79.5	24	26	0.1	0.02	4	0.1	0	Satisfactory
324	2080/12/19	11:40	Baneshwor	Min Bhawan SRT	Treated	Clear	1.46	<5	7.5	83.1	26	24	0.1	0.02	4	0.2	0	Satisfactory
325	2080/12/19	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	1.5	<5	7.4	79.3	24	26	0.1	0.02	4	0.4	0	Satisfactory
326	2080/12/19	11:25	Tripureshwar	Anamnagar SRT	Treated	Clear	0.92	<5	7.6	84.5	26	24	0.1	0.02	4	0.3	0	Satisfactory
327	2080/12/19	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.85	<5	7.5	82.5	26	28	0.1	0.02	4	0.2	0	Satisfactory
328	2080/12/19	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	8.0	441	98	140	0.1	0.02	12	0.8	0	Satisfactory
329	2080/12/19	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	1.14	<5	7.5	80.5	24	26	0.1	0.02	4	0.2	0	Satisfactory
330	2080/12/19	12:25	Lalitpur	Khumaltar SRT	Treated	Clear	1.27	<5	7.6	88.1	26	24	0.1	0.02	4	0.2	0	Satisfactory
331	2080/12/20	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	1.9	<5	7.1	65	22	26	0.1	0.02	6	0.4	0	Satisfactory
332	2080/12/20	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.5	76	24	32	0.1	0.02	6	0.2	0	Satisfactory
333	2080/12/20	15:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.6	77	24	32	0.1	0.02	6	0.3	0	Satisfactory
334	2080/12/20	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.61	<5	6.8	324	84	72	1.0	1.5	14	0.2	0	Satisfactory
335	2080/12/20	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.3	<5	6.9	218	50	54	1.0	1.5	14	0.3	0	Satisfactory
336	2080/12/20	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.0	91.2	24	38	0.1	0.02	4	0.3	0	Satisfactory
337	2080/12/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.94	<5	7.1	56	12	14	0.1	0.02	4	0.2	0	Satisfactory
338	2080/12/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.52	<5	6.9	61.9	10	16	0.1	0.02	4	0.2	0	Satisfactory
339	2080/12/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.74	<5	7.1	61.6	12	18	0.1	0.02	4	0.4	0	Satisfactory
340	2080/12/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.56	<5	6.9	80.8	10	14	0.1	0.02	4	1.0	0	Satisfactory
341	2080/12/20	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.67	<5	7.6	79.4	26	24	0.1	0.02	4	0.6	0	Satisfactory
342	2080/12/20	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.85	<5	7.5	80.9	26	24	0.1	0.02	4	0.4	0	Satisfactory
343	2080/12/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.04	<5	7.6	82.2	26	28	0.1	0.02	4	0.3	0	Satisfactory
344	2080/12/20	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.28	<5	7.4	74.4	24	22	0.1	0.02	4	0.4	0	Satisfactory
345	2080/12/20	10:30	Bhaktapur	Katunje SRT	Treated	Clear	1.61	<5	7.7	80.1	28	32	0.1	0.02	6	0.3	0	Satisfactory
346	2080/12/20	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.5	82.8	26	24	0.1	0.02	4	0.2	0	Satisfactory
347	2080/12/20	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	8.1	407	96	132	0.1	0.02	8	0.8	0	Satisfactory
348	2080/12/21	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.5	78	26	34	0.1	0.02	6	0.6	0	Satisfactory
349	2080/12/21	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.1	64	22	24	0.1	0.02	6	0.4	0	Satisfactory
350	2080/12/21	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.6	75	24	32	0.1	0.02	6	0.2	0	Satisfactory
351	2080/12/21	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.77	<5	6.8	342	84	74	1.0	1.5	18	0.8	0	Satisfactory
352	2080/12/21	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.1	90.8	24	38	0.1	0.02	4	0.3	0	Satisfactory
353	2080/12/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.93	<5	7.2	55.3	12	16	0.1	0.02	4	0.8	0	Satisfactory
354	2080/12/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.58	<5	7.3	54	20	16	0.1	0.02	4	0.9	0	Satisfactory
355	2080/12/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.69	<5	7.2	57	20	18	0.1	0.02	4	0.2	0	Satisfactory
356	2080/12/21	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.72	<5	7.6	78.4	32	18	0.1	0.02	4	0.2	0	Satisfactory
357	2080/12/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.29	<5	7.4	79	24	28	0.1	0.02	4	0.5	0	Satisfactory
358	2080/12/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.32	<5	7.5	79.7	26	24	0.1	0.02	4	0.7	0	Satisfactory
359	2080/12/21	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.65	<5	7.5	79.7	26	24	0.1	0.02	4	0.4	0	Satisfactory

360	2080/12/21	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.34	<5	7.3	78.4	24	26	0.1	0.02	4	0.4	0	Satisfactory
361	2080/12/21	8:15	Bhaktapur	Katunje SRT	Treated	Clear	1.57	<5	8.0	86.3	30	28	0.1	0.02	6	0.5	0	Satisfactory
362	2080/12/21	14:50	Baneshwor	Min Bhawan SRT	Treated	Clear	0.98	<5	7.6	79.6	26	28	0.1	0.02	4	0.3	0	Satisfactory
363	2080/12/21	14:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.29	<5	7.5	80.5	26	28	0.1	0.02	4	0.6	0	Satisfactory
364	2080/12/21	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.02	<5	7.7	87.7	28	26	0.1	0.02	4	0.8	0	Satisfactory
365	2080/12/21	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.22	<5	8.3	419	100	138	0.1	0.02	12	1.0	0	Satisfactory
366	2080/12/22	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.1	64	22	26	0.1	0.02	6	0.3	0	Satisfactory
367	2080/12/22	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.4	75	24	32	0.1	0.02	6	0.8	0	Satisfactory
368	2080/12/22	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.6	75	24	32	0.1	0.02	6	0.4	0	Satisfactory
369	2080/12/22	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.59	<5	6.8	334	84	74	1.0	1.5	14	0.8	0	Satisfactory
370	2080/12/22	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.07	<5	6.8	194	40	48	0.1	1.5	12	0.8	0	Satisfactory
371	2080/12/22	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.67	<5	7.1	88.6	24	38	0.1	0.02	4	0.2	0	Satisfactory
372	2080/12/22	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.3	<5	7.9	47.7	18	16	0.1	0.02	4	0.4	0	Satisfactory
373	2080/12/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.33	<5	7.2	49.3	12	14	0.1	0.02	4	0.8	0	Satisfactory
374	2080/12/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.3	51.9	20	18	0.1	0.02	4	0.4	0	Satisfactory
375	2080/12/22	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.4	<5	7.3	51.7	26	18	0.1	0.02	4	0.8	0	Satisfactory
376	2080/12/22	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.1	<5	8.3	78.9	34	26	0.1	0.02	4	0.4	0	Satisfactory
377	2080/12/22	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.88	<5	7.7	78.2	18	26	0.1	0.02	4	0.6	0	Satisfactory
378	2080/12/22	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.31	<5	7.7	77.6	28	26	0.1	0.02	4	0.4	0	Satisfactory
379	2080/12/22	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.25	<5	7.5	77.3	26	24	0.1	0.02	4	0.7	0	Satisfactory
380	2080/12/22	7:00	Bhaktapur	Katunje SRT	Treated	Clear	1.46	<5	7.5	80.6	30	28	0.1	0.02	4	0.7	0	Satisfactory
381	2080/12/22	10:55	Baneshwor	Min Bhawan SRT	Treated	Clear	1.42	<5	7.4	77.5	26	24	0.1	0.02	4	0.7	0	Satisfactory
382	2080/12/22	10:35	Tripureshwar	Anamnagar SRT	Treated	Clear	2.16	<5	7.5	78.1	26	24	0.1	0.02	4	0.9	0	Satisfactory
383	2080/12/22	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.12	<5	7.8	80.2	28	26	0.1	0.02	4	0.2	0	Satisfactory
384	2080/12/22	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.56	<5	8.0	431	102	134	0.1	0.02	10	0.8	0	Satisfactory
385	2080/12/22	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	2.55	<5	7.5	79	26	24	0.1	0.02	4	0.3	0	Satisfactory
386	2080/12/23	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.1	65	22	26	0.1	0.02	6	0.4	0	Satisfactory
387	2080/12/23	11:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.6	74	24	32	0.1	0.02	6	0.7	0	Satisfactory
388	2080/12/23	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.9	75	24	32	0.1	0.02	6	0.2	0	Satisfactory
389	2080/12/23	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.25	<5	6.8	330	80	74	1.0	1.5	16	0.8	0	Satisfactory
390	2080/12/23	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.81	<5	7.2	91.2	24	38	0.1	0.02	4	0.1	0	Satisfactory
391	2080/12/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.57	<5	7.5	48.7	16	14	0.1	0.02	4	0.3	0	Satisfactory
392	2080/12/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.05	<5	7.3	50.8	16	18	0.1	0.02	4	0.3	0	Satisfactory
393	2080/12/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.63	<5	7.1	54.6	12	16	0.1	0.02	4	0.5	0	Satisfactory
394	2080/12/23	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.68	<5	7.6	53.2	22	18	0.1	0.02	4	0.7	0	Satisfactory
395	2080/12/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.49	<5	7.5	76.4	26	24	0.1	0.02	4	0.4	0	Satisfactory
396	2080/12/23	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.27	<5	7.6	79.1	26	24	0.1	0.02	4	0.7	0	Satisfactory
397	2080/12/23	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.74	<5	7.7	79.7	28	24	0.1	0.02	4	0.3	0	Satisfactory
398	2080/12/23	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.73	<5	7.0	79.3	20	26	0.1	0.02	4	0.6	0	Satisfactory
399	2080/12/23	7:15	Bhaktapur	Katunje SRT	Treated	Clear	2.19	<5	7.5	79.2	24	26	0.1	0.02	4	0.5	0	Satisfactory
400	2080/12/23	10:15	Baneshwor	Min Bhawan SRT	Treated	Clear	2.71	<5	7.3	81	24	26	0.1	0.02	4	0.7	0	Satisfactory
401	2080/12/23	13:20	Baneshwor	Min Bhawan SRT	Treated	Clear	1.47	<5	7.4	81.2	24	26	0.1	0.02	4	0.3	0	Satisfactory
402	2080/12/23	10:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.69	<5	7.5	79.1	26	24	0.1	0.02	4	0.7	0	Satisfactory
403	2080/12/23	13:35	Tripureshwar	Anamnagar SRT	Treated	Clear	1.38	<5	8.0	80.6	24	26	0.1	0.02	4	0.6	0	Satisfactory
404	2080/12/23	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.5	<5	7.5	78.2	26	24	0.1	0.02	4	0.4	0	Satisfactory
405	2080/12/23	12:00	Lalitpur	Sainbu WTP	Treated	Clear	1.74	<5	8.2	427	100	138	0.1	0.02	10	0.6	0	Satisfactory
406	2080/12/23	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	1.63	<5	7.3	81.6	24	26	0.1	0.02	4	0.4	0	Satisfactory

407	2080/12/24	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.1	64	22	24	0.1	0.02	6	0.5	0	Satisfactory
408	2080/12/24	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.5	77	24	32	0.1	0.02	6	0.6	0	Satisfactory
409	2080/12/24	6:45	Bhaktapur	Katunje SRT	Treated	Clear	1.55	<5	7.2	80	24	26	0.1	0.02	4	0.4	0	Satisfactory
410	2080/12/24	7:15	Bhaktapur	Katunje SRT	Treated	Clear	1.73	<5	7.5	79.6	26	24	0.1	0.02	4	0.6	0	Satisfactory
411	2080/12/25	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.5	70	24	28	0.1	0.02	6	0.5	0	Satisfactory
412	2080/12/25	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.7	76	24	32	0.1	0.02	6	0.6	0	Satisfactory
413	2080/12/25	13:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.2	<5	7.6	77	24	32	0.1	0.02	6	0.5	0	Satisfactory
414	2080/12/25	15:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	6.9	76	24	32	0.1	0.02	6	0.2	0	Satisfactory
415	2080/12/25	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.19	<5	6.7	282	78	66	1.0	1.5	12	0.8	0	Satisfactory
416	2080/12/25	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.72	<5	6.9	210.7	46	52	1.0	1.5	10	0.8	0	Satisfactory
417	2080/12/25	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.68	<5	7.2	89.9	24	38	0.1	0.02	4	0.8	0	Satisfactory
418	2080/12/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.84	<5	7.5	52.9	22	18	0.1	0.02	4	0.5	0	Satisfactory
419	2080/12/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.06	<5	7.5	53.8	16	14	0.1	0.02	4	0.3	0	Satisfactory
420	2080/12/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.74	<5	7.5	55.4	18	16	0.1	0.02	4	0.7	0	Satisfactory
421	2080/12/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.32	<5	7.6	55.2	22	14	0.1	0.02	4	0.6	0	Satisfactory
422	2080/12/25	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.14	<5	7.5	76.3	26	24	0.1	0.02	4	0.8	0	Satisfactory
423	2080/12/25	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.32	<5	7.3	79.4	24	26	0.1	0.02	4	0.8	0	Satisfactory
424	2080/12/25	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.92	<5	7.7	83.6	28	24	0.1	0.02	4	0.2	0	Satisfactory
425	2080/12/25	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.21	<5	7.6	84.4	28	26	0.1	0.02	4	0.2	0	Satisfactory
426	2080/12/25	11:20	Baneshwor	Min Bhawan SRT	Treated	Clear	0.92	<5	7.7	78.4	28	24	0.1	0.02	4	0.7	0	Satisfactory
427	2080/12/25	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	1.5	<5	7.7	79.9	28	24	0.1	0.02	4	0.8	0	Satisfactory
428	2080/12/25	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.2	<5	7.4	82.6	24	26	0.1	0.02	4	0.3	0	Satisfactory
429	2080/12/25	12:00	Lalitpur	Sainbu WTP	Treated	Clear	1.54	<5	8.2	443	104	140	0.1	0.02	12	0.8	0	Satisfactory
430	2080/12/25	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.55	<5	7.7	80.8	28	24	0.1	0.02	4	0.3	0	Satisfactory
431	2080/12/26	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.5	67	24	26	0.1	0.02	6	0.5	0	Satisfactory
432	2080/12/26	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.7	76	24	32	0.1	0.02	6	0.5	0	Satisfactory
433	2080/12/26	13:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.52	<5	7.6	57.4	16	14	0.1	0.02	4	0.5	0	Satisfactory
434	2080/12/26	13:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.97	<5	7.7	85.2	28	24	0.1	0.02	4	0.6	0	Satisfactory
435	2080/12/26	7:55	Bhaktapur	Katunje SRT	Treated	Clear	2.18	<5	7.5	78.3	26	24	0.1	0.02	4	0.2	0	Satisfactory
436	2080/12/26	10:25	Baneshwor	Min Bhawan SRT	Treated	Clear	1.49	<5	7.5	82.1	26	24	0.1	0.02	4	0.3	0	Satisfactory
437	2080/12/26	10:40	Tripureshwar	Anamnagar SRT	Treated	Clear	1.4	<5	7.6	83.8	26	24	0.1	0.02	4	0.5	0	Satisfactory
438	2080/12/26	10:40	Maharajgunj	Balaju SRT	Treated	Clear	2.61	<5	7.6	84.5	26	24	0.1	0.02	4	0.6	0	Satisfactory
439	2080/12/26	8:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.05	<5	7.7	84.2	28	24	0.1	0.02	4	0.3	0	Satisfactory
440	2080/12/26	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.7	83.2	28	24	0.1	0.02	4	0.3	0	Satisfactory
441	2080/12/27	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.5	70	24	28	0.1	0.02	6	0.5	0	Satisfactory
442	2080/12/27	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.6	76	24	32	0.1	0.02	6	0.7	0	Satisfactory
443	2080/12/27	11:35	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.4	75	24	32	0.1	0.02	6	0.5	0	Satisfactory
444	2080/12/27	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.6	77	24	32	0.1	0.02	6	0.5	0	Satisfactory
445	2080/12/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.4	59.7	16	14	0.1	0.02	4	0.8	0	Satisfactory
446	2080/12/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.18	<5	7.5	60.2	16	14	0.1	0.02	4	0.6	0	Satisfactory
447	2080/12/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.65	<5	7.6	63.2	18	16	0.1	0.02	4	0.3	0	Satisfactory
448	2080/12/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.01	<5	7.3	59.6	14	16	0.1	0.02	4	0.9	0	Satisfactory
449	2080/12/27	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.68	<5	7.6	79.7	26	24	0.1	0.02	4	0.5	0	Satisfactory
450	2080/12/27	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.32	<5	7.6	79.7	26	24	0.1	0.02	4	0.5	0	Satisfactory
451	2080/12/27	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.15	<5	7.8	80.5	28	24	0.1	0.02	4	0.4	0	Satisfactory
452	2080/12/27	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.31	<5	7.6	79.6	26	24	0.1	0.02	4	0.6	0	Satisfactory
453	2080/12/27	7:12	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.7	82.8	28	24	0.1	0.02	4	0.1	0	Satisfactory

454	2080/12/27	11:35	Baneshwor	Min Bhawan SRT	Treated	Clear	1.14	<5	7.5	79.2	26	24	0.1	0.02	4	0.3	0	Satisfactory
455	2080/12/27	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.97	<5	7.5	80.1	26	24	0.1	0.02	4	0.4	0	Satisfactory
456	2080/12/27	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.1	<5	7.7	84.5	28	24	0.1	0.02	4	0.3	0	Satisfactory
457	2080/12/27	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	8.0	430	104	130	0.1	0.02	10	0.2	0	Satisfactory
458	2080/12/28	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.5	63	22	26	0.1	0.02	6	0.3	0	Satisfactory
459	2080/12/28	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.6	77	24	32	0.1	0.02	6	0.4	0	Satisfactory
460	2080/12/28	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	4.8	<5	7.6	76	24	32	0.1	0.02	6	0.3	0	Satisfactory
461	2080/12/28	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.69	<5	6.8	345	84	72	1.0	1.5	14	0.2	0	Satisfactory
462	2080/12/28	11:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.13	<5	7.4	89.7	24	38	0.1	0.02	4	0.1	0	Satisfactory
463	2080/12/28	11:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.34	<5	7.5	60.5	16	14	0.1	0.02	4	0.7	0	Satisfactory
464	2080/12/28	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.26	<5	7.4	60.8	14	16	0.1	0.02	4	0.7	0	Satisfactory
465	2080/12/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.6	54.1	16	14	0.1	0.02	4	0.5	0	Satisfactory
466	2080/12/28	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.32	<5	8.1	75.8	20	14	0.1	0.02	4	0.4	0	Satisfactory
467	2080/12/28	8:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.98	<5	7.8	67.9	20	14	0.1	0.02	4	0.2	0	Satisfactory
468	2080/12/28	11:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.04	<5	7.7	80.4	28	24	0.1	0.02	4	0.5	0	Satisfactory
469	2080/12/28	12:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.45	<5	7.7	80.3	28	24	0.1	0.02	4	0.5	0	Satisfactory
470	2080/12/28	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.34	<5	7.8	76.9	28	24	0.1	0.02	4	0.5	0	Satisfactory
471	2080/12/28	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.45	<5	8.1	78.6	32	24	0.1	0.02	4	0.6	0	Satisfactory
472	2080/12/28	7:20	Bhaktapur	Katunje SRT	Treated	Clear	0.93	<5	7.4	79.3	24	22	0.1	0.02	4	0.5	0	Satisfactory
473	2080/12/28	9:00	Baneshwor	Min Bhawan SRT	Treated	Clear	1.76	<5	7.6	80.2	26	24	0.1	0.02	4	1.0	0	Satisfactory
474	2080/12/28	9:20	Tripureshwar	Anamnagar SRT	Treated	Clear	1.22	<5	7.5	81.8	26	24	0.1	0.02	4	0.8	0	Satisfactory
475	2080/12/28	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.55	<5	7.6	82.1	26	24	0.1	0.02	4	0.3	0	Satisfactory
476	2080/12/28	12:00	Lalitpur	Sainbu WTP	Treated	Clear	0.41	<5	8.1	426	104	130	0.1	0.02	8	0.2	0	Satisfactory
477	2080/12/29	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.5	65	24	26	0.1	0.02	6	0.4	0	Satisfactory
478	2080/12/29	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.4	<5	7.7	76	24	32	0.1	0.02	6	0.4	0	Satisfactory
479	2080/12/29	8:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.25	<5	7.8	87.8	28	24	0.1	0.02	4	0.5	0	Satisfactory
480	2080/12/29	7:05	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.2	81.1	22	24	0.1	0.02	4	0.2	0	Satisfactory
481	2080/12/29	6:20	Baneshwor	Min Bhawan SRT	Treated	Clear	1.55	<5	7.8	81.4	28	24	0.1	0.02	4	0.6	0	Satisfactory
482	2080/12/29	6:10	Tripureshwar	Anamnagar SRT	Treated	Clear	1.81	<5	8.0	83.5	30	24	0.1	0.02	4	0.3	0	Satisfactory
483	2080/12/29	7:30	Maharajgunj	Balaju SRT	Treated	Clear	2.27	<5	8.1	80.7	32	24	0.1	0.02	4	0.2	0	Satisfactory
484	2080/12/29	7:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.21	<5	7.7	85.2	28	24	0.1	0.02	2	0.3	0	Satisfactory
485	2080/12/30	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.9	<5	7.6	71	24	28	0.1	0.02	6	0.2	0	Satisfactory
486	2080/12/30	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.8	<5	7.9	76	24	32	0.1	0.02	6	0.2	0	Satisfactory
487	2080/12/30	13:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.8	75	24	32	0.1	0.02	6	0.2	0	Satisfactory
488	2080/12/30	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.45	<5	7.4	56.1	14	16	0.1	0.02	4	0.1	0	Satisfactory
489	2080/12/30	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.87	<5	7.1	59.3	12	16	0.1	0.02	4	0.1	0	Satisfactory
490	2080/12/30	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.06	<5	7.6	60.8	16	14	0.1	0.02	4	0.2	0	Satisfactory
491	2080/12/30	10:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.4	<5	7.7	77.7	28	24	0.1	0.02	4	0.2	0	Satisfactory
492	2080/12/30	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.96	<5	7.5	78	26	24	0.1	0.02	4	0.2	0	Satisfactory
493	2080/12/30	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	8.1	81	32	28	0.1	0.02	4	0.8	0	Satisfactory
494	2080/12/30	7:10	Bhaktapur	Katunje SRT	Treated	Clear	0.92	<5	7.5	79.4	26	22	0.1	0.02	4	0.2	0	Satisfactory
495	2080/12/30	11:35	Baneshwor	Min Bhawan SRT	Treated	Clear	1.15	<5	7.4	78.4	24	22	0.1	0.02	4	0.2	0	Satisfactory
496	2080/12/30	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.79	<5	7.2	76.2	22	24	0.1	0.02	4	0.2	0	Satisfactory
497	2080/12/30	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.15	<5	7.8	78.5	28	24	0.1	0.02	4	0.3	0	Satisfactory
498	2080/12/30	12:00	Lalitpur	Sainbu WTP	Treated	Clear	1.08	<5	8.1	417	100	128	0.1	0.02	8	0.2	0	Satisfactory