



**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Baishakh 2081**

S.N	Date	Time	Branch	Sampling Location	Sample type	Appearance	Turbidity	Colour	pH	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks	
							(NTU)	(TCU)		µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100ml		
Units																			
National Drinking Water Quality Standard (NDWQS)							5	5.00	6.5-8.5	1500		500.0	0.3(3)	1.5	250.0	0.1-0.5	0 in 95% Samples		
1	2081/1/1	9:25	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.29	<5	7.1	56.2	12	18	0.1	0.02	4	0.13	0	Satisfactory	
2	2081/1/1	9:25	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1	<5	7.34	78.9	24	22	0.1	0.02	4	0.14	0	Satisfactory	
3	2081/1/1	7:11	Bhaktapur	Katunje SRT	Treated	Clear	1.73	<5	7.41	79.3	24	22	0.1	0.02	4	0.37	0	Satisfactory	
4	2081/1/1	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.4	<5	8.13	76.1	30	26	0.1	0.02	4	0.27	0	Satisfactory	
5	2081/1/1	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.35	<5	8.06	76.7	30	26	0.1	0.02	4	0.43	0	Satisfactory	
6	2081/1/1	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.66	70.9	30	26	0.1	0.02	4	0.55	0	Satisfactory	
7	2081/1/1	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.51	71.4	30	26	0.1	0.02	4	1.04	0	Satisfactory	
8	2081/1/1	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.69	75.3	30	26	0.1	0.02	4	1.46	0	Satisfactory	
9	2081/1/1	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.47	64	24	26	0.1	0.02	6	0.36	0	Satisfactory	
10	2081/1/1	13:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.72	77	24	32	0.1	0.02	6	0.10	0	Satisfactory	
11	2081/1/1	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.66	76	24	32	0.1	0.02	6	0.41	0	Satisfactory	
12	2081/1/2	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.8	<5	6.8	327	80	72	0.3	1.5	14	0.28	0	Satisfactory	
13	2081/1/2	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.18	<5	7.35	90.3	24	38	0.1	0.02	4	0.21	0	Satisfactory	
14	2081/1/2	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.33	<5	7.32	53.2	14	18	0.1	0.02	4	0.26	0	Satisfactory	
15	2081/1/2	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.49	<5	7.34	54	12	18	0.1	0.02	4	0.19	0	Satisfactory	
16	2081/1/2	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.6	56.7	24	14	0.1	0.02	4	0.21	0	Satisfactory	
17	2081/1/2	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.52	<5	7.73	57.2	24	20	0.1	0.02	4	0.33	0	Satisfactory	
18	2081/1/2	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	2.08	<5	7.48	80.6	26	24	0.1	0.02	4	0.84	0	Satisfactory	
19	2081/1/2	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.08	<5	7.62	78.5	26	24	0.1	0.02	4	0.43	0	Satisfactory	
20	2081/1/2	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.1	<5	7.84	81.5	30	26	0.1	0.02	4	0.65	0	Satisfactory	
21	2081/1/2	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.8	<5	7.9	80.7	30	24	0.1	0.02	4	0.55	0	Satisfactory	
22	2081/1/2	13:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.07	<5	7.96	80.5	30	24	0.1	0.02	4	0.54	0	Satisfactory	
23	2081/1/2	7:35	Bhaktapur	Katunje SRT	Treated	Clear	1.61	<5	7.48	77.3	26	22	0.1	0.02	4	0.42	0	Satisfactory	
24	2081/1/2	14:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.93	87.2	30	24	0.1	0.02	4	0.1	0	Satisfactory	
25	2081/1/2	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.2	<5	7.57	72.5	26	22	0.1	0.02	4	0.34	0	Satisfactory	
26	2081/1/2	13:30	Baneshwar	Min Bhawan SRT	Treated	Clear	1.76	<5	7.92	79.4	30	24	0.1	0.02	4	0.32	0	Satisfactory	
27	2081/1/2	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.96	73.8	30	26	0.1	0.02	4	0.47	0	Satisfactory	
28	2081/1/2	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.84	75.1	30	26	0.1	0.02	4	1.13	0	Satisfactory	
29	2081/1/2	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.71	73.4	30	26	0.1	0.02	4	0.47	0	Satisfactory	

30	2081/1/2	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.56	<5	7.65	72.4	30	26	0.1	0.02	4	0.8	0	Satisfactory
31	2081/1/2	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.94	74.1	30	26	0.1	0.02	4	0.84	0	Satisfactory
32	2081/1/2	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.48	<5	7.81	73.8	30	26	0.1	0.02	4	0.41	0	Satisfactory
33	2081/1/2	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	55	18	18	0.1	0.02	6	0.52	0	Satisfactory
34	2081/1/2	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.70	81	26	34	0.1	0.02	6	0.71	0	Satisfactory
35	2081/1/2	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.83	<5	7.97	419	102	130	0.1	0.02	8	0.1	0	Satisfactory
36	2081/1/3	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.11	<5	7.51	55	26	14	0.1	0.02	4	0.45	0	Satisfactory
37	2081/1/3	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.99	<5	7.5	56.4	14	14	0.1	0.02	4	0.63	0	Satisfactory
38	2081/1/3	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.23	<5	7.37	71.9	14	16	0.1	0.02	4	0.44	0	Satisfactory
39	2081/1/3	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.38	69.1	26	16	0.1	0.02	4	0.47	0	Satisfactory
40	2081/1/3	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.82	<5	7.74	79.3	18	24	0.1	0.02	4	0.65	0	Satisfactory
41	2081/1/3	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.53	<5	7.7	80.1	28	26	0.1	0.02	4	0.83	0	Satisfactory
42	2081/1/3	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.8	<5	7.63	78.8	26	24	0.1	0.02	4	0.62	0	Satisfactory
43	2081/1/3	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.94	<5	7.6	78.8	26	24	0.1	0.02	4	0.97	0	Satisfactory
44	2081/1/3	12:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.86	<5	7.52	78.9	26	24	0.1	0.02	4	0.37	0	Satisfactory
45	2081/1/3	14:30	Maharajgunj	Balaju SRT	Treated	Clear	1.12	<5	7.62	78.8	26	24	0.1	0.02	4	0.32	0	Satisfactory
46	2081/1/3	6:35	Bhaktapur	Katunje SRT	Treated	Clear	1.67	<5	7.61	82.2	26	24	0.1	0.02	4	0.91	0	Satisfactory
47	2081/1/3	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.56	<5	7.54	90.4	26	28	0.1	0.02	4	0.41	0	Satisfactory
48	2081/1/3	10:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.25	<5	7.52	82.3	26	24	0.1	0.02	4	0.1	0	Satisfactory
49	2081/1/3	12:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.06	<5	7.63	78.9	26	24	0.1	0.02	4	0.59	0	Satisfactory
50	2081/1/3	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.32	<5	7.98	78.1	30	26	0.1	0.02	4	0.6	0	Satisfactory
51	2081/1/3	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.4	<5	8.07	72.7	30	26	0.1	0.02	4	0.81	0	Satisfactory
52	2081/1/3	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.71	<5	7.69	73	30	26	0.1	0.02	4	0.4	0	Satisfactory
53	2081/1/3	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.73	<5	7.74	74.5	30	26	0.1	0.02	4	0.76	0	Satisfactory
54	2081/1/3	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.56	<5	7.7	74.8	30	26	0.1	0.02	4	1.1	0	Satisfactory
55	2081/1/3	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.67	74.1	30	26	0.1	0.02	4	0.78	0	Satisfactory
56	2081/1/3	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.82	75	30	26	0.1	0.02	4	1.35	0	Satisfactory
57	2081/1/3	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	64	22	26	0.1	0.02	6	0.42	0	Satisfactory
58	2081/1/3	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.55	77	26	34	0.1	0.02	6	0.50	0	Satisfactory
59	2081/1/3	11:35	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.73	80	26	34	0.1	0.02	6	0.34	0	Satisfactory
60	2081/1/3	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.9	<5	6.82	336	88	72	0.3	1.5	14	0.2	0	Satisfactory
61	2081/1/3	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.77	<5	6.85	229	52	56	0.3	1.5	14	0.32	0	Satisfactory
62	2081/1/3	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.96	435	108	132	0.1	0.02	10	0.1	0	Satisfactory
63	2081/1/3	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.8	<5	7.28	91.4	24	38	0.1	0.02	4	0.1	0	Satisfactory
64	2081/1/4	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.58	<5	7.63	54.8	16	14	0.1	0.02	4	0.52	0	Satisfactory
65	2081/1/4	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.94	<5	7.48	55.8	12	14	0.1	0.02	4	0.45	0	Satisfactory
66	2081/1/4	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.72	<5	7.56	71.2	16	14	0.1	0.02	4	0.48	0	Satisfactory
67	2081/1/4	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.77	<5	7.22	83.8	14	18	0.1	0.02	4	0.42	0	Satisfactory
68	2081/1/4	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.2	<5	7.78	80.2	28	24	0.1	0.02	4	0.77	0	Satisfactory
69	2081/1/4	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.23	<5	7.58	81	26	24	0.1	0.02	4	1.9	0	Satisfactory
70	2081/1/4	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.15	<5	7.78	78.9	28	24	0.1	0.02	4	0.39	0	Satisfactory
71	2081/1/4	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.51	<5	7.15	83	22	26	0.1	0.02	4	0.94	0	Satisfactory
72	2081/1/4	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.33	<5	7.6	79.3	26	24	0.1	0.02	4	0.78	0	Satisfactory
73	2081/1/4	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.39	<5	7.57	80.9	26	24	0.1	0.02	4	0.52	0	Satisfactory
74	2081/1/4	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.66	80.2	28	24	0.1	0.02	4	0.46	0	Satisfactory
75	2081/1/4	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	1.4	<5	7.68	78.4	28	24	0.1	0.02	4	0.55	0	Satisfactory

76	2081/1/4	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.31	<5	7.58	75.7	30	26	0.1	0.02	4	1.07	0	Satisfactory
77	2081/1/4	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.23	<5	8.07	75.1	30	26	0.1	0.02	4	0.7	0	Satisfactory
78	2081/1/4	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.6	75.3	30	26	0.1	0.02	4	1.1	0	Satisfactory
79	2081/1/4	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.59	<5	7.55	74.2	30	26	0.1	0.02	4	0.62	0	Satisfactory
80	2081/1/4	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.53	<5	7.47	76.9	30	26	0.1	0.02	4	1.65	0	Satisfactory
81	2081/1/4	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.83	73.3	30	26	0.1	0.02	4	0.6	0	Satisfactory
82	2081/1/4	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.25	<5	7.71	73.9	30	26	0.1	0.02	4	0.64	0	Satisfactory
83	2081/1/4	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.55	65	24	28	0.1	0.02	6	0.36	0	Satisfactory
84	2081/1/4	11:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.70	77	26	34	0.1	0.02	6	0.40	0	Satisfactory
85	2081/1/4	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.71	77	26	34	0.1	0.02	6	0.1	0	Satisfactory
86	2081/1/4	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.72	<5	6.87	305	84	72	0.3	1.5	12	0.14	0	Satisfactory
87	2081/1/4	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.45	<5	7.02	288	82	68	0.3	1.5	12	0.1	0	Satisfactory
88	2081/1/4	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.38	<5	8.06	418	106	134	0.1	0.02	10	0.75	0	Satisfactory
89	2081/1/4	15:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.7	<5	7.15	91.7	24	38	0.1	0.02	4	1.39	0	Satisfactory
90	2081/1/5	7:05	Bhaktapur	Katunje SRT	Treated	Clear	0.97	<5	7.58	83.1	26	24	0.1	0.02	4	0.91	0	Satisfactory
91	2081/1/5	8:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.52	<5	7.13	60.3	12	18	0.1	0.02	4	0.52	0	Satisfactory
92	2081/1/5	8:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.73	<5	7.26	78.2	24	26	0.1	0.02	4	0.46	0	Satisfactory
93	2081/1/5	6:40	Tripureshwar	Anamnagar SRT	Treated	Clear	1.23	<5	7.48	79.7	26	24	0.1	0.02	4	0.54	0	Satisfactory
94	2081/1/5	8:00	Maharajgunj	Balaju SRT	Treated	Clear	1.55	<5	7.05	84.5	22	26	0.1	0.02	4	0.63	0	Satisfactory
95	2081/1/5	6:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.93	<5	7.17	81.5	22	24	0.1	0.02	4	0.62	0	Satisfactory
96	2081/1/5	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.1	<5	7.35	83.5	24	26	0.1	0.02	4	0.35	0	Satisfactory
97	2081/1/5	7:20	Baneshwar	Min Bhawan SRT	Treated	Clear	1.64	<5	7.16	80.8	22	24	0.1	0.02	4	0.91	0	Satisfactory
98	2081/1/5	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.37	<5	7.92	74.8	30	26	0.1	0.02	4	0.87	0	Satisfactory
99	2081/1/5	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.97	74.7	30	26	0.1	0.02	4	0.31	0	Satisfactory
100	2081/1/5	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.31	<5	7.45	73.5	30	26	0.1	0.02	4	1.8	0	Satisfactory
101	2081/1/5	12:30	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.67	<5	7.61	74.5	30	26	0.1	0.02	4	1.63	0	Satisfactory
102	2081/1/5	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.55	66	22	28	0.1	0.02	6	0.30	0	Satisfactory
103	2081/1/5	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.80	81	26	34	0.1	0.02	6	0.1	0	Satisfactory
104	2081/1/6	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.85	<5	7.18	51	26	14	0.1	0.02	4	0.1	0	Satisfactory
105	2081/1/6	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.2	<5	7.24	49.6	14	14	0.1	0.02	4	0.1	0	Satisfactory
106	2081/1/6	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.04	<5	7.34	60.5	14	18	0.1	0.02	4	0.1	0	Satisfactory
107	2081/1/6	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.45	<5	7.51	69.9	26	18	0.1	0.02	4	0.9	0	Satisfactory
108	2081/1/6	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.07	<5	7.42	80.1	22	28	0.1	0.02	4	0.57	0	Satisfactory
109	2081/1/6	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.35	<5	7.52	77.6	26	24	0.1	0.02	4	0.45	0	Satisfactory
110	2081/1/6	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.04	<5	7.65	80.2	28	24	0.1	0.02	4	0.84	0	Satisfactory
111	2081/1/6	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.17	<5	7.63	78.8	26	24	0.1	0.02	4	0.81	0	Satisfactory
112	2081/1/6	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.02	<5	7.62	77.9	28	24	0.1	0.02	4	0.1	0	Satisfactory
113	2081/1/6	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.75	<5	7.6	82.8	26	24	0.1	0.02	4	0.6	0	Satisfactory
114	2081/1/6	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.79	<5	7.65	84.1	28	24	0.1	0.02	4	0.1	0	Satisfactory
115	2081/1/6	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	0.85	<5	7.64	77.4	28	24	0.1	0.02	4	0.1	0	Satisfactory
116	2081/1/6	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	8.06	73.3	30	26	0.1	0.02	4	0.32	0	Satisfactory
117	2081/1/6	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.36	<5	8.09	74.6	30	26	0.1	0.02	4	0.58	0	Satisfactory
118	2081/1/6	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	8.05	74.8	30	26	0.1	0.02	4	0.33	0	Satisfactory
119	2081/1/6	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.54	<5	8.04	74.5	30	26	0.1	0.02	4	0.44	0	Satisfactory
120	2081/1/6	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	8.03	74.7	30	26	0.1	0.02	4	0.48	0	Satisfactory
121	2081/1/6	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	7.95	73.2	30	26	0.1	0.02	4	0.42	0	Satisfactory
122	2081/1/6	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.53	<5	7.96	73.5	30	26	0.1	0.02	4	0.5	0	Satisfactory

123	2081/1/6	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.48	55	20	20	0.1	0.02	6	0.41	0	Satisfactory
124	2081/1/6	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.9	<5	7.83	75	26	32	0.1	0.02	6	0.16	0	Satisfactory
125	2081/1/6	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	6.74	307	82	72	0.3	1.5	12	0.12	0	Satisfactory
126	2081/1/6	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.62	<5	8.06	444	108	138	0.1	0.02	10	0.81	0	Satisfactory
127	2081/1/6	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.67	<5	7.29	86.4	22	38	0.1	0.02	4	0.1	0	Satisfactory
128	2081/1/7	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.54	<5	7.28	51.6	16	16	0.1	0.02	4	0.51	0	Satisfactory
129	2081/1/7	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.65	<5	7.51	53.5	12	20	0.1	0.02	4	0.1	0	Satisfactory
130	2081/1/7	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.12	<5	7.54	52.8	18	14	0.1	0.02	4	0.1	0	Satisfactory
131	2081/1/7	10:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.87	<5	7.47	80.2	26	24	0.1	0.02	4	0.53	0	Satisfactory
132	2081/1/7	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.89	<5	7.79	80.3	28	24	0.1	0.02	4	0.1	0	Satisfactory
133	2081/1/7	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.5	<5	7.72	81.2	28	24	0.1	0.02	4	0.1	0	Satisfactory
134	2081/1/7	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.16	<5	7.39	77.4	24	26	0.1	0.02	4	0.64	0	Satisfactory
135	2081/1/7	6:50	Bhaktapur	Katunje SRT	Treated	Clear	1.47	<5	7.58	79	26	24	0.1	0.02	4	0.46	0	Satisfactory
136	2081/1/7	12:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.75	<5	7.45	84	26	24	0.1	0.02	4	0.1	0	Satisfactory
137	2081/1/7	11:45	Baneshwar	Min Bhawan SRT	Treated	Clear	1.51	<5	7.41	80.3	24	26	0.1	0.02	4	0.57	0	Satisfactory
138	2081/1/7	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.87	<5	8	74.9	30	26	0.1	0.02	4	0.8	0	Satisfactory
139	2081/1/7	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.63	<5	8.05	75.2	30	26	0.1	0.02	4	1.28	0	Satisfactory
140	2081/1/7	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.62	<5	8.1	73	30	26	0.1	0.02	4	0.21	0	Satisfactory
141	2081/1/7	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.65	<5	8.15	74.1	30	26	0.1	0.02	4	0.35	0	Satisfactory
142	2081/1/7	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.87	72.9	30	26	0.1	0.02	4	0.49	0	Satisfactory
143	2081/1/7	16:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.98	73.2	30	26	0.1	0.02	4	0.68	0	Satisfactory
144	2081/1/7	9:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	53	22	22	0.1	0.02	6	0.30	0	Satisfactory
145	2081/1/7	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.83	76	24	32	0.1	0.02	6	0.23	0	Satisfactory
146	2081/1/7	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.84	<5	6.8	329	86	78	0.3	1.5	14	0.44	0	Satisfactory
147	2081/1/7	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.69	<5	8.11	421	96	134	0.1	0.02	10	0.95	0	Satisfactory
148	2081/1/7	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.4	89.2	24	38	0.1	0.02	4	0.1	0	Satisfactory
149	2081/1/8	13:45	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.08	<5	7.42	67.1	16	18	0.1	0.02	4	0.65	0	Satisfactory
150	2081/1/8	13:45	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.34	<5	7.23	78.5	22	26	0.1	0.02	4	0.48	0	Satisfactory
151	2081/1/8	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.19	<5	7.41	82.5	24	26	0.1	0.02	4	0.55	0	Satisfactory
152	2081/1/8	13:00	Maharajgunj	Balaju SRT	Treated	Clear	1.35	<5	7.33	80.5	24	26	0.1	0.02	4	0.5	0	Satisfactory
153	2081/1/8	7:05	Bhaktapur	Katunje SRT	Treated	Clear	1.64	<5	7.42	86	24	26	0.1	0.02	4	0.58	0	Satisfactory
154	2081/1/8	12:15	Lalitpur	Khumaltar SRT	Treated	Clear	1.21	<5	7.54	81.5	26	24	0.1	0.02	4	0.41	0	Satisfactory
155	2081/1/8	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	1.33	<5	7.47	82	26	24	0.1	0.02	4	0.45	0	Satisfactory
156	2081/1/8	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.99	72.8	30	26	0.1	0.02	4	0.31	0	Satisfactory
157	2081/1/8	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.45	<5	8.11	71.3	30	26	0.1	0.02	4	0.33	0	Satisfactory
158	2081/1/8	11:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.4	<5	8.02	73.2	30	26	0.1	0.02	4	0.62	0	Satisfactory
159	2081/1/8	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.52	59	20	22	0.1	0.02	6	0.34	0	Satisfactory
160	2081/1/8	15:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.57	71	24	30	0.1	0.02	6	0.1	0	Satisfactory
161	2081/1/9	10:40	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.95	<5	8.5	62.1	30	22	0.1	0.02	4	0.38	0	Satisfactory
162	2081/1/9	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.16	66	16	20	0.1	0.02	4	0.65	0	Satisfactory
163	2081/1/9	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.57	<5	7.56	65.3	14	20	0.1	0.02	4	0.65	0	Satisfactory
164	2081/1/9	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.93	<5	7.67	67.6	18	24	0.1	0.02	4	0.81	0	Satisfactory
165	2081/1/9	10:40	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.25	<5	7.99	80	30	26	0.1	0.02	4	0.85	0	Satisfactory
166	2081/1/9	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.79	<5	7.32	78.2	24	26	0.1	0.02	4	0.59	0	Satisfactory
167	2081/1/9	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.53	<5	7.64	79.8	26	24	0.1	0.02	4	0.55	0	Satisfactory
168	2081/1/9	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.37	<5	7.24	77.8	22	24	0.1	0.02	4	0.85	0	Satisfactory
169	2081/1/9	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.97	<5	7.4	80.3	24	26	0.1	0.02	4	0.43	0	Satisfactory

170	2081/1/9	8:30	Bhaktapur	Katunje SRT	Treated	Clear	1.67	<5	7.48	83	26	24	0.1	0.02	4	0.1	0	Satisfactory
171	2081/1/9	13:25	Lalitpur	Khumaltar SRT	Treated	Clear	1.96	<5	7.3	91.8	24	28	0.1	0.02	4	0.55	0	Satisfactory
172	2081/1/9	8:45	Kirtipur	Kirtipur SRT	Treated	Clear	1.26	<5	7.89	85.7	30	24	0.1	0.02	4	0.34	0	Satisfactory
173	2081/1/9	14:00	Baneshwar	Min Bhawan SRT	Treated	Clear	1.86	<5	7.12	80.5	22	26	0.1	0.02	4	0.44	0	Satisfactory
174	2081/1/9	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.6	<5	7.85	77.3	30	26	0.1	0.02	4	0.44	0	Satisfactory
175	2081/1/9	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.92	73	30	26	0.1	0.02	4	0.46	0	Satisfactory
176	2081/1/9	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.47	<5	7.84	72.4	30	26	0.1	0.02	4	0.81	0	Satisfactory
177	2081/1/9	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.46	<5	7.68	73.1	30	26	0.1	0.02	4	0.43	0	Satisfactory
178	2081/1/9	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.54	<5	7.87	73.5	30	26	0.1	0.02	4	1.12	0	Satisfactory
179	2081/1/9	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.44	73.2	30	26	0.1	0.02	4	0.99	0	Satisfactory
180	2081/1/9	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.36	<5	7.73	74.1	30	26	0.1	0.02	4	1.46	0	Satisfactory
181	2081/1/9	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.52	52	20	22	0.1	0.02	6	0.23	0	Satisfactory
182	2081/1/9	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.74	75	24	32	0.1	0.02	6	0.11	0	Satisfactory
183	2081/1/9	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.74	<5	6.84	338	90	80	0.3	1.5	16	0.6	0	Satisfactory
184	2081/1/9	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.82	<5	6.8	324	88	76	0.3	1.5	16	0.45	0	Satisfactory
185	2081/1/9	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	8.12	437	102	134	0.1	0.02	10	0.86	0	Satisfactory
186	2081/1/9	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.62	<5	7.4	86.4	24	38	0.1	0.02	4	0.1	0	Satisfactory
187	2081/1/10	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.26	<5	7.98	61	18	24	0.1	0.02	4	0.78	0	Satisfactory
188	2081/1/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.7	<5	7.17	61.5	30	18	0.1	0.02	4	0.36	0	Satisfactory
189	2081/1/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.98	<5	7.69	62.8	16	22	0.1	0.02	4	1.07	0	Satisfactory
190	2081/1/10	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.26	<5	7.6	61.3	14	20	0.1	0.02	4	0.11	0	Satisfactory
191	2081/1/10	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.44	<5	7.84	79.2	30	26	0.1	0.02	4	1.15	0	Satisfactory
192	2081/1/10	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.23	<5	7.02	73.3	10	24	0.1	0.02	4	1.29	0	Satisfactory
193	2081/1/10	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.82	<5	7.51	75.7	26	24	0.1	0.02	4	0.92	0	Satisfactory
194	2081/1/10	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.7	<5	7.49	76	26	24	0.1	0.02	4	0.92	0	Satisfactory
195	2081/1/10	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	1.78	<5	7.73	77.9	28	26	0.1	0.02	4	0.48	0	Satisfactory
196	2081/1/10	13:30	Maharajgunj	Balaju SRT	Treated	Clear	2.21	<5	7.79	78.9	28	24	0.1	0.02	4	0.1	0	Satisfactory
197	2081/1/10	6:08	Bhaktapur	Katunje SRT	Treated	Clear	1.69	<5	7.9	89	30	26	0.1	0.02	4	0.9	0	Satisfactory
198	2081/1/10	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	2.15	<5	7.73	79.9	28	26	0.1	0.02	4	0.1	0	Satisfactory
199	2081/1/10	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.9	<5	7.45	86.2	26	24	0.1	0.02	4	0.36	0	Satisfactory
200	2081/1/10	11:40	Baneshwar	Min Bhawan SRT	Treated	Clear	2.23	<5	7.62	77.8	26	28	0.1	0.02	4	0.75	0	Satisfactory
201	2081/1/10	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.82	<5	7.88	71.9	30	26	0.1	0.02	4	0.3	0	Satisfactory
202	2081/1/10	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	1.83	<5	7.98	72.7	30	26	0.1	0.02	4	0.59	0	Satisfactory
203	2081/1/10	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.98	<5	7.72	72.6	30	26	0.1	0.02	4	0.94	0	Satisfactory
204	2081/1/10	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.95	<5	7.46	71.7	30	26	0.1	0.02	4	0.93	0	Satisfactory
205	2081/1/10	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.5	<5	7.62	69	30	26	0.1	0.02	4	0.99	0	Satisfactory
206	2081/1/10	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.64	<5	7.81	69.6	30	26	0.1	0.02	4	0.57	0	Satisfactory
207	2081/1/10	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.51	54	18	18	0.1	0.02	6	0.34	0	Satisfactory
208	2081/1/10	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.62	77	24	32	0.1	0.02	6	0.14	0	Satisfactory
209	2081/1/10	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.75	<5	6.78	326	88	76	0.3	1.5	16	0.1	0	Satisfactory
210	2081/1/10	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	6.68	348	88	78	0.3	1.5	12	0.1	0	Satisfactory
211	2081/1/10	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.95	<5	8.22	452	108	140	0.1	0.02	12	1.15	0	Satisfactory
212	2081/1/10	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.66	<5	7.22	87.2	22	38	0.1	0.02	4	0.1	0	Satisfactory
213	2081/1/11	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.61	<5	7.87	64.4	30	24	0.1	0.02	4	0.68	0	Satisfactory
214	2081/1/11	12:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.57	<5	7.82	80.2	28	24	0.1	0.02	4	0.73	0	Satisfactory
215	2081/1/11	10:00	Tripureshwar	Anamnagar SRT	Treated	Clear	2.07	<5	7.93	82.3	30	26	0.1	0.02	4	0.44	0	Satisfactory
216	2081/1/11	7:10	Bhaktapur	Katunje SRT	Treated	Clear	1.51	<5	7.43	77.3	24	22	0.1	0.02	4	0.1	0	Satisfactory



217	2081/1/11	9:20	Lalitpur	Khumaltar SRT	Treated	Clear	2.1	<5	7.9	80.4	30	26	0.1	0.02	4	0.42	0	Satisfactory
218	2081/1/11	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.18	<5	7.92	84.2	30	26	0.1	0.02	4	0.32	0	Satisfactory
219	2081/1/11	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.7	<5	7.84	70	30	26	0.1	0.02	4	0.58	0	Satisfactory
220	2081/1/11	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.92	73.2	30	26	0.1	0.02	4	0.79	0	Satisfactory
221	2081/1/11	11:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.77	72.8	30	26	0.1	0.02	4	0.59	0	Satisfactory
222	2081/1/11	13:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.45	<5	7.61	72.4	30	26	0.1	0.02	4	0.83	0	Satisfactory
223	2081/1/11	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.26	<5	7.7	71.6	30	26	0.1	0.02	4	0.93	0	Satisfactory
224	2081/1/11	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	7.50	51	18	18	0.1	0.02	6	0.28	0	Satisfactory
225	2081/1/11	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.52	77	24	32	0.1	0.02	6	0.52	0	Satisfactory
226	2081/1/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.09	<5	7.63	66.4	30	20	0.1	0.02	4	1.25	0	Satisfactory
227	2081/1/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.51	<5	7.58	71.4	30	20	0.1	0.02	4	0.41	0	Satisfactory
228	2081/1/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.37	<5	7.78	66.4	22	20	0.1	0.02	4	1.37	0	Satisfactory
229	2081/1/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.11	<5	7.87	67.3	22	20	0.1	0.02	4	1.25	0	Satisfactory
230	2081/1/12	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.92	<5	7.6	79.7	26	24	0.1	0.02	4	1.06	0	Satisfactory
231	2081/1/12	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.12	<5	7.61	79.4	26	24	0.1	0.02	4	0.81	0	Satisfactory
232	2081/1/12	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.12	<5	7.74	79.4	28	24	0.1	0.02	4	0.95	0	Satisfactory
233	2081/1/12	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.66	<5	7.77	78.5	28	26	0.1	0.02	4	0.63	0	Satisfactory
234	2081/1/12	7:30	Bhaktapur	Katunje SRT	Treated	Clear	2.44	<5	7.53	79.5	26	24	0.1	0.02	4	0.91	0	Satisfactory
235	2081/1/12	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.58	<5	7.75	88.4	28	26	0.1	0.02	4	0.44	0	Satisfactory
236	2081/1/12	9:45	Baneshwar	Min Bhawan SRT	Treated	Clear	2.12	<5	7.96	81.5	30	26	0.1	0.02	4	0.48	0	Satisfactory
237	2081/1/12	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.82	72.4	30	26	0.1	0.02	4	0.22	0	Satisfactory
238	2081/1/12	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.6	<5	7.88	74.4	30	26	0.1	0.02	4	0.87	0	Satisfactory
239	2081/1/12	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.73	73.7	30	26	0.1	0.02	4	0.42	0	Satisfactory
240	2081/1/12	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.86	<5	7.74	78.1	30	26	0.1	0.02	4	0.65	0	Satisfactory
241	2081/1/12	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.77	<5	7.72	77	30	26	0.1	0.02	4	0.97	0	Satisfactory
242	2081/1/12	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.56	<5	7.74	76.8	30	26	0.1	0.02	4	0.72	0	Satisfactory
243	2081/1/12	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.92	<5	7.81	76.9	30	26	0.1	0.02	4	0.5	0	Satisfactory
244	2081/1/12	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.52	50	18	18	0.1	0.02	6	0.23	0	Satisfactory
245	2081/1/12	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.82	77	24	32	0.1	0.02	6	0.1	0	Satisfactory
246	2081/1/12	13:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.76	76	26	32	0.1	0.02	6	0.1	0	Satisfactory
247	2081/1/12	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	6.76	314	86	74	0.3	1.5	12	0.1	0	Satisfactory
248	2081/1/12	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	6.74	319	86	74	0.3	1.5	12	0.1	0	Satisfactory
249	2081/1/12	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.64	<5	8.1	470	110	146	0.1	0.02	12	0.1	0	Satisfactory
250	2081/1/12	14:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.78	<5	7.23	85.9	22	38	0.1	0.02	4	0.53	0	Satisfactory
251	2081/1/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.16	<5	7.4	54.3	14	12	0.1	0.02	4	0.1	0	Satisfactory
252	2081/1/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.48	<5	7.61	58.7	26	14	0.1	0.02	4	0.46	0	Satisfactory
253	2081/1/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.59	58.9	16	14	0.1	0.02	4	0.82	0	Satisfactory
254	2081/1/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	7.71	59.4	22	16	0.1	0.02	4	1.31	0	Satisfactory
255	2081/1/13	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.77	<5	7.52	80.6	26	24	0.1	0.02	4	1.24	0	Satisfactory
256	2081/1/13	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.5	<5	7.7	79.1	28	24	0.1	0.02	4	0.95	0	Satisfactory
257	2081/1/13	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.56	<5	7.85	79.3	30	24	0.1	0.02	4	0.32	0	Satisfactory
258	2081/1/13	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.78	<5	7.81	77.7	30	24	0.1	0.02	4	0.77	0	Satisfactory
259	2081/1/13	10:05	Tripureshwar	Anamnagar SRT	Treated	Clear	2.47	<5	7.42	78	24	22	0.1	0.02	4	0.74	0	Satisfactory
260	2081/1/13	6:45	Bhaktapur	Katunje SRT	Treated	Clear	2.7	<5	7.57	78.8	26	24	0.1	0.02	4	0.89	0	Satisfactory
261	2081/1/13	9:20	Lalitpur	Khumaltar SRT	Treated	Clear	2.48	<5	7.53	77.3	26	24	0.1	0.02	4	0.71	0	Satisfactory
262	2081/1/13	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.16	<5	7.65	80.5	28	26	0.1	0.02	4	0.45	0	Satisfactory
263	2081/1/13	9:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.42	<5	7.54	78	26	24	0.1	0.02	4	0.78	0	Satisfactory

264	2081/1/13	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.6	79.4	30	26	0.1	0.02	4	1.08	0	Satisfactory
265	2081/1/13	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.56	77.1	30	26	0.1	0.02	4	1.17	0	Satisfactory
266	2081/1/13	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.59	<5	7.8	77.9	30	26	0.1	0.02	4	0.94	0	Satisfactory
267	2081/1/13	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.82	<5	7.91	72.8	30	26	0.1	0.02	4	0.48	0	Satisfactory
268	2081/1/13	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.71	<5	7.85	73.8	30	26	0.1	0.02	4	0.6	0	Satisfactory
269	2081/1/13	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.89	<5	7.8	73.7	30	26	0.1	0.02	4	0.22	0	Satisfactory
270	2081/1/13	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.83	<5	7.82	73.8	30	26	0.1	0.02	4	0.44	0	Satisfactory
271	2081/1/13	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.53	50	18	18	0.1	0.02	6	0.31	0	Satisfactory
272	2081/1/13	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.85	77	26	32	0.1	0.02	6	0.41	0	Satisfactory
273	2081/1/13	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.29	<5	6.76	309	86	72	0.3	1.2	12	0.1	0	Satisfactory
274	2081/1/13	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.47	<5	6.75	332	88	74	0.3	1.4	12	0.1	0	Satisfactory
275	2081/1/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.54	<5	8.17	470	110	146	0.1	0.02	12	0.56	0	Satisfactory
276	2081/1/13	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.71	<5	7.18	86.8	22	38	0.1	0.02	4	0.1	0	Satisfactory
277	2081/1/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.28	<5	7.55	58.9	16	20	0.1	0.02	4	0.87	0	Satisfactory
278	2081/1/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.23	<5	7.2	60.9	16	20	0.1	0.02	4	0.89	0	Satisfactory
279	2081/1/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.38	<5	7.71	66.2	18	18	0.1	0.02	4	0.56	0	Satisfactory
280	2081/1/14	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.2	<5	7.62	84.5	26	24	0.1	0.02	4	0.81	0	Satisfactory
281	2081/1/14	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.44	<5	7.08	83.08	20	26	0.1	0.02	4	0.9	0	Satisfactory
282	2081/1/14	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.43	<5	7.85	86.2	30	26	0.1	0.02	4	0.85	0	Satisfactory
283	2081/1/14	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	1.31	<5	7.89	86.2	30	26	0.1	0.02	4	1.03	0	Satisfactory
284	2081/1/14	12:35	Maharajgunj	Balaju SRT	Treated	Clear	1.76	<5	7.89	87.1	30	26	0.1	0.02	4	0.86	0	Satisfactory
285	2081/1/14	6:40	Bhaktapur	Katunje SRT	Treated	Clear	2.06	<5	7.58	88.7	26	24	0.1	0.02	4	0.33	0	Satisfactory
286	2081/1/14	11:40	Lalitpur	Khumaltar SRT	Treated	Clear	2.77	<5	7.89	94.6	30	28	0.1	0.02	4	0.1	0	Satisfactory
287	2081/1/14	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.05	<5	7.65	85.3	28	24	0.1	0.02	6	0.33	0	Satisfactory
288	2081/1/14	11:00	Baneshwar	Min Bhawan SRT	Treated	Clear	1.83	<5	7.88	84.8	30	26	0.1	0.02	4	0.63	0	Satisfactory
289	2081/1/14	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.28	<5	7.75	72.9	30	26	0.1	0.02	4	0.31	0	Satisfactory
290	2081/1/14	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	7.86	74.4	30	26	0.1	0.02	4	0.42	0	Satisfactory
291	2081/1/14	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.64	74.7	30	26	0.1	0.02	4	0.57	0	Satisfactory
292	2081/1/14	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.47	<5	7.74	74.8	30	26	0.1	0.02	4	0.61	0	Satisfactory
293	2081/1/14	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.65	<5	7.68	74.4	30	26	0.1	0.02	4	0.44	0	Satisfactory
294	2081/1/14	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.64	<5	7.77	74	30	26	0.1	0.02	4	0.35	0	Satisfactory
295	2081/1/14	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.48	52	18	18	0.1	0.02	6	0.45	0	Satisfactory
296	2081/1/14	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.61	76	24	32	0.1	0.02	6	0.51	0	Satisfactory
297	2081/1/14	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.86	<5	6.7	314	86	72	0.3	1.5	14	0.22	0	Satisfactory
298	2081/1/14	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.78	<5	6.72	320	86	74	0.3	1.5	14	0.26	0	Satisfactory
299	2081/1/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.48	<5	8.17	456	106	142	0.1	0.02	12	0.28	0	Satisfactory
300	2081/1/14	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.46	<5	7.1	91.9	24	38	0.1	0.02	4	0.27	0	Satisfactory
301	2081/1/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.81	<5	7.64	70.9	16	20	0.1	0.02	4	1.05	0	Satisfactory
302	2081/1/15	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.37	<5	7.27	85	14	26	0.1	0.02	4	0.93	0	Satisfactory
303	2081/1/15	7:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.24	<5	7.4	92.9	24	26	0.1	0.02	4	1.26	0	Satisfactory
304	2081/1/15	8:00	Maharajgunj	Balaju SRT	Treated	Clear	1.61	<5	7.41	85.1	24	24	0.1	0.02	4	0.63	0	Satisfactory
305	2081/1/15	6:59	Bhaktapur	Katunje SRT	Treated	Clear	2.47	<5	7.3	86.3	24	26	0.1	0.02	4	0.45	0	Satisfactory
306	2081/1/15	6:50	Lalitpur	Khumaltar SRT	Treated	Clear	1.94	<5	7.52	85.9	26	24	0.1	0.02	4	0.32	0	Satisfactory
307	2081/1/15	7:20	Baneshwar	Min Bhawan SRT	Treated	Clear	1.97	<5	7.42	87.5	24	26	0.1	0.02	4	0.94	0	Satisfactory
308	2081/1/15	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.29	<5	7.83	74.5	30	26	0.1	0.02	4	0.25	0	Satisfactory
309	2081/1/15	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.32	<5	7.89	74.8	30	26	0.1	0.02	4	0.18	0	Satisfactory
310	2081/1/15	11:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.37	<5	7.66	75.3	30	26	0.1	0.02	4	0.49	0	Satisfactory

311	2081/1/15	13:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.65	<5	7.78	75.3	30	26	0.1	0.02	4	0.54	0	Satisfactory
312	2081/1/15	15:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.48	<5	7.77	73.5	30	26	0.1	0.02	4	0.71	0	Satisfactory
313	2081/1/15	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.57	<5	7.71	75.3	30	26	0.1	0.02	4	0.5	0	Satisfactory
314	2081/1/15	11:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.54	72	24	28	0.1	0.02	6	0.41	0	Satisfactory
315	2081/1/15	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.68	76	24	32	0.1	0.02	6	0.44	0	Satisfactory
316	2081/1/16	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.78	<5	7.59	58.1	14	14	0.1	0.02	4	0.76	0	Satisfactory
317	2081/1/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.62	<5	7.57	59.8	30	16	0.1	0.02	4	0.52	0	Satisfactory
318	2081/1/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.47	<5	7.76	65.8	32	14	0.1	0.02	4	0.95	0	Satisfactory
319	2081/1/16	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.65	<5	7.83	67.3	38	16	0.1	0.02	4	1.09	0	Satisfactory
320	2081/1/16	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.6	<5	7.75	85.7	28	24	0.1	0.02	4	0.8	0	Satisfactory
321	2081/1/16	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.3	<5	7.5	86.2	26	24	0.1	0.02	4	0.89	0	Satisfactory
322	2081/1/16	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.12	<5	7.87	90	30	28	0.1	0.02	4	0.79	0	Satisfactory
323	2081/1/16	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.1	<5	7.88	87.5	30	26	0.1	0.02	4	0.73	0	Satisfactory
324	2081/1/16	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.83	<5	8.04	84.4	30	26	0.1	0.02	4	0.13	0	Satisfactory
325	2081/1/16	6:59	Bhaktapur	Katunje SRT	Treated	Clear	1.62	<5	7.52	86.4	26	24	0.1	0.02	4	0.75	0	Satisfactory
326	2081/1/16	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	2.04	<5	8.06	95.3	30	26	0.1	0.02	4	0.1	0	Satisfactory
327	2081/1/16	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.25	<5	7.45	85.6	26	24	0.1	0.02	4	0.1	0	Satisfactory
328	2081/1/16	11:10	Baneshwar	Min Bhawan SRT	Treated	Clear	1.86	<5	7.78	87.8	28	26	0.1	0.02	4	0.72	0	Satisfactory
329	2081/1/16	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.36	<5	7.71	74.4	30	26	0.1	0.02	4	0.13	0	Satisfactory
330	2081/1/16	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.45	<5	7.79	75.7	30	26	0.1	0.02	4	0.12	0	Satisfactory
331	2081/1/16	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.69	<5	7.79	76.4	30	26	0.1	0.02	4	0.33	0	Satisfactory
332	2081/1/16	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.76	75.8	30	26	0.1	0.02	4	0.32	0	Satisfactory
333	2081/1/16	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.52	<5	7.92	75.3	30	26	0.1	0.02	4	0.24	0	Satisfactory
334	2081/1/16	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.89	75.3	30	26	0.1	0.02	4	0.42	0	Satisfactory
335	2081/1/16	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.51	72	24	28	0.1	0.02	6	0.41	0	Satisfactory
336	2081/1/16	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.80	78	26	34	0.1	0.02	6	0.43	0	Satisfactory
337	2081/1/16	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.72	77	24	32	0.1	0.02	6	0.1	0	Satisfactory
338	2081/1/16	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.74	<5	6.71	320	86	74	0.3	1.4	14	0.49	0	Satisfactory
339	2081/1/16	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	6.7	311	86	72	0.3	1.5	14	0.41	0	Satisfactory
340	2081/1/16	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.57	<5	7.96	465	110	142	0.1	0.02	12	0.78	0	Satisfactory
341	2081/1/16	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.87	<5	7.1	93.4	24	38	0.1	0.02	4	0.1	0	Satisfactory
342	2081/1/17	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.04	<5	7.39	65.1	14	24	0.1	0.02	4	0.85	0	Satisfactory
343	2081/1/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.08	<5	7.61	70	26	24	0.1	0.02	4	0.52	0	Satisfactory
344	2081/1/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.43	<5	7.68	69.2	18	22	0.1	0.02	4	1.4	0	Satisfactory
345	2081/1/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.51	<5	7.86	69	16	14	0.1	0.02	4	1.42	0	Satisfactory
346	2081/1/17	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.18	<5	7.62	87.1	26	24	0.1	0.02	4	0.6	0	Satisfactory
347	2081/1/17	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.47	<5	7.85	86.4	30	26	0.1	0.02	4	0.74	0	Satisfactory
348	2081/1/17	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.86	<5	7.73	86.5	28	26	0.1	0.02	4	0.44	0	Satisfactory
349	2081/1/17	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.8	<5	7.93	90.4	30	20	0.1	0.02	4	0.41	0	Satisfactory
350	2081/1/17	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	1.44	<5	7.89	87.4	30	26	0.1	0.02	4	0.72	0	Satisfactory
351	2081/1/17	13:00	Maharajgunj	Balaju SRT	Treated	Clear	0.74	<5	7.9	87.3	30	24	0.1	0.02	4	0.74	0	Satisfactory
352	2081/1/17	6:58	Bhaktapur	Katunje SRT	Treated	Clear	1.73	<5	6.69	87.7	12	26	0.1	0.02	6	0.42	0	Satisfactory
353	2081/1/17	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.61	<5	7.73	97.2	28	26	0.1	0.02	4	0.44	0	Satisfactory
354	2081/1/17	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.37	<5	7.5	86.2	26	24	0.1	0.02	4	0.3	0	Satisfactory
355	2081/1/17	10:05	Baneshwar	Min Bhawan SRT	Treated	Clear	1.66	<5	7.88	87.2	30	26	0.1	0.02	4	0.46	0	Satisfactory
356	2081/1/17	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.82	76.9	30	26	0.1	0.02	4	0.17	0	Satisfactory
357	2081/1/17	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.47	<5	7.9	74.8	30	26	0.1	0.02	4	0.32	0	Satisfactory



358	2081/1/17	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.9	78.2	30	26	0.1	0.02	4	0.16	0	Satisfactory
359	2081/1/17	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.7	75.8	30	26	0.1	0.02	4	0.45	0	Satisfactory
360	2081/1/17	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.55	<5	7.35	75.3	30	26	0.1	0.02	4	0.47	0	Satisfactory
361	2081/1/17	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.76	<5	7.55	75.6	30	26	0.1	0.02	4	0.27	0	Satisfactory
362	2081/1/17	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.65	<5	7.28	75.7	30	26	0.1	0.02	4	0.66	0	Satisfactory
363	2081/1/17	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.54	71	24	26	0.1	0.02	6	0.32	0	Satisfactory
364	2081/1/17	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.61	78	26	34	0.1	0.02	6	0.41	0	Satisfactory
365	2081/1/17	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.60	74	24	32	0.1	0.02	6	0.14	0	Satisfactory
366	2081/1/17	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.72	<5	6.9	333	92	80	0.3	1.5	16	0.83	0	Satisfactory
367	2081/1/17	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	6.79	311	84	70	0.3	1.5	14	0.41	0	Satisfactory
368	2081/1/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.79	<5	8	563	112	156	0.1	0.02	40	0.16	0	Satisfactory
369	2081/1/17	11:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.25	<5	7.05	92	24	38	0.1	0.02	4	0.23	0	Satisfactory
370	2081/1/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.95	<5	7.75	64.3	28	20	0.1	0.02	4	0.1	0	Satisfactory
371	2081/1/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.79	<5	7.7	64.6	16	20	0.1	0.02	4	0.18	0	Satisfactory
372	2081/1/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.61	<5	7.72	68.7	14	16	0.1	0.02	4	0.45	0	Satisfactory
373	2081/1/18	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.22	<5	7.78	73.4	18	20	0.1	0.02	4	1.76	0	Satisfactory
374	2081/1/18	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.64	<5	7.78	88.7	26	24	0.1	0.02	4	0.39	0	Satisfactory
375	2081/1/18	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.57	<5	7.74	88.4	28	26	0.1	0.02	4	0.42	0	Satisfactory
376	2081/1/18	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.18	<5	7.58	91.4	30	28	0.1	0.02	4	0.16	0	Satisfactory
377	2081/1/18	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.1	<5	7.71	88.6	28	24	0.1	0.02	4	0.48	0	Satisfactory
378	2081/1/18	10:40	Tripureshwar	Anamnagar SRT	Treated	Clear	1.15	<5	7.99	86	30	26	0.1	0.02	4	0.1	0	Satisfactory
379	2081/1/18	7:05	Bhaktapur	Katunje SRT	Treated	Clear	2.75	<5	7.75	92.8	28	26	0.1	0.02	4	0.61	0	Satisfactory
380	2081/1/18	11:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.34	<5	7.83	92.5	28	26	0.1	0.02	4	0.1	0	Satisfactory
381	2081/1/18	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.24	<5	7.49	87.7	26	24	0.1	0.02	4	0.32	0	Satisfactory
382	2081/1/18	10:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.49	<5	7.84	88.4	28	26	0.1	0.02	4	0.25	0	Satisfactory
383	2081/1/18	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.95	74	30	26	0.1	0.02	4	0.1	0	Satisfactory
384	2081/1/18	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	7.48	76.6	30	26	0.1	0.02	4	0.44	0	Satisfactory
385	2081/1/18	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.52	76.4	30	26	0.1	0.02	4	0.46	0	Satisfactory
386	2081/1/18	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.68	75.5	30	26	0.1	0.02	4	0.43	0	Satisfactory
387	2081/1/18	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.69	75.4	30	26	0.1	0.02	4	0.24	0	Satisfactory
388	2081/1/18	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.6	<5	7.6	75.6	30	26	0.1	0.02	4	0.59	0	Satisfactory
389	2081/1/18	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.54	76	24	28	0.1	0.02	6	0.42	0	Satisfactory
390	2081/1/18	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.81	79	24	32	0.1	0.02	6	0.1	0	Satisfactory
391	2081/1/18	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.51	78	26	34	0.1	0.02	6	0.37	0	Satisfactory
392	2081/1/18	12:35	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.54	68	26	34	0.1	0.02	6	0.28	0	Satisfactory
393	2081/1/18	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.51	<5	6.7	347	88	80	0.3	1.5	16	1.05	0	Satisfactory
394	2081/1/18	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.08	<5	6.7	319	86	72	0.3	1.4	14	0.38	0	Satisfactory
395	2081/1/18	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.19	<5	7.97	455	108	136	0.1	0.02	12	0.86	0	Satisfactory
396	2081/1/18	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.95	<5	7.1	91.3	24	38	0.1	0.02	4	0.1	0	Satisfactory
397	2081/1/19	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.7	75.2	26	14	0.1	0.02	4	0.55	0	Satisfactory
398	2081/1/19	9:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.15	<5	7.9	92.8	30	26	0.1	0.02	4	0.57	0	Satisfactory
399	2081/1/19	7:40	Tripureshwar	Anamnagar SRT	Treated	Clear	2.88	<5	8.04	91.2	28	26	0.1	0.02	4	0.62	0	Satisfactory
400	2081/1/19	8:00	Maharajgunj	Balaju SRT	Treated	Clear	1.78	<5	7.79	91	28	26	0.1	0.02	4	0.42	0	Satisfactory
401	2081/1/19	5:55	Bhaktapur	Katunje SRT	Treated	Clear	2.93	<5	7.57	93.4	26	28	0.1	0.02	4	0.34	0	Satisfactory
402	2081/1/19	7:05	Lalitpur	Khumaltar SRT	Treated	Clear	2.47	<5	7.93	101.3	30	26	0.1	0.02	4	0.37	0	Satisfactory
403	2081/1/19	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.63	<5	7.67	88.5	28	26	0.1	0.02	4	0.25	0	Satisfactory
404	2081/1/19	7:20	Baneshwar	Min Bhawan SRT	Treated	Clear	2.25	<5	7.85	91.4	30	26	0.1	0.02	4	0.6	0	Satisfactory

405	2081/1/19	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.39	<5	7.9	74.7	30	26	0.1	0.02	4	0.14	0	Satisfactory
406	2081/1/19	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.78	77.5	30	26	0.1	0.02	4	0.56	0	Satisfactory
407	2081/1/19	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.46	<5	7.82	76.2	30	26	0.1	0.02	4	0.85	0	Satisfactory
408	2081/1/19	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.91	76.8	30	26	0.1	0.02	4	0.75	0	Satisfactory
409	2081/1/19	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.48	67	24	28	0.1	0.02	6	0.26	0	Satisfactory
410	2081/1/19	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.76	77	26	24	0.1	0.02	6	0.45	0	Satisfactory
411	2081/1/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.31	<5	7.53	78.1	14	22	0.1	0.02	4	0.84	0	Satisfactory
412	2081/1/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.36	<5	7.58	79.1	18	14	0.1	0.02	4	1.02	0	Satisfactory
413	2081/1/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.23	<5	7.68	81.7	14	16	0.1	0.02	4	1.01	0	Satisfactory
414	2081/1/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.38	<5	7.6	82.1	26	20	0.1	0.02	4	1.02	0	Satisfactory
415	2081/1/20	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.16	<5	7.59	90.3	26	28	0.1	0.02	4	0.51	0	Satisfactory
416	2081/1/20	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	3.07	<5	7.79	88.9	28	26	0.1	0.02	4	0.48	0	Satisfactory
417	2081/1/20	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.37	<5	7.76	89.1	28	26	0.1	0.02	4	0.45	0	Satisfactory
418	2081/1/20	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.01	<5	7.75	87.9	28	24	0.1	0.02	4	0.58	0	Satisfactory
419	2081/1/20	10:45	Tripureshwar	Anamnagar SRT	Treated	Clear	1.87	<5	7.75	88.8	28	26	0.1	0.02	4	0.1	0	Satisfactory
420	2081/1/20	7:10	Bhaktapur	Katunje SRT	Treated	Clear	1.48	<5	7.72	97.7	28	26	0.1	0.02	4	0.1	0	Satisfactory
421	2081/1/20	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.93	<5	7.72	97.2	28	30	0.1	0.02	4	0.1	0	Satisfactory
422	2081/1/20	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.13	<5	7.76	92.5	28	26	0.1	0.02	4	0.27	0	Satisfactory
423	2081/1/20	11:00	Baneshwar	Min Bhawan SRT	Treated	Clear	2.16	<5	7.81	89.1	28	26	0.1	0.02	4	0.37	0	Satisfactory
424	2081/1/20	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.92	81.7	30	26	0.1	0.02	4	0.17	0	Satisfactory
425	2081/1/20	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.97	<5	7.82	83.4	30	26	0.1	0.02	4	0.2	0	Satisfactory
426	2081/1/20	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.52	<5	7.74	87.3	30	26	0.1	0.02	4	0.28	0	Satisfactory
427	2081/1/20	13:15	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.57	<5	7.41	74.8	30	26	0.1	0.02	4	0.46	0	Satisfactory
428	2081/1/20	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.45	<5	7.46	75.6	30	26	0.1	0.02	4	0.49	0	Satisfactory
429	2081/1/20	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.7	<5	7.69	75.5	30	26	0.1	0.02	4	0.36	0	Satisfactory
430	2081/1/20	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.55	<5	7.71	75.2	30	26	0.1	0.02	4	0.61	0	Satisfactory
431	2081/1/20	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	65	22	26	0.1	0.02	6	0.26	0	Satisfactory
432	2081/1/20	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.57	76	24	32	0.1	0.02	6	0.1	0	Satisfactory
433	2081/1/20	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.56	78	26	34	0.1	0.02	6	0.32	0	Satisfactory
434	2081/1/20	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.38	<5	6.71	317	86	72	0.3	1.5	14	0.28	0	Satisfactory
435	2081/1/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.04	<5	8.09	447	106	140	0.1	0.02	10	0.71	0	Satisfactory
436	2081/1/20	10:20	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.3	93.8	26	38	0.1	0.02	4	0.1	0	Satisfactory
437	2081/1/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.37	<5	7.34	67.4	14	24	0.1	0.02	4	0.1	0	Satisfactory
438	2081/1/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.79	<5	7.73	68.5	12	22	0.1	0.02	4	0.1	0	Satisfactory
439	2081/1/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.62	<5	7.5	69.7	26	22	0.1	0.02	4	0.24	0	Satisfactory
440	2081/1/21	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.1	<5	7.41	88	24	26	0.1	0.02	4	0.26	0	Satisfactory
441	2081/1/21	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.25	<5	7.76	89.2	28	26	0.1	0.02	4	0.23	0	Satisfactory
442	2081/1/21	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.35	<5	7.57	88.5	26	24	0.1	0.02	4	0.34	0	Satisfactory
443	2081/1/21	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.64	91.2	30	26	0.1	0.02	4	0.1	0	Satisfactory
444	2081/1/21	12:30	Maharajgunj	Balaju SRT	Treated	Clear	0.04	<5	7.79	89.2	30	24	0.1	0.02	4	0.1	0	Satisfactory
445	2081/1/21	8:10	Bhaktapur	Katunje SRT	Treated	Clear	0.26	<5	7.19	88.9	22	24	0.1	0.02	4	0.38	0	Satisfactory
446	2081/1/21	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.03	<5	7.84	89.4	28	26	0.1	0.02	4	0.1	0	Satisfactory
447	2081/1/21	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.18	<5	7.72	97.7	28	30	0.1	0.02	4	0.1	0	Satisfactory
448	2081/1/21	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	0.1	<5	7.73	90.2	26	26	0.1	0.02	4	0.1	0	Satisfactory
449	2081/1/21	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.33	<5	7.77	74.2	30	26	0.1	0.02	4	0.12	0	Satisfactory
450	2081/1/21	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.31	<5	7.72	76.1	30	26	0.1	0.02	4	0.72	0	Satisfactory
451	2081/1/21	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.41	<5	7.77	76.2	30	26	0.1	0.02	4	0.26	0	Satisfactory

452	2081/1/21	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.66	<5	7.71	76.3	30	26	0.1	0.02	4	0.54	0	Satisfactory
453	2081/1/21	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.82	75.8	30	26	0.1	0.02	4	0.43	0	Satisfactory
454	2081/1/21	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.57	<5	7.79	73.1	30	26	0.1	0.02	4	0.35	0	Satisfactory
455	2081/1/21	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.78	75.3	30	26	0.1	0.02	4	0.74	0	Satisfactory
456	2081/1/21	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.50	72	24	28	0.1	0.02	6	0.42	0	Satisfactory
457	2081/1/21	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.74	77	26	32	0.1	0.02	6	0.52	0	Satisfactory
458	2081/1/21	13:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.80	79	26	34	0.1	0.02	6	0.20	0	Satisfactory
459	2081/1/21	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	6.71	307	84	72	0.3	1.5	14	0.21	0	Satisfactory
460	2081/1/21	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.89	<5	8.16	437	106	120	0.1	0.02	10	0.1	0	Satisfactory
461	2081/1/21	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.82	<5	7.29	88.8	24	38	0.1	0.02	4	0.1	0	Satisfactory
462	2081/1/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.85	<5	7.72	65.8	26	16	0.1	0.02	4	0.1	0	Satisfactory
463	2081/1/22	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.88	<5	6.97	91.1	12	34	0.1	0.02	4	0.61	0	Satisfactory
464	2081/1/22	7:40	Tripureshwar	Anamnagar SRT	Treated	Clear	2.52	<5	7.32	89.2	24	28	0.1	0.02	4	0.54	0	Satisfactory
465	2081/1/22	8:10	Maharajgunj	Balaju SRT	Treated	Clear	3.62	<5	7.4	89	24	28	0.1	0.02	4	0.68	0	Satisfactory
466	2081/1/22	7:05	Lalitpur	Khumaltar SRT	Treated	Clear	1.56	<5	7.16	90.8	22	28	0.1	0.02	4	0.1	0	Satisfactory
467	2081/1/22	7:30	Baneshwar	Min Bhawan SRT	Treated	Clear	2.58	<5	7.25	90.4	24	28	0.1	0.02	4	0.69	0	Satisfactory
468	2081/1/22	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.28	<5	8.04	74.7	30	26	0.1	0.02	4	0.1	0	Satisfactory
469	2081/1/22	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.26	<5	7.97	76.2	30	26	0.1	0.02	4	0.45	0	Satisfactory
470	2081/1/22	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.41	<5	7.91	76.3	30	26	0.1	0.02	4	0.41	0	Satisfactory
471	2081/1/22	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.86	76.5	30	26	0.1	0.02	4	0.62	0	Satisfactory
472	2081/1/22	15:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.98	<5	7.93	76.6	30	26	0.1	0.02	4	0.52	0	Satisfactory
473	2081/1/22	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.51	73	24	30	0.1	0.02	6	0.32	0	Satisfactory
474	2081/1/22	15:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.72	78	26	32	0.1	0.02	6	0.42	0	Satisfactory
475	2081/1/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	7.28	85.7	26	18	0.1	0.02	4	0.84	0	Satisfactory
476	2081/1/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.36	<5	7.56	89.6	14	20	0.1	0.02	4	1.42	0	Satisfactory
477	2081/1/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.46	84.3	14	22	0.1	0.02	4	1.3	0	Satisfactory
478	2081/1/23	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.74	89.4	26	22	0.1	0.02	4	1.91	0	Satisfactory
479	2081/1/23	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.26	<5	7.45	85.6	26	14	0.1	0.02	4	0.21	0	Satisfactory
480	2081/1/23	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.39	<5	7.8	86.9	28	24	0.1	0.02	4	0.74	0	Satisfactory
481	2081/1/23	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.25	<5	7.63	88.3	26	24	0.1	0.02	4	0.63	0	Satisfactory
482	2081/1/23	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.18	<5	7.88	87.3	30	24	0.1	0.02	4	0.52	0	Satisfactory
483	2081/1/23	12:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.36	<5	7.69	88.3	28	26	0.1	0.02	4	0.1	0	Satisfactory
484	2081/1/23	12:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.72	<5	7.72	90.1	28	26	0.1	0.02	4	0.1	0	Satisfactory
485	2081/1/23	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.92	<5	7.57	85.8	26	24	0.1	0.02	4	0.1	0	Satisfactory
486	2081/1/23	12:15	Baneshwar	Min Bhawan SRT	Treated	Clear	0.45	<5	7.56	90.2	26	28	0.1	0.02	4	0.1	0	Satisfactory
487	2081/1/23	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.94	73	30	26	0.1	0.02	4	0.13	0	Satisfactory
488	2081/1/23	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.94	72.5	30	26	0.1	0.02	4	0.57	0	Satisfactory
489	2081/1/23	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.86	74.4	30	26	0.1	0.02	4	0.45	0	Satisfactory
490	2081/1/23	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.7	<5	7.98	73.7	30	26	0.1	0.02	4	0.26	0	Satisfactory
491	2081/1/23	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.75	<5	7.91	72.2	30	26	0.1	0.02	4	0.54	0	Satisfactory
492	2081/1/23	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.61	74.8	30	26	0.1	0.02	4	0.27	0	Satisfactory
493	2081/1/23	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.55	69	24	28	0.1	0.02	6	0.36	0	Satisfactory
494	2081/1/23	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.80	77	26	32	0.1	0.02	6	0.30	0	Satisfactory
495	2081/1/23	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.67	76	26	34	0.1	0.02	6	0.26	0	Satisfactory
496	2081/1/23	12:20	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.72	78	26	34	0.1	0.02	6	0.31	0	Satisfactory
497	2081/1/23	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.98	<5	6.7	290	82	70	0.3	1.5	10	0.1	0	Satisfactory
498	2081/1/23	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.62	<5	6.7	295	82	72	0.3	1.5	10	0.44	0	Satisfactory

499	2081/1/23	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.02	<5	7.89	419	98	126	0.1	0.02	8	0.1	0	Satisfactory
500	2081/1/23	16:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.86	<5	7.1	91.4	24	38	0.1	0.02	4	0.2	0	Satisfactory
501	2081/1/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.97	81.8	30	22	0.1	0.02	4	0.75	0	Satisfactory
502	2081/1/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.4	83.2	14	20	0.1	0.02	4	0.32	0	Satisfactory
503	2081/1/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.42	<5	7.5	85.4	26	22	0.1	0.02	4	0.61	0	Satisfactory
504	2081/1/24	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.79	<5	7.57	75.5	36	20	0.1	0.02	4	0.24	0	Satisfactory
505	2081/1/24	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.59	<5	7.47	85.1	26	24	0.1	0.02	4	0.47	0	Satisfactory
506	2081/1/24	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.5	<5	7.47	93.5	26	28	0.1	0.02	4	0.35	0	Satisfactory
507	2081/1/24	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.16	<5	7.76	87.8	28	24	0.1	0.02	4	0.53	0	Satisfactory
508	2081/1/24	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.4	<5	7.41	84.8	24	26	0.1	0.02	4	0.37	0	Satisfactory
509	2081/1/24	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.85	<5	8.2	85.5	32	24	0.1	0.02	4	0.1	0	Satisfactory
510	2081/1/24	13:10	Maharajgunj	Balaju SRT	Treated	Clear	0.55	<5	8.2	86.6	32	24	0.1	0.02	4	0.1	0	Satisfactory
511	2081/1/24	8:10	Bhaktapur	Katunje SRT	Treated	Clear	0.46	<5	7.28	89.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
512	2081/1/24	7:40	Bhaktapur	Katunje SRT	Treated	Clear	0.05	<5	7.25	88.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
513	2081/1/24	7:06	Bhaktapur	Katunje SRT	Treated	Clear	0.01	<5	7.31	86.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
514	2081/1/24	11:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.87	<5	8.02	87.7	30	24	0.1	0.02	4	0.1	0	Satisfactory
515	2081/1/24	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.83	<5	7.46	93.5	26	28	0.1	0.02	4	0.1	0	Satisfactory
516	2081/1/24	11:20	Baneshwar	Min Bhawan SRT	Treated	Clear	0.89	<5	8.15	93.1	32	28	0.1	0.02	4	0.24	0	Satisfactory
517	2081/1/24	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.48	<5	8.07	74.8	30	26	0.1	0.02	4	0.1	0	Satisfactory
518	2081/1/24	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.94	76.5	30	26	0.1	0.02	4	0.7	0	Satisfactory
519	2081/1/24	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.9	73.6	30	26	0.1	0.02	4	0.35	0	Satisfactory
520	2081/1/24	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.76	70.7	30	26	0.1	0.02	4	0.34	0	Satisfactory
521	2081/1/24	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.9	73.5	30	26	0.1	0.02	4	0.7	0	Satisfactory
522	2081/1/24	16:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.81	71.2	30	26	0.1	0.02	4	0.28	0	Satisfactory
523	2081/1/24	17:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	1.33	<5	7.77	71.1	30	26	0.1	0.02	4	0.19	0	Satisfactory
524	2081/1/24	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.52	67	22	28	0.1	0.02	6	0.33	0	Satisfactory
525	2081/1/24	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.67	78	26	34	0.1	0.02	6	0.20	0	Satisfactory
526	2081/1/24	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.53	76	24	32	0.1	0.02	6	0.43	0	Satisfactory
527	2081/1/24	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.78	<5	6.75	317	86	72	0.3	1.5	14	0.14	0	Satisfactory
528	2081/1/24	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.88	<5	6.75	323	88	72	0.3	1.5	14	0.29	0	Satisfactory
529	2081/1/24	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.43	<5	8.06	435	106	138	0.1	0.02	10	0.89	0	Satisfactory
530	2081/1/24	11:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.15	90.6	24	38	0.1	0.02	4	0.1	0	Satisfactory
531	2081/1/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.04	107.7	42	24	0.1	0.02	4	0.1	0	Satisfactory
532	2081/1/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	8.16	126.4	26	28	0.1	0.02	4	0.1	0	Satisfactory
533	2081/1/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.92	167.1	18	22	0.1	0.02	4	0.37	0	Satisfactory
534	2081/1/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.5	<5	6.92	172.8	16	34	0.1	0.02	4	0.43	0	Satisfactory
535	2081/1/25	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.32	<5	7.46	88.1	26	24	0.1	0.02	4	0.84	0	Satisfactory
536	2081/1/25	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	2.38	<5	8.24	89.3	32	24	0.1	0.02	4	0.75	0	Satisfactory
537	2081/1/25	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.3	<5	7.41	89.1	24	26	0.1	0.02	4	0.76	0	Satisfactory
538	2081/1/25	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	3.66	<5	7.49	85	26	24	0.1	0.02	4	1.87	0	Satisfactory
539	2081/1/25	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.45	<5	7.54	84.9	26	24	0.1	0.02	4	0.1	0	Satisfactory
540	2081/1/25	6:40	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.31	82.5	24	26	0.1	0.02	4	0.61	0	Satisfactory
541	2081/1/25	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.82	<5	7.15	90.7	22	26	0.1	0.02	4	0.1	0	Satisfactory
542	2081/1/25	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.52	<5	7.4	90.8	24	32	0.1	0.02	4	0.1	0	Satisfactory
543	2081/1/25	11:20	Baneshwar	Min Bhawan SRT	Treated	Clear	0.42	<5	7.29	84.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
544	2081/1/25	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.33	<5	8.06	74.7	30	26	0.1	0.02	4	0.13	0	Satisfactory
545	2081/1/25	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.82	71.1	30	26	0.1	0.02	4	0.21	0	Satisfactory

546	2081/1/25	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.88	<5	7.7	73	30	26	0.1	0.02	4	0.37	0	Satisfactory
547	2081/1/25	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.54	<5	7.94	73.8	30	26	0.1	0.02	4	0.94	0	Satisfactory
548	2081/1/25	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.91	<5	7.96	72.6	30	26	0.1	0.02	4	0.73	0	Satisfactory
549	2081/1/25	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.94	<5	8.05	71.7	30	26	0.1	0.02	4	0.56	0	Satisfactory
550	2081/1/25	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.52	71	24	28	0.1	0.02	6	0.31	0	Satisfactory
551	2081/1/25	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.80	76	24	32	0.1	0.02	6	0.16	0	Satisfactory
552	2081/1/25	15:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.52	75	24	32	0.1	0.02	6	0.14	0	Satisfactory
553	2081/1/25	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.72	<5	6.86	325	88	76	0.3	1.5	14	0.27	0	Satisfactory
554	2081/1/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.94	<5	8.17	466	110	144	0.1	0.02	14	0.91	0	Satisfactory
555	2081/1/25	16:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.1	89	24	38	0.1	0.02	4	0.14	0	Satisfactory
556	2081/1/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.43	<5	6.5	110.6	28	28	0.1	0.02	4	0.1	0	Satisfactory
557	2081/1/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.73	<5	6.5	111.9	16	24	0.1	0.02	4	0.1	0	Satisfactory
558	2081/1/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.88	<5	6.5	128.5	16	24	0.1	0.02	4	0.4	0	Satisfactory
559	2081/1/26	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.76	<5	6.5	130.6	16	28	0.1	0.02	4	0.58	0	Satisfactory
560	2081/1/26	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.7	<5	7.32	87.4	24	26	0.1	0.02	4	0.95	0	Satisfactory
561	2081/1/26	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.89	<5	6.96	87.6	20	26	0.1	0.02	4	0.93	0	Satisfactory
562	2081/1/26	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.3	<5	6.78	89.1	18	24	0.1	0.02	4	0.78	0	Satisfactory
563	2081/1/26	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.51	<5	7.67	86.1	20	26	0.1	0.02	4	0.91	0	Satisfactory
564	2081/1/26	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.6	86.7	26	24	0.1	0.02	4	0.1	0	Satisfactory
565	2081/1/26	7:05	Bhaktapur	Katunje SRT	Treated	Clear	0.29	<5	7.6	89.5	26	24	0.1	0.02	4	0.49	0	Satisfactory
566	2081/1/26	12:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.39	<5	7.3	87.1	24	26	0.1	0.02	4	0.39	0	Satisfactory
567	2081/1/26	9:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.84	<5	7.62	97.3	26	30	0.1	0.02	4	0.1	0	Satisfactory
568	2081/1/26	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.68	<5	8.12	74.3	30	26	0.1	0.02	4	0.11	0	Satisfactory
569	2081/1/26	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.67	<5	7.88	77.9	30	26	0.1	0.02	4	0.97	0	Satisfactory
570	2081/1/26	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.97	<5	7.7	70.1	30	26	0.1	0.02	4	0.23	0	Satisfactory
571	2081/1/26	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.73	<5	7.76	73.2	30	26	0.1	0.02	4	0.46	0	Satisfactory
572	2081/1/26	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.81	<5	7.8	73.5	30	26	0.1	0.02	4	0.38	0	Satisfactory
573	2081/1/26	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.9	73.1	30	26	0.1	0.02	4	0.85	0	Satisfactory
574	2081/1/26	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	72	24	28	0.1	0.02	6	0.22	0	Satisfactory
575	2081/1/26	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.73	77	24	32	0.1	0.02	6	0.1	0	Satisfactory
576	2081/1/26	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.74	75	24	32	0.1	0.02	6	0.16	0	Satisfactory
577	2081/1/26	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.85	<5	6.75	319	86	72	0.3	1.5	14	0.3	0	Satisfactory
578	2081/1/26	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.92	<5	6.72	326	88	74	0.3	1.5	14	0.36	0	Satisfactory
579	2081/1/26	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	8.12	459	108	140	0.1	0.02	14	0.56	0	Satisfactory
580	2081/1/26	13:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.81	<5	7.28	90.8	24	38	0.1	0.02	4	0.44	0	Satisfactory
581	2081/1/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.01	85	16	22	0.1	0.02	4	0.53	0	Satisfactory
582	2081/1/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	6.99	87.8	26	26	0.1	0.02	4	0.57	0	Satisfactory
583	2081/1/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.33	<5	6.88	88.7	16	26	0.1	0.02	4	0.51	0	Satisfactory
584	2081/1/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.21	87.4	10	28	0.1	0.02	4	0.3	0	Satisfactory
585	2081/1/27	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.79	<5	7.32	87.2	24	26	0.1	0.02	4	0.32	0	Satisfactory
586	2081/1/27	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.56	<5	7.38	87.8	24	26	0.1	0.02	4	0.35	0	Satisfactory
587	2081/1/27	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.35	<5	7.53	88.1	26	24	0.1	0.02	4	0.27	0	Satisfactory
588	2081/1/27	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.69	<5	7.45	88.3	26	24	0.1	0.02	4	0.34	0	Satisfactory
589	2081/1/27	9:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.87	<5	7.86	85.8	30	26	0.1	0.02	4	0.1	0	Satisfactory
590	2081/1/27	12:10	Maharajgunj	Balaju SRT	Treated	Clear	0.66	<5	7.68	86.5	28	26	0.1	0.02	4	0.1	0	Satisfactory
591	2081/1/27	6:35	Bhaktapur	Katunje SRT	Treated	Clear	1.03	<5	7.78	87.4	30	26	0.1	0.02	4	0.38	0	Satisfactory
592	2081/1/27	8:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.78	<5	7.18	86.2	32	26	0.1	0.02	4	0.35	0	Satisfactory



593	2081/1/27	9:40	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	8.04	88.2	30	28	0.1	0.02	4	0.29	0	Satisfactory
594	2081/1/27	8:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.07	<5	7.81	85.4	28	26	0.1	0.02	4	0.38	0	Satisfactory
595	2081/1/27	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.78	<5	8.14	72.2	30	26	0.1	0.02	4	0.11	0	Satisfactory
596	2081/1/27	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.92	75.8	30	26	0.1	0.02	4	1.19	0	Satisfactory
597	2081/1/27	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.92	76.3	30	26	0.1	0.02	4	0.22	0	Satisfactory
598	2081/1/27	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.85	<5	7.91	76.6	30	26	0.1	0.02	4	0.1	0	Satisfactory
599	2081/1/27	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.89	<5	7.94	77.4	30	26	0.1	0.02	4	0.54	0	Satisfactory
600	2081/1/27	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.96	<5	7.93	76.3	30	26	0.1	0.02	4	0.26	0	Satisfactory
601	2081/1/27	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.96	<5	7.95	75.8	30	26	0.1	0.02	4	0.16	0	Satisfactory
602	2081/1/27	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	70	24	28	0.1	0.02	6	0.43	0	Satisfactory
603	2081/1/27	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.9	<5	7.84	75	24	32	0.1	0.02	6	0.27	0	Satisfactory
604	2081/1/27	15:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.3	<5	7.90	80	26	34	0.1	0.02	6	0.1	0	Satisfactory
605	2081/1/27	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.36	<5	6.9	349	90	82	0.3	1.5	14	0.62	0	Satisfactory
606	2081/1/27	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.07	<5	6.86	330	88	76	0.3	1.5	14	0.22	0	Satisfactory
607	2081/1/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	8.14	435	108	124	0.1	0.02	10	0.1	0	Satisfactory
608	2081/1/27	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.04	<5	7.4	88.5	24	38	0.1	0.02	4	0.1	0	Satisfactory
609	2081/1/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.74	<5	7.26	86.2	28	28	0.1	0.02	4	0.27	0	Satisfactory
610	2081/1/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.75	<5	7.48	88.2	18	26	0.1	0.02	4	0.66	0	Satisfactory
611	2081/1/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.37	92.2	16	26	0.1	0.02	4	0.36	0	Satisfactory
612	2081/1/28	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.58	<5	7.53	88.6	26	24	0.1	0.02	4	0.57	0	Satisfactory
613	2081/1/28	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.55	<5	7.76	86.9	28	26	0.1	0.02	4	0.8	0	Satisfactory
614	2081/1/28	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.3	<5	7.8	86.6	28	24	0.1	0.02	4	0.24	0	Satisfactory
615	2081/1/28	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	8.38	88.9	34	24	0.1	0.02	4	0.32	0	Satisfactory
616	2081/1/28	6:35	Bhaktapur	Katunje SRT	Treated	Clear	2.45	<5	7.3	84.2	24	26	0.1	0.02	4	0.22	0	Satisfactory
617	2081/1/28	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.78	<5	7.9	91.9	30	26	0.1	0.02	4	0.26	0	Satisfactory
618	2081/1/28	9:35	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.64	96.6	26	28	0.1	0.02	4	0.26	0	Satisfactory
619	2081/1/28	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	0.23	<5	7.95	85.9	30	26	0.1	0.02	4	0.22	0	Satisfactory
620	2081/1/28	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.92	<5	8.15	78.4	30	26	0.1	0.02	4	0.12	0	Satisfactory
621	2081/1/28	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	1.01	<5	8.09	79	30	26	0.1	0.02	4	0.27	0	Satisfactory
622	2081/1/28	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.86	<5	7.8	72.1	30	26	0.1	0.02	4	0.82	0	Satisfactory
623	2081/1/28	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.77	<5	7.8	73.5	30	26	0.1	0.02	4	0.3	0	Satisfactory
624	2081/1/28	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.77	<5	7.83	73.9	30	26	0.1	0.02	4	0.69	0	Satisfactory
625	2081/1/28	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.95	<5	7.97	74.2	30	26	0.1	0.02	4	0.77	0	Satisfactory
626	2081/1/28	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.52	73	24	30	0.1	0.02	6	0.26	0	Satisfactory
627	2081/1/28	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.70	75	24	32	0.1	0.02	6	0.1	0	Satisfactory
628	2081/1/28	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.0	<5	7.64	75	24	32	0.1	0.02	6	0.30	0	Satisfactory
629	2081/1/28	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	3.12	<5	6.7	319	82	74	0.3	1.5	12	0.24	0	Satisfactory
630	2081/1/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.95	<5	8.04	445	110	138	0.1	0.02	10	0.1	0	Satisfactory
631	2081/1/28	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.07	<5	7.09	87.8	22	38	0.1	0.02	4	0.1	0	Satisfactory
632	2081/1/29	7:40	Bhaktapur	Katunje SRT	Treated	Clear	0.24	<5	7.94	90.8	30	28	0.1	0.02	4	0.1	0	Satisfactory
633	2081/1/29	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	1.62	<5	8.18	72.8	30	26	0.1	0.02	4	0.1	0	Satisfactory
634	2081/1/29	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	2.93	<5	7.94	76.1	30	26	0.1	0.02	4	1	0	Satisfactory
635	2081/1/29	11:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.98	<5	7.82	73.8	30	26	0.1	0.02	4	0.2	0	Satisfactory
636	2081/1/29	13:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.69	<5	7.64	76.2	30	26	0.1	0.02	4	0.62	0	Satisfactory
637	2081/1/29	15:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.92	<5	7.78	76	30	26	0.1	0.02	4	0.44	0	Satisfactory
638	2081/1/29	16:30	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.96	<5	7.74	73.4	30	26	0.1	0.02	4	0.32	0	Satisfactory
639	2081/1/29	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.53	69	24	28	0.1	0.02	6	0.32	0	Satisfactory

640	2081/1/29	11:20	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.74	75	24	32	0.1	0.02	6	0.1	0	Satisfactory
641	2081/1/29	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.84	77	26	34	0.1	0.02	6	0.37	0	Satisfactory
642	2081/1/30	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.17	<5	7.25	72.2	28	26	0.1	0.02	4	0.1	0	Satisfactory
643	2081/1/30	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.75	<5	7.86	76.2	14	24	0.1	0.02	4	0.27	0	Satisfactory
644	2081/1/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.35	<5	8.17	77.6	12	24	0.1	0.02	4	0.25	0	Satisfactory
645	2081/1/30	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.37	<5	8.12	80.9	26	24	0.1	0.02	4	0.29	0	Satisfactory
646	2081/1/30	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.23	<5	7.45	94.3	26	28	0.1	0.02	4	0.23	0	Satisfactory
647	2081/1/30	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.2	<5	7.94	93.2	30	28	0.1	0.02	4	0.25	0	Satisfactory
648	2081/1/30	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.25	<5	8.27	92.7	32	28	0.1	0.02	4	0.27	0	Satisfactory
649	2081/1/30	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.35	<5	8.07	93	22	26	0.1	0.02	4	0.24	0	Satisfactory
650	2081/1/30	10:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.16	<5	8.29	92.4	32	28	0.1	0.02	4	0.19	0	Satisfactory
651	2081/1/30	12:30	Maharajgunj	Balaju SRT	Treated	Clear	0.01	<5	8.35	91.4	34	28	0.1	0.02	4	0.14	0	Satisfactory
652	2081/1/30	6:45	Bhaktapur	Katunje SRT	Treated	Clear	1.05	<5	7.87	91.6	30	28	0.1	0.02	4	0.12	0	Satisfactory
653	2081/1/30	13:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.16	<5	8.34	93.4	32	28	0.1	0.02	4	0.13	0	Satisfactory
654	2081/1/30	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.77	<5	7.58	95.5	26	28	0.1	0.02	4	0.23	0	Satisfactory
655	2081/1/30	10:55	Baneshwar	Min Bhawan SRT	Treated	Clear	0.1	<5	8.26	91.2	32	28	0.1	0.02	4	0.29	0	Satisfactory
656	2081/1/30	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.61	<5	8.08	75.6	30	26	0.1	0.02	4	0.1	0	Satisfactory
657	2081/1/30	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.94	76.2	30	26	0.1	0.02	4	0.6	0	Satisfactory
658	2081/1/30	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.88	76.4	30	26	0.1	0.02	4	0.1	0	Satisfactory
659	2081/1/30	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.94	75.6	30	26	0.1	0.02	4	0.1	0	Satisfactory
660	2081/1/30	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.93	77.9	30	26	0.1	0.02	4	0.2	0	Satisfactory
661	2081/1/30	16:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.91	76.4	30	26	0.1	0.02	4	0.36	0	Satisfactory
662	2081/1/30	17:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.94	<5	7.92	75.6	30	26	0.1	0.02	4	0.15	0	Satisfactory
663	2081/1/30	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.48	68	24	28	0.1	0.02	6	0.24	0	Satisfactory
664	2081/1/30	11:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.87	76	24	32	0.1	0.02	6	0.1	0	Satisfactory
665	2081/1/30	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.88	78	26	34	0.1	0.02	6	0.51	0	Satisfactory
666	2081/1/30	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	6.91	324	88	74	0.3	1.5	14	0.72	0	Satisfactory
667	2081/1/30	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.14	<5	6.86	316	86	72	0.3	1.5	14	0.41	0	Satisfactory
668	2081/1/30	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.33	<5	7.97	458	110	140	0.1	0.02	12	0.78	0	Satisfactory
669	2081/1/30	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.22	92.4	24	38	0.1	0.02	4	0.11	0	Satisfactory
670	2081/1/31	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.09	<5	6.82	84.8	28	26	0.1	0.02	4	0.32	0	Satisfactory
671	2081/1/31	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.34	85.1	28	22	0.1	0.02	4	0.46	0	Satisfactory
672	2081/1/31	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.2	93.3	12	28	0.1	0.02	4	0.45	0	Satisfactory
673	2081/1/31	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.4	90.9	14	22	0.1	0.02	4	0.32	0	Satisfactory
674	2081/1/31	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.1	<5	7.27	92.5	24	26	0.1	0.02	4	0.75	0	Satisfactory
675	2081/1/31	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.25	<5	7.58	92.9	26	28	0.1	0.02	4	0.29	0	Satisfactory
676	2081/1/31	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.85	<5	7.47	91	16	26	0.1	0.02	4	0.23	0	Satisfactory
677	2081/1/31	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.33	<5	7.96	92.2	30	28	0.1	0.02	4	0.34	0	Satisfactory
678	2081/1/31	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.82	90.7	30	26	0.1	0.02	4	0.1	0	Satisfactory
679	2081/1/31	7:40	Bhaktapur	Katunje SRT	Treated	Clear	1.48	<5	7.16	87.6	22	26	0.1	0.02	4	0.1	0	Satisfactory
680	2081/1/31	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	8.27	97.7	34	28	0.1	0.02	4	0.1	0	Satisfactory
681	2081/1/31	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.85	<5	7.69	95.3	28	26	0.1	0.02	4	0.1	0	Satisfactory
682	2081/1/31	11:00	Baneshwar	Min Bhawan SRT	Treated	Clear	0.01	<5	7.61	88.6	26	24	0.1	0.02	4	0.1	0	Satisfactory
683	2081/1/31	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.96	74.1	30	26	0.1	0.02	4	0.1	0	Satisfactory
684	2081/1/31	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.95	74.7	30	26	0.1	0.02	4	0.1	0	Satisfactory
685	2081/1/31	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.25	<5	7.57	72.3	30	26	0.1	0.02	4	0.66	0	Satisfactory
686	2081/1/31	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.97	74.4	30	26	0.1	0.02	4	0.6	0	Satisfactory

687	2081/1/31	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.74	<5	7.89	74.2	30	26	0.1	0.02	4	0.57	0	Satisfactory
688	2081/1/31	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.83	<5	7.97	73.5	30	26	0.1	0.02	4	0.51	0	Satisfactory
689	2081/1/31	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.75	<5	7.85	72.8	30	26	0.1	0.02	4	0.19	0	Satisfactory
690	2081/1/31	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	71	24	30	0.1	0.02	6	0.18	0	Satisfactory
691	2081/1/31	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.61	76	24	32	0.1	0.02	6	0.1	0	Satisfactory
692	2081/1/31	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.54	77	26	34	0.1	0.02	6	0.1	0	Satisfactory
693	2081/1/31	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	6.88	344	90	80	0.3	1.5	16	0.74	0	Satisfactory
694	2081/1/31	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.63	<5	6.85	336	88	76	0.3	1.5	12	0.39	0	Satisfactory
695	2081/1/31	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.08	<5	7.94	447	108	134	0.1	0.02	10	0.1	0	Satisfactory
696	2081/1/31	15:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.89	<5	7.3	90.7	24	38	0.1	0.02	4	0.39	0	Satisfactory