



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Baishakh 2081

S.N	Date	Time	Branch	Sampling Location	Sample type	Appearance	Turbidity	Colour	pH	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
Units							(NTU)	(TCU)		µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100ml	
National Drinking Water Quality Standard (NDWQS)							5	5.00	6.5-8.5	1500		500.0	0.3(3)	1.5	250.0	0.1-0.5	0 in 95% Samples	
1	2081/1/1	9:25	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.29	<5	7.1	56.2	12	18	0.1	0.02	4	0.13	0	Satisfactory
2	2081/1/1	9:25	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1	<5	7.34	78.9	24	22	0.1	0.02	4	0.14	0	Satisfactory
3	2081/1/1	7:11	Bhaktapur	Katunje SRT	Treated	Clear	1.73	<5	7.41	79.3	24	22	0.1	0.02	4	0.37	0	Satisfactory
4	2081/1/1	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.4	<5	8.13	76.1	30	26	0.1	0.02	4	0.27	0	Satisfactory
5	2081/1/1	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.35	<5	8.06	76.7	30	26	0.1	0.02	4	0.43	0	Satisfactory
6	2081/1/1	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.66	70.9	30	26	0.1	0.02	4	0.55	0	Satisfactory
7	2081/1/1	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.51	71.4	30	26	0.1	0.02	4	1.04	0	Satisfactory
8	2081/1/1	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.69	75.3	30	26	0.1	0.02	4	1.46	0	Satisfactory
9	2081/1/1	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.47	64	24	26	0.1	0.02	6	0.36	0	Satisfactory
10	2081/1/1	13:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.72	77	24	32	0.1	0.02	6	0.10	0	Satisfactory
11	2081/1/1	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.66	76	24	32	0.1	0.02	6	0.41	0	Satisfactory
12	2081/1/2	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.8	<5	6.8	327	80	72	0.3	1.5	14	0.28	0	Satisfactory
13	2081/1/2	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.18	<5	7.35	90.3	24	38	0.1	0.02	4	0.21	0	Satisfactory
14	2081/1/2	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.33	<5	7.32	53.2	14	18	0.1	0.02	4	0.26	0	Satisfactory
15	2081/1/2	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.49	<5	7.34	54	12	18	0.1	0.02	4	0.19	0	Satisfactory
16	2081/1/2	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.6	56.7	24	14	0.1	0.02	4	0.21	0	Satisfactory
17	2081/1/2	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.52	<5	7.73	57.2	24	20	0.1	0.02	4	0.33	0	Satisfactory
18	2081/1/2	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	2.08	<5	7.48	80.6	26	24	0.1	0.02	4	0.84	0	Satisfactory
19	2081/1/2	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.08	<5	7.62	78.5	26	24	0.1	0.02	4	0.43	0	Satisfactory
20	2081/1/2	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.1	<5	7.84	81.5	30	26	0.1	0.02	4	0.65	0	Satisfactory
21	2081/1/2	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.8	<5	7.9	80.7	30	24	0.1	0.02	4	0.55	0	Satisfactory
22	2081/1/2	13:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.07	<5	7.96	80.5	30	24	0.1	0.02	4	0.54	0	Satisfactory
23	2081/1/2	7:35	Bhaktapur	Katunje SRT	Treated	Clear	1.61	<5	7.48	77.3	26	22	0.1	0.02	4	0.42	0	Satisfactory
24	2081/1/2	14:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.93	87.2	30	24	0.1	0.02	4	0.1	0	Satisfactory
25	2081/1/2	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.2	<5	7.57	72.5	26	22	0.1	0.02	4	0.34	0	Satisfactory
26	2081/1/2	13:30	Baneshwar	Min Bhawan SRT	Treated	Clear	1.76	<5	7.92	79.4	30	24	0.1	0.02	4	0.32	0	Satisfactory
27	2081/1/2	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.96	73.8	30	26	0.1	0.02	4	0.47	0	Satisfactory
28	2081/1/2	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.84	75.1	30	26	0.1	0.02	4	1.13	0	Satisfactory
29	2081/1/2	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.71	73.4	30	26	0.1	0.02	4	0.47	0	Satisfactory

30	2081/1/2	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.56	<5	7.65	72.4	30	26	0.1	0.02	4	0.8	0	Satisfactory
31	2081/1/2	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.94	74.1	30	26	0.1	0.02	4	0.84	0	Satisfactory
32	2081/1/2	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.48	<5	7.81	73.8	30	26	0.1	0.02	4	0.41	0	Satisfactory
33	2081/1/2	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	55	18	18	0.1	0.02	6	0.52	0	Satisfactory
34	2081/1/2	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.70	81	26	34	0.1	0.02	6	0.71	0	Satisfactory
35	2081/1/2	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.83	<5	7.97	419	102	130	0.1	0.02	8	0.1	0	Satisfactory
36	2081/1/3	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.11	<5	7.51	55	26	14	0.1	0.02	4	0.45	0	Satisfactory
37	2081/1/3	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.99	<5	7.5	56.4	14	14	0.1	0.02	4	0.63	0	Satisfactory
38	2081/1/3	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.23	<5	7.37	71.9	14	16	0.1	0.02	4	0.44	0	Satisfactory
39	2081/1/3	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.38	69.1	26	16	0.1	0.02	4	0.47	0	Satisfactory
40	2081/1/3	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.82	<5	7.74	79.3	18	24	0.1	0.02	4	0.65	0	Satisfactory
41	2081/1/3	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.53	<5	7.7	80.1	28	26	0.1	0.02	4	0.83	0	Satisfactory
42	2081/1/3	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.8	<5	7.63	78.8	26	24	0.1	0.02	4	0.62	0	Satisfactory
43	2081/1/3	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.94	<5	7.6	78.8	26	24	0.1	0.02	4	0.97	0	Satisfactory
44	2081/1/3	12:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.86	<5	7.52	78.9	26	24	0.1	0.02	4	0.37	0	Satisfactory
45	2081/1/3	14:30	Maharajgunj	Balaju SRT	Treated	Clear	1.12	<5	7.62	78.8	26	24	0.1	0.02	4	0.32	0	Satisfactory
46	2081/1/3	6:35	Bhaktapur	Katunje SRT	Treated	Clear	1.67	<5	7.61	82.2	26	24	0.1	0.02	4	0.91	0	Satisfactory
47	2081/1/3	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.56	<5	7.54	90.4	26	28	0.1	0.02	4	0.41	0	Satisfactory
48	2081/1/3	10:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.25	<5	7.52	82.3	26	24	0.1	0.02	4	0.1	0	Satisfactory
49	2081/1/3	12:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.06	<5	7.63	78.9	26	24	0.1	0.02	4	0.59	0	Satisfactory
50	2081/1/3	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.32	<5	7.98	78.1	30	26	0.1	0.02	4	0.6	0	Satisfactory
51	2081/1/3	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.4	<5	8.07	72.7	30	26	0.1	0.02	4	0.81	0	Satisfactory
52	2081/1/3	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.71	<5	7.69	73	30	26	0.1	0.02	4	0.4	0	Satisfactory
53	2081/1/3	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.73	<5	7.74	74.5	30	26	0.1	0.02	4	0.76	0	Satisfactory
54	2081/1/3	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.56	<5	7.7	74.8	30	26	0.1	0.02	4	1.1	0	Satisfactory
55	2081/1/3	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.67	74.1	30	26	0.1	0.02	4	0.78	0	Satisfactory
56	2081/1/3	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.82	75	30	26	0.1	0.02	4	1.35	0	Satisfactory
57	2081/1/3	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	64	22	26	0.1	0.02	6	0.42	0	Satisfactory
58	2081/1/3	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.55	77	26	34	0.1	0.02	6	0.50	0	Satisfactory
59	2081/1/3	11:35	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.73	80	26	34	0.1	0.02	6	0.34	0	Satisfactory
60	2081/1/3	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.9	<5	6.82	336	88	72	0.3	1.5	14	0.2	0	Satisfactory
61	2081/1/3	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.77	<5	6.85	229	52	56	0.3	1.5	14	0.32	0	Satisfactory
62	2081/1/3	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.96	435	108	132	0.1	0.02	10	0.1	0	Satisfactory
63	2081/1/3	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.8	<5	7.28	91.4	24	38	0.1	0.02	4	0.1	0	Satisfactory
64	2081/1/4	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.58	<5	7.63	54.8	16	14	0.1	0.02	4	0.52	0	Satisfactory
65	2081/1/4	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.94	<5	7.48	55.8	12	14	0.1	0.02	4	0.45	0	Satisfactory
66	2081/1/4	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.72	<5	7.56	71.2	16	14	0.1	0.02	4	0.48	0	Satisfactory
67	2081/1/4	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.77	<5	7.22	83.8	14	18	0.1	0.02	4	0.42	0	Satisfactory
68	2081/1/4	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.2	<5	7.78	80.2	28	24	0.1	0.02	4	0.77	0	Satisfactory
69	2081/1/4	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.23	<5	7.58	81	26	24	0.1	0.02	4	1.9	0	Satisfactory
70	2081/1/4	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.15	<5	7.78	78.9	28	24	0.1	0.02	4	0.39	0	Satisfactory
71	2081/1/4	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.51	<5	7.15	83	22	26	0.1	0.02	4	0.94	0	Satisfactory
72	2081/1/4	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.33	<5	7.6	79.3	26	24	0.1	0.02	4	0.78	0	Satisfactory
73	2081/1/4	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.39	<5	7.57	80.9	26	24	0.1	0.02	4	0.52	0	Satisfactory
74	2081/1/4	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.66	80.2	28	24	0.1	0.02	4	0.46	0	Satisfactory
75	2081/1/4	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	1.4	<5	7.68	78.4	28	24	0.1	0.02	4	0.55	0	Satisfactory

76	2081/1/4	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.31	<5	7.58	75.7	30	26	0.1	0.02	4	1.07	0	Satisfactory
77	2081/1/4	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.23	<5	8.07	75.1	30	26	0.1	0.02	4	0.7	0	Satisfactory
78	2081/1/4	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.6	75.3	30	26	0.1	0.02	4	1.1	0	Satisfactory
79	2081/1/4	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.59	<5	7.55	74.2	30	26	0.1	0.02	4	0.62	0	Satisfactory
80	2081/1/4	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.53	<5	7.47	76.9	30	26	0.1	0.02	4	1.65	0	Satisfactory
81	2081/1/4	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.83	73.3	30	26	0.1	0.02	4	0.6	0	Satisfactory
82	2081/1/4	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.25	<5	7.71	73.9	30	26	0.1	0.02	4	0.64	0	Satisfactory
83	2081/1/4	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.55	65	24	28	0.1	0.02	6	0.36	0	Satisfactory
84	2081/1/4	11:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.70	77	26	34	0.1	0.02	6	0.40	0	Satisfactory
85	2081/1/4	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.71	77	26	34	0.1	0.02	6	0.1	0	Satisfactory
86	2081/1/4	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.72	<5	6.87	305	84	72	0.3	1.5	12	0.14	0	Satisfactory
87	2081/1/4	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.45	<5	7.02	288	82	68	0.3	1.5	12	0.1	0	Satisfactory
88	2081/1/4	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.38	<5	8.06	418	106	134	0.1	0.02	10	0.75	0	Satisfactory
89	2081/1/4	15:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.7	<5	7.15	91.7	24	38	0.1	0.02	4	1.39	0	Satisfactory
90	2081/1/5	7:05	Bhaktapur	Katunje SRT	Treated	Clear	0.97	<5	7.58	83.1	26	24	0.1	0.02	4	0.91	0	Satisfactory
91	2081/1/5	8:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.52	<5	7.13	60.3	12	18	0.1	0.02	4	0.52	0	Satisfactory
92	2081/1/5	8:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.73	<5	7.26	78.2	24	26	0.1	0.02	4	0.46	0	Satisfactory
93	2081/1/5	6:40	Tripureshwar	Anamnagar SRT	Treated	Clear	1.23	<5	7.48	79.7	26	24	0.1	0.02	4	0.54	0	Satisfactory
94	2081/1/5	8:00	Maharajgunj	Balaju SRT	Treated	Clear	1.55	<5	7.05	84.5	22	26	0.1	0.02	4	0.63	0	Satisfactory
95	2081/1/5	6:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.93	<5	7.17	81.5	22	24	0.1	0.02	4	0.62	0	Satisfactory
96	2081/1/5	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.1	<5	7.35	83.5	24	26	0.1	0.02	4	0.35	0	Satisfactory
97	2081/1/5	7:20	Baneshwar	Min Bhawan SRT	Treated	Clear	1.64	<5	7.16	80.8	22	24	0.1	0.02	4	0.91	0	Satisfactory
98	2081/1/5	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.37	<5	7.92	74.8	30	26	0.1	0.02	4	0.87	0	Satisfactory
99	2081/1/5	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.97	74.7	30	26	0.1	0.02	4	0.31	0	Satisfactory
100	2081/1/5	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.31	<5	7.45	73.5	30	26	0.1	0.02	4	1.8	0	Satisfactory
101	2081/1/5	12:30	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.67	<5	7.61	74.5	30	26	0.1	0.02	4	1.63	0	Satisfactory
102	2081/1/5	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.55	66	22	28	0.1	0.02	6	0.30	0	Satisfactory
103	2081/1/5	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.80	81	26	34	0.1	0.02	6	0.1	0	Satisfactory
104	2081/1/6	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.85	<5	7.18	51	26	14	0.1	0.02	4	0.1	0	Satisfactory
105	2081/1/6	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.2	<5	7.24	49.6	14	14	0.1	0.02	4	0.1	0	Satisfactory
106	2081/1/6	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.04	<5	7.34	60.5	14	18	0.1	0.02	4	0.1	0	Satisfactory
107	2081/1/6	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.45	<5	7.51	69.9	26	18	0.1	0.02	4	0.9	0	Satisfactory
108	2081/1/6	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.07	<5	7.42	80.1	22	28	0.1	0.02	4	0.57	0	Satisfactory
109	2081/1/6	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.35	<5	7.52	77.6	26	24	0.1	0.02	4	0.45	0	Satisfactory
110	2081/1/6	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.04	<5	7.65	80.2	28	24	0.1	0.02	4	0.84	0	Satisfactory
111	2081/1/6	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.17	<5	7.63	78.8	26	24	0.1	0.02	4	0.81	0	Satisfactory
112	2081/1/6	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.02	<5	7.62	77.9	28	24	0.1	0.02	4	0.1	0	Satisfactory
113	2081/1/6	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.75	<5	7.6	82.8	26	24	0.1	0.02	4	0.6	0	Satisfactory
114	2081/1/6	12:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.79	<5	7.65	84.1	28	24	0.1	0.02	4	0.1	0	Satisfactory
115	2081/1/6	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	0.85	<5	7.64	77.4	28	24	0.1	0.02	4	0.1	0	Satisfactory
116	2081/1/6	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	8.06	73.3	30	26	0.1	0.02	4	0.32	0	Satisfactory
117	2081/1/6	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.36	<5	8.09	74.6	30	26	0.1	0.02	4	0.58	0	Satisfactory
118	2081/1/6	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	8.05	74.8	30	26	0.1	0.02	4	0.33	0	Satisfactory
119	2081/1/6	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.54	<5	8.04	74.5	30	26	0.1	0.02	4	0.44	0	Satisfactory
120	2081/1/6	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	8.03	74.7	30	26	0.1	0.02	4	0.48	0	Satisfactory
121	2081/1/6	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	7.95	73.2	30	26	0.1	0.02	4	0.42	0	Satisfactory
122	2081/1/6	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.53	<5	7.96	73.5	30	26	0.1	0.02	4	0.5	0	Satisfactory

123	2081/1/6	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.48	55	20	20	0.1	0.02	6	0.41	0	Satisfactory
124	2081/1/6	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.9	<5	7.83	75	26	32	0.1	0.02	6	0.16	0	Satisfactory
125	2081/1/6	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	6.74	307	82	72	0.3	1.5	12	0.12	0	Satisfactory
126	2081/1/6	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.62	<5	8.06	444	108	138	0.1	0.02	10	0.81	0	Satisfactory
127	2081/1/6	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.67	<5	7.29	86.4	22	38	0.1	0.02	4	0.1	0	Satisfactory
128	2081/1/7	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.54	<5	7.28	51.6	16	16	0.1	0.02	4	0.51	0	Satisfactory
129	2081/1/7	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.65	<5	7.51	53.5	12	20	0.1	0.02	4	0.1	0	Satisfactory
130	2081/1/7	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.12	<5	7.54	52.8	18	14	0.1	0.02	4	0.1	0	Satisfactory
131	2081/1/7	10:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.87	<5	7.47	80.2	26	24	0.1	0.02	4	0.53	0	Satisfactory
132	2081/1/7	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.89	<5	7.79	80.3	28	24	0.1	0.02	4	0.1	0	Satisfactory
133	2081/1/7	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.5	<5	7.72	81.2	28	24	0.1	0.02	4	0.1	0	Satisfactory
134	2081/1/7	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.16	<5	7.39	77.4	24	26	0.1	0.02	4	0.64	0	Satisfactory
135	2081/1/7	6:50	Bhaktapur	Katunje SRT	Treated	Clear	1.47	<5	7.58	79	26	24	0.1	0.02	4	0.46	0	Satisfactory
136	2081/1/7	12:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.75	<5	7.45	84	26	24	0.1	0.02	4	0.1	0	Satisfactory
137	2081/1/7	11:45	Baneshwar	Min Bhawan SRT	Treated	Clear	1.51	<5	7.41	80.3	24	26	0.1	0.02	4	0.57	0	Satisfactory
138	2081/1/7	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.87	<5	8	74.9	30	26	0.1	0.02	4	0.8	0	Satisfactory
139	2081/1/7	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.63	<5	8.05	75.2	30	26	0.1	0.02	4	1.28	0	Satisfactory
140	2081/1/7	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.62	<5	8.1	73	30	26	0.1	0.02	4	0.21	0	Satisfactory
141	2081/1/7	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.65	<5	8.15	74.1	30	26	0.1	0.02	4	0.35	0	Satisfactory
142	2081/1/7	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.87	72.9	30	26	0.1	0.02	4	0.49	0	Satisfactory
143	2081/1/7	16:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.98	73.2	30	26	0.1	0.02	4	0.68	0	Satisfactory
144	2081/1/7	9:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	53	22	22	0.1	0.02	6	0.30	0	Satisfactory
145	2081/1/7	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.83	76	24	32	0.1	0.02	6	0.23	0	Satisfactory
146	2081/1/7	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.84	<5	6.8	329	86	78	0.3	1.5	14	0.44	0	Satisfactory
147	2081/1/7	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.69	<5	8.11	421	96	134	0.1	0.02	10	0.95	0	Satisfactory
148	2081/1/7	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.4	89.2	24	38	0.1	0.02	4	0.1	0	Satisfactory
149	2081/1/8	13:45	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.08	<5	7.42	67.1	16	18	0.1	0.02	4	0.65	0	Satisfactory
150	2081/1/8	13:45	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.34	<5	7.23	78.5	22	26	0.1	0.02	4	0.48	0	Satisfactory
151	2081/1/8	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.19	<5	7.41	82.5	24	26	0.1	0.02	4	0.55	0	Satisfactory
152	2081/1/8	13:00	Maharajgunj	Balaju SRT	Treated	Clear	1.35	<5	7.33	80.5	24	26	0.1	0.02	4	0.5	0	Satisfactory
153	2081/1/8	7:05	Bhaktapur	Katunje SRT	Treated	Clear	1.64	<5	7.42	86	24	26	0.1	0.02	4	0.58	0	Satisfactory
154	2081/1/8	12:15	Lalitpur	Khumaltar SRT	Treated	Clear	1.21	<5	7.54	81.5	26	24	0.1	0.02	4	0.41	0	Satisfactory
155	2081/1/8	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	1.33	<5	7.47	82	26	24	0.1	0.02	4	0.45	0	Satisfactory
156	2081/1/8	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.99	72.8	30	26	0.1	0.02	4	0.31	0	Satisfactory
157	2081/1/8	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.45	<5	8.11	71.3	30	26	0.1	0.02	4	0.33	0	Satisfactory
158	2081/1/8	11:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.4	<5	8.02	73.2	30	26	0.1	0.02	4	0.62	0	Satisfactory
159	2081/1/8	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.52	59	20	22	0.1	0.02	6	0.34	0	Satisfactory
160	2081/1/8	15:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.57	71	24	30	0.1	0.02	6	0.1	0	Satisfactory
161	2081/1/9	10:40	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.95	<5	8.5	62.1	30	22	0.1	0.02	4	0.38	0	Satisfactory
162	2081/1/9	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.16	66	16	20	0.1	0.02	4	0.65	0	Satisfactory
163	2081/1/9	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.57	<5	7.56	65.3	14	20	0.1	0.02	4	0.65	0	Satisfactory
164	2081/1/9	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.93	<5	7.67	67.6	18	24	0.1	0.02	4	0.81	0	Satisfactory
165	2081/1/9	10:40	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.25	<5	7.99	80	30	26	0.1	0.02	4	0.85	0	Satisfactory
166	2081/1/9	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.79	<5	7.32	78.2	24	26	0.1	0.02	4	0.59	0	Satisfactory
167	2081/1/9	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.53	<5	7.64	79.8	26	24	0.1	0.02	4	0.55	0	Satisfactory
168	2081/1/9	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.37	<5	7.24	77.8	22	24	0.1	0.02	4	0.85	0	Satisfactory
169	2081/1/9	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.97	<5	7.4	80.3	24	26	0.1	0.02	4	0.43	0	Satisfactory

170	2081/1/9	8:30	Bhaktapur	Katunje SRT	Treated	Clear	1.67	<5	7.48	83	26	24	0.1	0.02	4	0.1	0	Satisfactory
171	2081/1/9	13:25	Lalitpur	Khumaltar SRT	Treated	Clear	1.96	<5	7.3	91.8	24	28	0.1	0.02	4	0.55	0	Satisfactory
172	2081/1/9	8:45	Kirtipur	Kirtipur SRT	Treated	Clear	1.26	<5	7.89	85.7	30	24	0.1	0.02	4	0.34	0	Satisfactory
173	2081/1/9	14:00	Baneshwar	Min Bhawan SRT	Treated	Clear	1.86	<5	7.12	80.5	22	26	0.1	0.02	4	0.44	0	Satisfactory
174	2081/1/9	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.6	<5	7.85	77.3	30	26	0.1	0.02	4	0.44	0	Satisfactory
175	2081/1/9	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.92	73	30	26	0.1	0.02	4	0.46	0	Satisfactory
176	2081/1/9	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.47	<5	7.84	72.4	30	26	0.1	0.02	4	0.81	0	Satisfactory
177	2081/1/9	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.46	<5	7.68	73.1	30	26	0.1	0.02	4	0.43	0	Satisfactory
178	2081/1/9	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.54	<5	7.87	73.5	30	26	0.1	0.02	4	1.12	0	Satisfactory
179	2081/1/9	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.44	73.2	30	26	0.1	0.02	4	0.99	0	Satisfactory
180	2081/1/9	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.36	<5	7.73	74.1	30	26	0.1	0.02	4	1.46	0	Satisfactory
181	2081/1/9	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.52	52	20	22	0.1	0.02	6	0.23	0	Satisfactory
182	2081/1/9	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.74	75	24	32	0.1	0.02	6	0.11	0	Satisfactory
183	2081/1/9	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.74	<5	6.84	338	90	80	0.3	1.5	16	0.6	0	Satisfactory
184	2081/1/9	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.82	<5	6.8	324	88	76	0.3	1.5	16	0.45	0	Satisfactory
185	2081/1/9	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	8.12	437	102	134	0.1	0.02	10	0.86	0	Satisfactory
186	2081/1/9	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.62	<5	7.4	86.4	24	38	0.1	0.02	4	0.1	0	Satisfactory
187	2081/1/10	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.26	<5	7.98	61	18	24	0.1	0.02	4	0.78	0	Satisfactory
188	2081/1/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.7	<5	7.17	61.5	30	18	0.1	0.02	4	0.36	0	Satisfactory
189	2081/1/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.98	<5	7.69	62.8	16	22	0.1	0.02	4	1.07	0	Satisfactory
190	2081/1/10	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.26	<5	7.6	61.3	14	20	0.1	0.02	4	0.11	0	Satisfactory
191	2081/1/10	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.44	<5	7.84	79.2	30	26	0.1	0.02	4	1.15	0	Satisfactory
192	2081/1/10	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.23	<5	7.02	73.3	10	24	0.1	0.02	4	1.29	0	Satisfactory
193	2081/1/10	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.82	<5	7.51	75.7	26	24	0.1	0.02	4	0.92	0	Satisfactory
194	2081/1/10	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.7	<5	7.49	76	26	24	0.1	0.02	4	0.92	0	Satisfactory
195	2081/1/10	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	1.78	<5	7.73	77.9	28	26	0.1	0.02	4	0.48	0	Satisfactory
196	2081/1/10	13:30	Maharajgunj	Balaju SRT	Treated	Clear	2.21	<5	7.79	78.9	28	24	0.1	0.02	4	0.1	0	Satisfactory
197	2081/1/10	6:08	Bhaktapur	Katunje SRT	Treated	Clear	1.69	<5	7.9	89	30	26	0.1	0.02	4	0.9	0	Satisfactory
198	2081/1/10	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	2.15	<5	7.73	79.9	28	26	0.1	0.02	4	0.1	0	Satisfactory
199	2081/1/10	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.9	<5	7.45	86.2	26	24	0.1	0.02	4	0.36	0	Satisfactory
200	2081/1/10	11:40	Baneshwar	Min Bhawan SRT	Treated	Clear	2.23	<5	7.62	77.8	26	28	0.1	0.02	4	0.75	0	Satisfactory
201	2081/1/10	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.82	<5	7.88	71.9	30	26	0.1	0.02	4	0.3	0	Satisfactory
202	2081/1/10	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	1.83	<5	7.98	72.7	30	26	0.1	0.02	4	0.59	0	Satisfactory
203	2081/1/10	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.98	<5	7.72	72.6	30	26	0.1	0.02	4	0.94	0	Satisfactory
204	2081/1/10	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.95	<5	7.46	71.7	30	26	0.1	0.02	4	0.93	0	Satisfactory
205	2081/1/10	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.5	<5	7.62	69	30	26	0.1	0.02	4	0.99	0	Satisfactory
206	2081/1/10	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.64	<5	7.81	69.6	30	26	0.1	0.02	4	0.57	0	Satisfactory
207	2081/1/10	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.51	54	18	18	0.1	0.02	6	0.34	0	Satisfactory
208	2081/1/10	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.62	77	24	32	0.1	0.02	6	0.14	0	Satisfactory
209	2081/1/10	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.75	<5	6.78	326	88	76	0.3	1.5	16	0.1	0	Satisfactory
210	2081/1/10	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	6.68	348	88	78	0.3	1.5	12	0.1	0	Satisfactory
211	2081/1/10	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.95	<5	8.22	452	108	140	0.1	0.02	12	1.15	0	Satisfactory
212	2081/1/10	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.66	<5	7.22	87.2	22	38	0.1	0.02	4	0.1	0	Satisfactory
213	2081/1/11	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.61	<5	7.87	64.4	30	24	0.1	0.02	4	0.68	0	Satisfactory
214	2081/1/11	12:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.57	<5	7.82	80.2	28	24	0.1	0.02	4	0.73	0	Satisfactory
215	2081/1/11	10:00	Tripureshwar	Anamnagar SRT	Treated	Clear	2.07	<5	7.93	82.3	30	26	0.1	0.02	4	0.44	0	Satisfactory
216	2081/1/11	7:10	Bhaktapur	Katunje SRT	Treated	Clear	1.51	<5	7.43	77.3	24	22	0.1	0.02	4	0.1	0	Satisfactory

217	2081/1/11	9:20	Lalitpur	Khumaltar SRT	Treated	Clear	2.1	<5	7.9	80.4	30	26	0.1	0.02	4	0.42	0	Satisfactory
218	2081/1/11	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.18	<5	7.92	84.2	30	26	0.1	0.02	4	0.32	0	Satisfactory
219	2081/1/11	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.7	<5	7.84	70	30	26	0.1	0.02	4	0.58	0	Satisfactory
220	2081/1/11	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.92	73.2	30	26	0.1	0.02	4	0.79	0	Satisfactory
221	2081/1/11	11:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.77	72.8	30	26	0.1	0.02	4	0.59	0	Satisfactory
222	2081/1/11	13:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.45	<5	7.61	72.4	30	26	0.1	0.02	4	0.83	0	Satisfactory
223	2081/1/11	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.26	<5	7.7	71.6	30	26	0.1	0.02	4	0.93	0	Satisfactory
224	2081/1/11	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.1	<5	7.50	51	18	18	0.1	0.02	6	0.28	0	Satisfactory
225	2081/1/11	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.52	77	24	32	0.1	0.02	6	0.52	0	Satisfactory
226	2081/1/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.09	<5	7.63	66.4	30	20	0.1	0.02	4	1.25	0	Satisfactory
227	2081/1/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.51	<5	7.58	71.4	30	20	0.1	0.02	4	0.41	0	Satisfactory
228	2081/1/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.37	<5	7.78	66.4	22	20	0.1	0.02	4	1.37	0	Satisfactory
229	2081/1/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.11	<5	7.87	67.3	22	20	0.1	0.02	4	1.25	0	Satisfactory
230	2081/1/12	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.92	<5	7.6	79.7	26	24	0.1	0.02	4	1.06	0	Satisfactory
231	2081/1/12	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.12	<5	7.61	79.4	26	24	0.1	0.02	4	0.81	0	Satisfactory
232	2081/1/12	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.12	<5	7.74	79.4	28	24	0.1	0.02	4	0.95	0	Satisfactory
233	2081/1/12	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.66	<5	7.77	78.5	28	26	0.1	0.02	4	0.63	0	Satisfactory
234	2081/1/12	7:30	Bhaktapur	Katunje SRT	Treated	Clear	2.44	<5	7.53	79.5	26	24	0.1	0.02	4	0.91	0	Satisfactory
235	2081/1/12	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.58	<5	7.75	88.4	28	26	0.1	0.02	4	0.44	0	Satisfactory
236	2081/1/12	9:45	Baneshwar	Min Bhawan SRT	Treated	Clear	2.12	<5	7.96	81.5	30	26	0.1	0.02	4	0.48	0	Satisfactory
237	2081/1/12	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.82	72.4	30	26	0.1	0.02	4	0.22	0	Satisfactory
238	2081/1/12	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.6	<5	7.88	74.4	30	26	0.1	0.02	4	0.87	0	Satisfactory
239	2081/1/12	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.73	73.7	30	26	0.1	0.02	4	0.42	0	Satisfactory
240	2081/1/12	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.86	<5	7.74	78.1	30	26	0.1	0.02	4	0.65	0	Satisfactory
241	2081/1/12	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.77	<5	7.72	77	30	26	0.1	0.02	4	0.97	0	Satisfactory
242	2081/1/12	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.56	<5	7.74	76.8	30	26	0.1	0.02	4	0.72	0	Satisfactory
243	2081/1/12	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.92	<5	7.81	76.9	30	26	0.1	0.02	4	0.5	0	Satisfactory
244	2081/1/12	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.52	50	18	18	0.1	0.02	6	0.23	0	Satisfactory
245	2081/1/12	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.82	77	24	32	0.1	0.02	6	0.1	0	Satisfactory
246	2081/1/12	13:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.76	76	26	32	0.1	0.02	6	0.1	0	Satisfactory
247	2081/1/12	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	6.76	314	86	74	0.3	1.5	12	0.1	0	Satisfactory
248	2081/1/12	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	6.74	319	86	74	0.3	1.5	12	0.1	0	Satisfactory
249	2081/1/12	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.64	<5	8.1	470	110	146	0.1	0.02	12	0.1	0	Satisfactory
250	2081/1/12	14:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.78	<5	7.23	85.9	22	38	0.1	0.02	4	0.53	0	Satisfactory
251	2081/1/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.16	<5	7.4	54.3	14	12	0.1	0.02	4	0.1	0	Satisfactory
252	2081/1/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.48	<5	7.61	58.7	26	14	0.1	0.02	4	0.46	0	Satisfactory
253	2081/1/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.59	58.9	16	14	0.1	0.02	4	0.82	0	Satisfactory
254	2081/1/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	7.71	59.4	22	16	0.1	0.02	4	1.31	0	Satisfactory
255	2081/1/13	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.77	<5	7.52	80.6	26	24	0.1	0.02	4	1.24	0	Satisfactory
256	2081/1/13	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.5	<5	7.7	79.1	28	24	0.1	0.02	4	0.95	0	Satisfactory
257	2081/1/13	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.56	<5	7.85	79.3	30	24	0.1	0.02	4	0.32	0	Satisfactory
258	2081/1/13	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.78	<5	7.81	77.7	30	24	0.1	0.02	4	0.77	0	Satisfactory
259	2081/1/13	10:05	Tripureshwar	Anamnagar SRT	Treated	Clear	2.47	<5	7.42	78	24	22	0.1	0.02	4	0.74	0	Satisfactory
260	2081/1/13	6:45	Bhaktapur	Katunje SRT	Treated	Clear	2.7	<5	7.57	78.8	26	24	0.1	0.02	4	0.89	0	Satisfactory
261	2081/1/13	9:20	Lalitpur	Khumaltar SRT	Treated	Clear	2.48	<5	7.53	77.3	26	24	0.1	0.02	4	0.71	0	Satisfactory
262	2081/1/13	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.16	<5	7.65	80.5	28	26	0.1	0.02	4	0.45	0	Satisfactory
263	2081/1/13	9:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.42	<5	7.54	78	26	24	0.1	0.02	4	0.78	0	Satisfactory

264	2081/1/13	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.6	79.4	30	26	0.1	0.02	4	1.08	0	Satisfactory
265	2081/1/13	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.56	77.1	30	26	0.1	0.02	4	1.17	0	Satisfactory
266	2081/1/13	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.59	<5	7.8	77.9	30	26	0.1	0.02	4	0.94	0	Satisfactory
267	2081/1/13	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.82	<5	7.91	72.8	30	26	0.1	0.02	4	0.48	0	Satisfactory
268	2081/1/13	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.71	<5	7.85	73.8	30	26	0.1	0.02	4	0.6	0	Satisfactory
269	2081/1/13	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.89	<5	7.8	73.7	30	26	0.1	0.02	4	0.22	0	Satisfactory
270	2081/1/13	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.83	<5	7.82	73.8	30	26	0.1	0.02	4	0.44	0	Satisfactory
271	2081/1/13	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.53	50	18	18	0.1	0.02	6	0.31	0	Satisfactory
272	2081/1/13	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.85	77	26	32	0.1	0.02	6	0.41	0	Satisfactory
273	2081/1/13	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.29	<5	6.76	309	86	72	0.3	1.2	12	0.1	0	Satisfactory
274	2081/1/13	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.47	<5	6.75	332	88	74	0.3	1.4	12	0.1	0	Satisfactory
275	2081/1/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.54	<5	8.17	470	110	146	0.1	0.02	12	0.56	0	Satisfactory
276	2081/1/13	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.71	<5	7.18	86.8	22	38	0.1	0.02	4	0.1	0	Satisfactory
277	2081/1/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.28	<5	7.55	58.9	16	20	0.1	0.02	4	0.87	0	Satisfactory
278	2081/1/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.23	<5	7.2	60.9	16	20	0.1	0.02	4	0.89	0	Satisfactory
279	2081/1/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.38	<5	7.71	66.2	18	18	0.1	0.02	4	0.56	0	Satisfactory
280	2081/1/14	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.2	<5	7.62	84.5	26	24	0.1	0.02	4	0.81	0	Satisfactory
281	2081/1/14	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.44	<5	7.08	83.08	20	26	0.1	0.02	4	0.9	0	Satisfactory
282	2081/1/14	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.43	<5	7.85	86.2	30	26	0.1	0.02	4	0.85	0	Satisfactory
283	2081/1/14	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	1.31	<5	7.89	86.2	30	26	0.1	0.02	4	1.03	0	Satisfactory
284	2081/1/14	12:35	Maharajgunj	Balaju SRT	Treated	Clear	1.76	<5	7.89	87.1	30	26	0.1	0.02	4	0.86	0	Satisfactory
285	2081/1/14	6:40	Bhaktapur	Katunje SRT	Treated	Clear	2.06	<5	7.58	88.7	26	24	0.1	0.02	4	0.33	0	Satisfactory
286	2081/1/14	11:40	Lalitpur	Khumaltar SRT	Treated	Clear	2.77	<5	7.89	94.6	30	28	0.1	0.02	4	0.1	0	Satisfactory
287	2081/1/14	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.05	<5	7.65	85.3	28	24	0.1	0.02	6	0.33	0	Satisfactory
288	2081/1/14	11:00	Baneshwar	Min Bhawan SRT	Treated	Clear	1.83	<5	7.88	84.8	30	26	0.1	0.02	4	0.63	0	Satisfactory
289	2081/1/14	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.28	<5	7.75	72.9	30	26	0.1	0.02	4	0.31	0	Satisfactory
290	2081/1/14	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	7.86	74.4	30	26	0.1	0.02	4	0.42	0	Satisfactory
291	2081/1/14	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.64	74.7	30	26	0.1	0.02	4	0.57	0	Satisfactory
292	2081/1/14	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.47	<5	7.74	74.8	30	26	0.1	0.02	4	0.61	0	Satisfactory
293	2081/1/14	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.65	<5	7.68	74.4	30	26	0.1	0.02	4	0.44	0	Satisfactory
294	2081/1/14	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.64	<5	7.77	74	30	26	0.1	0.02	4	0.35	0	Satisfactory
295	2081/1/14	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.48	52	18	18	0.1	0.02	6	0.45	0	Satisfactory
296	2081/1/14	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.61	76	24	32	0.1	0.02	6	0.51	0	Satisfactory
297	2081/1/14	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.86	<5	6.7	314	86	72	0.3	1.5	14	0.22	0	Satisfactory
298	2081/1/14	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.78	<5	6.72	320	86	74	0.3	1.5	14	0.26	0	Satisfactory
299	2081/1/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.48	<5	8.17	456	106	142	0.1	0.02	12	0.28	0	Satisfactory
300	2081/1/14	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.46	<5	7.1	91.9	24	38	0.1	0.02	4	0.27	0	Satisfactory
301	2081/1/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.81	<5	7.64	70.9	16	20	0.1	0.02	4	1.05	0	Satisfactory
302	2081/1/15	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.37	<5	7.27	85	14	26	0.1	0.02	4	0.93	0	Satisfactory
303	2081/1/15	7:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.24	<5	7.4	92.9	24	26	0.1	0.02	4	1.26	0	Satisfactory
304	2081/1/15	8:00	Maharajgunj	Balaju SRT	Treated	Clear	1.61	<5	7.41	85.1	24	24	0.1	0.02	4	0.63	0	Satisfactory
305	2081/1/15	6:59	Bhaktapur	Katunje SRT	Treated	Clear	2.47	<5	7.3	86.3	24	26	0.1	0.02	4	0.45	0	Satisfactory
306	2081/1/15	6:50	Lalitpur	Khumaltar SRT	Treated	Clear	1.94	<5	7.52	85.9	26	24	0.1	0.02	4	0.32	0	Satisfactory
307	2081/1/15	7:20	Baneshwar	Min Bhawan SRT	Treated	Clear	1.97	<5	7.42	87.5	24	26	0.1	0.02	4	0.94	0	Satisfactory
308	2081/1/15	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.29	<5	7.83	74.5	30	26	0.1	0.02	4	0.25	0	Satisfactory
309	2081/1/15	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.32	<5	7.89	74.8	30	26	0.1	0.02	4	0.18	0	Satisfactory
310	2081/1/15	11:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.37	<5	7.66	75.3	30	26	0.1	0.02	4	0.49	0	Satisfactory

311	2081/1/15	13:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.65	<5	7.78	75.3	30	26	0.1	0.02	4	0.54	0	Satisfactory
312	2081/1/15	15:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.48	<5	7.77	73.5	30	26	0.1	0.02	4	0.71	0	Satisfactory
313	2081/1/15	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.57	<5	7.71	75.3	30	26	0.1	0.02	4	0.5	0	Satisfactory
314	2081/1/15	11:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.54	72	24	28	0.1	0.02	6	0.41	0	Satisfactory
315	2081/1/15	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.68	76	24	32	0.1	0.02	6	0.44	0	Satisfactory
316	2081/1/16	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.78	<5	7.59	58.1	14	14	0.1	0.02	4	0.76	0	Satisfactory
317	2081/1/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.62	<5	7.57	59.8	30	16	0.1	0.02	4	0.52	0	Satisfactory
318	2081/1/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.47	<5	7.76	65.8	32	14	0.1	0.02	4	0.95	0	Satisfactory
319	2081/1/16	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.65	<5	7.83	67.3	38	16	0.1	0.02	4	1.09	0	Satisfactory
320	2081/1/16	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.6	<5	7.75	85.7	28	24	0.1	0.02	4	0.8	0	Satisfactory
321	2081/1/16	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.3	<5	7.5	86.2	26	24	0.1	0.02	4	0.89	0	Satisfactory
322	2081/1/16	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.12	<5	7.87	90	30	28	0.1	0.02	4	0.79	0	Satisfactory
323	2081/1/16	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.1	<5	7.88	87.5	30	26	0.1	0.02	4	0.73	0	Satisfactory
324	2081/1/16	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.83	<5	8.04	84.4	30	26	0.1	0.02	4	0.13	0	Satisfactory
325	2081/1/16	6:59	Bhaktapur	Katunje SRT	Treated	Clear	1.62	<5	7.52	86.4	26	24	0.1	0.02	4	0.75	0	Satisfactory
326	2081/1/16	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	2.04	<5	8.06	95.3	30	26	0.1	0.02	4	0.1	0	Satisfactory
327	2081/1/16	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.25	<5	7.45	85.6	26	24	0.1	0.02	4	0.1	0	Satisfactory
328	2081/1/16	11:10	Baneshwar	Min Bhawan SRT	Treated	Clear	1.86	<5	7.78	87.8	28	26	0.1	0.02	4	0.72	0	Satisfactory
329	2081/1/16	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.36	<5	7.71	74.4	30	26	0.1	0.02	4	0.13	0	Satisfactory
330	2081/1/16	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.45	<5	7.79	75.7	30	26	0.1	0.02	4	0.12	0	Satisfactory
331	2081/1/16	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.69	<5	7.79	76.4	30	26	0.1	0.02	4	0.33	0	Satisfactory
332	2081/1/16	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.76	75.8	30	26	0.1	0.02	4	0.32	0	Satisfactory
333	2081/1/16	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.52	<5	7.92	75.3	30	26	0.1	0.02	4	0.24	0	Satisfactory
334	2081/1/16	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.89	75.3	30	26	0.1	0.02	4	0.42	0	Satisfactory
335	2081/1/16	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.51	72	24	28	0.1	0.02	6	0.41	0	Satisfactory
336	2081/1/16	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.80	78	26	34	0.1	0.02	6	0.43	0	Satisfactory
337	2081/1/16	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.72	77	24	32	0.1	0.02	6	0.1	0	Satisfactory
338	2081/1/16	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.74	<5	6.71	320	86	74	0.3	1.4	14	0.49	0	Satisfactory
339	2081/1/16	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	6.7	311	86	72	0.3	1.5	14	0.41	0	Satisfactory
340	2081/1/16	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.57	<5	7.96	465	110	142	0.1	0.02	12	0.78	0	Satisfactory
341	2081/1/16	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.87	<5	7.1	93.4	24	38	0.1	0.02	4	0.1	0	Satisfactory
342	2081/1/17	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.04	<5	7.39	65.1	14	24	0.1	0.02	4	0.85	0	Satisfactory
343	2081/1/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.08	<5	7.61	70	26	24	0.1	0.02	4	0.52	0	Satisfactory
344	2081/1/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.43	<5	7.68	69.2	18	22	0.1	0.02	4	1.4	0	Satisfactory
345	2081/1/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.51	<5	7.86	69	16	14	0.1	0.02	4	1.42	0	Satisfactory
346	2081/1/17	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.18	<5	7.62	87.1	26	24	0.1	0.02	4	0.6	0	Satisfactory
347	2081/1/17	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.47	<5	7.85	86.4	30	26	0.1	0.02	4	0.74	0	Satisfactory
348	2081/1/17	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.86	<5	7.73	86.5	28	26	0.1	0.02	4	0.44	0	Satisfactory
349	2081/1/17	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.8	<5	7.93	90.4	30	20	0.1	0.02	4	0.41	0	Satisfactory
350	2081/1/17	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	1.44	<5	7.89	87.4	30	26	0.1	0.02	4	0.72	0	Satisfactory
351	2081/1/17	13:00	Maharajgunj	Balaju SRT	Treated	Clear	0.74	<5	7.9	87.3	30	24	0.1	0.02	4	0.74	0	Satisfactory
352	2081/1/17	6:58	Bhaktapur	Katunje SRT	Treated	Clear	1.73	<5	6.69	87.7	12	26	0.1	0.02	6	0.42	0	Satisfactory
353	2081/1/17	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.61	<5	7.73	97.2	28	26	0.1	0.02	4	0.44	0	Satisfactory
354	2081/1/17	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.37	<5	7.5	86.2	26	24	0.1	0.02	4	0.3	0	Satisfactory
355	2081/1/17	10:05	Baneshwar	Min Bhawan SRT	Treated	Clear	1.66	<5	7.88	87.2	30	26	0.1	0.02	4	0.46	0	Satisfactory
356	2081/1/17	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.82	76.9	30	26	0.1	0.02	4	0.17	0	Satisfactory
357	2081/1/17	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.47	<5	7.9	74.8	30	26	0.1	0.02	4	0.32	0	Satisfactory

358	2081/1/17	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.9	78.2	30	26	0.1	0.02	4	0.16	0	Satisfactory
359	2081/1/17	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.7	75.8	30	26	0.1	0.02	4	0.45	0	Satisfactory
360	2081/1/17	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.55	<5	7.35	75.3	30	26	0.1	0.02	4	0.47	0	Satisfactory
361	2081/1/17	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.76	<5	7.55	75.6	30	26	0.1	0.02	4	0.27	0	Satisfactory
362	2081/1/17	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.65	<5	7.28	75.7	30	26	0.1	0.02	4	0.66	0	Satisfactory
363	2081/1/17	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.54	71	24	26	0.1	0.02	6	0.32	0	Satisfactory
364	2081/1/17	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.61	78	26	34	0.1	0.02	6	0.41	0	Satisfactory
365	2081/1/17	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.60	74	24	32	0.1	0.02	6	0.14	0	Satisfactory
366	2081/1/17	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.72	<5	6.9	333	92	80	0.3	1.5	16	0.83	0	Satisfactory
367	2081/1/17	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	6.79	311	84	70	0.3	1.5	14	0.41	0	Satisfactory
368	2081/1/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.79	<5	8	563	112	156	0.1	0.02	40	0.16	0	Satisfactory
369	2081/1/17	11:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.25	<5	7.05	92	24	38	0.1	0.02	4	0.23	0	Satisfactory
370	2081/1/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.95	<5	7.75	64.3	28	20	0.1	0.02	4	0.1	0	Satisfactory
371	2081/1/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.79	<5	7.7	64.6	16	20	0.1	0.02	4	0.18	0	Satisfactory
372	2081/1/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.61	<5	7.72	68.7	14	16	0.1	0.02	4	0.45	0	Satisfactory
373	2081/1/18	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.22	<5	7.78	73.4	18	20	0.1	0.02	4	1.76	0	Satisfactory
374	2081/1/18	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.64	<5	7.78	88.7	26	24	0.1	0.02	4	0.39	0	Satisfactory
375	2081/1/18	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.57	<5	7.74	88.4	28	26	0.1	0.02	4	0.42	0	Satisfactory
376	2081/1/18	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.18	<5	7.58	91.4	30	28	0.1	0.02	4	0.16	0	Satisfactory
377	2081/1/18	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.1	<5	7.71	88.6	28	24	0.1	0.02	4	0.48	0	Satisfactory
378	2081/1/18	10:40	Tripureshwar	Anamnagar SRT	Treated	Clear	1.15	<5	7.99	86	30	26	0.1	0.02	4	0.1	0	Satisfactory
379	2081/1/18	7:05	Bhaktapur	Katunje SRT	Treated	Clear	2.75	<5	7.75	92.8	28	26	0.1	0.02	4	0.61	0	Satisfactory
380	2081/1/18	11:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.34	<5	7.83	92.5	28	26	0.1	0.02	4	0.1	0	Satisfactory
381	2081/1/18	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.24	<5	7.49	87.7	26	24	0.1	0.02	4	0.32	0	Satisfactory
382	2081/1/18	10:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.49	<5	7.84	88.4	28	26	0.1	0.02	4	0.25	0	Satisfactory
383	2081/1/18	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.95	74	30	26	0.1	0.02	4	0.1	0	Satisfactory
384	2081/1/18	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.42	<5	7.48	76.6	30	26	0.1	0.02	4	0.44	0	Satisfactory
385	2081/1/18	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.52	76.4	30	26	0.1	0.02	4	0.46	0	Satisfactory
386	2081/1/18	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.68	75.5	30	26	0.1	0.02	4	0.43	0	Satisfactory
387	2081/1/18	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.69	75.4	30	26	0.1	0.02	4	0.24	0	Satisfactory
388	2081/1/18	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.6	<5	7.6	75.6	30	26	0.1	0.02	4	0.59	0	Satisfactory
389	2081/1/18	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.54	76	24	28	0.1	0.02	6	0.42	0	Satisfactory
390	2081/1/18	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.81	79	24	32	0.1	0.02	6	0.1	0	Satisfactory
391	2081/1/18	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.51	78	26	34	0.1	0.02	6	0.37	0	Satisfactory
392	2081/1/18	12:35	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.54	68	26	34	0.1	0.02	6	0.28	0	Satisfactory
393	2081/1/18	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.51	<5	6.7	347	88	80	0.3	1.5	16	1.05	0	Satisfactory
394	2081/1/18	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.08	<5	6.7	319	86	72	0.3	1.4	14	0.38	0	Satisfactory
395	2081/1/18	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.19	<5	7.97	455	108	136	0.1	0.02	12	0.86	0	Satisfactory
396	2081/1/18	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.95	<5	7.1	91.3	24	38	0.1	0.02	4	0.1	0	Satisfactory
397	2081/1/19	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.7	75.2	26	14	0.1	0.02	4	0.55	0	Satisfactory
398	2081/1/19	9:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.15	<5	7.9	92.8	30	26	0.1	0.02	4	0.57	0	Satisfactory
399	2081/1/19	7:40	Tripureshwar	Anamnagar SRT	Treated	Clear	2.88	<5	8.04	91.2	28	26	0.1	0.02	4	0.62	0	Satisfactory
400	2081/1/19	8:00	Maharajgunj	Balaju SRT	Treated	Clear	1.78	<5	7.79	91	28	26	0.1	0.02	4	0.42	0	Satisfactory
401	2081/1/19	5:55	Bhaktapur	Katunje SRT	Treated	Clear	2.93	<5	7.57	93.4	26	28	0.1	0.02	4	0.34	0	Satisfactory
402	2081/1/19	7:05	Lalitpur	Khumaltar SRT	Treated	Clear	2.47	<5	7.93	101.3	30	26	0.1	0.02	4	0.37	0	Satisfactory
403	2081/1/19	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.63	<5	7.67	88.5	28	26	0.1	0.02	4	0.25	0	Satisfactory
404	2081/1/19	7:20	Baneshwar	Min Bhawan SRT	Treated	Clear	2.25	<5	7.85	91.4	30	26	0.1	0.02	4	0.6	0	Satisfactory

405	2081/1/19	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.39	<5	7.9	74.7	30	26	0.1	0.02	4	0.14	0	Satisfactory
406	2081/1/19	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.78	77.5	30	26	0.1	0.02	4	0.56	0	Satisfactory
407	2081/1/19	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.46	<5	7.82	76.2	30	26	0.1	0.02	4	0.85	0	Satisfactory
408	2081/1/19	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.91	76.8	30	26	0.1	0.02	4	0.75	0	Satisfactory
409	2081/1/19	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.48	67	24	28	0.1	0.02	6	0.26	0	Satisfactory
410	2081/1/19	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.2	<5	7.76	77	26	24	0.1	0.02	6	0.45	0	Satisfactory
411	2081/1/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.31	<5	7.53	78.1	14	22	0.1	0.02	4	0.84	0	Satisfactory
412	2081/1/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.36	<5	7.58	79.1	18	14	0.1	0.02	4	1.02	0	Satisfactory
413	2081/1/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.23	<5	7.68	81.7	14	16	0.1	0.02	4	1.01	0	Satisfactory
414	2081/1/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.38	<5	7.6	82.1	26	20	0.1	0.02	4	1.02	0	Satisfactory
415	2081/1/20	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.16	<5	7.59	90.3	26	28	0.1	0.02	4	0.51	0	Satisfactory
416	2081/1/20	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	3.07	<5	7.79	88.9	28	26	0.1	0.02	4	0.48	0	Satisfactory
417	2081/1/20	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.37	<5	7.76	89.1	28	26	0.1	0.02	4	0.45	0	Satisfactory
418	2081/1/20	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.01	<5	7.75	87.9	28	24	0.1	0.02	4	0.58	0	Satisfactory
419	2081/1/20	10:45	Tripureshwar	Anamnagar SRT	Treated	Clear	1.87	<5	7.75	88.8	28	26	0.1	0.02	4	0.1	0	Satisfactory
420	2081/1/20	7:10	Bhaktapur	Katunje SRT	Treated	Clear	1.48	<5	7.72	97.7	28	26	0.1	0.02	4	0.1	0	Satisfactory
421	2081/1/20	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.93	<5	7.72	97.2	28	30	0.1	0.02	4	0.1	0	Satisfactory
422	2081/1/20	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.13	<5	7.76	92.5	28	26	0.1	0.02	4	0.27	0	Satisfactory
423	2081/1/20	11:00	Baneshwar	Min Bhawan SRT	Treated	Clear	2.16	<5	7.81	89.1	28	26	0.1	0.02	4	0.37	0	Satisfactory
424	2081/1/20	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.38	<5	7.92	81.7	30	26	0.1	0.02	4	0.17	0	Satisfactory
425	2081/1/20	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.97	<5	7.82	83.4	30	26	0.1	0.02	4	0.2	0	Satisfactory
426	2081/1/20	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.52	<5	7.74	87.3	30	26	0.1	0.02	4	0.28	0	Satisfactory
427	2081/1/20	13:15	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.57	<5	7.41	74.8	30	26	0.1	0.02	4	0.46	0	Satisfactory
428	2081/1/20	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.45	<5	7.46	75.6	30	26	0.1	0.02	4	0.49	0	Satisfactory
429	2081/1/20	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.7	<5	7.69	75.5	30	26	0.1	0.02	4	0.36	0	Satisfactory
430	2081/1/20	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.55	<5	7.71	75.2	30	26	0.1	0.02	4	0.61	0	Satisfactory
431	2081/1/20	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	65	22	26	0.1	0.02	6	0.26	0	Satisfactory
432	2081/1/20	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.57	76	24	32	0.1	0.02	6	0.1	0	Satisfactory
433	2081/1/20	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.56	78	26	34	0.1	0.02	6	0.32	0	Satisfactory
434	2081/1/20	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.38	<5	6.71	317	86	72	0.3	1.5	14	0.28	0	Satisfactory
435	2081/1/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.04	<5	8.09	447	106	140	0.1	0.02	10	0.71	0	Satisfactory
436	2081/1/20	10:20	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.3	93.8	26	38	0.1	0.02	4	0.1	0	Satisfactory
437	2081/1/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.37	<5	7.34	67.4	14	24	0.1	0.02	4	0.1	0	Satisfactory
438	2081/1/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.79	<5	7.73	68.5	12	22	0.1	0.02	4	0.1	0	Satisfactory
439	2081/1/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.62	<5	7.5	69.7	26	22	0.1	0.02	4	0.24	0	Satisfactory
440	2081/1/21	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.1	<5	7.41	88	24	26	0.1	0.02	4	0.26	0	Satisfactory
441	2081/1/21	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.25	<5	7.76	89.2	28	26	0.1	0.02	4	0.23	0	Satisfactory
442	2081/1/21	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.35	<5	7.57	88.5	26	24	0.1	0.02	4	0.34	0	Satisfactory
443	2081/1/21	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.64	91.2	30	26	0.1	0.02	4	0.1	0	Satisfactory
444	2081/1/21	12:30	Maharajgunj	Balaju SRT	Treated	Clear	0.04	<5	7.79	89.2	30	24	0.1	0.02	4	0.1	0	Satisfactory
445	2081/1/21	8:10	Bhaktapur	Katunje SRT	Treated	Clear	0.26	<5	7.19	88.9	22	24	0.1	0.02	4	0.38	0	Satisfactory
446	2081/1/21	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.03	<5	7.84	89.4	28	26	0.1	0.02	4	0.1	0	Satisfactory
447	2081/1/21	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.18	<5	7.72	97.7	28	30	0.1	0.02	4	0.1	0	Satisfactory
448	2081/1/21	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	0.1	<5	7.73	90.2	26	26	0.1	0.02	4	0.1	0	Satisfactory
449	2081/1/21	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.33	<5	7.77	74.2	30	26	0.1	0.02	4	0.12	0	Satisfactory
450	2081/1/21	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.31	<5	7.72	76.1	30	26	0.1	0.02	4	0.72	0	Satisfactory
451	2081/1/21	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.41	<5	7.77	76.2	30	26	0.1	0.02	4	0.26	0	Satisfactory

452	2081/1/21	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.66	<5	7.71	76.3	30	26	0.1	0.02	4	0.54	0	Satisfactory
453	2081/1/21	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.82	75.8	30	26	0.1	0.02	4	0.43	0	Satisfactory
454	2081/1/21	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.57	<5	7.79	73.1	30	26	0.1	0.02	4	0.35	0	Satisfactory
455	2081/1/21	18:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.78	75.3	30	26	0.1	0.02	4	0.74	0	Satisfactory
456	2081/1/21	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.2	<5	7.50	72	24	28	0.1	0.02	6	0.42	0	Satisfactory
457	2081/1/21	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.74	77	26	32	0.1	0.02	6	0.52	0	Satisfactory
458	2081/1/21	13:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.1	<5	7.80	79	26	34	0.1	0.02	6	0.20	0	Satisfactory
459	2081/1/21	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	6.71	307	84	72	0.3	1.5	14	0.21	0	Satisfactory
460	2081/1/21	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.89	<5	8.16	437	106	120	0.1	0.02	10	0.1	0	Satisfactory
461	2081/1/21	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.82	<5	7.29	88.8	24	38	0.1	0.02	4	0.1	0	Satisfactory
462	2081/1/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.85	<5	7.72	65.8	26	16	0.1	0.02	4	0.1	0	Satisfactory
463	2081/1/22	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.88	<5	6.97	91.1	12	34	0.1	0.02	4	0.61	0	Satisfactory
464	2081/1/22	7:40	Tripureshwar	Anamnagar SRT	Treated	Clear	2.52	<5	7.32	89.2	24	28	0.1	0.02	4	0.54	0	Satisfactory
465	2081/1/22	8:10	Maharajgunj	Balaju SRT	Treated	Clear	3.62	<5	7.4	89	24	28	0.1	0.02	4	0.68	0	Satisfactory
466	2081/1/22	7:05	Lalitpur	Khumaltar SRT	Treated	Clear	1.56	<5	7.16	90.8	22	28	0.1	0.02	4	0.1	0	Satisfactory
467	2081/1/22	7:30	Baneshwar	Min Bhawan SRT	Treated	Clear	2.58	<5	7.25	90.4	24	28	0.1	0.02	4	0.69	0	Satisfactory
468	2081/1/22	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.28	<5	8.04	74.7	30	26	0.1	0.02	4	0.1	0	Satisfactory
469	2081/1/22	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.26	<5	7.97	76.2	30	26	0.1	0.02	4	0.45	0	Satisfactory
470	2081/1/22	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.41	<5	7.91	76.3	30	26	0.1	0.02	4	0.41	0	Satisfactory
471	2081/1/22	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.44	<5	7.86	76.5	30	26	0.1	0.02	4	0.62	0	Satisfactory
472	2081/1/22	15:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.98	<5	7.93	76.6	30	26	0.1	0.02	4	0.52	0	Satisfactory
473	2081/1/22	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.51	73	24	30	0.1	0.02	6	0.32	0	Satisfactory
474	2081/1/22	15:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.72	78	26	32	0.1	0.02	6	0.42	0	Satisfactory
475	2081/1/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	7.28	85.7	26	18	0.1	0.02	4	0.84	0	Satisfactory
476	2081/1/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.36	<5	7.56	89.6	14	20	0.1	0.02	4	1.42	0	Satisfactory
477	2081/1/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.46	84.3	14	22	0.1	0.02	4	1.3	0	Satisfactory
478	2081/1/23	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.74	89.4	26	22	0.1	0.02	4	1.91	0	Satisfactory
479	2081/1/23	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.26	<5	7.45	85.6	26	14	0.1	0.02	4	0.21	0	Satisfactory
480	2081/1/23	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.39	<5	7.8	86.9	28	24	0.1	0.02	4	0.74	0	Satisfactory
481	2081/1/23	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.25	<5	7.63	88.3	26	24	0.1	0.02	4	0.63	0	Satisfactory
482	2081/1/23	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.18	<5	7.88	87.3	30	24	0.1	0.02	4	0.52	0	Satisfactory
483	2081/1/23	12:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.36	<5	7.69	88.3	28	26	0.1	0.02	4	0.1	0	Satisfactory
484	2081/1/23	12:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.72	<5	7.72	90.1	28	26	0.1	0.02	4	0.1	0	Satisfactory
485	2081/1/23	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.92	<5	7.57	85.8	26	24	0.1	0.02	4	0.1	0	Satisfactory
486	2081/1/23	12:15	Baneshwar	Min Bhawan SRT	Treated	Clear	0.45	<5	7.56	90.2	26	28	0.1	0.02	4	0.1	0	Satisfactory
487	2081/1/23	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.35	<5	7.94	73	30	26	0.1	0.02	4	0.13	0	Satisfactory
488	2081/1/23	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.43	<5	7.94	72.5	30	26	0.1	0.02	4	0.57	0	Satisfactory
489	2081/1/23	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.62	<5	7.86	74.4	30	26	0.1	0.02	4	0.45	0	Satisfactory
490	2081/1/23	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.7	<5	7.98	73.7	30	26	0.1	0.02	4	0.26	0	Satisfactory
491	2081/1/23	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.75	<5	7.91	72.2	30	26	0.1	0.02	4	0.54	0	Satisfactory
492	2081/1/23	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.61	74.8	30	26	0.1	0.02	4	0.27	0	Satisfactory
493	2081/1/23	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.55	69	24	28	0.1	0.02	6	0.36	0	Satisfactory
494	2081/1/23	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.80	77	26	32	0.1	0.02	6	0.30	0	Satisfactory
495	2081/1/23	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.67	76	26	34	0.1	0.02	6	0.26	0	Satisfactory
496	2081/1/23	12:20	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.72	78	26	34	0.1	0.02	6	0.31	0	Satisfactory
497	2081/1/23	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.98	<5	6.7	290	82	70	0.3	1.5	10	0.1	0	Satisfactory
498	2081/1/23	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.62	<5	6.7	295	82	72	0.3	1.5	10	0.44	0	Satisfactory

499	2081/1/23	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.02	<5	7.89	419	98	126	0.1	0.02	8	0.1	0	Satisfactory
500	2081/1/23	16:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.86	<5	7.1	91.4	24	38	0.1	0.02	4	0.2	0	Satisfactory
501	2081/1/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.97	81.8	30	22	0.1	0.02	4	0.75	0	Satisfactory
502	2081/1/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.4	83.2	14	20	0.1	0.02	4	0.32	0	Satisfactory
503	2081/1/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.42	<5	7.5	85.4	26	22	0.1	0.02	4	0.61	0	Satisfactory
504	2081/1/24	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.79	<5	7.57	75.5	36	20	0.1	0.02	4	0.24	0	Satisfactory
505	2081/1/24	10:30	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	0.59	<5	7.47	85.1	26	24	0.1	0.02	4	0.47	0	Satisfactory
506	2081/1/24	12:00	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	0.5	<5	7.47	93.5	26	28	0.1	0.02	4	0.35	0	Satisfactory
507	2081/1/24	14:00	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	0.16	<5	7.76	87.8	28	24	0.1	0.02	4	0.53	0	Satisfactory
508	2081/1/24	15:30	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	0.4	<5	7.41	84.8	24	26	0.1	0.02	4	0.37	0	Satisfactory
509	2081/1/24	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.85	<5	8.2	85.5	32	24	0.1	0.02	4	0.1	0	Satisfactory
510	2081/1/24	13:10	Maharajgunj	Balaju SRT	Treated	Clear	0.55	<5	8.2	86.6	32	24	0.1	0.02	4	0.1	0	Satisfactory
511	2081/1/24	8:10	Bhaktapur	Katunje SRT	Treated	Clear	0.46	<5	7.28	89.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
512	2081/1/24	7:40	Bhaktapur	Katunje SRT	Treated	Clear	0.05	<5	7.25	88.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
513	2081/1/24	7:06	Bhaktapur	Katunje SRT	Treated	Clear	0.01	<5	7.31	86.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
514	2081/1/24	11:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.87	<5	8.02	87.7	30	24	0.1	0.02	4	0.1	0	Satisfactory
515	2081/1/24	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.83	<5	7.46	93.5	26	28	0.1	0.02	4	0.1	0	Satisfactory
516	2081/1/24	11:20	Baneshwar	Min Bhawan SRT	Treated	Clear	0.89	<5	8.15	93.1	32	28	0.1	0.02	4	0.24	0	Satisfactory
517	2081/1/24	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.48	<5	8.07	74.8	30	26	0.1	0.02	4	0.1	0	Satisfactory
518	2081/1/24	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.94	76.5	30	26	0.1	0.02	4	0.7	0	Satisfactory
519	2081/1/24	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.9	73.6	30	26	0.1	0.02	4	0.35	0	Satisfactory
520	2081/1/24	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.76	70.7	30	26	0.1	0.02	4	0.34	0	Satisfactory
521	2081/1/24	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.9	73.5	30	26	0.1	0.02	4	0.7	0	Satisfactory
522	2081/1/24	16:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.81	71.2	30	26	0.1	0.02	4	0.28	0	Satisfactory
523	2081/1/24	17:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	1.33	<5	7.77	71.1	30	26	0.1	0.02	4	0.19	0	Satisfactory
524	2081/1/24	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.52	67	22	28	0.1	0.02	6	0.33	0	Satisfactory
525	2081/1/24	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.67	78	26	34	0.1	0.02	6	0.20	0	Satisfactory
526	2081/1/24	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.53	76	24	32	0.1	0.02	6	0.43	0	Satisfactory
527	2081/1/24	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.78	<5	6.75	317	86	72	0.3	1.5	14	0.14	0	Satisfactory
528	2081/1/24	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.88	<5	6.75	323	88	72	0.3	1.5	14	0.29	0	Satisfactory
529	2081/1/24	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.43	<5	8.06	435	106	138	0.1	0.02	10	0.89	0	Satisfactory
530	2081/1/24	11:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.15	90.6	24	38	0.1	0.02	4	0.1	0	Satisfactory
531	2081/1/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.04	107.7	42	24	0.1	0.02	4	0.1	0	Satisfactory
532	2081/1/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	8.16	126.4	26	28	0.1	0.02	4	0.1	0	Satisfactory
533	2081/1/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.92	167.1	18	22	0.1	0.02	4	0.37	0	Satisfactory
534	2081/1/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.5	<5	6.92	172.8	16	34	0.1	0.02	4	0.43	0	Satisfactory
535	2081/1/25	10:30	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	0.32	<5	7.46	88.1	26	24	0.1	0.02	4	0.84	0	Satisfactory
536	2081/1/25	12:00	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	2.38	<5	8.24	89.3	32	24	0.1	0.02	4	0.75	0	Satisfactory
537	2081/1/25	14:00	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	0.3	<5	7.41	89.1	24	26	0.1	0.02	4	0.76	0	Satisfactory
538	2081/1/25	15:30	Mahankalchaur	Mahankalchaur Melamchauri	Treated	Clear	3.66	<5	7.49	85	26	24	0.1	0.02	4	1.87	0	Satisfactory
539	2081/1/25	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.45	<5	7.54	84.9	26	24	0.1	0.02	4	0.1	0	Satisfactory
540	2081/1/25	6:40	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.31	82.5	24	26	0.1	0.02	4	0.61	0	Satisfactory
541	2081/1/25	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.82	<5	7.15	90.7	22	26	0.1	0.02	4	0.1	0	Satisfactory
542	2081/1/25	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.52	<5	7.4	90.8	24	32	0.1	0.02	4	0.1	0	Satisfactory
543	2081/1/25	11:20	Baneshwar	Min Bhawan SRT	Treated	Clear	0.42	<5	7.29	84.2	24	26	0.1	0.02	4	0.1	0	Satisfactory
544	2081/1/25	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.33	<5	8.06	74.7	30	26	0.1	0.02	4	0.13	0	Satisfactory
545	2081/1/25	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.82	71.1	30	26	0.1	0.02	4	0.21	0	Satisfactory

546	2081/1/25	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.88	<5	7.7	73	30	26	0.1	0.02	4	0.37	0	Satisfactory
547	2081/1/25	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.54	<5	7.94	73.8	30	26	0.1	0.02	4	0.94	0	Satisfactory
548	2081/1/25	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.91	<5	7.96	72.6	30	26	0.1	0.02	4	0.73	0	Satisfactory
549	2081/1/25	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.94	<5	8.05	71.7	30	26	0.1	0.02	4	0.56	0	Satisfactory
550	2081/1/25	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.52	71	24	28	0.1	0.02	6	0.31	0	Satisfactory
551	2081/1/25	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.4	<5	7.80	76	24	32	0.1	0.02	6	0.16	0	Satisfactory
552	2081/1/25	15:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.52	75	24	32	0.1	0.02	6	0.14	0	Satisfactory
553	2081/1/25	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.72	<5	6.86	325	88	76	0.3	1.5	14	0.27	0	Satisfactory
554	2081/1/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.94	<5	8.17	466	110	144	0.1	0.02	14	0.91	0	Satisfactory
555	2081/1/25	16:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.1	89	24	38	0.1	0.02	4	0.14	0	Satisfactory
556	2081/1/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.43	<5	6.5	110.6	28	28	0.1	0.02	4	0.1	0	Satisfactory
557	2081/1/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.73	<5	6.5	111.9	16	24	0.1	0.02	4	0.1	0	Satisfactory
558	2081/1/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.88	<5	6.5	128.5	16	24	0.1	0.02	4	0.4	0	Satisfactory
559	2081/1/26	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.76	<5	6.5	130.6	16	28	0.1	0.02	4	0.58	0	Satisfactory
560	2081/1/26	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.7	<5	7.32	87.4	24	26	0.1	0.02	4	0.95	0	Satisfactory
561	2081/1/26	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	2.89	<5	6.96	87.6	20	26	0.1	0.02	4	0.93	0	Satisfactory
562	2081/1/26	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	1.3	<5	6.78	89.1	18	24	0.1	0.02	4	0.78	0	Satisfactory
563	2081/1/26	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.51	<5	7.67	86.1	20	26	0.1	0.02	4	0.91	0	Satisfactory
564	2081/1/26	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.6	86.7	26	24	0.1	0.02	4	0.1	0	Satisfactory
565	2081/1/26	7:05	Bhaktapur	Katunje SRT	Treated	Clear	0.29	<5	7.6	89.5	26	24	0.1	0.02	4	0.49	0	Satisfactory
566	2081/1/26	12:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.39	<5	7.3	87.1	24	26	0.1	0.02	4	0.39	0	Satisfactory
567	2081/1/26	9:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.84	<5	7.62	97.3	26	30	0.1	0.02	4	0.1	0	Satisfactory
568	2081/1/26	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.68	<5	8.12	74.3	30	26	0.1	0.02	4	0.11	0	Satisfactory
569	2081/1/26	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.67	<5	7.88	77.9	30	26	0.1	0.02	4	0.97	0	Satisfactory
570	2081/1/26	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.97	<5	7.7	70.1	30	26	0.1	0.02	4	0.23	0	Satisfactory
571	2081/1/26	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.73	<5	7.76	73.2	30	26	0.1	0.02	4	0.46	0	Satisfactory
572	2081/1/26	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.81	<5	7.8	73.5	30	26	0.1	0.02	4	0.38	0	Satisfactory
573	2081/1/26	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.72	<5	7.9	73.1	30	26	0.1	0.02	4	0.85	0	Satisfactory
574	2081/1/26	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.3	<5	7.53	72	24	28	0.1	0.02	6	0.22	0	Satisfactory
575	2081/1/26	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.73	77	24	32	0.1	0.02	6	0.1	0	Satisfactory
576	2081/1/26	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.3	<5	7.74	75	24	32	0.1	0.02	6	0.16	0	Satisfactory
577	2081/1/26	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.85	<5	6.75	319	86	72	0.3	1.5	14	0.3	0	Satisfactory
578	2081/1/26	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.92	<5	6.72	326	88	74	0.3	1.5	14	0.36	0	Satisfactory
579	2081/1/26	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	8.12	459	108	140	0.1	0.02	14	0.56	0	Satisfactory
580	2081/1/26	13:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.81	<5	7.28	90.8	24	38	0.1	0.02	4	0.44	0	Satisfactory
581	2081/1/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.01	85	16	22	0.1	0.02	4	0.53	0	Satisfactory
582	2081/1/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	6.99	87.8	26	26	0.1	0.02	4	0.57	0	Satisfactory
583	2081/1/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.33	<5	6.88	88.7	16	26	0.1	0.02	4	0.51	0	Satisfactory
584	2081/1/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.21	87.4	10	28	0.1	0.02	4	0.3	0	Satisfactory
585	2081/1/27	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.79	<5	7.32	87.2	24	26	0.1	0.02	4	0.32	0	Satisfactory
586	2081/1/27	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.56	<5	7.38	87.8	24	26	0.1	0.02	4	0.35	0	Satisfactory
587	2081/1/27	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.35	<5	7.53	88.1	26	24	0.1	0.02	4	0.27	0	Satisfactory
588	2081/1/27	15:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.69	<5	7.45	88.3	26	24	0.1	0.02	4	0.34	0	Satisfactory
589	2081/1/27	9:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.87	<5	7.86	85.8	30	26	0.1	0.02	4	0.1	0	Satisfactory
590	2081/1/27	12:10	Maharajgunj	Balaju SRT	Treated	Clear	0.66	<5	7.68	86.5	28	26	0.1	0.02	4	0.1	0	Satisfactory
591	2081/1/27	6:35	Bhaktapur	Katunje SRT	Treated	Clear	1.03	<5	7.78	87.4	30	26	0.1	0.02	4	0.38	0	Satisfactory
592	2081/1/27	8:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.78	<5	7.18	86.2	32	26	0.1	0.02	4	0.35	0	Satisfactory

593	2081/1/27	9:40	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	8.04	88.2	30	28	0.1	0.02	4	0.29	0	Satisfactory
594	2081/1/27	8:50	Baneshwar	Min Bhawan SRT	Treated	Clear	1.07	<5	7.81	85.4	28	26	0.1	0.02	4	0.38	0	Satisfactory
595	2081/1/27	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.78	<5	8.14	72.2	30	26	0.1	0.02	4	0.11	0	Satisfactory
596	2081/1/27	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.61	<5	7.92	75.8	30	26	0.1	0.02	4	1.19	0	Satisfactory
597	2081/1/27	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.58	<5	7.92	76.3	30	26	0.1	0.02	4	0.22	0	Satisfactory
598	2081/1/27	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.85	<5	7.91	76.6	30	26	0.1	0.02	4	0.1	0	Satisfactory
599	2081/1/27	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.89	<5	7.94	77.4	30	26	0.1	0.02	4	0.54	0	Satisfactory
600	2081/1/27	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.96	<5	7.93	76.3	30	26	0.1	0.02	4	0.26	0	Satisfactory
601	2081/1/27	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.96	<5	7.95	75.8	30	26	0.1	0.02	4	0.16	0	Satisfactory
602	2081/1/27	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	70	24	28	0.1	0.02	6	0.43	0	Satisfactory
603	2081/1/27	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.9	<5	7.84	75	24	32	0.1	0.02	6	0.27	0	Satisfactory
604	2081/1/27	15:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.3	<5	7.90	80	26	34	0.1	0.02	6	0.1	0	Satisfactory
605	2081/1/27	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.36	<5	6.9	349	90	82	0.3	1.5	14	0.62	0	Satisfactory
606	2081/1/27	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.07	<5	6.86	330	88	76	0.3	1.5	14	0.22	0	Satisfactory
607	2081/1/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	8.14	435	108	124	0.1	0.02	10	0.1	0	Satisfactory
608	2081/1/27	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.04	<5	7.4	88.5	24	38	0.1	0.02	4	0.1	0	Satisfactory
609	2081/1/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.74	<5	7.26	86.2	28	28	0.1	0.02	4	0.27	0	Satisfactory
610	2081/1/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.75	<5	7.48	88.2	18	26	0.1	0.02	4	0.66	0	Satisfactory
611	2081/1/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.59	<5	7.37	92.2	16	26	0.1	0.02	4	0.36	0	Satisfactory
612	2081/1/28	10:30	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.58	<5	7.53	88.6	26	24	0.1	0.02	4	0.57	0	Satisfactory
613	2081/1/28	12:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.55	<5	7.76	86.9	28	26	0.1	0.02	4	0.8	0	Satisfactory
614	2081/1/28	14:00	Mahankalchaur	Mahankalchaur Melamch	Treated	Clear	0.3	<5	7.8	86.6	28	24	0.1	0.02	4	0.24	0	Satisfactory
615	2081/1/28	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	8.38	88.9	34	24	0.1	0.02	4	0.32	0	Satisfactory
616	2081/1/28	6:35	Bhaktapur	Katunje SRT	Treated	Clear	2.45	<5	7.3	84.2	24	26	0.1	0.02	4	0.22	0	Satisfactory
617	2081/1/28	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.78	<5	7.9	91.9	30	26	0.1	0.02	4	0.26	0	Satisfactory
618	2081/1/28	9:35	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.64	96.6	26	28	0.1	0.02	4	0.26	0	Satisfactory
619	2081/1/28	11:30	Baneshwar	Min Bhawan SRT	Treated	Clear	0.23	<5	7.95	85.9	30	26	0.1	0.02	4	0.22	0	Satisfactory
620	2081/1/28	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.92	<5	8.15	78.4	30	26	0.1	0.02	4	0.12	0	Satisfactory
621	2081/1/28	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	1.01	<5	8.09	79	30	26	0.1	0.02	4	0.27	0	Satisfactory
622	2081/1/28	10:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.86	<5	7.8	72.1	30	26	0.1	0.02	4	0.82	0	Satisfactory
623	2081/1/28	12:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.77	<5	7.8	73.5	30	26	0.1	0.02	4	0.3	0	Satisfactory
624	2081/1/28	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.77	<5	7.83	73.9	30	26	0.1	0.02	4	0.69	0	Satisfactory
625	2081/1/28	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.95	<5	7.97	74.2	30	26	0.1	0.02	4	0.77	0	Satisfactory
626	2081/1/28	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.52	73	24	30	0.1	0.02	6	0.26	0	Satisfactory
627	2081/1/28	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.70	75	24	32	0.1	0.02	6	0.1	0	Satisfactory
628	2081/1/28	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.0	<5	7.64	75	24	32	0.1	0.02	6	0.30	0	Satisfactory
629	2081/1/28	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	3.12	<5	6.7	319	82	74	0.3	1.5	12	0.24	0	Satisfactory
630	2081/1/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.95	<5	8.04	445	110	138	0.1	0.02	10	0.1	0	Satisfactory
631	2081/1/28	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.07	<5	7.09	87.8	22	38	0.1	0.02	4	0.1	0	Satisfactory
632	2081/1/29	7:40	Bhaktapur	Katunje SRT	Treated	Clear	0.24	<5	7.94	90.8	30	28	0.1	0.02	4	0.1	0	Satisfactory
633	2081/1/29	6:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	1.62	<5	8.18	72.8	30	26	0.1	0.02	4	0.1	0	Satisfactory
634	2081/1/29	8:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	2.93	<5	7.94	76.1	30	26	0.1	0.02	4	1	0	Satisfactory
635	2081/1/29	11:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.98	<5	7.82	73.8	30	26	0.1	0.02	4	0.2	0	Satisfactory
636	2081/1/29	13:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.69	<5	7.64	76.2	30	26	0.1	0.02	4	0.62	0	Satisfactory
637	2081/1/29	15:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.92	<5	7.78	76	30	26	0.1	0.02	4	0.44	0	Satisfactory
638	2081/1/29	16:30	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.96	<5	7.74	73.4	30	26	0.1	0.02	4	0.32	0	Satisfactory
639	2081/1/29	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.53	69	24	28	0.1	0.02	6	0.32	0	Satisfactory

640	2081/1/29	11:20	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.74	75	24	32	0.1	0.02	6	0.1	0	Satisfactory
641	2081/1/29	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.84	77	26	34	0.1	0.02	6	0.37	0	Satisfactory
642	2081/1/30	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.17	<5	7.25	72.2	28	26	0.1	0.02	4	0.1	0	Satisfactory
643	2081/1/30	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.75	<5	7.86	76.2	14	24	0.1	0.02	4	0.27	0	Satisfactory
644	2081/1/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.35	<5	8.17	77.6	12	24	0.1	0.02	4	0.25	0	Satisfactory
645	2081/1/30	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.37	<5	8.12	80.9	26	24	0.1	0.02	4	0.29	0	Satisfactory
646	2081/1/30	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.23	<5	7.45	94.3	26	28	0.1	0.02	4	0.23	0	Satisfactory
647	2081/1/30	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	1.2	<5	7.94	93.2	30	28	0.1	0.02	4	0.25	0	Satisfactory
648	2081/1/30	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.25	<5	8.27	92.7	32	28	0.1	0.02	4	0.27	0	Satisfactory
649	2081/1/30	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.35	<5	8.07	93	22	26	0.1	0.02	4	0.24	0	Satisfactory
650	2081/1/30	10:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.16	<5	8.29	92.4	32	28	0.1	0.02	4	0.19	0	Satisfactory
651	2081/1/30	12:30	Maharajgunj	Balaju SRT	Treated	Clear	0.01	<5	8.35	91.4	34	28	0.1	0.02	4	0.14	0	Satisfactory
652	2081/1/30	6:45	Bhaktapur	Katunje SRT	Treated	Clear	1.05	<5	7.87	91.6	30	28	0.1	0.02	4	0.12	0	Satisfactory
653	2081/1/30	13:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.16	<5	8.34	93.4	32	28	0.1	0.02	4	0.13	0	Satisfactory
654	2081/1/30	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.77	<5	7.58	95.5	26	28	0.1	0.02	4	0.23	0	Satisfactory
655	2081/1/30	10:55	Baneshwar	Min Bhawan SRT	Treated	Clear	0.1	<5	8.26	91.2	32	28	0.1	0.02	4	0.29	0	Satisfactory
656	2081/1/30	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.61	<5	8.08	75.6	30	26	0.1	0.02	4	0.1	0	Satisfactory
657	2081/1/30	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.94	76.2	30	26	0.1	0.02	4	0.6	0	Satisfactory
658	2081/1/30	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.88	76.4	30	26	0.1	0.02	4	0.1	0	Satisfactory
659	2081/1/30	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.94	75.6	30	26	0.1	0.02	4	0.1	0	Satisfactory
660	2081/1/30	14:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.93	77.9	30	26	0.1	0.02	4	0.2	0	Satisfactory
661	2081/1/30	16:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.91	76.4	30	26	0.1	0.02	4	0.36	0	Satisfactory
662	2081/1/30	17:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.94	<5	7.92	75.6	30	26	0.1	0.02	4	0.15	0	Satisfactory
663	2081/1/30	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.48	68	24	28	0.1	0.02	6	0.24	0	Satisfactory
664	2081/1/30	11:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.87	76	24	32	0.1	0.02	6	0.1	0	Satisfactory
665	2081/1/30	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.88	78	26	34	0.1	0.02	6	0.51	0	Satisfactory
666	2081/1/30	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	6.91	324	88	74	0.3	1.5	14	0.72	0	Satisfactory
667	2081/1/30	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.14	<5	6.86	316	86	72	0.3	1.5	14	0.41	0	Satisfactory
668	2081/1/30	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.33	<5	7.97	458	110	140	0.1	0.02	12	0.78	0	Satisfactory
669	2081/1/30	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.22	92.4	24	38	0.1	0.02	4	0.11	0	Satisfactory
670	2081/1/31	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.09	<5	6.82	84.8	28	26	0.1	0.02	4	0.32	0	Satisfactory
671	2081/1/31	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	7.34	85.1	28	22	0.1	0.02	4	0.46	0	Satisfactory
672	2081/1/31	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.2	93.3	12	28	0.1	0.02	4	0.45	0	Satisfactory
673	2081/1/31	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.4	90.9	14	22	0.1	0.02	4	0.32	0	Satisfactory
674	2081/1/31	10:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.1	<5	7.27	92.5	24	26	0.1	0.02	4	0.75	0	Satisfactory
675	2081/1/31	12:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.25	<5	7.58	92.9	26	28	0.1	0.02	4	0.29	0	Satisfactory
676	2081/1/31	14:00	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.85	<5	7.47	91	16	26	0.1	0.02	4	0.23	0	Satisfactory
677	2081/1/31	15:30	Mahankalchaur	Mahankalchaur Melamchaur	Treated	Clear	0.33	<5	7.96	92.2	30	28	0.1	0.02	4	0.34	0	Satisfactory
678	2081/1/31	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.82	90.7	30	26	0.1	0.02	4	0.1	0	Satisfactory
679	2081/1/31	7:40	Bhaktapur	Katunje SRT	Treated	Clear	1.48	<5	7.16	87.6	22	26	0.1	0.02	4	0.1	0	Satisfactory
680	2081/1/31	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	8.27	97.7	34	28	0.1	0.02	4	0.1	0	Satisfactory
681	2081/1/31	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.85	<5	7.69	95.3	28	26	0.1	0.02	4	0.1	0	Satisfactory
682	2081/1/31	11:00	Baneshwar	Min Bhawan SRT	Treated	Clear	0.01	<5	7.61	88.6	26	24	0.1	0.02	4	0.1	0	Satisfactory
683	2081/1/31	6:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.96	74.1	30	26	0.1	0.02	4	0.1	0	Satisfactory
684	2081/1/31	8:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.95	74.7	30	26	0.1	0.02	4	0.1	0	Satisfactory
685	2081/1/31	10:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.25	<5	7.57	72.3	30	26	0.1	0.02	4	0.66	0	Satisfactory
686	2081/1/31	12:00	Sundarijal WT Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.97	74.4	30	26	0.1	0.02	4	0.6	0	Satisfactory

687	2081/1/31	14:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.74	<5	7.89	74.2	30	26	0.1	0.02	4	0.57	0	Satisfactory
688	2081/1/31	16:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.83	<5	7.97	73.5	30	26	0.1	0.02	4	0.51	0	Satisfactory
689	2081/1/31	17:00	Sundarijal WT Sectio	New Sundarijal WTP	Treated	Clear	0.75	<5	7.85	72.8	30	26	0.1	0.02	4	0.19	0	Satisfactory
690	2081/1/31	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	71	24	30	0.1	0.02	6	0.18	0	Satisfactory
691	2081/1/31	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.61	76	24	32	0.1	0.02	6	0.1	0	Satisfactory
692	2081/1/31	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.54	77	26	34	0.1	0.02	6	0.1	0	Satisfactory
693	2081/1/31	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	6.88	344	90	80	0.3	1.5	16	0.74	0	Satisfactory
694	2081/1/31	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.63	<5	6.85	336	88	76	0.3	1.5	12	0.39	0	Satisfactory
695	2081/1/31	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.08	<5	7.94	447	108	134	0.1	0.02	10	0.1	0	Satisfactory
696	2081/1/31	15:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.89	<5	7.3	90.7	24	38	0.1	0.02	4	0.39	0	Satisfactory