



**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Jestha 2081**

S.N	Date	Time	Branch	Sampling Location	Sample type	Appearance	Turbidity	Colour	p <sup>H</sup>	E.C.	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks	
<b>Units</b> →								(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	/100ml	
<b>National Drinking Water Quality Standard (NDWQS)</b> →								5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2081/02/01	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.62	<5	8.19	492	110	134	0.1	0.02	14	0.86	0	Satisfactory	
2	2081/02/01	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.18	95	14	22	0.1	0.02	4	0.31	0	Satisfactory	
3	2081/02/01	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.47	100.8	22	26	0.1	0.02	4	0.75	0	Satisfactory	
4	2081/02/01	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.09	96.5	20	24	0.1	0.02	4	0.84	0	Satisfactory	
5	2081/02/01	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.17	110	20	24	0.1	0.02	4	0.92	0	Satisfactory	
6	2081/02/01	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.47	66	24	24	0.1	0.02	6	0.23	0	Satisfactory	
7	2081/02/01	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.71	75	24	32	0.1	0.02	6	0.10	0	Satisfactory	
8	2081/02/01	16:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.57	78	26	32	0.1	0.02	6	0.33	0	Satisfactory	
9	2081/02/01	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.62	<5	6.84	333	88	78	0.9	0.3	14	0.34	0	Satisfactory	
10	2081/02/01	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.89	<5	6.8	329	88	76	0.95	0.3	14	0.2	0	Satisfactory	
11	2081/02/01	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.94	<5	7.3	92.1	24	38	0.1	0.02	4	0.10	0	Satisfactory	
12	2081/02/01	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.08	<5	7.39	99.5	22	26	0.1	0.02	4	0.56	0	Satisfactory	
13	2081/02/01	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.45	<5	7.67	95.4	22	26	0.1	0.02	4	0.38	0	Satisfactory	
14	2081/02/01	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.33	<5	7.49	92.5	22	26	0.1	0.02	4	0.45	0	Satisfactory	
15	2081/02/01	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.49	<5	7.57	95.9	22	26	0.1	0.02	4	0.65	0	Satisfactory	
16	2081/02/01	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.22	<5	7.71	95.3	30	26	0.1	0.02	4	0.1	0	Satisfactory	
17	2081/02/01	9:30	Bhaktapur	Katunje SRT	Treated	Clear	0.16	<5	7.74	99.4	28	28	0.1	0.02	4	0.1	0	Satisfactory	
18	2081/02/01	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.93	<5	7.86	99.5	28	26	0.1	0.02	4	0.1	0	Satisfactory	
19	2081/02/01	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.83	<5	7.96	97.5	30	28	0.1	0.02	4	0.15	0	Satisfactory	
20	2081/02/01	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.95	92.1	30	26	0.1	0.02	4	0.1	0	Satisfactory	
21	2081/02/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	8.13	74.1	28	34	0.1	0.02	6	0.10	0	Satisfactory	
22	2081/02/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	8	76.9	28	34	0.1	0.02	6	0.54	0	Satisfactory	
23	2081/02/01	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.94	77.2	28	34	0.1	0.02	6	0.1	0	Satisfactory	
24	2081/02/01	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.77	72.1	28	34	0.1	0.02	6	0.21	0	Satisfactory	
25	2081/02/01	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.89	75.1	28	34	0.1	0.02	6	0.84	0	Satisfactory	
26	2081/02/01	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	8.03	73.3	28	34	0.1	0.02	6	0.11	0	Satisfactory	
27	2081/02/01	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	8.1	72.4	28	34	0.1	0.02	6	0.74	0	Satisfactory	
28	2081/02/02	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.45	<5	8.02	45.5	110	140	0.1	0.02	12	0.88	0	Satisfactory	
29	2081/02/02	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.23	<5	6.86	98	20	24	0.1	0.02	4	0.68	0	Satisfactory	
30	2081/02/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.2	92.8	20	24	0.1	0.02	4	0.39	0	Satisfactory	
31	2081/02/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.19	<5	7.39	94.8	20	24	0.1	0.02	4	0.14	0	Satisfactory	
32	2081/02/02	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.32	91	20	24	0.1	0.02	4	0.3	0	Satisfactory	
33	2081/02/02	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.52	69	24	26	0.1	0.02	6	0.32	0	Satisfactory	

34	2081/02/02	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.6	<5	7.80	77	26	32	0.1	0.02	6	0.10	0	Satisfactory
35	2081/02/02	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.4	<5	7.67	79	26	34	0.1	0.02	6	0.37	0	Satisfactory
36	2081/02/02	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.71	<5	6.95	356	94	80	0.95	0.3	16	0.47	0	Satisfactory
37	2081/02/02	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.56	<5	6.9	343	92	78	0.95	0.3	16	0.29	0	Satisfactory
38	2081/02/02	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.85	<5	7.29	92.9	24	38	0.1	0.02	4	0.1	0	Satisfactory
39	2081/02/02	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.82	<5	7.25	100.4	22	26	0.1	0.02	4	0.1	0	Satisfactory
40	2081/02/02	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.39	95.9	26	28	0.1	0.02	4	0.12	0	Satisfactory
41	2081/02/02	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.69	<5	7.69	99.3	26	28	0.1	0.02	4	0.1	0	Satisfactory
42	2081/02/02	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.67	<5	7.57	96	26	28	0.1	0.02	4	0.1	0	Satisfactory
43	2081/02/02	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	1.55	<5	7.8	94.9	26	28	0.1	0.02	4	0.1	0	Satisfactory
44	2081/02/02	6:45	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	6.96	102.6	22	26	0.1	0.02	4	0.1	0	Satisfactory
45	2081/02/02	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.25	<5	7.85	102.8	26	28	0.1	0.02	4	0.1	0	Satisfactory
46	2081/02/02	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.82	<5	7.78	103.6	26	28	0.1	0.02	4	0.1	0	Satisfactory
47	2081/02/02	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	1.53	<5	7.83	95.3	26	28	0.1	0.02	4	0.1	0	Satisfactory
48	2081/02/02	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.51	<5	7.93	77.9	28	34	0.1	0.02	6	0.10	0	Satisfactory
49	2081/02/02	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.08	<5	7.92	80.6	28	34	0.1	0.02	6	0.1	0	Satisfactory
50	2081/02/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.77	78	28	34	0.1	0.02	6	0.27	0	Satisfactory
51	2081/02/02	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.89	75	28	34	0.1	0.02	6	0.1	0	Satisfactory
52	2081/02/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.77	75.3	28	34	0.1	0.02	6	0.37	0	Satisfactory
53	2081/02/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.89	75.1	28	34	0.1	0.02	6	0.4	0	Satisfactory
54	2081/02/02	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.81	75.5	28	34	0.1	0.02	6	0.2	0	Satisfactory
55	2081/02/03	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.02	<5	7.97	460	110	140	0.1	0.02	12	0.47	0	Satisfactory
56	2081/02/03	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.25	97.7	22	26	0.1	0.02	4	0.41	0	Satisfactory
57	2081/02/03	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.16	98.7	22	26	0.1	0.02	4	0.48	0	Satisfactory
58	2081/02/03	14:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.77	<5	7.17	96.7	22	26	0.1	0.02	4	0.45	0	Satisfactory
59	2081/02/03	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	7.23	92.7	22	26	0.1	0.02	4	0.46	0	Satisfactory
60	2081/02/03	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.51	69	24	26	0.1	0.02	6	0.25	0	Satisfactory
61	2081/02/03	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.62	78	26	32	0.1	0.02	6	0.10	0	Satisfactory
62	2081/02/03	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.51	79	26	34	0.1	0.02	6	0.10	0	Satisfactory
63	2081/02/03	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.8	<5	6.9	347	92	80	0.95	0.3	14	0.34	0	Satisfactory
64	2081/02/03	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.57	<5	6.86	327	88	76	0.95	0.3	14	0.18	0	Satisfactory
65	2081/02/03	15:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.91	<5	7.15	96.4	26	38	0.1	0.02	4	0.73	0	Satisfactory
66	2081/02/03	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.24	<5	7.4	98.5	26	28	0.1	0.02	4	0.1	0	Satisfactory
67	2081/02/03	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.19	<5	7.68	103	26	28	0.1	0.02	4	1.07	0	Satisfactory
68	2081/02/03	14:15	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.43	<5	7.74	101.9	26	28	0.1	0.02	4	0.38	0	Satisfactory
69	2081/02/03	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.49	102.5	26	28	0.1	0.02	4	0.45	0	Satisfactory
70	2081/02/03	12:00	Tripureshwar	Anamnagar SRT	Treated	Clear	1.32	<5	7.88	101.6	26	28	0.1	0.02	4	0.1	0	Satisfactory
71	2081/02/03	13:00	Maharajgunj	Balaju SRT	Treated	Clear	0.15	<5	7.76	105.2	30	24	0.1	0.02	4	0.1	0	Satisfactory
72	2081/02/03	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	3.98	<5	7.83	109.4	26	28	0.1	0.02	4	0.1	0	Satisfactory
73	2081/02/03	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.15	<5	7.6	111.2	26	28	0.1	0.02	4	0.1	0	Satisfactory
74	2081/02/03	12:00	Baneshwor	Minbhawan SRT	Treated	Clear	1.25	<5	7.88	101.2	26	28	0.1	0.02	4	0.1	0	Satisfactory
75	2081/02/03	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.97	75	28	34	0.1	0.02	6	0.1	0	Satisfactory
76	2081/02/03	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.28	<5	8.06	77.8	28	34	0.1	0.02	6	0.1	0	Satisfactory
77	2081/02/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.78	79.8	28	34	0.1	0.02	6	1.31	0	Satisfactory
78	2081/02/03	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	8.15	75.3	28	34	0.1	0.02	6	0.33	0	Satisfactory
79	2081/02/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.99	76	28	34	0.1	0.02	6	0.71	0	Satisfactory
80	2081/02/03	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.98	75.9	28	34	0.1	0.02	6	0.69	0	Satisfactory
81	2081/02/03	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.76	76.1	28	34	0.1	0.02	6	0.74	0	Satisfactory
82	2081/02/04	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.08	<5	8.13	447	108	140	0.1	0.02	12	0.62	0	Satisfactory
83	2081/02/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.45	83.5	22	26	0.1	0.02	4	0.11	0	Satisfactory
84	2081/02/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.4	80.7	22	26	0.1	0.02	4	0.33	0	Satisfactory
85	2081/02/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.56	77.9	20	24	0.1	0.02	4	0.18	0	Satisfactory

86	2081/02/04	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.48	72	24	28	0.1	0.02	6	0.22	0	Satisfactory
87	2081/02/04	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.80	76	24	32	0.1	0.02	6	0.10	0	Satisfactory
88	2081/02/04	14:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.76	78	26	34	0.1	0.02	6	0.10	0	Satisfactory
89	2081/02/04	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.12	<5	6.86	355	94	80	0.95	0.3	16	1.02	0	Satisfactory
90	2081/02/04	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.93	<5	7.25	95.1	26	38	0.1	0.02	4	0.10	0	Satisfactory
91	2081/02/04	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.91	<5	7.75	99	26	28	0.1	0.02	4	0.12	0	Satisfactory
92	2081/02/04	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.42	95.9	26	28	0.1	0.02	4	0.34	0	Satisfactory
93	2081/02/04	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.57	<5	7.67	97.1	26	28	0.1	0.02	4	0.1	0	Satisfactory
94	2081/02/04	6:45	Bhaktapur	Katunje SRT	Treated	Clear	1.37	<5	7.7	99.9	26	28	0.1	0.02	4	0.1	0	Satisfactory
95	2081/02/04	6:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.04	<5	7.99	104.1	26	28	0.1	0.02	4	0.1	0	Satisfactory
96	2081/02/04	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	8.04	75.8	28	34	0.1	0.02	6	0.1	0	Satisfactory
97	2081/02/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.93	76.1	28	34	0.1	0.02	6	0.38	0	Satisfactory
98	2081/02/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.98	77.6	28	34	0.1	0.02	6	0.15	0	Satisfactory
99	2081/02/04	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.95	75.2	28	34	0.1	0.02	6	0.1	0	Satisfactory
100	2081/02/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.88	76.5	28	34	0.1	0.02	6	0.88	0	Satisfactory
101	2081/02/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.82	75.8	28	34	0.1	0.02	6	0.56	0	Satisfactory
102	2081/02/05	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.33	80.5	22	26	0.1	0.02	4	0.27	0	Satisfactory
103	2081/02/05	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	72	24	28	0.1	0.02	6	0.17	0	Satisfactory
104	2081/02/05	11:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.81	78	26	34	0.1	0.02	6	0.10	0	Satisfactory
105	2081/02/05	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.05	<5	7.84	98.2	26	28	0.1	0.02	4	0.11	0	Satisfactory
106	2081/02/05	12:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.13	102.1	26	28	0.1	0.02	4	0.1	0	Satisfactory
107	2081/02/05	14:00	Maharajgunj	Balaju SRT	Treated	Clear	0.86	<5	7.85	101	30	24	0.1	0.02	4	0.1	0	Satisfactory
108	2081/02/05	6:40	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.64	98.2	26	28	0.1	0.02	4	0.27	0	Satisfactory
109	2081/02/05	13:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.15	<5	7.82	102.8	26	28	0.1	0.02	4	0.1	0	Satisfactory
110	2081/02/05	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.35	<5	7.85	103.5	26	28	0.1	0.02	4	0.1	0	Satisfactory
111	2081/02/05	12:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.12	<5	7.81	100.9	26	28	0.1	0.02	4	0.1	0	Satisfactory
112	2081/02/05	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	8.02	77.1	28	34	0.1	0.02	6	0.1	0	Satisfactory
113	2081/02/05	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.98	79.6	28	34	0.1	0.02	6	0.61	0	Satisfactory
114	2081/02/05	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.98	79.8	28	34	0.1	0.02	6	0.1	0	Satisfactory
115	2081/02/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	8.12	441	108	136	0.1	0.02	10	0.81	0	Satisfactory
116	2081/02/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.07	91.8	22	26	0.1	0.02	4	0.1	0	Satisfactory
117	2081/02/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.26	99.5	20	28	0.1	0.02	6	0.1	0	Satisfactory
118	2081/02/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.32	91.8	20	28	0.1	0.02	6	0.15	0	Satisfactory
119	2081/02/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.59	87.6	26	24	0.1	0.02	6	0.1	0	Satisfactory
120	2081/02/06	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.52	72	24	28	0.1	0.02	6	0.33	0	Satisfactory
121	2081/02/06	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.78	78	26	34	0.1	0.02	6	0.10	0	Satisfactory
122	2081/02/06	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.84	79	26	34	0.1	0.02	6	0.10	0	Satisfactory
123	2081/02/06	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.08	<5	7.15	371	98	84	0.9	0.3	14	0.52	0	Satisfactory
124	2081/02/06	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.9	<5	6.9	348	94	78	0.95	0.3	14	0.24	0	Satisfactory
125	2081/02/06	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.1	<5	7.4	98.6	28	38	0.1	0.02	4	0.1	0	Satisfactory
126	2081/02/06	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.85	<5	7.45	99.7	26	28	0.1	0.02	4	0.23	0	Satisfactory
127	2081/02/06	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.02	<5	7.79	99.7	28	32	0.1	0.02	6	0.27	0	Satisfactory
128	2081/02/06	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.43	<5	7.77	96.1	28	30	0.1	0.02	6	0.1	0	Satisfactory
129	2081/02/06	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.05	<5	7.8	98.3	28	32	0.1	0.02	6	1.03	0	Satisfactory
130	2081/02/06	9:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.71	96.2	28	24	0.1	0.02	6	0.22	0	Satisfactory
131	2081/02/06	6:45	Bhaktapur	Katunje SRT	Treated	Clear	0.01	<5	7.83	105.2	28	30	0.1	0.02	4	0.37	0	Satisfactory
132	2081/02/06	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	0.08	<5	7.97	104.8	30	28	0.1	0.02	6	0.1	0	Satisfactory
133	2081/02/06	6:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.65	95.8	28	30	0.1	0.02	6	0.23	0	Satisfactory
134	2081/02/06	12:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	8.06	101.3	30	28	0.1	0.02	6	0.18	0	Satisfactory
135	2081/02/06	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.82	81.3	28	34	0.1	0.02	6	0.68	0	Satisfactory
136	2081/02/06	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	8.03	75.5	28	34	0.1	0.02	6	0.1	0	Satisfactory

137	2081/02/06	10:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.44	<5	7.85	77.6	28	34	0.1	0.02	6	0.49	0	Satisfactory
138	2081/02/06	12:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.72	<5	7.69	75.2	28	34	0.1	0.02	6	0.22	0	Satisfactory
139	2081/02/06	14:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.44	<5	7.66	76.8	28	34	0.1	0.02	6	1.05	0	Satisfactory
140	2081/02/06	16:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.44	<5	7.92	75	28	34	0.1	0.02	6	0.19	0	Satisfactory
141	2081/02/06	18:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.78	<5	7.97	75.2	28	34	0.1	0.02	6	0.39	0	Satisfactory
142	2081/02/07	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.34	<5	8.22	449	108	138	0.1	0.02	10	0.75	0	Satisfactory
143	2081/02/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.72	<5	7.62	78.2	22	20	0.1	0.02	6	0.29	0	Satisfactory
144	2081/02/07	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.42	<5	7.4	78.7	18	20	0.1	0.02	6	0.23	0	Satisfactory
145	2081/02/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.95	<5	7.55	81.1	20	22	0.1	0.02	6	0.1	0	Satisfactory
146	2081/02/07	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.32	110.7	14	22	0.1	0.02	6	0.13	0	Satisfactory
147	2081/02/07	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.50	71	24	28	0.1	0.02	6	0.28	0	Satisfactory
148	2081/02/07	11:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.78	80	26	34	0.1	0.02	6	0.10	0	Satisfactory
149	2081/02/07	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.70	78	26	34	0.1	0.02	6	0.31	0	Satisfactory
150	2081/02/07	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.67	<5	6.8	362	96	82	0.57	0.3	14	0.2	0	Satisfactory
151	2081/02/07	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.06	<5	6.8	344	90	80	0.95	0.3	14	0.28	0	Satisfactory
152	2081/02/07	15:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.34	<5	7.25	97.9	28	38	0.1	0.02	4	0.21	0	Satisfactory
153	2081/02/07	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.35	<5	7.35	97.2	28	26	0.1	0.02	6	0.25	0	Satisfactory
154	2081/02/07	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.27	<5	7.6	99.1	26	28	0.1	0.02	6	0.23	0	Satisfactory
155	2081/02/07	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.34	<5	7.74	100.6	28	26	0.1	0.02	6	0.19	0	Satisfactory
156	2081/02/07	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.24	<5	7.64	99.1	26	28	0.1	0.02	6	0.57	0	Satisfactory
157	2081/02/07	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.4	96.1	24	28	0.1	0.02	6	0.71	0	Satisfactory
158	2081/02/07	12:50	Maharajgunj	Balaju SRT	Treated	Clear	0.16	<5	7.61	101.5	26	28	0.1	0.02	6	0.51	0	Satisfactory
159	2081/02/07	10:30	Bhaktapur	Katunje SRT	Treated	Clear	1.3	<5	7.8	105.4	28	26	0.1	0.02	6	0.1	0	Satisfactory
160	2081/02/07	11:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.16	<5	7.61	99.8	26	28	0.1	0.02	6	0.1	0	Satisfactory
161	2081/02/07	8:50	Kirtipur	Kirtipur SRT	Treated	Clear	2.8	<5	7.74	101.6	28	26	0.1	0.02	6	0.1	0	Satisfactory
162	2081/02/07	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.07	<5	7.62	98.3	26	28	0.1	0.02	6	0.46	0	Satisfactory
163	2081/02/07	6:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.6	<5	7.93	75	28	34	0.1	0.02	6	0.18	0	Satisfactory
164	2081/02/07	8:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.55	<5	7.82	74.6	28	34	0.1	0.02	6	0.17	0	Satisfactory
165	2081/02/07	10:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.84	<5	7.92	74.8	28	34	0.1	0.02	6	0.11	0	Satisfactory
166	2081/02/07	12:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.74	<5	7.94	74.4	28	34	0.1	0.02	6	0.54	0	Satisfactory
167	2081/02/07	14:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.98	<5	7.79	74.3	28	34	0.1	0.02	6	0.9	0	Satisfactory
168	2081/02/07	16:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.96	<5	7.76	74.4	28	34	0.1	0.02	6	0.8	0	Satisfactory
169	2081/02/07	18:00	Sundaridal WTP Section	New Sundaridal WTP	Treated	Clear	0.57	<5	7.55	75.1	28	34	0.1	0.02	6	1.04	0	Satisfactory
170	2081/02/08	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.7	97.8	12	28	0.1	0.02	6	0.1	0	Satisfactory
171	2081/02/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.2	101.4	12	24	0.1	0.02	6	0.1	0	Satisfactory
172	2081/02/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.35	<5	6.5	114.40	12	26	0.1	0.02	6	0.1	0	Satisfactory
173	2081/02/08	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.2	<5	6.5	136.30	10	28	0.1	0.02	6	0.1	0	Satisfactory
174	2081/02/08	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.7	<5	7.48	71	24	26	0.1	0.02	6	0.36	0	Satisfactory
175	2081/02/08	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.0	<5	7.66	79	26	34	0.1	0.02	6	0.23	0	Satisfactory
176	2081/02/08	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.62	78	26	34	0.1	0.02	6	0.50	0	Satisfactory
177	2081/02/08	10:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.09	<5	6.88	354	96	82	0.57	0.3	10	0.1	0	Satisfactory
178	2081/02/08	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.1	<5	6.85	342	92	82	0.95	0.3	12	0.31	0	Satisfactory
179	2081/02/08	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.14	<5	7.28	96.8	26	38	0.1	0.02	4	0.1	0	Satisfactory
180	2081/02/08	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.73	<5	7.3	97.9	24	28	0.1	0.02	6	0.39	0	Satisfactory
181	2081/02/08	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.25	<5	7.68	98.1	28	26	0.1	0.02	6	1.04	0	Satisfactory
182	2081/02/08	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.26	98.9	24	28	0.1	0.02	6	0.68	0	Satisfactory
183	2081/02/08	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.53	<5	6.61	97.1	18	20	0.1	0.02	6	0.45	0	Satisfactory
184	2081/02/08	10:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.46	<5	7.37	95.1	24	28	0.1	0.02	6	0.5	0	Satisfactory
185	2081/02/08	6:32	Bhaktapur	Katunje SRT	Treated	Clear	3.37	<5	7.72	104	28	26	0.1	0.02	6	0.39	0	Satisfactory
186	2081/02/08	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	1.56	<5	7.58	99.4	26	28	0.1	0.02	6	0.1	0	Satisfactory
187	2081/02/08	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.95	<5	7.74	110.3	28	26	0.1	0.02	6	0.1	0	Satisfactory

188	2081/02/08	10:50	Baneshwor	Minbhawan SRT	Treated	Clear	0.26	<5	7.73	98.2	28	26	0.1	0.02	6	0.82	0	Satisfactory
189	2081/02/08	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.94	74.8	28	34	0.1	0.02	6	0.19	0	Satisfactory
190	2081/02/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	8.01	73.8	28	34	0.1	0.02	6	0.12	0	Satisfactory
191	2081/02/08	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.87	77.3	28	34	0.1	0.02	6	0.23	0	Satisfactory
192	2081/02/08	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.73	76.1	28	34	0.1	0.02	6	0.42	0	Satisfactory
193	2081/02/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.7	76	28	34	0.1	0.02	6	0.88	0	Satisfactory
194	2081/02/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.56	76.1	28	34	0.1	0.02	6	0.95	0	Satisfactory
195	2081/02/08	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.61	75.4	28	34	0.1	0.02	6	0.83	0	Satisfactory
196	2081/02/09	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.81	<5	7.97	550	110	138	0.1	0.02	28	0.84	0	Satisfactory
197	2081/02/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.67	123.4	6	34	0.1	0.3	6	0.1	0	Satisfactory
198	2081/02/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.76	125.2	10	28	0.1	0.3	6	0.52	0	Satisfactory
199	2081/02/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.78	128	12	26	0.1	0.3	6	0.54	0	Satisfactory
200	2081/02/09	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.82	131.7	16	26	1.4	0.3	6	0.28	0	Satisfactory
201	2081/02/09	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	68	24	28	0.1	0.02	6	0.28	0	Satisfactory
202	2081/02/09	11:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.94	78	26	34	0.1	0.02	6	0.10	0	Satisfactory
203	2081/02/09	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	1.5	<5	7.88	79	26	34	0.1	0.02	6	0.10	0	Satisfactory
204	2081/02/09	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.29	100.3	24	26	0.1	0.02	6	0.1	0	Satisfactory
205	2081/02/09	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.78	<5	7.17	99.3	22	28	0.1	0.02	6	0.1	0	Satisfactory
206	2081/02/09	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.85	<5	7.32	103	24	26	0.1	0.02	6	0.5	0	Satisfactory
207	2081/02/09	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.25	101.9	20	22	0.1	0.3	6	0.41	0	Satisfactory
208	2081/02/09	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.13	<5	7.43	101.6	24	28	0.1	0.02	6	0.1	0	Satisfactory
209	2081/02/09	12:30	Maharajgunj	Balaju SRT	Treated	Clear	1.52	<5	7.44	105	24	28	0.1	0.02	6	0.1	0	Satisfactory
210	2081/02/09	7:27	Bhaktapur	Katunje SRT	Treated	Clear	1.12	<5	7.41	106.4	24	26	0.1	0.02	6	0.1	0	Satisfactory
211	2081/02/09	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.42	106.2	24	28	0.1	0.02	6	0.1	0	Satisfactory
212	2081/02/09	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.65	<5	8.09	108.8	32	28	0.1	0.02	6	0.1	0	Satisfactory
213	2081/02/09	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.35	<5	7.28	121.3	24	28	0.1	0.02	6	0.1	0	Satisfactory
214	2081/02/09	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	8.1	75.8	28	34	0.1	0.02	6	0.1	0	Satisfactory
215	2081/02/09	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.02	<5	7.72	75.8	28	34	0.1	0.02	6	0.6	0	Satisfactory
216	2081/02/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.7	75.7	28	34	0.1	0.02	6	0.83	0	Satisfactory
217	2081/02/09	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.64	75.1	28	34	0.1	0.02	6	0.61	0	Satisfactory
218	2081/02/09	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.73	74.5	28	34	0.1	0.02	6	0.34	0	Satisfactory
219	2081/02/10	9:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	6.5	85.90	20	18	0.2	0.02	6	0.10	0	Satisfactory
220	2081/02/10	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.7	<5	7.52	73	24	30	0.1	0.02	6	0.30	0	Satisfactory
221	2081/02/10	12:35	Maharajgunj	Bansbari SRT	Treated	Clear	3.2	<5	8.04	81	26	34	0.1	0.02	6	0.10	0	Satisfactory
222	2081/02/10	9:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.79	<5	6.54	105.3	20	26	0.1	0.02	6	0.95	0	Satisfactory
223	2081/02/10	6:44	Bhaktapur	Katunje SRT	Treated	Clear	0.29	<5	6.51	97.4	14	28	0.1	0.02	6	0.49	0	Satisfactory
224	2081/02/10	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.9	75.2	28	34	0.1	0.02	6	0.27	0	Satisfactory
225	2081/02/10	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.88	75.3	28	34	0.1	0.02	6	0.58	0	Satisfactory
226	2081/02/10	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.74	75.7	28	34	0.1	0.02	6	0.71	0	Satisfactory
227	2081/02/10	17:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.89	75.4	28	34	0.1	0.02	6	0.36	0	Satisfactory
228	2081/02/11	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.27	<5	8.04	476	108	120	0.1	0.02	14	0.78	0	Satisfactory
229	2081/02/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.3	<5	6.58	121.6	16	24	0.1	0.02	6	0.1	0	Satisfactory
230	2081/02/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.06	<5	6.5	127.80	14	26	0.1	0.02	6	0.21	0	Satisfactory
231	2081/02/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	6.5	109.50	12	26	0.1	0.02	6	0.17	0	Satisfactory
232	2081/02/11	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.8	<5	7.51	73	24	30	0.1	0.02	6	0.41	0	Satisfactory
233	2081/02/11	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	1.5	<5	7.93	82	26	34	0.1	0.02	6	0.31	0	Satisfactory
234	2081/02/11	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.76	79	26	34	0.1	0.02	6	0.10	0	Satisfactory
235	2081/02/11	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1.5	<5	7.87	81	26	34	0.1	0.02	6	0.43	0	Satisfactory
236	2081/02/11	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.83	<5	6.87	368	96	82	0.95	0.3	14	0.21	0	Satisfactory
237	2081/02/11	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.61	<5	6.8	340	90	74	0.95	0.3	12	0.24	0	Satisfactory
238	2081/02/11	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.95	<5	7.2	96.4	26	38	0.1	0.02	4	0.1	0	Satisfactory



239	2081/02/11	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.15	<5	7.47	99.4	16	28	0.1	0.02	6	0.1	0	Satisfactory
240	2081/02/11	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.08	<5	7.05	100.6	22	26	0.1	0.02	6	0.4	0	Satisfactory
241	2081/02/11	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.54	<5	7.54	103.2	26	24	0.1	0.02	6	0.28	0	Satisfactory
242	2081/02/11	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.36	103.6	24	38	0.1	0.02	6	0.65	0	Satisfactory
243	2081/02/11	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.11	<5	7.45	106.5	26	30	0.1	0.02	6	1.1	0	Satisfactory
244	2081/02/11	6:10	Bhaktapur	Katunje SRT	Treated	Clear	0.35	<5	7.2	109.1	24	28	0.1	0.02	6	0.48	0	Satisfactory
245	2081/02/11	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.48	109.7	26	30	0.1	0.02	6	0.18	0	Satisfactory
246	2081/02/11	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.26	<5	7.29	102.8	24	28	0.1	0.02	6	0.1	0	Satisfactory
247	2081/02/11	11:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.04	<5	7.37	102.7	24	30	0.1	0.02	6	0.52	0	Satisfactory
248	2081/02/11	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.87	74.4	28	34	0.1	0.02	6	0.58	0	Satisfactory
249	2081/02/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.9	77.7	28	34	0.1	0.02	6	0.3	0	Satisfactory
250	2081/02/11	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	8.07	75.4	28	34	0.1	0.02	6	0.35	0	Satisfactory
251	2081/02/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.77	76.9	28	34	0.1	0.02	6	0.67	0	Satisfactory
252	2081/02/11	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.7	73.4	28	34	0.1	0.02	6	0.49	0	Satisfactory
253	2081/02/11	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.68	75.1	28	34	0.1	0.02	6	0.18	0	Satisfactory
254	2081/02/12	8:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.45	<5	7.3	96	24	26	0.1	0.02	6	0.21	0	Satisfactory
255	2081/02/12	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.53	72	24	26	0.1	0.02	6	0.27	0	Satisfactory
256	2081/02/12	13:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.9	<5	7.47	85	26	34	0.1	0.02	6	0.10	0	Satisfactory
257	2081/02/12	8:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.61	<5	7.5	112.8	26	28	0.1	0.02	6	0.10	0	Satisfactory
258	2081/02/12	6:35	Tripureshwar	Anamnagar SRT	Treated	Clear	2.32	<5	7.72	111.2	28	26	0.1	0.02	6	0.43	0	Satisfactory
259	2081/02/12	7:15	Maharajgunj	Balaju SRT	Treated	Clear	2.6	<5	7.67	108.8	28	26	0.1	0.02	6	0.6	0	Satisfactory
260	2081/02/12	6:18	Bhaktapur	Katunje SRT	Treated	Clear	2.2	<5	7.63	120.6	26	28	0.1	0.02	6	0.21	0	Satisfactory
261	2081/02/12	7:00	Lalitpur	Khumaltar SRT	Treated	Clear	2.92	<5	7.48	110.5	26	28	0.1	0.02	6	0.44	0	Satisfactory
262	2081/02/12	7:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.25	<5	7.52	110.9	26	24	0.1	0.02	6	0.25	0	Satisfactory
263	2081/02/12	6:25	Baneshwor	Minbhawan SRT	Treated	Clear	2.78	<5	7.58	107.8	28	26	0.1	0.02	6	0.46	0	Satisfactory
264	2081/02/12	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.94	<5	7.51	72.3	28	34	0.1	0.02	6	0.1	0	Satisfactory
265	2081/02/12	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.39	76.6	28	34	0.1	0.02	6	0.75	0	Satisfactory
266	2081/02/12	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.59	74.8	28	34	0.1	0.02	6	0.58	0	Satisfactory
267	2081/02/12	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.42	<5	7.66	75.3	28	34	0.1	0.02	6	0.31	0	Satisfactory
268	2081/02/12	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.44	<5	7.67	76.1	28	34	0.1	0.02	6	0.77	0	Satisfactory
269	2081/02/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.94	<5	8.16	501	110	138	0.1	0.02	12	0.83	0	Satisfactory
270	2081/02/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.25	<5	7.55	99.8	26	22	0.1	0.02	6	0.24	0	Satisfactory
271	2081/02/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	6.86	117.9	18	28	0.1	0.02	6	0.94	0	Satisfactory
272	2081/02/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.25	115.9	22	26	0.1	0.02	6	1.89	0	Satisfactory
273	2081/02/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.86	<5	7.62	102.9	26	28	0.1	0.02	6	0.1	0	Satisfactory
274	2081/02/13	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.46	68	24	26	0.1	0.02	6	0.22	0	Satisfactory
275	2081/02/13	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	2.8	<5	7.62	81	26	34	0.1	0.02	6	0.10	0	Satisfactory
276	2081/02/13	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.3	<5	7.54	78	26	34	0.1	0.02	6	0.30	0	Satisfactory
277	2081/02/13	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.64	<5	6.82	349	90	78	0.57	0.3	14	0.28	0	Satisfactory
278	2081/02/13	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.77	<5	6.8	332	88	76	0.95	0.3	14	0.14	0	Satisfactory
279	2081/02/13	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.95	<5	7.15	98.4	26	38	0.1	0.02	4	0.22	0	Satisfactory
280	2081/02/13	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.67	113.9	28	26	0.1	0.02	6	0.1	0	Satisfactory
281	2081/02/13	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.25	<5	7.35	102.8	24	28	0.1	0.02	6	0.13	0	Satisfactory
282	2081/02/13	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.66	99.1	28	26	0.1	0.02	6	0.28	0	Satisfactory
283	2081/02/13	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	8.1	106.6	32	28	0.1	0.02	6	0.56	0	Satisfactory
284	2081/02/13	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.35	<5	7.72	105.6	28	26	0.1	0.02	6	0.35	0	Satisfactory
285	2081/02/13	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.82	<5	7.96	110.5	30	28	0.1	0.02	6	0.1	0	Satisfactory
286	2081/02/13	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	2.96	<5	7.75	113.7	28	26	0.1	0.02	6	0.25	0	Satisfactory
287	2081/02/13	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.87	106.9	30	28	0.1	0.02	6	0.31	0	Satisfactory
288	2081/02/13	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.63	73.4	28	34	0.1	0.02	6	0.26	0	Satisfactory
289	2081/02/13	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.73	73.1	28	34	0.1	0.02	6	0.10	0	Satisfactory

290	2081/02/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.73	76	28	34	0.1	0.02	6	0.1	0	Satisfactory
291	2081/02/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	7.48	75.3	28	34	0.1	0.02	6	0.14	0	Satisfactory
292	2081/02/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.47	<5	7.63	77.7	28	34	0.1	0.02	6	0.6	0	Satisfactory
293	2081/02/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.67	79.7	28	34	0.1	0.02	6	0.95	0	Satisfactory
294	2081/02/13	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.62	79.5	28	34	0.1	0.02	6	0.96	0	Satisfactory
295	2081/02/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.41	<5	7.97	462	108	136	0.1	0.02	10	0.71	0	Satisfactory
296	2081/02/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.24	<5	7.62	98.5	24	30	0.1	0.02	6	0.64	0	Satisfactory
297	2081/02/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.27	<5	7.74	106	28	26	0.1	0.02	6	0.31	0	Satisfactory
298	2081/02/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.44	97.8	24	26	0.1	0.02	6	0.31	0	Satisfactory
299	2081/02/14	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.19	<5	7.27	109.3	22	24	0.1	0.02	6	0.52	0	Satisfactory
300	2081/02/14	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.50	70	24	28	0.1	0.02	6	0.41	0	Satisfactory
301	2081/02/14	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.3	<5	7.63	80	26	34	0.1	0.02	6	0.10	0	Satisfactory
302	2081/02/14	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	1.1	<5	7.50	77	26	34	0.1	0.02	6	0.32	0	Satisfactory
303	2081/02/14	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.72	<5	6.85	378	102	82	0.57	0.3	14	0.38	0	Satisfactory
304	2081/02/14	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.43	<5	6.84	349	94	76	0.95	0.3	14	0.34	0	Satisfactory
305	2081/02/14	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.41	<5	7.38	99.5	28	38	0.1	0.02	4	0.1	0	Satisfactory
306	2081/02/14	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.26	<5	7.95	105.5	30	28	0.1	0.02	6	0.25	0	Satisfactory
307	2081/02/14	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.41	<5	7.77	104.2	28	26	0.1	0.02	6	0.28	0	Satisfactory
308	2081/02/14	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.36	<5	7.66	117.2	28	26	0.1	0.02	6	0.29	0	Satisfactory
309	2081/02/14	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.42	101.3	24	26	0.1	0.02	6	0.75	0	Satisfactory
310	2081/02/14	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.46	<5	7.73	109.6	28	30	0.1	0.02	6	0.58	0	Satisfactory
311	2081/02/14	9:00	Bhaktapur	Katunje SRT	Treated	Clear	0.01	<5	7.85	114	30	28	0.1	0.02	6	0.68	0	Satisfactory
312	2081/02/14	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.33	<5	7.76	116.8	28	30	0.1	0.02	6	0.1	0	Satisfactory
313	2081/02/14	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.79	<5	7.95	104.9	30	26	0.1	0.02	6	0.1	0	Satisfactory
314	2081/02/14	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.8	110.7	28	30	0.1	0.02	6	0.43	0	Satisfactory
315	2081/02/14	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	7.8	77.7	28	34	0.1	0.02	6	0.15	0	Satisfactory
316	2081/02/14	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.87	73.5	28	34	0.1	0.02	6	0.12	0	Satisfactory
317	2081/02/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.69	75.4	28	34	0.1	0.02	6	0.44	0	Satisfactory
318	2081/02/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	7.67	74.4	28	34	0.1	0.02	6	0.24	0	Satisfactory
319	2081/02/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.53	76.5	28	34	0.1	0.02	6	1.26	0	Satisfactory
320	2081/02/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.58	75.2	28	34	0.1	0.02	6	0.62	0	Satisfactory
321	2081/02/14	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.49	76.1	28	34	0.1	0.02	6	0.41	0	Satisfactory
322	2081/02/15	8:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.36	109.8	24	24	0.1	0.02	6	0.32	0	Satisfactory
323	2081/02/15	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.51	71	24	28	0.1	0.02	6	0.36	0	Satisfactory
324	2081/02/15	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.6	<5	7.84	80	26	34	0.1	0.02	6	0.34	0	Satisfactory
325	2081/02/15	8:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.37	<5	7.65	105.7	28	26	0.1	0.02	6	0.25	0	Satisfactory
326	2081/02/15	6:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.35	101.9	24	28	0.1	0.02	6	0.78	0	Satisfactory
327	2081/02/15	8:15	Maharajgunj	Balaju SRT	Treated	Clear	0.25	<5	7.46	100.7	26	28	0.1	0.02	6	0.2	0	Satisfactory
328	2081/02/15	6:20	Bhaktapur	Katunje SRT	Treated	Clear	0.01	<5	7.54	107.9	26	30	0.1	0.02	6	0.25	0	Satisfactory
329	2081/02/15	7:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	7.27	103.6	24	28	0.1	0.02	6	0.25	0	Satisfactory
330	2081/02/15	8:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.2	<5	7.3	103.1	24	28	0.1	0.02	6	0.23	0	Satisfactory
331	2081/02/15	6:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.3	104.2	24	28	0.1	0.02	6	0.57	0	Satisfactory
332	2081/02/15	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.9	74.2	28	34	0.1	0.02	6	0.10	0	Satisfactory
333	2081/02/15	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.96	75.7	28	34	0.1	0.02	6	0.10	0	Satisfactory
334	2081/02/15	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.86	<5	7.9	76.1	28	34	0.1	0.02	6	0.38	0	Satisfactory
335	2081/02/15	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.2	<5	7.7	75.7	28	34	0.1	0.02	6	0.41	0	Satisfactory
336	2081/02/15	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.7	75.1	28	34	0.1	0.02	6	0.2	0	Satisfactory
337	2081/02/16	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	7.98	485	108	138	0.1	0.02	12	0.79	0	Satisfactory
338	2081/02/16	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.57	<5	7.34	90.5	24	26	0.1	0.02	6	0.1	0	Satisfactory
339	2081/02/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.65	<5	7.32	90.2	20	24	0.1	0.02	6	0.25	0	Satisfactory
340	2081/02/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.22	<5	7.34	103.3	20	28	0.1	0.02	6	1.48	0	Satisfactory

341	2081/02/16	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.47	<5	7.3	106.2	20	24	0.1	0.02	6	1.21	0	Satisfactory
342	2081/02/16	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.51	67	24	26	0.1	0.02	6	0.37	0	Satisfactory
343	2081/02/16	11:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.77	80	26	34	0.1	0.02	6	0.10	0	Satisfactory
344	2081/02/16	14:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.73	81	26	34	0.1	0.02	6	0.31	0	Satisfactory
345	2081/02/16	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.15	<5	6.78	373	96	80	0.57	0.3	12	0.1	0	Satisfactory
346	2081/02/16	14:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.1	<5	7.38	106	28	40	0.1	0.02	4	1.65	0	Satisfactory
347	2081/02/16	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.62	<5	7.56	112.8	28	26	0.1	0.02	6	0.35	0	Satisfactory
348	2081/02/16	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.35	105.2	24	30	0.1	0.02	6	1.5	0	Satisfactory
349	2081/02/16	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.51	101.8	26	30	0.1	0.02	6	0.28	0	Satisfactory
350	2081/02/16	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.13	<5	7.55	102.5	22	24	0.1	0.02	6	0.83	0	Satisfactory
351	2081/02/16	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.35	102.3	24	32	0.1	0.02	6	0.35	0	Satisfactory
352	2081/02/16	6:48	Bhaktapur	Katunje SRT	Treated	Clear	0.48	<5	7.35	110.7	24	30	0.1	0.02	6	0.2	0	Satisfactory
353	2081/02/16	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	7.59	166.5	26	32	0.1	0.02	6	0.1	0	Satisfactory
354	2081/02/16	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.35	<5	7.68	114.7	30	28	0.1	0.02	6	0.2	0	Satisfactory
355	2081/02/16	12:50	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.52	102.2	26	30	0.1	0.02	6	0.29	0	Satisfactory
356	2081/02/16	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.41	74.2	28	34	0.1	0.02	6	0.1	0	Satisfactory
357	2081/02/16	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.43	78.4	28	34	0.1	0.02	6	1.1	0	Satisfactory
358	2081/02/16	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.3	75.8	28	34	0.1	0.02	6	0.92	0	Satisfactory
359	2081/02/16	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.68	<5	7.24	85.2	28	34	0.1	0.02	6	0.44	0	Satisfactory
360	2081/02/16	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.32	73.1	28	34	0.1	0.02	6	0.94	0	Satisfactory
361	2081/02/16	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.44	74.8	28	34	0.1	0.02	6	0.64	0	Satisfactory
362	2081/02/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.11	<5	7.95	491	108	140	0.1	0.02	12	0.82	0	Satisfactory
363	2081/02/17	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.75	<5	7.2	85.8	20	24	0.1	0.02	6	0.1	0	Satisfactory
364	2081/02/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.76	<5	7.3	80	22	24	0.1	0.02	6	0.4	0	Satisfactory
365	2081/02/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	7.35	92.4	22	26	0.1	0.02	6	0.23	0	Satisfactory
366	2081/02/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	7.44	103.7	22	32	0.1	0.02	6	0.62	0	Satisfactory
367	2081/02/17	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.54	73	24	28	0.1	0.02	6	0.32	0	Satisfactory
368	2081/02/17	11:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.7	<5	7.66	79	26	34	0.1	0.02	6	0.10	0	Satisfactory
369	2081/02/17	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	2.1	<5	7.61	78	26	34	0.1	0.02	6	0.26	0	Satisfactory
370	2081/02/17	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.42	<5	6.92	355	94	76	0.57	0.3	14	0.38	0	Satisfactory
371	2081/02/17	15:20	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.78	<5	6.5	92.40	26	36	0.1	0.02	4	0.56	0	Satisfactory
372	2081/02/17	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.08	<5	7.47	106.2	26	28	0.1	0.02	6	0.39	0	Satisfactory
373	2081/02/17	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.26	<5	7.45	99.3	26	30	0.1	0.02	6	0.34	0	Satisfactory
374	2081/02/17	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.82	<5	7.5	105.4	26	30	0.1	0.02	6	0.25	0	Satisfactory
375	2081/02/17	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.72	<5	7.53	108.2	26	30	0.1	0.02	6	0.49	0	Satisfactory
376	2081/02/17	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.01	<5	7.53	102.3	26	28	0.1	0.02	6	1.73	0	Satisfactory
377	2081/02/17	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.46	100.4	26	28	0.1	0.02	6	0.29	0	Satisfactory
378	2081/02/17	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.55	100.1	26	28	0.1	0.02	6	0.27	0	Satisfactory
379	2081/02/17	6:22	Bhaktapur	Katunje SRT	Treated	Clear	0.01	<5	7.45	111.1	26	28	0.1	0.02	6	0.27	0	Satisfactory
380	2081/02/17	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.01	<5	7.57	106.6	26	28	0.1	0.02	6	0.1	0	Satisfactory
381	2081/02/17	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.45	<5	7.7	72.6	28	34	0.1	0.02	6	0.16	0	Satisfactory
382	2081/02/17	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.34	<5	7.66	71.7	28	34	0.1	0.02	6	0.14	0	Satisfactory
383	2081/02/17	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.78	<5	7.5	79.7	28	34	0.1	0.02	6	1.09	0	Satisfactory
384	2081/02/17	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.82	<5	7.28	73.9	28	34	0.1	0.02	6	0.12	0	Satisfactory
385	2081/02/17	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.64	<5	7.17	75.4	28	34	0.1	0.02	6	1.01	0	Satisfactory
386	2081/02/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	5	<5	7.46	75.9	28	34	0.1	0.02	6	0.82	0	Satisfactory
387	2081/02/17	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	5	<5	7.45	75.1	28	34	0.1	0.02	6	0.21	0	Satisfactory
388	2081/02/18	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.52	<5	7.82	503	110	138	0.1	0.02	14	0.83	0	Satisfactory
389	2081/02/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.13	<5	7.61	90.1	24	26	0.1	0.02	6	0.21	0	Satisfactory
390	2081/02/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.45	89.3	24	28	0.1	0.02	6	0.32	0	Satisfactory
391	2081/02/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.59	89.4	26	24	0.1	0.02	6	0.1	0	Satisfactory



392	2081/02/18	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.7	<5	7.50	70	24	28	0.1	0.02	6	0.54	0	Satisfactory
393	2081/02/18	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	3.1	<5	7.56	77	26	34	0.1	0.02	6	0.84	0	Satisfactory
394	2081/02/18	13:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.3	<5	7.46	74	24	32	0.1	0.02	6	0.20	0	Satisfactory
395	2081/02/18	11:40	Maharajgunj	Panipokhari SRT	Treated	Clear	3.2	<5	7.57	80	26	34	0.1	0.02	6	0.67	0	Satisfactory
396	2081/02/18	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.4	<5	6.96	354	94	70	0.57	0.3	12	0.1	0	Satisfactory
397	2081/02/18	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.9	<5	6.99	356	94	70	0.57	0.3	16	0.61	0	Satisfactory
398	2081/02/18	14:20	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.4	<5	7.25	95.7	28	38	0.1	0.02	4	0.74	0	Satisfactory
399	2081/02/18	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.65	<5	7.78	103.1	28	30	0.1	0.02	6	0.2	0	Satisfactory
400	2081/02/18	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.32	99.8	24	28	0.1	0.02	6	0.39	0	Satisfactory
401	2081/02/18	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.29	<5	7.75	99	28	30	0.1	0.02	6	0.94	0	Satisfactory
402	2081/02/18	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	1.28	<5	7.64	110.2	28	30	0.1	0.02	6	0.11	0	Satisfactory
403	2081/02/18	6:46	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.6	108.7	28	26	0.1	0.02	6	0.20	0	Satisfactory
404	2081/02/18	11:55	Lalitpur	Khumaltar SRT	Treated	Clear	1.35	<5	7.85	117.5	30	28	0.1	0.02	6	0.1	0	Satisfactory
405	2081/02/18	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.82	<5	7.82	104.1	28	32	0.1	0.02	6	0.1	0	Satisfactory
406	2081/02/18	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	1.23	<5	7.5	111.5	26	30	0.1	0.02	6	0.28	0	Satisfactory
407	2081/02/18	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.76	<5	7.59	72.6	28	34	0.1	0.02	6	0.1	0	Satisfactory
408	2081/02/18	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.63	<5	7.6	70.3	28	34	0.1	0.02	6	0.17	0	Satisfactory
409	2081/02/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.33	<5	7.5	74.5	28	34	0.1	0.02	6	0.36	0	Satisfactory
410	2081/02/18	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	4.13	<5	7.4	67.7	28	34	0.1	0.02	6	0.26	0	Satisfactory
411	2081/02/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.93	<5	7.12	70.3	28	34	0.1	0.02	6	1.36	0	Satisfactory
412	2081/02/18	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.37	<5	7.36	71.4	28	34	0.1	0.02	6	0.67	0	Satisfactory
413	2081/02/19	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.17	<5	7.54	81.4	22	24	0.1	0.02	6	0.22	0	Satisfactory
414	2081/02/19	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.7	<5	7.47	70	24	28	0.1	0.02	6	0.34	0	Satisfactory
415	2081/02/19	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	2.3	<5	7.66	77	26	34	0.1	0.02	6	0.88	0	Satisfactory
416	2081/02/19	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.35	<5	7.49	100.1	26	28	0.1	0.02	6	1.1	0	Satisfactory
417	2081/02/19	14:00	Maharajgunj	Balaju SRT	Treated	Clear	0.01	<5	7.65	100.7	28	30	0.1	0.02	6	0.1	0	Satisfactory
418	2081/02/19	13:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.53	102.5	26	28	0.1	0.02	6	0.81	0	Satisfactory
419	2081/02/19	7:15	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.6	108.7	28	26	0.1	0.02	6	0.20	0	Satisfactory
420	2081/02/19	12:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.22	<5	6.99	103.8	22	28	0.1	0.02	6	0.1	0	Satisfactory
421	2081/02/19	13:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.41	101.7	24	28	0.1	0.02	6	0.1	0	Satisfactory
422	2081/02/19	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.72	70.8	28	34	0.1	0.02	6	0.1	0	Satisfactory
423	2081/02/19	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.7	71.1	28	34	0.1	0.02	6	1.7	0	Satisfactory
424	2081/02/19	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.74	71.4	28	34	0.1	0.02	6	1.1	0	Satisfactory
425	2081/02/19	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.76	70.9	28	34	0.1	0.02	6	0.98	0	Satisfactory
426	2081/02/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	7.99	504	110	142	0.1	0.02	14	0.75	0	Satisfactory
427	2081/02/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.47	101.9	24	26	0.1	0.02	6	0.33	0	Satisfactory
428	2081/02/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.46	106.3	22	24	0.1	0.02	6	0.82	0	Satisfactory
429	2081/02/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.65	109.3	24	22	0.1	0.02	6	0.26	0	Satisfactory
430	2081/02/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.53	109	22	20	0.1	0.02	6	0.44	0	Satisfactory
431	2081/02/20	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.53	71	24	28	0.1	0.02	6	0.31	0	Satisfactory
432	2081/02/20	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	2.1	<5	7.71	78	26	34	0.1	0.02	6	0.20	0	Satisfactory
433	2081/02/20	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	2.1	<5	7.60	76	26	34	0.1	0.02	6	0.42	0	Satisfactory
434	2081/02/20	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.23	<5	6.92	354	94	72	0.57	0.3	12	0.1	0	Satisfactory
435	2081/02/20	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.97	<5	6.9	339	90	68	0.57	0.3	12	0.16	0	Satisfactory
436	2081/02/20	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.02	<5	6.9	324	90	68	0.57	0.3	12	0.1	0	Satisfactory
437	2081/02/20	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.27	<5	7.72	102.2	28	30	0.1	0.02	6	0.1	0	Satisfactory
438	2081/02/20	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.55	105.2	26	28	0.1	0.02	6	0.88	0	Satisfactory
439	2081/02/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.8	103.7	28	30	0.1	0.02	6	0.45	0	Satisfactory
440	2081/02/20	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.54	<5	7.65	104.3	28	30	0.1	0.02	6	0.35	0	Satisfactory
441	2081/02/20	12:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.45	<5	7.65	99.3	28	26	0.1	0.02	6	0.15	0	Satisfactory
442	2081/02/20	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	7.82	101.7	28	32	0.1	0.02	6	0.1	0	Satisfactory

443	2081/02/20	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.01	<5	7.79	107.2	28	30	0.1	0.02	6	0.1	0	Satisfactory
444	2081/02/20		Baneshwor	Minbhawan SRT	Treated	Clear	0.14	<5	7.75	99.5	28	30	0.1	0.02	6	0.1	0	Satisfactory
445	2081/02/20	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.66	70.5	28	34	0.1	0.02	6	0.1	0	Satisfactory
446	2081/02/20	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.73	71.2	28	34	0.1	0.02	6	0.1	0	Satisfactory
447	2081/02/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.56	75	28	34	0.1	0.02	6	1.25	0	Satisfactory
448	2081/02/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.5	73.6	28	34	0.1	0.02	6	1.36	0	Satisfactory
449	2081/02/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.17	<5	7.62	72.7	28	34	0.1	0.02	6	1.12	0	Satisfactory
450	2081/02/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.72	<5	7.88	69.9	28	34	0.1	0.02	6	0.22	0	Satisfactory
451	2081/02/20	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.14	<5	7.74	71.4	28	34	0.1	0.02	6	0.92	0	Satisfactory
452	2081/02/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.33	100	22	26	0.1	0.02	6	0.34	0	Satisfactory
453	2081/02/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.38	107.5	22	26	0.1	0.02	6	0.42	0	Satisfactory
454	2081/02/21	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.07	<5	7.79	105.8	24	28	0.1	0.02	6	0.11	0	Satisfactory
455	2081/02/21	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.58	110.2	24	26	0.1	0.02	6	0.47	0	Satisfactory
456	2081/02/21	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.51	70	24	28	0.1	0.02	6	0.28	0	Satisfactory
457	2081/02/21	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	2.4	<5	7.60	79	26	34	0.1	0.02	6	0.20	0	Satisfactory
458	2081/02/21	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	2.1	<5	7.61	78	26	34	0.1	0.02	6	0.24	0	Satisfactory
459	2081/02/21	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.9	<5	7.60	79	26	34	0.1	0.02	6	0.46	0	Satisfactory
460	2081/02/21	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.78	<5	6.92	350	94	70	0.57	0.3	12	0.1	0	Satisfactory
461	2081/02/21	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.65	<5	7.01	339	92	70	0.57	0.3	12	0.1	0	Satisfactory
462	2081/02/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.72	<5	7.12	104.7	22	30	0.1	0.02	6	0.29	0	Satisfactory
463	2081/02/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.36	<5	7.57	103.2	26	28	0.1	0.02	6	0.85	0	Satisfactory
464	2081/02/21	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.86	101.6	30	26	0.1	0.02	6	0.1	0	Satisfactory
465	2081/02/21	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.96	101	30	28	0.1	0.02	6	0.1	0	Satisfactory
466	2081/02/21	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.07	<5	7.88	108.1	30	28	0.1	0.02	6	0.1	0	Satisfactory
467	2081/02/21	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.51	<5	7.91	73.2	28	34	0.1	0.02	6	0.14	0	Satisfactory
468	2081/02/21	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.23	<5	7.81	75.5	28	34	0.1	0.02	6	1.31	0	Satisfactory
469	2081/02/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.33	<5	7.73	74.6	28	34	0.1	0.02	6	1.43	0	Satisfactory
470	2081/02/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.35	<5	7.57	71.5	28	34	0.1	0.02	6	0.23	0	Satisfactory
471	2081/02/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.62	<5	7.56	74.2	28	34	0.1	0.02	6	0.85	0	Satisfactory
472	2081/02/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.29	<5	7.55	73.6	28	34	0.1	0.02	6	1.02	0	Satisfactory
473	2081/02/21	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.58	<5	7.72	72.5	28	34	0.1	0.02	6	1.06	0	Satisfactory
474	2081/02/22	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.64	<5	8.09	498	108	134	0.1	0.02	12	0.78	0	Satisfactory
475	2081/02/22	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.37	99.2	24	28	0.1	0.02	6	0.21	0	Satisfactory
476	2081/02/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.27	<5	8.2	103.9	32	28	0.1	0.02	6	0.5	0	Satisfactory
477	2081/02/22	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.3	102.5	20	24	0.1	0.02	6	0.24	0	Satisfactory
478	2081/02/22	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.96	104.2	24	26	0.1	0.02	6	0.37	0	Satisfactory
479	2081/02/22	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.9	<5	7.52	71	24	28	0.1	0.02	6	0.37	0	Satisfactory
480	2081/02/22	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	3.1	<5	7.76	76	26	34	0.1	0.02	6	0.20	0	Satisfactory
481	2081/02/22	13:50	Maharajgunj	Bansbari SRT	Treated	Clear	3.1	<5	7.71	76	26	34	0.1	0.02	6	0.43	0	Satisfactory
482	2081/02/22	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	3.4	<5	7.72	76	26	34	0.1	0.02	6	0.51	0	Satisfactory
483	2081/02/22	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.8	<5	6.91	374	100	72	0.76	0.3	14	0.4	0	Satisfactory
484	2081/02/22	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.74	<5	6.85	364	96	72	0.57	0.3	14	0.33	0	Satisfactory
485	2081/02/22	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	4.3	<5	6.97	175	44	40	0.3	1.5	4	0.44	0	Satisfactory
486	2081/02/22	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.21	<5	7.53	107	26	30	0.1	0.02	6	0.17	0	Satisfactory
487	2081/02/22	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.66	<5	8.15	108.8	32	30	0.1	0.02	6	0.74	0	Satisfactory
488	2081/02/22	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.38	<5	7.67	107.2	28	26	0.1	0.02	6	0.1	0	Satisfactory
489	2081/02/22	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.93	<5	8.17	107.2	32	30	0.1	0.02	6	0.31	0	Satisfactory
490	2081/02/22	14:00	Maharajgunj	Balaju SRT	Treated	Clear	2.07	<5	7.77	109.7	28	30	0.1	0.02	6	0.45	0	Satisfactory
491	2081/02/22	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.07	<5	7.75	102.3	28	26	0.1	0.02	6	0.25	0	Satisfactory
492	2081/02/22	7:30	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.6	111.7	28	26	0.1	0.02	6	0.20	0	Satisfactory
493	2081/02/22	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.17	<5	8.16	104.9	32	30	0.1	0.02	6	0.1	0	Satisfactory

494	2081/02/22	9:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.64	103.4	28	30	0.1	0.02	6	0.1	0	Satisfactory
495	2081/02/22	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	1.16	<5	7.82	104.9	28	26	0.1	0.02	6	0.25	0	Satisfactory
496	2081/02/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.61	<5	8.05	70.7	28	34	0.1	0.02	6	0.20	0	Satisfactory
497	2081/02/22	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.22	<5	7.91	74.7	28	34	0.1	0.02	6	1.57	0	Satisfactory
498	2081/02/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.94	<5	7.88	74	28	34	0.1	0.02	6	1.33	0	Satisfactory
499	2081/02/22	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.94	<5	7.62	71.1	28	34	0.1	0.02	6	0.25	0	Satisfactory
500	2081/02/22	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.09	<5	7.81	72.6	28	34	0.1	0.02	6	0.37	0	Satisfactory
501	2081/02/22	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.22	<5	7.9	75.5	28	34	0.1	0.02	6	1.31	0	Satisfactory
502	2081/02/22	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.65	75.7	28	34	0.1	0.02	6	1.33	0	Satisfactory
503	2081/02/23	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.09	<5	8.09	506	110	136	0.1	0.02	12	0.81	0	Satisfactory
504	2081/02/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.52	92.2	24	26	0.1	0.02	6	0.55	0	Satisfactory
505	2081/02/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	6.72	92.6	18	24	0.1	0.02	6	0.75	0	Satisfactory
506	2081/02/23	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	6.95	91.8	20	26	0.1	0.02	6	0.22	0	Satisfactory
507	2081/02/23	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.47	<5	7.25	88.7	22	26	0.1	0.02	6	0.49	0	Satisfactory
508	2081/02/23	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.47	72	24	28	0.1	0.02	6	0.38	0	Satisfactory
509	2081/02/23	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1.6	<5	7.57	77	26	34	0.1	0.02	6	0.61	0	Satisfactory
510	2081/02/23	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.49	<5	6.79	376	96	72	0.57	0.3	14	0.18	0	Satisfactory
511	2081/02/23	12:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.02	<5	7.06	106.2	28	40	0.1	0.02	4	0.25	0	Satisfactory
512	2081/02/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.03	<5	7.54	101.5	26	28	0.1	0.02	6	1.17	0	Satisfactory
513	2081/02/23	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	6.95	106.9	20	32	0.1	0.02	6	0.83	0	Satisfactory
514	2081/02/23	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.04	105.7	20	30	0.1	0.02	6	0.69	0	Satisfactory
515	2081/02/23	16:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.09	<5	7.18	103.9	22	28	0.1	0.02	6	0.47	0	Satisfactory
516	2081/02/23	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.08	103.1	22	30	0.1	0.02	6	0.23	0	Satisfactory
517	2081/02/23	7:20	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.5	110.1	24	26	0.1	0.02	6	0.20	0	Satisfactory
518	2081/02/23	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.01	<5	6.95	104.1	20	30	0.1	0.02	6	0.1	0	Satisfactory
519	2081/02/23	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.32	<5	7.75	112.4	28	26	0.1	0.02	6	0.2	0	Satisfactory
520	2081/02/23	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.12	<5	6.5	101.70	14	30	0.1	0.02	6	0.1	0	Satisfactory
521	2081/02/23	12:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.01	<5	7.06	106.2	20	30	0.1	0.02	6	0.25	0	Satisfactory
522	2081/02/23	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.86	71.8	28	34	0.1	0.02	6	0.13	0	Satisfactory
523	2081/02/23	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.81	77.5	28	34	0.1	0.02	6	1.14	0	Satisfactory
524	2081/02/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.75	75.3	28	34	0.1	0.02	6	0.83	0	Satisfactory
525	2081/02/23	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.62	74.1	28	34	0.1	0.02	6	0.86	0	Satisfactory
526	2081/02/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.79	74.7	28	34	0.1	0.02	6	1.19	0	Satisfactory
527	2081/02/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.6	74.8	28	34	0.1	0.02	6	1.05	0	Satisfactory
528	2081/02/23	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.84	77.5	28	34	0.1	0.02	6	0.56	0	Satisfactory
529	2081/02/24	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.55	<5	7.98	505	110	136	0.1	0.02	12	0.69	0	Satisfactory
530	2081/02/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.36	<5	7.38	94.6	20	26	0.1	0.02	6	0.12	0	Satisfactory
531	2081/02/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.3	133.6	20	26	0.1	0.02	6	0.23	0	Satisfactory
532	2081/02/24	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.7	121	24	28	0.1	0.02	6	0.35	0	Satisfactory
533	2081/02/24	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.01	<5	7.3	125.3	20	26	0.1	0.02	6	0.27	0	Satisfactory
534	2081/02/24	8:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.47	72	24	28	0.1	0.02	6	0.32	0	Satisfactory
535	2081/02/24	9:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.5	<5	7.51	80	26	34	0.1	0.02	6	0.32	0	Satisfactory
536	2081/02/24	15:45	Maharajgunj	Panipokhari SRT	Treated	Clear	1.0	<5	7.71	79	26	34	0.1	0.02	6	0.54	0	Satisfactory
537	2081/02/24	12:45	Madhyapur Thimi	Bode WTP	Treated	Clear	1.91	<5	6.92	382	100	74	0.57	0.3	12	0.1	0	Satisfactory
538	2081/02/24	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.85	<5	6.88	364	96	72	0.57	0.3	12	0.24	0	Satisfactory
539	2081/02/24	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.61	<5	7.05	109	28	40	0.1	0.02	4	0.1	0	Satisfactory
540	2081/02/24	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.38	112.8	24	30	0.1	0.02	6	0.57	0	Satisfactory
541	2081/02/24	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.01	<5	7.23	113.9	22	28	0.1	0.02	6	0.9	0	Satisfactory
542	2081/02/24	14:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.29	<5	7.7	112.6	28	32	0.1	0.02	6	0.79	0	Satisfactory
543	2081/02/24	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.57	<5	7.5	111.6	26	28	0.1	0.02	6	0.78	0	Satisfactory
544	2081/02/24	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.01	<5	7.56	111.6	28	32	0.1	0.02	6	0.35	0	Satisfactory

545	2081/02/24	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.01	<5	7.4	115.5	24	30	0.1	0.02	6	0.17	0	Satisfactory
546	2081/02/24	10:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.01	<5	7.4	109.6	24	32	0.1	0.02	6	0.65	0	Satisfactory
547	2081/02/24	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.81	72.3	28	34	0.1	0.02	6	0.15	0	Satisfactory
548	2081/02/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.73	76.7	28	34	0.1	0.02	6	0.87	0	Satisfactory
549	2081/02/24	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.8	75.1	28	34	0.1	0.02	6	1.05	0	Satisfactory
550	2081/02/24	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.79	73.8	28	34	0.1	0.02	6	0.86	0	Satisfactory
551	2081/02/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.73	73	28	34	0.1	0.02	6	0.36	0	Satisfactory
552	2081/02/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.75	77.2	28	34	0.1	0.02	6	0.65	0	Satisfactory
553	2081/02/24	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.69	75.4	28	34	0.1	0.02	6	0.85	0	Satisfactory
554	2081/02/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.67	<5	8.12	507	110	140	0.1	0.02	14	0.94	0	Satisfactory
555	2081/02/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.1	94.8	20	28	0.1	0.02	6	0.17	0	Satisfactory
556	2081/02/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.5	95.2	22	28	0.1	0.02	6	0.3	0	Satisfactory
557	2081/02/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.4	92.3	24	28	0.1	0.02	6	0.22	0	Satisfactory
558	2081/02/25	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.46	69	24	28	0.1	0.02	6	0.42	0	Satisfactory
559	2081/02/25	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.7	<5	7.63	76	26	34	0.1	0.02	6	0.46	0	Satisfactory
560	2081/02/25	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.93	<5	6.96	374	94	66	0.76	0.3	12	0.1	0	Satisfactory
561	2081/02/25	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.86	<5	6.95	354	92	64	0.76	0.3	12	0.26	0	Satisfactory
562	2081/02/25	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.09	<5	7.38	91.1	26	36	0.1	0.02	4	0.1	0	Satisfactory
563	2081/02/25	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.31	<5	7.55	109.2	26	28	0.1	0.02	6	1.1	0	Satisfactory
564	2081/02/25	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.7	105	28	26	0.1	0.02	6	0.5	0	Satisfactory
565	2081/02/25	6:36	Bhaktapur	Katunje SRT	Treated	Clear	2.04	<5	7.7	132.1	28	30	0.1	0.02	6	0.20	0	Satisfactory
566	2081/02/25	7:30	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.7	111.1	28	26	0.1	0.02	6	0.17	0	Satisfactory
567	2081/02/25	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.7	114.5	26	26	0.1	0.02	6	0.1	0	Satisfactory
568	2081/02/25	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.86	76.7	28	34	0.1	0.02	6	0.1	0	Satisfactory
569	2081/02/25	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.98	76.5	28	34	0.1	0.02	6	0.42	0	Satisfactory
570	2081/02/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.94	76.8	28	34	0.1	0.02	6	0.58	0	Satisfactory
571	2081/02/25	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.73	75	28	34	0.1	0.02	6	1.1	0	Satisfactory
572	2081/02/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.62	<5	7.82	77.1	28	34	0.1	0.02	6	0.73	0	Satisfactory
573	2081/02/25	16:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.79	75.2	28	34	0.1	0.02	6	0.52	0	Satisfactory
574	2081/02/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.7	97.5	26	28	0.1	0.02	6	0.25	0	Satisfactory
575	2081/02/26	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.47	71	24	28	0.1	0.02	6	0.44	0	Satisfactory
576	2081/02/26	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	1.4	<5	7.37	78	26	34	0.1	0.02	6	0.63	0	Satisfactory
577	2081/02/26	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.8	110.5	28	32	0.1	0.02	6	0.20	0	Satisfactory
578	2081/02/26	11:55	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.7	113.4	28	30	0.1	0.02	6	0.65	0	Satisfactory
579	2081/02/26	11:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.4	114.2	28	30	0.1	0.02	6	0.7	0	Satisfactory
580	2081/02/26	6:45	Bhaktapur	Katunje SRT	Treated	Clear	0.4	<5	7.8	108.5	28	26	0.1	0.02	6	0.6	0	Satisfactory
581	2081/02/26	10:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.7	115.5	28	30	0.1	0.02	6	0.20	0	Satisfactory
582	2081/02/26	10:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.8	112.5	28	26	0.1	0.02	6	0.20	0	Satisfactory
583	2081/02/26	11:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.7	111.2	28	30	0.1	0.02	6	0.25	0	Satisfactory
584	2081/02/26	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.66	75.5	28	34	0.1	0.02	6	0.20	0	Satisfactory
585	2081/02/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.76	72.5	28	34	0.1	0.02	6	0.49	0	Satisfactory
586	2081/02/26	11:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.76	74.2	28	34	0.1	0.02	6	0.43	0	Satisfactory
587	2081/02/26	13:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.8	75.1	28	34	0.1	0.02	6	0.46	0	Satisfactory
588	2081/02/26	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.68	73.8	28	34	0.1	0.02	6	0.37	0	Satisfactory
589	2081/02/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	8.06	493	102	130	0.1	0.02	12	0.1	0	Satisfactory
590	2081/02/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.52	103	22	28	0.1	0.02	6	0.26	0	Satisfactory
591	2081/02/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.85	<5	7.9	106.1	30	28	0.1	0.02	6	0.38	0	Satisfactory
592	2081/02/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.25	<5	7.59	107.5	24	22	0.1	0.02	6	0.22	0	Satisfactory
593	2081/02/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.56	111.2	22	26	0.1	0.02	6	0.1	0	Satisfactory
594	2081/02/27	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.47	76	24	28	0.1	0.02	6	0.42	0	Satisfactory
595	2081/02/27	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.74	76	26	34	0.1	0.02	6	0.37	0	Satisfactory

596	2081/02/27	15:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.9	<5	7.57	77	26	34	0.1	0.02	6	0.42	0	Satisfactory
597	2081/02/27	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.6	<5	6.92	363	92	66	0.3	1.5	12	0.16	0	Satisfactory
598	2081/02/27	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	6.9	352	90	64	0.3	1.5	12	0.3	0	Satisfactory
599	2081/02/27	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.55	<5	7.35	90.6	26	36	0.1	0.02	4	0.1	0	Satisfactory
600	2081/02/27	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.17	<5	7.52	108	26	28	0.1	0.02	6	0.94	0	Satisfactory
601	2081/02/27	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.8	112.6	30	28	0.1	0.02	6	1.06	0	Satisfactory
602	2081/02/27	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.25	<5	7.64	109.6	26	28	0.1	0.02	6	0.32	0	Satisfactory
603	2081/02/27		Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.73	111.2	28	30	0.1	0.02	6	0.7	0	Satisfactory
604	2081/02/27	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.54	109.6	26	24	0.1	0.02	6	0.27	0	Satisfactory
605	2081/02/27	6:45	Bhaktapur	Katunje SRT	Treated	Clear	0.82	<5	7.7	107.1	28	26	0.1	0.02	6	0.23	0	Satisfactory
606	2081/02/27	13:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.45	116.4	26	28	0.1	0.02	6	0.2	0	Satisfactory
607	2081/02/27	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.6	109.7	28	30	0.1	0.02	6	0.20	0	Satisfactory
608	2081/02/27	12:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.49	111.8	26	28	0.1	0.02	6	0.41	0	Satisfactory
609	2081/02/27	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.92	72.8	28	34	0.1	0.02	6	0.20	0	Satisfactory
610	2081/02/27	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.86	78.2	28	34	0.1	0.02	6	0.91	0	Satisfactory
611	2081/02/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.7	75.8	28	34	0.1	0.02	6	1.3	0	Satisfactory
612	2081/02/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.61	72.9	28	34	0.1	0.02	6	0.65	0	Satisfactory
613	2081/02/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.41	73.9	28	34	0.1	0.02	6	1.17	0	Satisfactory
614	2081/02/27	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.5	74.68	28	34	0.1	0.02	6	0.32	0	Satisfactory
615	2081/02/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.66	<5	8.09	551	110	142	0.1	0.02	18	0.3	0	Satisfactory
616	2081/02/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.55	106.1	24	28	0.1	0.02	6	0.34	0	Satisfactory
617	2081/02/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.48	115.7	22	26	0.1	0.02	6	0.33	0	Satisfactory
618	2081/02/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.6	111.9	22	26	0.1	0.02	6	0.42	0	Satisfactory
619	2081/02/28	15:45	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.56	<5	7.8	53.7	18	14	0.1	0.02	6	0.31	0	Satisfactory
620	2081/02/28	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.54	71	24	28	0.1	0.02	6	0.51	0	Satisfactory
621	2081/02/28	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.2	<5	7.72	76	26	34	0.1	0.02	6	0.54	0	Satisfactory
622	2081/02/28	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.8	<5	7.54	77	26	34	0.1	0.02	6	0.20	0	Satisfactory
623	2081/02/28	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.26	<5	6.96	346	90	64	0.3	1.5	14	0.32	0	Satisfactory
624	2081/02/28	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.93	<5	6.95	297	82	60	0.3	1.5	12	0.28	0	Satisfactory
625	2081/02/28	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.46	<5	7.3	91.8	26	36	0.1	0.02	4	0.1	0	Satisfactory
626	2081/02/28	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.73	113.8	28	30	0.1	0.02	6	1.05	0	Satisfactory
627	2081/02/28	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.67	118.7	28	26	0.1	0.02	6	1.1	0	Satisfactory
628	2081/02/28	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.8	114.7	28	30	0.1	0.02	6	0.11	0	Satisfactory
629	2081/02/28	15:45	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.67	<5	8.06	116.2	30	28	0.1	0.02	6	0.26	0	Satisfactory
630	2081/02/28		Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.65	109.3	28	28	0.1	0.02	6	0.20	0	Satisfactory
631	2081/02/28	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.9	117.3	30	28	0.1	0.02	6	0.28	0	Satisfactory
632	2081/02/28	6:20	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.62	115.4	26	30	0.1	0.02	6	0.20	0	Satisfactory
633	2081/02/28	12:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.94	111.3	30	28	0.1	0.02	6	0.20	0	Satisfactory
634	2081/02/28	15:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.68	121	28	30	0.1	0.02	6	0.15	0	Satisfactory
635	2081/02/28	11:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	8	118.5	30	28	0.1	0.02	6	0.20	0	Satisfactory
636	2081/02/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.8	72.1	28	34	0.1	0.02	6	0.20	0	Satisfactory
637	2081/02/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.78	77.1	28	34	0.1	0.02	6	0.62	0	Satisfactory
638	2081/02/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.72	74.7	28	34	0.1	0.02	6	1.24	0	Satisfactory
639	2081/02/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.78	72.1	28	34	0.1	0.02	6	0.27	0	Satisfactory
640	2081/02/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.82	72.1	28	34	0.1	0.02	6	0.81	0	Satisfactory
641	2081/02/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.63	74.9	28	34	0.1	0.02	6	0.91	0	Satisfactory
642	2081/02/28	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.81	71.5	28	34	0.1	0.02	6	0.34	0	Satisfactory
643	2/29/2081	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.92	<5	7.88	114.2	26	28	0.1	0.02	6	0.53	0	Satisfactory
644	2/29/2081	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	7.77	115.01	26	24	0.1	0.02	6	0.42	0	Satisfactory
645	2/29/2081	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.53	<5	7.5	110	22	28	0.1	0.02	6	0.21	0	Satisfactory
646	2/29/2081	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.93	<5	7.46	108.7	22	28	0.1	0.02	6	0.20	0	Satisfactory



647	2/30/2081	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.39	<5	7.61	110.6	24	28	0.1	0.02	6	0.49	0	Satisfactory
648	2/30/2081	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.27	<5	7.5	110.4	22	26	0.1	0.02	6	0.6	0	Satisfactory
649	2/30/2081	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.29	<5	7.76	127.1	22	26	0.1	0.02	6	0.6	0	Satisfactory
650	2/30/2081	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.29	<5	7.09	110.4	20	26	0.1	0.02	6	0.32	0	Satisfactory
651	2/31/2081	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.02	<5	7.4	100.3	20	24	0.1	0.02	6	0.19	0	Satisfactory
652	2/31/2081	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.22	<5	7.2	99.7	20	24	0.1	0.02	6	0.3	0	Satisfactory
653	2/31/2081	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.97	<5	7.2	102.9	20	26	0.1	0.02	6	0.14	0	Satisfactory
654	2/31/2081	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.73	<5	7.2	102.5	20	26	0.1	0.02	6	0.2	0	Satisfactory
655	2/32/2081	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.29	<5	7.6	96	22	24	0.1	0.02	6	0.20	0	Satisfactory
656	2/32/2081	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.81	<5	7.4	94.5	20	24	0.1	0.02	6	0.1	0	Satisfactory
657	2/32/2081	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.34	90	22	20	0.1	0.02	6	0.20	0	Satisfactory
658	2081/02/29	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	8.11	530	100	134	0.1	0.02	18	0.1	0	Satisfactory
659	2081/02/30	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.79	<5	8.21	491	98	134	0.1	0.02	12	0.74	0	Satisfactory
660	2081/02/31	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.21	<5	7.91	526	112	140	0.1	0.02	18	0.85	0	Satisfactory
661	2081/02/32	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.87	<5	8.01	531	112	142	0.1	0.02	18	0.88	0	Satisfactory
662	2081/2/29	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.48	72	24	28	0.1	0.02	6	0.33	0	Satisfactory
663	2081/2/29	10:45	Maharajgunj	Balaju SRT	Treated	Clear	0.9	<5	7.54	77	26	34	0.1	0.02	6	0.20	0	Satisfactory
664	2081/2/29	15:25	Maharajgunj	Balaju SRT	Treated	Clear	1.1	<5	7.52	74	24	32	0.1	0.02	6	0.47	0	Satisfactory
665	2081/2/29	11: AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.44	<5	6.92	314	84	60	0.3	1.5	14	0.1	0	Satisfactory
666	2081/2/29	2:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.4	<5	6.9	310	84	60	0.3	1.5	12	0.23	0	Satisfactory
667	2081/2/29	1:30 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.71	<5	7.67	109.5	30	40	0.1	0.02	4	0.96	0	Satisfactory
668	2081/2/29	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.98	<5	8.16	108	32	28	0.1	0.02	6	0.53	0	Satisfactory
669	2081/2/29	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.95	<5	7.93	103.3	30	26	0.1	0.02	6	1.04	0	Satisfactory
670	2081/2/29	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.68	<5	7.65	107.65	28	26	0.1	0.02	6	0.68	0	Satisfactory
671	2081/2/29	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.83	<5	7.63	104	26	28	0.1	0.02	6	0.4	0	Satisfactory
672	2081/2/29	12:40	Baneshwor	Anamnagar SRT	Treated	Clear	0.54	<5	7.75	109.4	30	26	0.1	0.02	6	0.33	0	Satisfactory
673	2081/2/29	6:50	Bhaktapur	Katunje SRT	Treated	Clear	0.36	<5	7.64	111.4	28	24	0.1	0.02	6	0.20	0	Satisfactory
674	2081/2/29	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.58	<5	6.86	116.9	20	28	0.1	0.02	6	0.23	0	Satisfactory
675	2081/2/29	12:50	Baneshwor	Minbhawan SRT	Treated	Clear	1.11	<5	7.84	107.9	30	26	0.1	0.02	6	0.16	0	Satisfactory
676	2081/2/29	13:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.71	<5	7.67	109.5	28	26	0.1	0.02	6	0.96	0	Satisfactory
677	2081/2/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.89	71.2	28	34	0.1	0.02	6	0.12	0	Satisfactory
678	2081/2/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.81	73.6	28	34	0.1	0.02	6	1.1	0	Satisfactory
679	2081/2/29	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.7	70.7	28	34	0.1	0.02	6	1.36	0	Satisfactory
680	2081/2/29	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.64	70.3	28	34	0.1	0.02	6	1.6	0	Satisfactory
681	2081/2/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.76	68.5	28	34	0.1	0.02	6	0.5	0	Satisfactory
682	2081/2/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.78	70.4	28	34	0.1	0.02	6	0.58	0	Satisfactory
683	2081/2/29	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.62	71.8	28	34	0.1	0.02	6	1.34	0	Satisfactory
684	2081/2/30	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.5	<5	7.47	62	22	26	0.1	0.02	6	0.53	0	Satisfactory
685	2081/2/30	10:15	Maharajgunj	Balaju SRT	Treated	Clear	1.0	<5	7.70	78	26	34	0.1	0.02	6	0.62	0	Satisfactory
686	2081/2/30	15:25	Maharajgunj	Balaju SRT	Treated	Clear	4.7	<5	7.53	76	26	34	0.1	0.02	6	0.70	0	Satisfactory
687	2081/2/30	11: AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.77	<5	6.8	327	86	62	0.3	1.5	16	0.57	0	Satisfactory
688	2081/2/30	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.18	<5	6.98	309	84	60	0.3	1.5	10	0.1	0	Satisfactory
689	2081/2/30	10:15 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.14	<5	7.25	110	28	40	0.1	0.02	4	0.1	0	Satisfactory
690	2081/2/30	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.42	<5	7.66	104.2	28	30	0.1	0.02	6	0.76	0	Satisfactory
691	2081/2/30	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.99	<5	7.8	101	28	30	0.1	0.02	6	0.67	0	Satisfactory
692	2081/2/30	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.83	<5	7.89	124.7	30	28	0.1	0.02	6	0.44	0	Satisfactory
693	2081/2/30	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.38	<5	7.22	105	24	26	0.1	0.02	6	1.17	0	Satisfactory
694	2081/2/30	10:15	Maharajgunj	Balaju SRT	Treated	Clear	4.03	<5	7.84	115	28	26	0.1	0.02	6	0.20	0	Satisfactory
695	2081/2/30	13:15	Baneshwor	Anamnagar SRT	Treated	Clear	1.4	<5	7.97	107	30	28	0.1	0.02	6	0.4	0	Satisfactory
696	2081/2/30	6:30	Bhaktapur	Katunje SRT	Treated	Clear	0.96	<5	7.69	107.9	28	30	0.1	0.02	6	0.16	0	Satisfactory
697	2081/2/30	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	1.32	<5	7.8	99.4	28	22	0.1	0.02	6	0.11	0	Satisfactory

698	2081/2/30	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.33	<5	7.95	137.5	30	28	0.1	0.02	6	0.75	0	Satisfactory
699	2081/2/30	13:00	Baneshwor	Minbhawan SRT	Treated	Clear	1.18	<5	7.76	101.5	28	30	0.1	0.02	6	0.6	0	Satisfactory
700	2081/2/30	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.7	<5	7.97	68.4	28	34	0.1	0.02	6	0.20	0	Satisfactory
701	2081/2/30	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.88	<5	7.83	70.9	28	34	0.1	0.02	6	1.19	0	Satisfactory
702	2081/2/30	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.73	<5	7.84	71.7	28	34	0.1	0.02	6	1.04	0	Satisfactory
703	2081/2/30	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	7.67	67.2	28	34	0.1	0.02	6	0.46	0	Satisfactory
704	2081/2/30	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.54	71.5	28	34	0.1	0.02	6	0.73	0	Satisfactory
705	2081/2/30	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.69	70.1	28	34	0.1	0.02	6	0.25	0	Satisfactory
706	2081/2/30	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.75	69.6	28	34	0.1	0.02	6	0.62	0	Satisfactory
707	2081/2/31	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.6	<5	7.46	68	24	28	0.1	0.02	6	0.48	0	Satisfactory
708	2081/2/31	10:15	Maharajgunj	Balaju SRT	Treated	Clear	1.5	<5	7.53	74	24	32	0.1	0.02	6	0.62	0	Satisfactory
709	2081/2/31	15:20	Maharajgunj	Balaju SRT	Treated	Clear	1.2	<5	7.44	74	24	32	0.1	0.02	6	0.54	0	Satisfactory
710	2081/2/31	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.82	<5	6.83	334	86	60	0.3	1.5	12	0.16	0	Satisfactory
711	2081/2/31	3:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.27	<5	6.94	215	50	48	0.3	1.5	4	0.1	0	Satisfactory
712	2081/2/31	3:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.4	<5	7.1	85.6	24	38	0.1	0.02	4	0.86	0	Satisfactory
713	2081/2/31	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.35	<5	7.3	91.5	24	26	0.1	0.02	6	0.9	0	Satisfactory
714	2081/2/31	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.57	<5	7.13	101.5	22	34	0.1	0.02	6	0.8	0	Satisfactory
715	2081/2/31	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.55	<5	7.3	105	24	30	0.1	0.02	6	0.8	0	Satisfactory
716	2081/2/31	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.4	102.8	24	28	0.1	0.02	6	0.5	0	Satisfactory
717	2081/2/31	11:10	Baneshwor	Anamnagar SRT	Treated	Clear	0.32	<5	7	101.4	20	26	0.1	0.02	6	0.48	0	Satisfactory
718	2081/2/31	6:10	Bhaktapur	Katunje SRT	Treated	Clear	0.38	<5	7.2	109	22	26	0.1	0.02	6	0.21	0	Satisfactory
719	2081/2/31	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	1.06	<5	7	110.4	22	26	0.1	0.02	6	1.3	0	Satisfactory
720	2081/2/31	11:55	Kirtipur	Kirtipur SRT	Treated	Clear	0.44	<5	7.2	91.3	22	26	0.1	0.02	6	0.27	0	Satisfactory
721	2081/2/31	13:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.22	<5	6.9	102.1	20	26	0.1	0.02	6	0.8	0	Satisfactory
722	2081/2/31	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.82	68.9	28	34	0.1	0.02	6	0.39	0	Satisfactory
723	2081/2/31	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.57	70.01	28	34	0.1	0.02	6	1.36	0	Satisfactory
724	2081/2/31	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.59	70.61	28	34	0.1	0.02	6	1.38	0	Satisfactory
725	2081/2/31	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.49	68.91	28	34	0.1	0.02	6	0.72	0	Satisfactory
726	2081/2/31	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.8	64.7	28	34	0.1	0.02	6	0.51	0	Satisfactory
727	2081/2/31	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.71	68.7	28	34	0.1	0.02	6	0.1	0	Satisfactory
728	2081/2/32	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.4	<5	7.48	68	24	28	0.1	0.02	6	0.43	0	Satisfactory
729	2081/2/32	14:10	Maharajgunj	Balaju SRT	Treated	Clear	0.7	<5	7.72	73	24	32	0.1	0.02	6	0.34	0	Satisfactory
730	2081/2/32	11:20	Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.84	76	26	34	0.1	0.02	6	0.36	0	Satisfactory
731	2081/2/32	11: AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.81	<5	7.03	389	102	70	0.3	1.5	18	1.25	0	Satisfactory
732	2081/2/32	2:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.08	<5	6.8	345	88	66	0.3	1.5	16	0.62	0	Satisfactory
733	2081/2/32	2:45 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.7	102	28	40	0.1	0.02	4	0.14	0	Satisfactory
734	2081/2/32	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.55	<5	7.8	97	28	26	0.1	0.02	6	0.20	0	Satisfactory
735	2081/2/32	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.67	<5	7.88	94.5	30	26	0.1	0.02	6	0.20	0	Satisfactory
736	2081/2/32	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	7.5	98.3	26	28	0.1	0.02	6	0.20	0	Satisfactory
737	2081/2/32	10:30	Bhaktapur	Katunje SRT	Treated	Clear	0.39	<5	7.6	108.7	26	28	0.1	0.02	6	0.20	0	Satisfactory
738	2081/2/32	11:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.51	<5	7.8	108	28	32	0.1	0.02	6	0.1	0	Satisfactory
739	2081/2/32	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.39	<5	7.8	66.9	28	34	0.1	0.02	6	0.1	0	Satisfactory
740	2081/2/32	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.69	<5	7.7	67.4	28	34	0.1	0.02	6	0.1	0	Satisfactory
741	2081/2/32	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.67	65.3	28	34	0.1	0.02	6	0.1	0	Satisfactory
742	2081/2/32	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.76	67.1	28	34	0.1	0.02	6	0.1	0	Satisfactory