



**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Bhadra 2081**

S.N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	p <sup>H</sup>	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks	
							(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml		
<b>Units</b>																			
<b>National Drinking Water Quality Standard (NDWQS)</b>							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples		
1	2081/05/01	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.13	32	12	12	0.1	0.02	6	0.53	0	Satisfactory	
2	2081/05/01	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.12	33	12	12	0.1	0.02	6	0.64	0	Satisfactory	
3	2081/05/01	0:15	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	6.94	34.6	12	14	0.1	0.02	6	1.65	0	Satisfactory	
4	2081/05/01	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.03	34.3	12	14	0.1	0.02	6	1.2	0	Satisfactory	
5	2081/05/01	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.11	31.7	12	14	0.1	0.02	6	0.86	0	Satisfactory	
6	2081/05/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.15	31.8	12	14	0.1	0.02	6	0.98	0	Satisfactory	
7	2081/05/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.54	<5	7.11	31.9	12	14	0.1	0.02	6	1.54	0	Satisfactory	
8	2081/05/01	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.19	32.2	12	14	0.1	0.02	6	0.31	0	Satisfactory	
9	2081/05/01	0:15	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	6.87	32	12	14	0.1	0.02	6	1.22	0	Satisfactory	
10	2081/05/01	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.78	<5	6.67	37.9	12	14	0.1	0.02	6	1.5	0	Satisfactory	
11	2081/05/01	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.23	<5	6.69	36.8	12	14	0.1	0.02	6	1.56	0	Satisfactory	
12	2081/05/01	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.06	<5	6.67	33.6	12	14	0.1	0.02	6	1.59	0	Satisfactory	
13	2081/05/01	13:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.57	<5	7.86	82.9	28	30	0.1	0.02	8	0.77	0	Satisfactory	
14	2081/05/01	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.11	<5	7.64	77.1	26	26	0.1	0.02	8	0.8	0	Satisfactory	
15	2081/05/01	13:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.12	<5	7.98	86.5	30	30	0.1	0.02	10	0.75	0	Satisfactory	
16	2081/05/01	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.68	<5	7.3	57.2	22	22	0.1	0.02	8	0.65	0	Satisfactory	

17	2081/05/01	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.11	<5	7.79	75.9	28	26	0.1	0.02	8	0.86	0	Satisfactory
18	2081/05/02	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.63	<5	7.06	35	12	12	0.1	0.02	6	0.62	0	Satisfactory
19	2081/05/02	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	6.91	39	14	16	0.1	0.02	6	0.91	0	Satisfactory
20	2081/05/02	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.77	<5	6.85	372	90	78	0.38	1.5	16	0.52	0	Satisfactory
21	2081/05/02	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.98	<5	6.85	373	90	78	0.38	1.5	12	0.14	0	Satisfactory
22	2081/05/02	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.88	<5	6.85	368	90	76	0.38	1.5	12	0.16	0	Satisfactory
23	2081/05/02	11:45	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.59	<5	6.77	34.5	12	14	0.1	0.02	6	1.53	0	Satisfactory
24	2081/05/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.49	<5	6.85	36.9	12	14	0.1	0.02	6	1.54	0	Satisfactory
25	2081/05/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.19	38.9	12	14	0.1	0.02	6	0.91	0	Satisfactory
26	2081/05/02	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.28	37.5	12	14	0.1	0.02	6	1.62	0	Satisfactory
27	2081/05/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.29	<5	7.3	41.5	12	14	0.1	0.02	6	0.94	0	Satisfactory
28	2081/05/02	11:45	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.16	<5	7	35.8	12	14	0.1	0.02	6	1.28	0	Satisfactory
29	2081/05/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.52	<5	6.92	45.4	12	14	0.1	0.02	6	1.04	0	Satisfactory
30	2081/05/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.87	<5	7	42.9	12	14	0.1	0.02	6	1.47	0	Satisfactory
31	2081/05/02	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.33	<5	7.27	42.6	12	14	0.1	0.02	6	0.76	0	Satisfactory
32	2081/05/02	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.29	41.3	12	14	0.1	0.02	6	1	0	Satisfactory
33	2081/05/02	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	1.25	<5	7.84	79.3	28	26	0.1	0.02	8	0.74	0	Satisfactory
34	2081/05/02	2:05	Kirtipur	Kirtipur SRT	Treated	Clear	0.01	<5	8.01	85.4	30	30	0.1	0.02	10	0.72	0	Satisfactory
35	2081/05/02	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.12	<5	7.59	90.2	26	28	0.1	0.02	10	1.34	0	Satisfactory
36	2081/05/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.60	<5	7.6	87.6	26	28	0.1	0.02	10	1.15	0	Satisfactory
37	2081/05/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.22	<5	7.59	84	26	28	0.1	0.02	10	0.6	0	Satisfactory
38	2081/05/02	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.31	<5	7.62	80.1	26	28	0.1	0.02	10	0.4	0	Satisfactory
39	2081/05/02	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	1.92	<5	7.65	73.2	28	24	0.1	0.02	8	0.92	0	Satisfactory
40	2081/05/02	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.12	<5	8.18	386	96	110	0.1	0.02	8	0.28	0	Satisfactory
41	2081/05/03	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	6.94	32	12	12	0.1	0.02	6	0.92	0	Satisfactory

42	2081/05/03	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	6.94	36	12	14	0.1	0.02	6	0.87	0	Satisfactory
43	2081/05/03	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.01	<5	6.9	345	88	68	0.38	1.5	10	0.27	0	Satisfactory
44	2081/05/03	11:45	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.33	39.7	12	14	0.1	0.02	6	1.13	0	Satisfactory
45	2081/05/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.78	<5	7.26	38.9	12	14	0.1	0.02	6	0.97	0	Satisfactory
46	2081/05/03	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.21	38.9	12	14	0.1	0.02	6	0.76	0	Satisfactory
47	2081/05/03	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.11	37	12	14	0.1	0.02	6	1.34	0	Satisfactory
48	2081/05/03	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.08	<5	7.12	38.2	12	14	0.1	0.02	6	1.13	0	Satisfactory
49	2081/05/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.3	36.8	12	14	0.1	0.02	6	0.44	0	Satisfactory
50	2081/05/03	11:50	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.21	37.1	12	14	0.1	0.02	6	0.58	0	Satisfactory
51	2081/05/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.4	37.2	12	14	0.1	0.02	6	1.1	0	Satisfactory
52	2081/05/03	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.1	36	12	14	0.1	0.02	6	1.92	0	Satisfactory
53	2081/05/03	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.99	<5	7.25	38.9	12	14	0.1	0.02	6	1.45	0	Satisfactory
54	2081/05/03	8:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	7.65	82.5	26	28	0.1	0.02	10	0.42	0	Satisfactory
55	2081/05/04	11:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	6.93	31	12	12	0.1	0.02	6	0.71	0	Satisfactory
56	2081/05/04	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	6.93	31	10	12	0.1	0.02	6	0.70	0	Satisfactory
57	2081/05/04	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.96	<5	6.88	358	90	70	0.38	1.5	10	0.22	0	Satisfactory
58	2081/05/04	11:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	7.26	36.2	12	14	0.1	0.02	6	1.81	0	Satisfactory
59	2081/05/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.2	<5	7.22	36.9	12	14	0.1	0.02	6	1.33	0	Satisfactory
60	2081/05/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.31	<5	7.29	37.3	12	14	0.1	0.02	6	0.97	0	Satisfactory
61	2081/05/04	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.41	<5	7.27	35.7	12	14	0.1	0.02	6	1.07	0	Satisfactory
62	2081/05/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.87	<5	7.21	34.7	12	14	0.1	0.02	6	0.39	0	Satisfactory
63	2081/05/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.5	46.3	12	14	0.1	0.02	6	0.52	0	Satisfactory
64	2081/05/04	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.1	39.3	12	14	0.1	0.02	6	0.68	0	Satisfactory
65	2081/05/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.3	41.1	12	14	0.1	0.02	6	0.71	0	Satisfactory
66	2081/05/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.4	<5	7.02	34.6	12	14	0.1	0.02	6	1.15	0	Satisfactory

67	2081/05/04	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.46	<5	6.83	34.5	12	14	0.1	0.02	6	1.04	0	Satisfactory
68	2081/05/04	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.11	<5	7.64	77.1	26	26	0.1	0.02	8	0.8	0	Satisfactory
69	2081/05/04		Kirtipur	Kirtipur SRT	Treated	Clear	0.12	<5	7.98	86.6	30	30	0.1	0.02	10	0.75	0	Satisfactory
70	2081/05/04	14:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.86	<5	7.3	57.2	24	28	0.1	0.02	10	0.65	0	Satisfactory
71	2081/05/04	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.41	<5	7.86	57	30	18	0.1	0.02	8	0.86	0	Satisfactory
72	2081/05/05	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	6.90	42	14	16	0.1	0.02	6	0.72	0	Satisfactory
73	2081/05/05	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	6.94	46	16	18	0.1	0.02	6	1.03	0	Satisfactory
74	2081/05/05	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	0.98	<5	6.94	353	90	68	0.38	1.5	10	0.44	0	Satisfactory
75	2081/05/05	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.03	<5	6.92	355	90	70	0.38	1.5	12	0.31	0	Satisfactory
76	2081/05/05	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.17	<5	6.9	350	90	70	0.5	1.5	12	0.2	0	Satisfactory
77	2081/05/05	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.58	<5	6.99	34.1	12	14	0.1	0.02	6	1.53	0	Satisfactory
78	2081/05/05	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.1	33.4	12	14	0.1	0.02	6	1.39	0	Satisfactory
79	2081/05/05	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.09	34.5	12	14	0.1	0.02	6	1.16	0	Satisfactory
80	2081/05/05	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.1	35.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
81	2081/05/05	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	6.82	34.4	12	14	0.1	0.02	6	1.25	0	Satisfactory
82	2081/05/05	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.02	<5	6.87	34.5	12	14	0.1	0.02	6	0.88	0	Satisfactory
83	2081/05/05	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	6.57	35.7	12	14	0.1	0.02	6	0.7	0	Satisfactory
84	2081/05/05	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	6.57	35.7	12	14	0.1	0.02	6	1.43	0	Satisfactory
85	2081/05/05	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	6.77	35.5	12	14	0.1	0.02	6	1.25	0	Satisfactory
86	2081/05/05	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	6.63	34.7	12	14	0.1	0.02	6	1.37	0	Satisfactory
87	2081/05/05	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	6.85	36.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
88	2081/05/05	13:55	Tripureshwar	Anamnagar SRT	Treated	Clear	1.52	<5	7.45	71.7	26	26	0.1	0.02	8	0.8	0	Satisfactory
89	2081/05/05	14:05	Kirtipur	Kirtipur SRT	Treated	Clear	0.64	<5	7.85	92.4	30	32	0.1	0.02	10	0.34	0	Satisfactory
90	2081/05/05	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.51	<5	7.4	68.4	24	28	0.1	0.02	10	1.48	0	Satisfactory
91	2081/05/05	11:55	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.73	<5	7.59	71.3	26	28	0.1	0.02	10	1.42	0	Satisfactory
92	2081/05/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	7.3	66.8	24	28	0.1	0.02	10	0.96	0	Satisfactory

93	2081/05/05	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.62	<5	7.32	65.4	24	28	0.1	0.02	10	0.2	0	Satisfactory
94	2081/05/05	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.87	<5	7.54	76.7	26	26	0.1	0.02	8	0.6	0	Satisfactory
95	2081/05/05	11:40	Maharajgunj	Panipokhari inlet	Treated	Clear	0.55	<5	7.7	74.6	28	22	0.1	0.02	8	0.2	0	Satisfactory
96	2081/05/05	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.85	<5	7.93	370	94	106	0.1	0.02	6	0.69	0	Satisfactory
97	2081/05/06	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.56	<5	6.86	50	18	20	0.1	0.02	6	0.87	0	Satisfactory
98	2081/05/06	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	6.93	42	16	16	0.1	0.02	6	0.97	0	Satisfactory
99	2081/05/06	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	0.99	<5	6.88	361	90	76	0.3	1.5	14	0.44	0	Satisfactory
100	2081/05/06	15:45	Madhyapur Thimi	Bode WTP	Treated	Clear	1.16	<5	6.92	343	90	74	0.3	1.5	10	0.49	0	Satisfactory
101	2081/05/06	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.91	<5	6.88	42.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
102	2081/05/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.19	<5	6.82	36.9	12	14	0.1	0.02	6	1.2	0	Satisfactory
103	2081/05/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	6.89	39.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
104	2081/05/06	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	6.87	41.7	12	14	0.1	0.02	6	1.59	0	Satisfactory
105	2081/05/06	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	6.82	42.4	12	14	0.1	0.02	6	1.03	0	Satisfactory
106	2081/05/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.34	<5	6.97	44.2	12	14	0.1	0.02	6	1.94	0	Satisfactory
107	2081/05/06	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	6.64	42.3	12	14	0.1	0.02	6	1.34	0	Satisfactory
108	2081/05/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.19	<5	6.79	43.7	12	14	0.1	0.02	6	0.9	0	Satisfactory
109	2081/05/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	6.72	49.1	12	14	0.1	0.02	6	1.39	0	Satisfactory
110	2081/05/06	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	6.69	47.6	12	14	0.1	0.02	6	1.39	0	Satisfactory
111	2081/05/06	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	6.98	46.6	12	14	0.1	0.02	6	1.69	0	Satisfactory
112	2081/05/06	13:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.18	<5	7.56	70.1	26	26	0.1	0.02	8	0.57	0	Satisfactory
113	2081/05/06		Lalitpur	Khumaltar SRT	Treated	Clear	1.33	<5	7.37	74.2	24	26	0.1	0.02	8	0.54	0	Satisfactory
114	2081/05/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.31	<5	7.21	63.5	22	28	0.1	0.02	10	0.47	0	Satisfactory
115	2081/05/06	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.30	<5	7.02	54.9	20	24	0.1	0.02	10	0.44	0	Satisfactory
116	2081/05/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.75	<5	7.2	54.2	22	24	0.1	0.02	10	0.4	0	Satisfactory
117	2081/05/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.15	<5	7.12	55.7	22	24	0.1	0.02	10	0.89	0	Satisfactory

118	2081/05/06	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.87	<5	7.52	73.9	26	24	0.1	0.02	8	1.06	0	Satisfactory
119	2081/05/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.68	<5	7.72	375	100	114	0.1	0.02	10	0.81	0	Satisfactory
120	2081/05/07	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	6.86	32	12	12	0.1	0.02	6	0.87	0	Satisfactory
121	2081/05/07	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	6.91	32	12	12	0.1	0.02	6	0.92	0	Satisfactory
122	2081/05/07	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.21	<5	6.91	354	90	70	0.3	1.5	12	0.11	0	Satisfactory
123	2081/05/07	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.78	<5	6.92	358	92	70	0.3	1.5	12	0.2	0	Satisfactory
124	2081/05/07	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.25	38.7	12	14	0.1	0.02	6	1.87	0	Satisfactory
125	2081/05/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.42	<5	7.1	38.9	12	14	0.1	0.02	6	1.32	0	Satisfactory
126	2081/05/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.06	38.9	12	14	0.1	0.02	6	1.09	0	Satisfactory
127	2081/05/07	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.22	<5	7.02	38.8	12	14	0.1	0.02	6	1.53	0	Satisfactory
128	2081/05/07	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.83	<5	7.01	37.3	12	14	0.1	0.02	6	1.72	0	Satisfactory
129	2081/05/07	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.18	<5	7.1	40	12	14	0.1	0.02	6	1.76	0	Satisfactory
130	2081/05/07	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	6.83	36.9	12	14	0.1	0.02	6	0.62	0	Satisfactory
131	2081/05/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.03	40	12	14	0.1	0.02	6	1.31	0	Satisfactory
132	2081/05/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	6.67	38.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
133	2081/05/07	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.39	<5	7.3	40.2	12	14	0.1	0.02	6	1.28	0	Satisfactory
134	2081/05/07	11:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.29	<5	7.4	80.2	24	28	0.1	0.02	8	0.97	0	Satisfactory
135	2081/05/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.35	<5	6.85	56.2	20	24	0.1	0.02	10	0.96	0	Satisfactory
136	2081/05/07	11:55	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.23	<5	7.27	55.2	24	24	0.1	0.02	10	0.2	0	Satisfactory
137	2081/05/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.26	<5	7.2	54.9	22	24	0.1	0.02	10	0.38	0	Satisfactory
138	2081/05/07	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.27	<5	7.2	89.4	22	32	0.1	0.02	8	1.53	0	Satisfactory
139	2081/05/07	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.09	<5	7.74	348	100	106	0.1	0.02	6	0.75	0	Satisfactory
140	2081/05/08	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	6.90	33	12	12	0.1	0.02	6	0.67	0	Satisfactory
141	2081/05/08	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	6.93	34	12	12	0.1	0.02	6	0.74	0	Satisfactory
142	2081/05/08	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.14	<5	6.94	351	92	70	0.3	1.5	12	0.14	0	Satisfactory

143	2081/05/08	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.57	<5	7.28	40.1	12	14	0.1	0.02	6	1.07	0	Satisfactory
144	2081/05/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.18	<5	7.26	38.9	12	14	0.1	0.02	6	0.92	0	Satisfactory
145	2081/05/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.09	<5	7.15	37.1	12	14	0.1	0.02	6	0.73	0	Satisfactory
146	2081/05/08	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.23	<5	7.15	37.1	12	14	0.1	0.02	6	1.54	0	Satisfactory
147	2081/05/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.15	35.7	12	14	0.1	0.02	6	1.61	0	Satisfactory
148	2081/05/08	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.11	36.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
149	2081/05/08	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.04	36.2	12	14	0.1	0.02	6	1.17	0	Satisfactory
150	2081/05/08	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.39	<5	6.69	42.4	12	14	0.1	0.02	6	0.53	0	Satisfactory
151	2081/05/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.83	<5	6.79	37.3	12	14	0.1	0.02	6	0.84	0	Satisfactory
152	2081/05/08	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	6.72	44.3	12	14	0.1	0.02	6	1.36	0	Satisfactory
153	2081/05/08	13:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.26	<5	7.55	73.6	26	26	0.1	0.02	8	1.29	0	Satisfactory
154	2081/05/08	0:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.33	<5	7.63	82	26	26	0.1	0.02	8	0.87	0	Satisfactory
155	2081/05/08	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	0.81	<5	7.83	89	28	30	0.1	0.02	10	0.58	0	Satisfactory
156	2081/05/08	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.94	<5	7.6	51.1	26	24	0.1	0.02	10	0.19	0	Satisfactory
157	2081/05/08	14:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.19	<5	7.5	74.5	26	26	0.1	0.02	8	1.04	0	Satisfactory
158	2081/05/09	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	6.92	32	12	12	0.1	0.02	6	0.87	0	Satisfactory
159	2081/05/09	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	6.91	34	12	14	0.1	0.02	6	0.91	0	Satisfactory
160	2081/05/09	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.49	<5	6.92	348	92	70	0.3	1.5	12	0.2	0	Satisfactory
161	2081/05/09	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.01	<5	6.9	362	92	72	0.3	1.5	12	0.11	0	Satisfactory
162	2081/05/09	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.23	<5	6.9	360	92	70	0.3	1.5	12	0.12	0	Satisfactory
163	2081/05/09	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.23	<5	6.85	44.2	12	14	0.1	0.02	6	1.53	0	Satisfactory
164	2081/05/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	6.8	35.7	12	14	0.1	0.02	6	1.88	0	Satisfactory
165	2081/05/09	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.14	<5	6.98	35.9	12	14	0.1	0.02	6	0.98	0	Satisfactory
166	2081/05/09	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.33	<5	6.95	34.7	12	14	0.1	0.02	6	1.46	0	Satisfactory
167	2081/05/09	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.13	33.5	12	14	0.1	0.02	6	1.35	0	Satisfactory

168	2081/05/09	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.25	34.6	12	14	0.1	0.02	6	0.48	0	Satisfactory
169	2081/05/09	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.21	49.6	12	14	0.1	0.02	6	0.93	0	Satisfactory
170	2081/05/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	6.93	33.2	12	14	0.1	0.02	6	1.5	0	Satisfactory
171	2081/05/09	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.2	33.3	12	14	0.1	0.02	6	0.88	0	Satisfactory
172	2081/05/09	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.1	33.61	12	14	0.1	0.02	6	0.86	0	Satisfactory
173	2081/05/09	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.04	32.7	12	14	0.1	0.02	6	1.22	0	Satisfactory
174	2081/05/09	14:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.51	<5	6.69	76.1	18	28	0.1	0.02	8	1.02	0	Satisfactory
175	2081/05/09	13:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.45	<5	6.98	81.8	20	26	0.1	0.02	8	1.07	0	Satisfactory
176	2081/05/09	13:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.45	<5	6.86	86.8	20	30	0.1	0.02	10	0.82	0	Satisfactory
177	2081/05/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	6.79	52.2	18	24	0.1	0.02	10	0.61	0	Satisfactory
178	2081/05/09	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.93	<5	6.88	53.5	20	24	0.1	0.02	10	0.74	0	Satisfactory
179	2081/05/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.31	<5	6.8	52.8	18	24	0.1	0.02	10	0.58	0	Satisfactory
180	2081/05/09	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.47	<5	6.76	53.2	18	24	0.1	0.02	10	0.66	0	Satisfactory
181	2081/05/09	14:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.86	<5	6.85	86.9	20	28	0.1	0.02	8	0.95	0	Satisfactory
182	2081/05/09	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.67	<5	7.85	349	100	114	0.1	0.02	6	0.96	0	Satisfactory
183	2081/05/10	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.14	32	12	12	0.1	0.02	6	0.72	0	Satisfactory
184	2081/05/10	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	6.94	32	12	12	0.1	0.02	6	0.74	0	Satisfactory
185	2081/05/10	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.45	<5	6.92	364	92	72	0.3	1.5	14	0.4	0	Satisfactory
186	2081/05/10	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.07	32.9	12	14	0.1	0.02	6	1.63	0	Satisfactory
187	2081/05/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.11	32.7	12	14	0.1	0.02	6	1.94	0	Satisfactory
188	2081/05/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.17	32.4	12	14	0.1	0.02	6	1.53	0	Satisfactory
189	2081/05/10	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.19	<5	7.08	31.4	12	14	0.1	0.02	6	1.81	0	Satisfactory
190	2081/05/10	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.18	30.8	12	14	0.1	0.02	6	1.4	0	Satisfactory
191	2081/05/10	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.1	32.3	12	14	0.1	0.02	6	0.52	0	Satisfactory
192	2081/05/10	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.23	32.3	12	14	0.1	0.02	6	0.81	0	Satisfactory



193	2081/05/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.31	33.6	12	14	0.1	0.02	6	1.12	0	Satisfactory
194	2081/05/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.25	<5	7.46	33	12	14	0.1	0.02	6	0.46	0	Satisfactory
195	2081/05/10	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.92	<5	7.13	32.7	12	14	0.1	0.02	6	1.35	0	Satisfactory
196	2081/05/10	10:45	Tripureshwar	Anamnagar SRT	Treated	Clear	0.10	<5	6.96	72.1	20	26	0.1	0.02	8	0.65	0	Satisfactory
197	2081/05/10	0:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.23	<5	7.06	70	22	26	0.1	0.02	8	0.78	0	Satisfactory
198	2081/05/10	11:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.70	<5	6.95	82.5	20	28	0.1	0.02	10	0.97	0	Satisfactory
199	2081/05/10	16:10	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.28	<5	7.37	62.24	24	24	0.1	0.02	10	0.75	0	Satisfactory
200	2081/05/10	0:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.10	<5	7.03	69.9	20	24	0.1	0.02	8	0.97	0	Satisfactory
201	2081/05/11	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	6.90	34	12	12	0.1	0.02	6	0.70	0	Satisfactory
202	2081/05/11	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	6.93	34	12	12	0.1	0.02	6	0.75	0	Satisfactory
203	2081/05/11	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.01	<5	6.83	433	116	90	0.3	1.5	16	0.86	0	Satisfactory
204	2081/05/11	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.6	<5	6.86	427	114	88	0.3	1.5	14	0.39	0	Satisfactory
205	2081/05/11	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.7	<5	7.15	32.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
206	2081/05/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.34	<5	7.43	32.7	12	14	0.1	0.02	6	0.2	0	Satisfactory
207	2081/05/11	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.18	49.9	12	14	0.1	0.02	6	1.04	0	Satisfactory
208	2081/05/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	6.88	33.9	12	14	0.1	0.02	6	0.5	0	Satisfactory
209	2081/05/11	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.02	<5	6.87	35.4	12	14	0.1	0.02	6	0.48	0	Satisfactory
210	2081/05/11	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.04	<5	7.01	41	12	14	0.1	0.02	6	0.67	0	Satisfactory
211	2081/05/11	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.55	<5	7.08	45.9	14	14	0.1	0.02	6	1.99	0	Satisfactory
212	2081/05/11	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.43	<5	7.11	69.4	22	24	0.1	0.02	8	0.76	0	Satisfactory
213	2081/05/11	0:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.52	<5	7.17	73.5	22	26	0.1	0.02	8	0.75	0	Satisfactory
214	2081/05/11	0:10	Kirtipur	Kirtipur SRT	Treated	Clear	0.44	<5	7.15	80.3	22	28	0.1	0.02	10	0.8	0	Satisfactory
215	2081/05/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.34	<5	6.75	50.6	18	24	0.1	0.02	10	0.55	0	Satisfactory
216	2081/05/11	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.54	<5	6.89	51.2	20	24	0.1	0.02	10	0.44	0	Satisfactory
217	2081/05/11	14:00	Mahankalchaur	Mahankalchaur	Treated	Clear	2.30	<5	7.08	53.2	22	24	0.1	0.02	10	0.48	0	Satisfactory

218	2081/05/11	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.20	<5	7.07	72.3	22	24	0.1	0.02	10	0.38	0	Satisfactory
219	2081/05/11	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.48	<5	7.18	68.5	22	24	0.1	0.02	8	0.79	0	Satisfactory
220	2081/05/11	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.02	<5	7.84	353	102	114	0.1	0.02	6	0.69	0	Satisfactory
221	2081/05/12	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.06	32	12	12	0.1	0.02	6	0.74	0	Satisfactory
222	2081/05/12	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.14	34	12	12	0.1	0.02	6	0.92	0	Satisfactory
223	2081/05/12	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.9	<5	6.94	318	84	66	0.3	1.5	12	0.12	0	Satisfactory
224	2081/05/12	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.44	<5	6.95	328	86	68	0.3	1.5	12	0.15	0	Satisfactory
225	2081/05/12	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	7.07	41.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
226	2081/05/12	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.21	41.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
227	2081/05/12	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.2	40.6	12	14	0.1	0.02	6	1.91	0	Satisfactory
228	2081/05/12	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.23	41.6	12	14	0.1	0.02	6	1.95	0	Satisfactory
229	2081/05/12	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.08	37.8	12	14	0.1	0.02	6	1.53	0	Satisfactory
230	2081/05/12	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.3	32.7	12	14	0.1	0.02	6	1.2	0	Satisfactory
231	2081/05/12	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.5	29.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
232	2081/05/12	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	7.51	32.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
233	2081/05/12	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.16	<5	7.52	32.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
234	2081/05/12	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.48	33.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
235	2081/05/12	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.38	33.4	12	14	0.1	0.02	6	0.37	0	Satisfactory
236	2081/05/12	11:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.68	<5	7.3	69.4	24	24	0.1	0.02	8	0.51	0	Satisfactory
237	2081/05/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.28	<5	6.92	53.4	20	24	0.1	0.02	10	0.2	0	Satisfactory
238	2081/05/12	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	6.9	50.7	20	24	0.1	0.02	10	0.46	0	Satisfactory
239	2081/05/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.85	<5	7.35	53.5	24	24	0.1	0.02	10	0.4	0	Satisfactory
240	2081/05/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.78	<5	7.42	55.7	24	24	0.1	0.02	10	0.61	0	Satisfactory
241	2081/05/12	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.54	<5	7.11	72.8	22	26	0.1	0.02	8	0.34	0	Satisfactory
242	2081/05/12	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.12	<5	8.14	398	102	118	0.1	0.02	10	0.75	0	Satisfactory

243	2081/05/13	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.20	34	12	12	0.1	0.02	6	0.96	0	Satisfactory
244	2081/05/13	14:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.37	40	16	16	0.1	0.02	6	1.04	0	Satisfactory
245	2081/05/13	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.24	<5	6.96	342	90	70	0.3	1.5	12	0.1	0	Satisfactory
246	2081/05/13	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.2	32.1	12	14	0.1	0.02	6	0.36	0	Satisfactory
247	2081/05/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.25	32.1	12	14	0.1	0.02	6	1.11	0	Satisfactory
248	2081/05/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.11	35.9	12	14	0.1	0.02	6	1.84	0	Satisfactory
249	2081/05/13	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.03	35.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
250	2081/05/13	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	6.98	34.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
251	2081/05/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	6.89	41.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
252	2081/05/13	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.12	37.9	12	14	0.1	0.02	6	1.31	0	Satisfactory
253	2081/05/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	6.83	40.3	12	14	0.1	0.02	6	1.8	0	Satisfactory
254	2081/05/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.06	37.1	12	14	0.1	0.02	6	0.23	0	Satisfactory
255	2081/05/13	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	6.97	40.8	14	14	0.1	0.02	6	1.31	0	Satisfactory
256	2081/05/13	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.12	40.9	14	14	0.1	0.02	6	1.83	0	Satisfactory
257	2081/05/13	13:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.75	<5	7.45	83.1	26	28	0.1	0.02	8	0.68	0	Satisfactory
258	2081/05/13	0:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.46	<5	7.52	83.8	26	26	0.1	0.02	8	0.98	0	Satisfactory
259	2081/05/13	0:55	Kirtipur	Kirtipur SRT	Treated	Clear	0.69	<5	7.53	91.5	26	28	0.1	0.02	10	0.9	0	Satisfactory
260	2081/05/13	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.12	<5	6.87	61.4	20	24	0.1	0.02	10	0.2	0	Satisfactory
261	2081/05/13	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.47	<5	7.16	61.8	22	24	0.1	0.02	10	0.54	0	Satisfactory
262	2081/05/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.78	<5	7.12	62.7	22	24	0.1	0.02	10	0.53	0	Satisfactory
263	2081/05/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.75	<5	7.4	63.4	24	24	0.1	0.02	10	0.82	0	Satisfactory
264	2081/05/13	11:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.60	<5	7.52	77.4	26	26	0.1	0.02	8	0.81	0	Satisfactory
265	2081/05/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.94	<5	8.37	405	104	110	0.1	0.02	14	0.61	0	Satisfactory
266	2081/05/14	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	32	12	12	0.1	0.02	6	0.90	0	Satisfactory
267	2081/05/14	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.27	36	14	14	0.1	0.02	6	0.93	0	Satisfactory

268	2081/05/14	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	1.61	<5	6.98	360	92	72	0.3	1.5	12	0.2	0	Satisfactory
269	2081/05/14	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.04	37.6	12	14	0.1	0.02	6	1.27	0	Satisfactory
270	2081/05/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.11	37.9	12	14	0.1	0.02	6	1.14	0	Satisfactory
271	2081/05/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.19	38.5	12	14	0.1	0.02	6	1.02	0	Satisfactory
272	2081/05/14	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.15	38.2	12	14	0.1	0.02	6	1.9	0	Satisfactory
273	2081/05/14	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.11	37.6	12	14	0.1	0.02	6	1.97	0	Satisfactory
274	2081/05/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	6.84	43.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
275	2081/05/14	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	6.91	40.1	14	14	0.1	0.02	6	1.43	0	Satisfactory
276	2081/05/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	6.97	39.9	12	14	0.1	0.02	6	1.48	0	Satisfactory
277	2081/05/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7	41.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
278	2081/05/14	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.25	<5	6.67	44.9	12	14	0.1	0.02	6	1.63	0	Satisfactory
279	2081/05/14	10:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.54	<5	7.28	69.1	22	22	0.1	0.02	8	0.5	0	Satisfactory
280	2081/05/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.94	<5	7.11	30.7	22	24	0.1	0.02	10		0	Satisfactory
281	2081/05/14	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.78	<5	7.18	60.4	22	24	0.1	0.02	10	0.91	0	Satisfactory
282	2081/05/14	14:00	Mahankalchaur	Mahankalchaur	Treated	Clear	1.10	<5	7.25	62.5	24	24	0.1	0.02	10	0.91	0	Satisfactory
283	2081/05/14	10:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.48	<5	7.41	37.1	24	16	0.1	0.02	8	0.56	0	Satisfactory
284	2081/05/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.19	<5	8.39	354	96	106	0.1	0.02	6	0.79	0	Satisfactory
285	2081/05/15	11:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.36	35	12	12	0.1	0.02	6	0.94	0	Satisfactory
286	2081/05/15	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.37	34	12	12	0.1	0.02	6	0.86	0	Satisfactory
287	2081/05/15	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.41	<5	6.96	358	92	70	0.3	1.5	12	0.2	0	Satisfactory
288	2081/05/15	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	6.83	42.7	12	14	0.1	0.02	6	1.93	0	Satisfactory
289	2081/05/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.33	<5	6.98	38.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
290	2081/05/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	6.99	38.5	12	14	0.1	0.02	6	1.71	0	Satisfactory
291	2081/05/15	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7	39.3	12	14	0.1	0.02	6	1.81	0	Satisfactory
292	2081/05/15	8:00	Sundarijal WTP	New Sundarijal	Treated	Clear	0.96	<5	7.08	38.9	12	14	0.1	0.02	6	1.79	0	Satisfactory
293	2081/05/15	10:00	Sundarijal WTP	New Sundarijal	Treated	Clear	1.02	<5	6.9	36.4	12	14	0.1	0.02	6	1.26	0	Satisfactory

294	2081/05/15	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	6.84	36.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
295	2081/05/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	6.77	39.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
296	2081/05/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	6.9	38.3	12	14	0.1	0.02	6	1.88	0	Satisfactory
297	2081/05/15	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	6.77	37.8	12	14	0.1	0.02	6	1.72	0	Satisfactory
298	2081/05/15	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	6.78	36.8	12	14	0.1	0.02	6	1.51	0	Satisfactory
299	2081/05/15	7:25	Mahankalchaur	Bagmati inlet	Treated	Clear	0.62	<5	7.39	74.6	24	26	0.1	0.02	8	0.3	0	Satisfactory
300	2081/05/15	8:00	Mahankalchaur	Bagmati inlet	Treated	Clear	0.56	<5	7.6	82.6	26	28	0.1	0.02	8	0.66	0	Satisfactory
301	2081/05/15	8:30	Mahankalchaur	Bagmati inlet	Treated	Clear	0.63	<5	7.52	81.5	26	28	0.1	0.02	8	0.98	0	Satisfactory
302	2081/05/15	6:10	Mahankalchaur	Bagmati inlet	Treated	Clear	0.92	<5	7.56	80.4	26	28	0.1	0.02	8	0.56	0	Satisfactory
303	2081/05/15	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.92	<5	7.21	68.1	22	24	0.1	0.02	10	0.36	0	Satisfactory
304	2081/05/16	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.36	33	12	12	0.1	0.02	6	0.87	0	Satisfactory
305	2081/05/16	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.52	<5	6.86	36	12	14	0.1	0.02	6	0.94	0	Satisfactory
306	2081/05/16	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.03	<5	6.99	369	94	72	0.3	1.5	10	0.2	0	Satisfactory
307	2081/05/16	13:45	Madhyapur Thimi	Bode WTP	Treated	Clear	1.09	<5	6.98	363	94	72	0.3	1.5	10	0.27	0	Satisfactory
308	2081/05/16	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.36	<5	6.98	365	94	72	0.3	1.5	12	0.11	0	Satisfactory
309	2081/05/16	0:05	Sundarijal WTP	New Sundarijal	Treated	Clear	1.08	<5	7.05	39.9	12	14	0.1	0.02	6	1.98	0	Satisfactory
310	2081/05/16	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.01	39.3	12	14	0.1	0.02	6	1.11	0	Satisfactory
311	2081/05/16	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.08	38.9	12	14	0.1	0.02	6	1.01	0	Satisfactory
312	2081/05/16	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.4	<5	7.02	34.6	12	14	0.1	0.02	6	1.96	0	Satisfactory
313	2081/05/16	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	6.88	34.4	12	14	0.1	0.02	6	1.03	0	Satisfactory
314	2081/05/16	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	6.97	38.8	12	14	0.1	0.02	6	0.46	0	Satisfactory
315	2081/05/16	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.24	<5	7.1	38.6	12	14	0.1	0.02	6	0.52	0	Satisfactory
316	2081/05/16	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.91	<5	6.9	32.4	12	14	0.1	0.02	6	0.62	0	Satisfactory
317	2081/05/16	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.01	<5	6.94	33.9	12	14	0.1	0.02	6	0.57	0	Satisfactory
318	2081/05/16	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.95	<5	6.82	34.6	12	14	0.1	0.02	6	0.72	0	Satisfactory
319	2081/05/16	22:00	Sundarijal WTP	New Sundarijal	Treated	Clear	1.61	<5	6.78	36.3	12	14	0.1	0.02	6	0.92	0	Satisfactory

320	2081/05/16	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.20	<5	7.74	83	28	28	0.1	0.02	8	1.08	0	Satisfactory
321	2081/05/16	13:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.60	<5	7.18	77.8	22	26	0.1	0.02	8	1.31	0	Satisfactory
322	2081/05/16	0:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.22	<5	7.96	88.9	30	28	0.1	0.02	10	0.87	0	Satisfactory
323	2081/05/16	10:30	Mahankalchaur	Mahankalchaur	Treated	Clear	0.10	<5	7.38	56.3	24	24	0.1	0.02	10	0.23	0	Satisfactory
324	2081/05/16	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	7.35	58.8	24	24	0.1	0.02	10	1.28	0	Satisfactory
325	2081/05/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.25	<5	7.42	60.3	24	24	0.1	0.02	10	0.78	0	Satisfactory
326	2081/05/16	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.19	<5	7.47	58.5	26	24	0.1	0.02	10	1.32	0	Satisfactory
327	2081/05/16	11:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.21	<5	7.98	77.6	30	26	0.1	0.02	8	1.57	0	Satisfactory
328	2081/05/16	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.98	<5	8.48	365	98	110	0.1	0.02	6	0.83	0	Satisfactory
329	2081/05/17	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.56	<5	6.61	35	12	14	0.1	0.02	6	0.66	0	Satisfactory
330	2081/05/17	14:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	6.72	35	12	14	0.1	0.02	6	1.04	0	Satisfactory
331	2081/05/17	16:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	6.93	34	12	12	0.1	0.02	6	0.98	0	Satisfactory
332	2081/05/17	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	1.31	<5	6.88	390	98	80	0.3	1.5	12	0.23	0	Satisfactory
333	2081/05/17	0:05	Madhyapur Thimi	Bode WTP	Treated	Clear	1.32	<5	6.88	377	94	74	0.3	1.5	14	0.39	0	Satisfactory
334	2081/05/17	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.92	<5	6.87	383	96	80	0.3	1.5	16	0.49	0	Satisfactory
335	2081/05/17	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.03	<5	6.56	378	94	74	0.3	1.5	14	0.36	0	Satisfactory
336	2081/05/17	0:10	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.68	<5	6.68	36	12	14	0.1	0.02	6	1.09	0	Satisfactory
337	2081/05/17	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.97	<5	6.7	36.3	12	14	0.1	0.02	6	0.93	0	Satisfactory
338	2081/05/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.38	<5	6.77	34.9	12	14	0.1	0.02	6	0.84	0	Satisfactory
339	2081/05/17	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.62	<5	6.73	39.5	12	14	0.1	0.02	6	1.07	0	Satisfactory
340	2081/05/17	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.57	<5	6.76	39	12	14	0.1	0.02	6	0.75	0	Satisfactory
341	2081/05/17	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.42	<5	6.79	40.3	12	14	0.1	0.02	6	0.62	0	Satisfactory
342	2081/05/17	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.55	<5	6.85	41.4	12	14	0.1	0.02	6	0.83	0	Satisfactory
343	2081/05/17	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.28	<5	6.7	40.5	12	14	0.1	0.02	6	1.06	0	Satisfactory
344	2081/05/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.67	<5	6.61	40.9	12	14	0.1	0.02	6	0.81	0	Satisfactory
345	2081/05/17	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.59	<5	6.77	41	12	14	0.1	0.02	6	1.3	0	Satisfactory

346	2081/05/17	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.6	<5	6.65	38.3	12	14	0.1	0.02	6	1.2	0	Satisfactory
347	2081/05/17	11:03	Tripureshwar	Anamnagar SRT	Treated	Clear	0.10	<5	7.18	78.6	22	28	0.1	0.02	8	0.44	0	Satisfactory
348	2081/05/17	14:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.75	<5	7.39	80.1	24	26	0.1	0.02	8	0.34	0	Satisfactory
349	2081/05/17	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.02	<5	6.85	53.1	20	24	0.1	0.02	10	0.74	0	Satisfactory
350	2081/05/17	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	6.82	54.9	18	24	0.1	0.02	10	0.45	0	Satisfactory
351	2081/05/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.55	<5	7.71	54.3	28	24	0.1	0.02	10	0.95	0	Satisfactory
352	2081/05/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.85	<5	7.3	53.2	24	24	0.1	0.02	10	0.42	0	Satisfactory
353	2081/05/17	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.28	<5	7.28	76.2	24	26	0.1	0.02	8	0.25	0	Satisfactory
354	2081/05/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.74	<5	8.14	375	100	112	0.1	0.02	8	0.54	0	Satisfactory
355	2081/05/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.34	386	100	114	0.1	0.02	8	0.26	0	Satisfactory
356	2081/05/18	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	1.72	<5	7.12	35	12	12	0.1	0.02	6	0.63	0	Satisfactory
357	2081/05/18	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.26	<5	7.94	37	14	14	0.1	0.02	6	1.02	0	Satisfactory
358	2081/05/18	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.20	<5	7.17	37	14	14	0.1	0.02	6	0.97	0	Satisfactory
359	2081/05/18	10:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.39	<5	6.82	372	94	72	0.3	1.5	12	0.28	0	Satisfactory
360	2081/05/18	0:05	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	6.8	373	94	72	0.3	1.5	12	0.38	0	Satisfactory
361	2081/05/18	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.48	<5	6.78	375	94	72	0.3	1.5	12	0.17	0	Satisfactory
362	2081/05/18	15:45	Madhyapur Thimi	Bode WTP	Treated	Clear	0.91	<5	6.77	376	94	72	0.3	1.5	16	0.61	0	Satisfactory
363	2081/05/18	0:10	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.59	<5	7.09	38	12	14	0.1	0.02	6	1.2	0	Satisfactory
364	2081/05/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.42	<5	6.99	38.7	12	14	0.1	0.02	6	2.01	0	Satisfactory
365	2081/05/18	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	6.95	38.6	12	14	0.1	0.02	6	1.69	0	Satisfactory
366	2081/05/18	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	6.97	34.1	12	14	0.1	0.02	6	1.25	0	Satisfactory
367	2081/05/18	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.89	<5	7.21	32.9	12	14	0.1	0.02	6	0.29	0	Satisfactory
368	2081/05/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.14	<5	7.27	36	12	14	0.1	0.02	6	0.1	0	Satisfactory
369	2081/05/18	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	6.81	32.5	12	14	0.1	0.02	6	0.1	0	Satisfactory

370	2081/05/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	6.92	34.7	12	14	0.1	0.02	6	0.1	0	Satisfactory
371	2081/05/18	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.39	<5	7.44	38.8	12	14	0.1	0.02	6	0.1	0	Satisfactory
372	2081/05/18	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.57	<5	7.36	39.6	14	14	0.1	0.02	6	0.1	0	Satisfactory
373	2081/05/18	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.85	<5	7.45	39.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
374	2081/05/18	0:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.34	<5	6.79	78.6	18	26	0.1	0.02	8	0.23	0	Satisfactory
375	2081/05/18	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.23	<5	6.79	91	18	26	0.1	0.02	8	0.24	0	Satisfactory
376	2081/05/18	14:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.08	<5	7.04	87.3	20	28	0.1	0.02	10	0.17	0	Satisfactory
377	2081/05/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.11	<5	6.78	52	18	24	0.1	0.02	10	0.59	0	Satisfactory
378	2081/05/18	11:55	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.59	<5	7.01	55.1	20	24	0.1	0.02	10	0.55	0	Satisfactory
379	2081/05/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.77	<5	7.34	52.9	24	24	0.1	0.02	10	0.53	0	Satisfactory
380	2081/05/18	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.29	<5	6.85	102.9	20	30	0.1	0.02	10	0.75	0	Satisfactory
381	2081/05/18	0:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.20	<5	6.66	75.6	18	26	0.1	0.02	8	0.16	0	Satisfactory
382	2081/05/18	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.74	<5	8.27	390	106	118	0.1	0.02	10	0.24	0	Satisfactory
383	2081/05/19	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.10	32	12	12	0.1	0.02	6	0.50	0	Satisfactory
384	2081/05/19	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.33	33	12	12	0.1	0.02	6	1.02	0	Satisfactory
385	2081/05/19	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.27	31	12	12	0.1	0.02	6	0.98	0	Satisfactory
386	2081/05/19	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	1.35	<5	6.8	382	94	74	0.3	1.5	14	0.45	0	Satisfactory
387	2081/05/19	11:55	Madhyapur Thimi	Bode WTP	Treated	Clear	1.25	<5	6.82	377	94	72	0.3	1.5	16	0.42	0	Satisfactory
388	2081/05/19	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.12	<5	6.82	357	90	70	0.3	1.5	10	0.38	0	Satisfactory
389	2081/05/19	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.71	<5	7.25	39.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
390	2081/05/19	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.21	<5	7.28	39.9	12	14	0.1	0.02	6	1.2	0	Satisfactory
391	2081/05/19	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.86	<5	7.31	39.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
392	2081/05/19	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.75	<5	7.36	35.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
393	2081/05/19	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.72	<5	7.55	34.9	12	14	0.1	0.02	6	1.2	0	Satisfactory
394	2081/05/19	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.41	<5	7.61	39.9	12	14	0.1	0.02	6	1.2	0	Satisfactory



395	2081/05/19	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.07	<5	7.34	46	12	14	0.1	0.02	6	1.2	0	Satisfactory
396	2081/05/19	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.41	45.2	14	14	0.1	0.02	6	1.2	0	Satisfactory
397	2081/05/19	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.29	38.3	12	14	0.1	0.02	6	1.2	0	Satisfactory
398	2081/05/19	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.23	38.7	12	14	0.1	0.02	6	1.2	0	Satisfactory
399	2081/05/19	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.6	39.4	12	14	0.1	0.02	6	0.54	0	Satisfactory
400	2081/05/19	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.34	<5	6.66	55.4	18	24	0.1	0.02	10	0.84	0	Satisfactory
401	2081/05/19	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.49	<5	6.85	51.8	20	24	0.1	0.02	10	0.86	0	Satisfactory
402	2081/05/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.88	<5	7.1	53.6	22	24	0.1	0.02	10	0.72	0	Satisfactory
403	2081/05/19	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.82	<5	6.92	54.7	20	24	0.1	0.02	10	0.68	0	Satisfactory
404	2081/05/19	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.74	<5	8.06	392	106	118	0.1	0.02	10	0.41	0	Satisfactory
405	2081/05/20	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.63	<5	7.32	35	12	12	0.1	0.02	6	0.70	0	Satisfactory
406	2081/05/20	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.52	<5	7.32	37	14	14	0.1	0.02	6	1.04	0	Satisfactory
407	2081/05/20	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.71	<5	7.26	34	12	12	0.1	0.02	6	1.01	0	Satisfactory
408	2081/05/20	10:20	Madhyapur Thimi	Bode WTP	Treated	Clear	1.53	<5	7.03	361	94	70	0.3	1.5	14	0.4	0	Satisfactory
409	2081/05/20	0:05	Madhyapur Thimi	Bode WTP	Treated	Clear	1.66	<5	6.95	353	92	70	0.3	1.5	12	0.15	0	Satisfactory
410	2081/05/20	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.59	<5	6.92	356	92	70	0.3	1.5	14	0.33	0	Satisfactory
411	2081/05/20	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.22	<5	6.93	354	90	70	0.3	1.5	14	0.16	0	Satisfactory
412	2081/05/20	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.51	39.6	12	14	0.1	0.02	6	1.29	0	Satisfactory
413	2081/05/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.46	38.4	12	14	0.1	0.02	6	1.79	0	Satisfactory
414	2081/05/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.33	32.7	12	14	0.1	0.02	6	1.91	0	Satisfactory
415	2081/05/20	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.23	32.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
416	2081/05/20	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.05	34.7	12	14	0.1	0.02	6	1.81	0	Satisfactory
417	2081/05/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.08	34.2	12	14	0.1	0.02	6	1.38	0	Satisfactory
418	2081/05/20	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	6.82	37.4	12	14	0.1	0.02	6	1.4	0	Satisfactory

419	2081/05/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.16	<5	6.77	37.5	12	14	0.1	0.02	6	1.9	0	Satisfactory
420	2081/05/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	6.84	34.3	12	14	0.1	0.02	6	1.73	0	Satisfactory
421	2081/05/20	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.1	37	12	14	0.1	0.02	6	1.49	0	Satisfactory
422	2081/05/20	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.07	35	12	14	0.1	0.02	6	1.89	0	Satisfactory
423	2081/05/20	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.97	<5	7.05	72.4	22	26	0.1	0.02	8	0.29	0	Satisfactory
424	2081/05/20	14:15	Maharajgunj	Balaju SRT	Treated	Clear	1.29	<5	7.87	150.8	30	28	0.1	0.02	10	0.8	0	Satisfactory
425	2081/05/20	0:15	Lalitpur	Khumaltar SRT	Treated	Clear	1.10	<5	7.3	77.9	24	26	0.1	0.02	8	0.35	0	Satisfactory
426	2081/05/20	0:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.47	<5	7.54	85.6	26	28	0.1	0.02	10	0.43	0	Satisfactory
427	2081/05/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.96	<5	6.82	49.8	18	24	0.1	0.02	10	0.33	0	Satisfactory
428	2081/05/20	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.97	<5	7.45	56.2	26	24	0.1	0.02	10	0.87	0	Satisfactory
429	2081/05/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.75	<5	7.33	53	24	24	0.1	0.02	10	0.87	0	Satisfactory
430	2081/05/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.80	<5	7.03	53	22	24	0.1	0.02	10	0.65	0	Satisfactory
431	2081/05/20	11:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.23	<5	7.33	81.8	24	26	0.1	0.02	8	0.25	0	Satisfactory
432	2081/05/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	8.42	394	102	120	0.1	0.02	14	0.67	0	Satisfactory
433	2081/05/21	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.37	<5	7.31	30	10	12	0.1	0.02	6	0.67	0	Satisfactory
434	2081/05/21	16:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	7.34	31	12	10	0.1	0.02	6	0.92	0	Satisfactory
435	2081/05/21	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.32	32	12	12	0.1	0.02	6	0.86	0	Satisfactory
436	2081/05/21	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.09	35.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
437	2081/05/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.11	35.9	12	14	0.1	0.02	6	1.71	0	Satisfactory
438	2081/05/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.17	38.9	12	14	0.1	0.02	6	1.44	0	Satisfactory
439	2081/05/21	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.14	33.3	12	14	0.1	0.02	6	1.61	0	Satisfactory
440	2081/05/21	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.07	34.2	12	14	0.1	0.02	6	1.55	0	Satisfactory
441	2081/05/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	6.92	41.2	12	14	0.1	0.02	6	1.36	0	Satisfactory
442	2081/05/21	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.3	37.4	12	14	0.1	0.02	6	1.06	0	Satisfactory

443	2081/05/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.16	36.9	12	14	0.1	0.02	6	1.1	0	Satisfactory
444	2081/05/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.16	36.8	12	14	0.1	0.02	6	1.22	0	Satisfactory
445	2081/05/21	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.98	<5	7	37.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
446	2081/05/21	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.97	<5	7.21	53.3	22	24	0.1	0.02	10	1	0	Satisfactory
447	2081/05/21	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.63	<5	6.81	51.2	18	24	0.1	0.02	10	1.3	0	Satisfactory
448	2081/05/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.72	<5	6.87	51.9	20	24	0.1	0.02	10	0.98	0	Satisfactory
449	2081/05/21	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.19	<5	8.28	393	102	120	0.1	0.02	12	0.82	0	Satisfactory
450	2081/05/22	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.31	33	12	12	0.1	0.02	6	0.90	0	Satisfactory
451	2081/05/22	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.33	35	12	12	0.1	0.02	6	1.04	0	Satisfactory
452	2081/05/22	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.26	<5	7.26	32	12	12	0.1	0.02	6	0.98	0	Satisfactory
453	2081/05/22	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.25	<5	6.99	365	94	72	0.3	1.5	14	0.31	0	Satisfactory
454	2081/05/22	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.73	<5	7.03	37.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
455	2081/05/22	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.1	38.3	14	14	0.1	0.02	6	1.2	0	Satisfactory
456	2081/05/22	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.08	38.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
457	2081/05/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.11	38.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
458	2081/05/22	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.05	36.2	12	14	0.1	0.02	6	1.82	0	Satisfactory
459	2081/05/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	6.93	36.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
460	2081/05/22	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.8	<5	7.1	37	12	14	0.1	0.02	6	0.52	0	Satisfactory
461	2081/05/22	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.2	<5	7.1	35.6	12	14	0.1	0.02	6	0.42	0	Satisfactory
462	2081/05/22	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.96	<5	6.98	35.9	12	14	0.1	0.02	6	0.21	0	Satisfactory
463	2081/05/22	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	6.82	36.7	12	14	0.1	0.02	6	1.2	0	Satisfactory
464	2081/05/22	8:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.45	<5	7.24	66	22	22	0.1	0.02	8	0.5	0	Satisfactory
465	2081/05/22	10:10	Maharajgunj	Balaju SRT	Treated	Clear	0.70	<5	7.9	126.1	34	28	0.1	0.02	10	1.43	0	Satisfactory
466	2081/05/22	9:20	Kirtipur	Kirtipur SRT	Treated	Clear	0.30	<5	7.39	82.3	24	28	0.1	0.02	10	0.95	0	Satisfactory

467	2081/05/22	10:45	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.91	<5	6.55	50	16	24	0.1	0.02	10	0.77	0	Satisfactory
468	2081/05/23	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.46	<5	7.31	32	12	12	0.1	0.02	6	0.72	0	Satisfactory
469	2081/05/23	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	7.22	34	12	14	0.1	0.02	6	1.02	0	Satisfactory
470	2081/05/23	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.34	30	12	12	0.1	0.02	6	0.90	0	Satisfactory
471	2081/05/23	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	0.92	<5	7.09	393	102	74	0.3	1.5	20	0.37	0	Satisfactory
472	2081/05/23	0:05	Madhyapur Thimi	Bode WTP	Treated	Clear	1.03	<5	7.1	364	96	72	0.3	1.5	18	0.49	0	Satisfactory
473	2081/05/23	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.13	<5	7.01	366	94	72	0.3	1.5	14	0.11	0	Satisfactory
474	2081/05/23	16:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.1	<5	7.04	365	94	72	0.3	1.5	14	0.1	0	Satisfactory
475	2081/05/23	16:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.93	<5	7.05	230	70	62	0.3	1.5	10	0.2	0	Satisfactory
476	2081/05/23	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.05	35.4	12	14	0.1	0.02	6	0.62	0	Satisfactory
477	2081/05/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.03	35.8	12	14	0.1	0.02	6	1.03	0	Satisfactory
478	2081/05/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	6.84	36.7	12	14	0.1	0.02	6	0.5	0	Satisfactory
479	2081/05/23	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.07	29.9	12	14	0.1	0.02	6	0.64	0	Satisfactory
480	2081/05/23	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	6.97	28.7	12	14	0.1	0.02	6	1.52	0	Satisfactory
481	2081/05/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.1	30.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
482	2081/05/23	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	6.97	31.2	12	14	0.1	0.02	6	1.82	0	Satisfactory
483	2081/05/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.2	42	14	14	0.1	0.02	6	1.89	0	Satisfactory
484	2081/05/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	6.86	33.8	12	14	0.1	0.02	6	1.72	0	Satisfactory
485	2081/05/23	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	6.49	32.5	12	14	0.1	0.02	6	1.55	0	Satisfactory
486	2081/05/23	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.09	31.9	12	14	0.1	0.02	6	1.9	0	Satisfactory
487	2081/05/23	11:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.20	<5	6.67	52.5	18	24	0.1	0.02	10	0.89	0	Satisfactory
488	2081/05/23	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.33	<5	7.05	51	22	24	0.1	0.02	10	0.51	0	Satisfactory
489	2081/05/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.10	<5	7.3	53.9	24	24	0.1	0.02	10	1.14	0	Satisfactory
490	2081/05/23	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.90	<5	7.01	54.9	20	24	0.1	0.02	10	0.63	0	Satisfactory

491	2081/05/23	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.84	<5	8.07	404	108	124	0.1	0.02	12	0.36	0	Satisfactory
492	2081/05/24	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.32	34	12	12	0.1	0.02	6	0.87	0	Satisfactory
493	2081/05/24	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.30	31	12	12	0.1	0.02	6	0.74	0	Satisfactory
494	2081/05/24	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.32	34	12	12	0.1	0.02	6	1.04	0	Satisfactory
495	2081/05/24	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.23	<5	7.03	389	102	72	0.3	1.5	16	0.39	0	Satisfactory
496	2081/05/24	0:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.49	<5	6.99	376	98	70	0.3	1.5	16	0.36	0	Satisfactory
497	2081/05/24	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.08	<5	6.95	338	90	68	0.3	1.5	6	0.28	0	Satisfactory
498	2081/05/24	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.5	<5	6.9	355	90	70	0.3	1.5	16	0.35	0	Satisfactory
499	2081/05/24	16:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.2	<5	7.05	298	80	66	0.3	1.5	10	0.33	0	Satisfactory
500	2081/05/24	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.11	31.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
501	2081/05/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.1	32.8	12	14	0.1	0.02	6	1.91	0	Satisfactory
502	2081/05/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.07	32.9	12	14	0.1	0.02	6	1.73	0	Satisfactory
503	2081/05/24	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.01	33.8	12	14	0.1	0.02	6	2.02	0	Satisfactory
504	2081/05/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.1	30.7	12	14	0.1	0.02	6	1.98	0	Satisfactory
505	2081/05/24	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	7.19	32.4	12	14	0.1	0.02	6	0.95	0	Satisfactory
506	2081/05/24	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	7.05	32.4	12	14	0.1	0.02	6	1.04	0	Satisfactory
507	2081/05/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	6.76	30.9	12	14	0.1	0.02	6	1.2	0	Satisfactory
508	2081/05/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.05	31.8	12	14	0.1	0.02	6	1.61	0	Satisfactory
509	2081/05/24	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.08	31.3	12	14	0.1	0.02	6	0.86	0	Satisfactory
510	2081/05/24	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	6.9	30.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
511	2081/05/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.02	51.8	20	24	0.1	0.02	10	0.42	0	Satisfactory
512	2081/05/24	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.67	<5	6.94	55.2	20	24	0.1	0.02	10	0.41	0	Satisfactory
513	2081/05/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.60	<5	7.15	57.2	22	24	0.1	0.02	10	0.7	0	Satisfactory
514	2081/05/24	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.10	<5	6.92	51.9	20	24	0.1	0.02	10	0.66	0	Satisfactory
515	2081/05/24	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.06	<5	8.13	4.6	102	120	0.1	0.02	12	0.64	0	Satisfactory

516	2081/05/25	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.31	30	10	10	0.1	0.02	6	0.52	0	Satisfactory
517	2081/05/25	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.34	31	10	12	0.1	0.02	6	0.91	0	Satisfactory
518	2081/05/25	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.40	31	10	12	0.1	0.02	6	0.87	0	Satisfactory
519	2081/05/25	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	6.96	31.7	12	14	0.1	0.02	6	1.2	0	Satisfactory
520	2081/05/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	6.92	32.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
521	2081/05/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	6.94	32.9	12	14	0.1	0.02	6	1.83	0	Satisfactory
522	2081/05/25	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	6.91	32.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
523	2081/05/25	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.07	<5	7.08	30.7	12	14	0.1	0.02	6	1.7	0	Satisfactory
524	2081/05/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	6.97	33.5	12	14	0.1	0.02	6	1.58	0	Satisfactory
525	2081/05/25	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	6.69	32.7	12	14	0.1	0.02	6	1.47	0	Satisfactory
526	2081/05/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	6.72	35.1	12	14	0.1	0.02	6	1.2	0	Satisfactory
527	2081/05/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	6.9	32.2	12	14	0.1	0.02	6	1.7	0	Satisfactory
528	2081/05/25	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	6.87	32.7	12	14	0.1	0.02	6	1.52	0	Satisfactory
529	2081/05/25	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	6.93	32.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
530	2081/05/25	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.70	<5	7.83	95.1	28	30	0.1	0.02	8	1.75	0	Satisfactory
531	2081/05/25	0:05	Maharajgunj	Balaju SRT	Treated	Clear	0.50	<5	7.59	81.3	26	28	0.1	0.02	10	0.3	0	Satisfactory
532	2081/05/25	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.90	<5	7.49	87.2	26	26	0.1	0.02	8	0.81	0	Satisfactory
533	2081/05/25	0:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.90	<5	7.91	105.8	30	30	0.1	0.02	10	0.28	0	Satisfactory
534	2081/05/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.70	<5	7.44	63.7	24	24	0.1	0.02	10	0.15	0	Satisfactory
535	2081/05/25	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.40	<5	7.33	56.8	24	24	0.1	0.02	10	0.46	0	Satisfactory
536	2081/05/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.40	<5	7.4	51.9	24	24	0.1	0.02	10	0.47	0	Satisfactory
537	2081/05/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.33	49.5	24	24	0.1	0.02	10	0.22	0	Satisfactory
538	2081/05/25	0:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.30	<5	7.59	76.6	26	26	0.1	0.02	8	0.97	0	Satisfactory
539	2081/05/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.16	<5	8.11	361	94	118	0.1	0.02	8	0.68	0	Satisfactory
540	2081/05/26	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.30	30	10	12	0.1	0.02	6	0.51	0	Satisfactory

541	2081/05/26	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.32	31	12	12	0.1	0.02	6	1.02	0	Satisfactory
542	2081/05/26	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.24	<5	6.92	359	92	70	0.3	1.5	12	0.2	0	Satisfactory
543	2081/05/26	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.35	<5	6.92	32.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
544	2081/05/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	6.97	33.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
545	2081/05/26	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	6.93	32.8	12	14	0.1	0.02	6	1.99	0	Satisfactory
546	2081/05/26	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	6.96	33.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
547	2081/05/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.14	32.4	12	14	0.1	0.02	6	1.76	0	Satisfactory
548	2081/05/26	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	6.94	33.4	12	14	0.1	0.02	6	0.89	0	Satisfactory
549	2081/05/26	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.01	32.3	12	14	0.1	0.02	6	1.44	0	Satisfactory
550	2081/05/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	6.96	34.4	12	14	0.1	0.02	6	1.92	0	Satisfactory
551	2081/05/26	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7	33.1	12	14	0.1	0.02	6	1.42	0	Satisfactory
552	2081/05/26	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	6.96	32.8	12	14	0.1	0.02	6	1.34	0	Satisfactory
553	2081/05/26	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	6.99	31.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
554	2081/05/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5.00	<5	7.06	54.7	22	24	0.1	0.02	10	0.42	0	Satisfactory
555	2081/05/26	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.70	<5	7.17	53.7	22	24	0.1	0.02	10	0.89	0	Satisfactory
556	2081/05/26	10:30	Lalitpur	Sainbu WTP	Treated	Clear	3.17	<5	8.13	402	102	124	0.1	0.02	10	0.85	0	Satisfactory
557	2081/05/27	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	7.23	34	12	12	0.1	0.02	6	0.67	0	Satisfactory
558	2081/05/27	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.30	34	12	12	0.1	0.02	6	0.80	0	Satisfactory
559	2081/05/27	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.34	35	12	14	0.1	0.02	6	0.84	0	Satisfactory
560	2081/05/27	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	6.98	369	96	72	0.3	1.5	16	0.23	0	Satisfactory
561	2081/05/27	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.02	<5	6.97	381	100	74	0.3	1.5	16	0.26	0	Satisfactory
562	2081/05/27	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.39	<5	6.96	374	96	72	0.3	1.5	16	0.41	0	Satisfactory
563	2081/05/27	11:55	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.01	31.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
564	2081/05/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.03	31.9	12	14	0.1	0.02	6	1.2	0	Satisfactory
565	2081/05/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.13	31.7	12	14	0.1	0.02	6	2	0	Satisfactory

566	2081/05/27	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.17	31.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
567	2081/05/27	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.14	30.8	12	14	0.1	0.02	6	1.46	0	Satisfactory
568	2081/05/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.26	32.8	12	14	0.1	0.02	6	0.79	0	Satisfactory
569	2081/05/27	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	6.87	33.3	12	14	0.1	0.02	6	2.01	0	Satisfactory
570	2081/05/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	6.71	33.1	12	14	0.1	0.02	6	1.65	0	Satisfactory
571	2081/05/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	6.99	32.5	12	14	0.1	0.02	6	1.63	0	Satisfactory
572	2081/05/27	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	6.97	32.7	12	14	0.1	0.02	6	1.74	0	Satisfactory
573	2081/05/27	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.32	34.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
574	2081/05/27	11:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.80	<5	7.2	75.8	22	26	0.1	0.02	8	0.78	0	Satisfactory
575	2081/05/27	13:30	Maharajgunj	Balaju SRT	Treated	Clear	0.80	<5	7.61	91.2	26	28	0.1	0.02	10	0.98	0	Satisfactory
576	2081/05/27	0:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.90	<5	6.59	78.9	16	26	0.1	0.02	8	1.09	0	Satisfactory
577	2081/05/27	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.50	<5	7.48	58.5	26	24	0.1	0.02	10	0.55	0	Satisfactory
578	2081/05/27	11:55	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.20	<5	8.12	64.4	32	26	0.1	0.02	10	0.5	0	Satisfactory
579	2081/05/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.30	<5	7.56	66.6	26	26	0.1	0.02	10	0.81	0	Satisfactory
580	2081/05/27	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.30	<5	7.38	52.6	24	26	0.1	0.02	10	0.64	0	Satisfactory
581	2081/05/27	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.40	<5	6.56	78.4	16	26	0.1	0.02	8	0.79	0	Satisfactory
582	2081/05/27	11:30	Maharajgunj	Panipokhari inlet	Treated	Clear	0.90	<5	7.26	81.2	24	22	0.1	0.02	8	0.27	0	Satisfactory
583	2081/05/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	2.81	<5	8.14	410	104	126	0.1	0.02	14	0.75	0	Satisfactory
584	2081/05/28	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.27	35	12	12	0.1	0.02	6	0.82	0	Satisfactory
585	2081/05/28	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.34	34	12	12	0.1	0.02	6	0.91	0	Satisfactory
586	2081/05/28	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.78	<5	7.01	426	114	82	0.3	1.5	22	0.91	0	Satisfactory
587	2081/05/28	0:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.31	<5	7.03	399	110	74	0.3	1.5	20	0.59	0	Satisfactory
588	2081/05/28	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.86	<5	7.05	381	108	72	0.3	1.5	20	0.3	0	Satisfactory
589	2081/05/28	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.02	<5	7.3	34.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
590	2081/05/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.29	33.8	12	14	0.1	0.02	6	1.94	0	Satisfactory



591	2081/05/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.29	34.9	12	14	0.1	0.02	6	2.01	0	Satisfactory
592	2081/05/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.22	35.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
593	2081/05/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.44	33.7	12	14	0.1	0.02	6	0.74	0	Satisfactory
594	2081/05/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.18	35.8	12	14	0.1	0.02	6	1.05	0	Satisfactory
595	2081/05/28	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.26	<5	7.08	36.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
596	2081/05/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	6.79	35.9	12	14	0.1	0.02	6	1.91	0	Satisfactory
597	2081/05/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	6.99	35.4	12	14	0.1	0.02	6	1.42	0	Satisfactory
598	2081/05/28	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.23	<5	7.28	35.4	12	14	0.1	0.02	6	1.46	0	Satisfactory
599	2081/05/28	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.30	<5	7.2	63.7	22	22	0.1	0.02	8	0.9	0	Satisfactory
600	2081/05/28	13:15	Maharajgunj	Balaju SRT	Treated	Clear	0.50	<5	6.96	78.2	20	28	0.1	0.02	10	0.81	0	Satisfactory
601	2081/05/28	0:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.80	<5	6.93	73	20	26	0.1	0.02	8	0.4	0	Satisfactory
602	2081/05/28	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.10	<5	7.69	61.1	28	26	0.1	0.02	10	0.72	0	Satisfactory
603	2081/05/28	0:05	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.90	<5	7.56	65.7	26	26	0.1	0.02	10	0.59	0	Satisfactory
604	2081/05/28		Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.00	<5	7.72	85.2	28	26	0.1	0.02	10	3.22	0	Satisfactory
605	2081/05/28	11:45	Maharajgunj	Panipokhari inlet	Treated	Clear	0.70	<5	7.13	72.6	22	22	0.1	0.02	8	0.23	0	Satisfactory
606	2081/05/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.05	<5	8.19	406	104	126	0.1	0.02	14	0.85	0	Satisfactory
607	2081/05/29	11:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.30	33	12	12	0.1	0.02	6	0.90	0	Satisfactory
608	2081/05/29	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.32	34	12	12	0.1	0.02	6	0.94	0	Satisfactory
609	2081/05/29	15:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.34	35	12	12	0.1	0.02	6	0.87	0	Satisfactory
610	2081/05/29	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.39	<5	7.08	377	110	72	0.3	1.5	18	0.32	0	Satisfactory
611	2081/05/29	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.31	35.6	12	14	0.1	0.02	6	1.2	0	Satisfactory
612	2081/05/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.32	34.9	12	14	0.1	0.02	6	1.94	0	Satisfactory
613	2081/05/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.33	34.1	12	14	0.1	0.02	6	1.88	0	Satisfactory
614	2081/05/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.35	34.2	12	14	0.1	0.02	6	1.2	0	Satisfactory
615	2081/05/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.37	32.9	12	14	0.1	0.02	6	1.44	0	Satisfactory

616	2081/05/29	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.24	33.3	12	14	0.1	0.02	6	0.58	0	Satisfactory
617	2081/05/29	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7	34.4	12	14	0.1	0.02	6	1.23	0	Satisfactory
618	2081/05/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	6.99	36	12	14	0.1	0.02	6	1.67	0	Satisfactory
619	2081/05/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	6.98	35.4	12	14	0.1	0.02	6	1.12	0	Satisfactory
620	2081/05/29	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.24	<5	7.25	34.6	12	14	0.1	0.02	6	1.98	0	Satisfactory
621	2081/05/29	8:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.60	<5	7.24	65.2	22	20	0.1	0.02	8	1.24	0	Satisfactory
622	2081/05/29	8:45	Maharajgunj	Balaju SRT	Treated	Clear	0.30	<5	7.26	78.4	24	28	0.1	0.02	10	0.9	0	Satisfactory
623	2081/05/29	7:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.40	<5	7.14	72.4	22	26	0.1	0.02	8	1.06	0	Satisfactory
624	2081/05/29	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.40	<5	7.17	52.6	22	26	0.1	0.02	10	0.58	0	Satisfactory
625	2081/05/29	8:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.20	<5	7.1	67.6	22	22	0.1	0.02	8	1.21	0	Satisfactory
626	2081/05/29	11:10	Maharajgunj	Panipokhari inlet	Treated	Clear	0.40	<5	6.67	66.5	18	22	0.1	0.02	8	0.42	0	Satisfactory
627	2081/05/30	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.50	<5	7.32	34	12	12	0.1	0.02	6	0.66	0	Satisfactory
628	2081/05/30	13:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.44	<5	7.29	26	12	12	0.1	0.02	6	1.02	0	Satisfactory
629	2081/05/30	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.36	<5	7.27	35	12	12	0.1	0.02	6	0.97	0	Satisfactory
630	2081/05/30	10:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	7.2	384	118	70	0.3	1.5	18	0.24	0	Satisfactory
631	2081/05/30	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.25	<5	7.15	372	112	70	0.3	1.5	20	0.62	0	Satisfactory
632	2081/05/30	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.24	<5	7.01	366	108	70	0.3	1.5	18	0.46	0	Satisfactory
633	2081/05/30	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.24	34.7	12	14	0.1	0.02	6	1.2	0	Satisfactory
634	2081/05/30	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.31	34.3	12	14	0.1	0.02	6	1.92	0	Satisfactory
635	2081/05/30	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.37	34.8	12	14	0.1	0.02	6	1.65	0	Satisfactory
636	2081/05/30	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.41	34.2	12	14	0.1	0.02	6	1.5	0	Satisfactory
637	2081/05/30	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	7.3	34.2	12	14	0.1	0.02	6	1.36	0	Satisfactory
638	2081/05/30	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.34	34.8	12	14	0.1	0.02	6	1.2	0	Satisfactory
639	2081/05/30	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.47	35.4	12	14	0.1	0.02	6	1.56	0	Satisfactory
640	2081/05/30	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	6.99	31.8	12	14	0.1	0.02	6	2	0	Satisfactory

641	2081/05/30	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.05	31.5	12	14	0.1	0.02	6	1.76	0	Satisfactory
642	2081/05/30	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.23	<5	7.05	32.4	12	14	0.1	0.02	6	1.4	0	Satisfactory
643	2081/05/30	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.22	30.5	12	14	0.1	0.02	6	1.98	0	Satisfactory
644	2081/05/30	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	4.20	<5	7.18	76.2	22	20	0.1	0.02	8	0.79	0	Satisfactory
645	2081/05/30	13:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.70	<5	7.02	75.6	20	26	0.1	0.02	8	0.77	0	Satisfactory
646	2081/05/30	0:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.60	<5	7	75.6	20	24	0.1	0.02	10	0.99	0	Satisfactory
647	2081/05/30	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.60	<5	8.05	66.3	32	26	0.1	0.02	10	0.94	0	Satisfactory
648	2081/05/30	11:55	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.20	<5	7.31	62.2	24	26	0.1	0.02	10	0.65	0	Satisfactory
649	2081/05/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.30	<5	7.29	62.2	24	26	0.1	0.02	10	0.82	0	Satisfactory
650	2081/05/30	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.00	<5	7.03	60.5	20	26	0.1	0.02	10	0.81	0	Satisfactory
651	2081/05/30	13:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.40	<5	7.1	73.5	22	22	0.1	0.02	8	1.16	0	Satisfactory
652	2081/05/30	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.94	<5	7.91	388	100	120	0.1	0.02	10	0.34	0	Satisfactory
653	2081/05/31	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	4.51	<5	7.17	34	12	12	0.1	0.02	6	0.70	0	Satisfactory
654	2081/05/31	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	3.24	<5	7.22	35	12	12	0.1	0.02	6	0.67	0	Satisfactory
655	2081/05/31	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	2.50	<5	7.24	35	12	12	0.1	0.02	6	0.74	0	Satisfactory
656	2081/05/31	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.3	<5	6.99	364	108	68	0.3	1.5	16	0.51	0	Satisfactory
657	2081/05/31	0:05	Madhyapur Thimi	Bode WTP	Treated	Clear	2.28	<5	6.98	368	108	70	0.3	1.5	16	0.33	0	Satisfactory
658	2081/05/31	15:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.86	<5	6.95	361	106	68	0.3	1.5	14	0.1	0	Satisfactory
659	2081/05/31	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.16	30.5	12	14	0.1	0.02	6	1.2	0	Satisfactory
660	2081/05/31	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.2	30.3	12	14	0.1	0.02	6	1.2	0	Satisfactory
661	2081/05/31	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.23	30.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
662	2081/05/31	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.22	30.4	12	14	0.1	0.02	6	1.2	0	Satisfactory
663	2081/05/31	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.15	29.8	12	14	0.1	0.02	6	1.38	0	Satisfactory
664	2081/05/31	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.23	28.6	12	14	0.1	0.02	6	1.47	0	Satisfactory
665	2081/05/31	0:05	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.28	30.4	12	14	0.1	0.02	6	0.81	0	Satisfactory

666	2081/05/31	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.12	37.3	12	14	0.1	0.02	6	1.12	0	Satisfactory
667	2081/05/31	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.19	37.2	12	14	0.1	0.02	6	0.42	0	Satisfactory
668	2081/05/31	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.12	36.2	12	14	0.1	0.02	6	0.85	0	Satisfactory
669	2081/05/31	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	6.82	40.7	14	14	0.1	0.02	6	1.61	0	Satisfactory
670	2081/05/31	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.40	<5	7.3	67.6	24	22	0.1	0.02	8	1.16	0	Satisfactory
671	2081/05/31	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.20	<5	7.18	61.8	22	26	0.1	0.02	10	0.43	0	Satisfactory
672	2081/05/31	11:50	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.40	<5	6.94	58.6	20	26	0.1	0.02	10	0.67	0	Satisfactory
673	2081/05/31	0:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.60	<5	7.06	60.2	22	26	0.1	0.02	10	0.88	0	Satisfactory
674	2081/05/31	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.30	<5	7.31	59.8	24	26	0.1	0.02	10	0.73	0	Satisfactory
675	2081/05/31	0:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.30	<5	6.66	37.5	18	16	0.1	0.02	8	0.85	0	Satisfactory
676	2081/05/31	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.48	<5	8.14	386	100	122	0.1	0.02	12	0.22	0	Satisfactory