



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Ashwin 2081

S.N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity (NTU)	Colour (TCU)	p ^H	Electrical Conductivity (µS/cm)	Total Alkalinity (mg/L)	Total Hardness (mg/L)	Total Iron (mg/L)	Total Ammonia (mg/L)	Chloride (mg/L)	F.R.C. (mg/L)	Total Coliforms (CFU/100 ml)	Remarks
Units							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
National Drinking Water Quality Standard (NDWQS)							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2081/06/01	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.46	83.7	26	12	0.1	0.02	8	0.73	0	Satisfactory
2	2081/06/01	9:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.3	73.5	24	22	0.1	0.02	6	1.24	0	Satisfactory
3	2081/06/01	10:00	Mahankalchaur	Arubari SRT	Treated	Clear	0.32	<5	7.3	80.2	24	22	0.1	0.02	8	0.76	0	Satisfactory
4	2081/06/01	8:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.25	<5	7.35	73.6	24	18	0.1	0.02	6	1.17	0	Satisfactory
5	2081/06/01	8:15	Kirtipur	Kirtipur SRT	Treated	Clear	0.23	<5	7.5	79.2	26	18	0.1	0.02	6	0.8	0	Satisfactory
6	2081/06/01	9:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	7.25	69.5	24	16	0.1	0.02	6	0.25	0	Satisfactory
7	2081/06/01	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.93	<5	7.18	36	12	14	0.1	0.02	6	0.81	0	Satisfactory
8	2081/06/01	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.73	<5	7.24	35	12	12	0.1	0.02	6	0.91	0	Satisfactory
9	2081/06/01	15:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.53	<5	7.22	36	12	12	0.1	0.02	6	0.94	0	Satisfactory
10	2081/06/01	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.85	<5	7.06	379	102	70	0.3	1.5	18	0.34	0	Satisfactory
11	2081/06/01	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	6.87	38.2	12	12	0.1	0.02	6	1.98	0	Satisfactory
12	2081/06/01	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	7.01	38.7	12	12	0.1	0.02	6	2.11	0	Satisfactory
13	2081/06/01	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.3	<5	7.1	32.7	12	12	0.1	0.02	6	1.84	0	Satisfactory
14	2081/06/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	7.15	32.3	12	12	0.1	0.02	6	1.97	0	Satisfactory
15	2081/06/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.1	36.2	12	12	0.1	0.02	6	0.64	0	Satisfactory
16	2081/06/01	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.16	37.1	12	12	0.1	0.02	6	1.68	0	Satisfactory
17	2081/06/01	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.2	36.4	12	12	0.1	0.02	6	0.76	0	Satisfactory
18	2081/06/01	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.22	31.6	12	12	0.1	0.02	6	1.68	0	Satisfactory

19	2081/06/01	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	6.82	31.5	12	12	0.1	0.02	6	2.23	0	Satisfactory
20	2081/06/02	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.17	<5	8.07	381	100	118	0.1	0.02	8	0.1	0	Satisfactory
21	2081/06/02	10:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.97	55.5	30	12	0.1	0.02	8	0.84	0	Satisfactory
22	2081/06/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.09	91.4	22	12	0.1	0.02	8	1.6	0	Satisfactory
23	2081/06/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.24	88.1	22	12	0.1	0.02	8	1.11	0	Satisfactory
24	2081/06/02	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	6.65	78.5	18	12	0.1	0.02	8	0.96	0	Satisfactory
25	2081/06/02	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.47	<5	7.23	36	12	14	0.1	0.02	6	0.76	0	Satisfactory
26	2081/06/02	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.36	<5	7.40	36	12	12	0.1	0.02	6	1.04	0	Satisfactory
27	2081/06/02	16:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.43	34	12	12	0.1	0.02	6	0.92	0	Satisfactory
28	2081/06/02	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.75	<5	7.06	357	94	68	0.3	1.5	14	0.2	0	Satisfactory
29	2081/06/02	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.79	<5	6.84	373	92	70	0.3	1.5	22	0.94	0	Satisfactory
30	2081/06/02	15:45	Madhyapur Thimi	Bode WTP	Treated	Clear	1.96	<5	6.95	369	92	68	0.3	1.5	18	0.5	0	Satisfactory
31	2081/06/02	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	6.96	31.5	12	12	0.1	0.02	6	2.22	0	Satisfactory
32	2081/06/02	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	6.99	31.7	12	12	0.1	0.02	6	1.99	0	Satisfactory
33	2081/06/02	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.15	30.1	12	12	0.1	0.02	6	1.54	0	Satisfactory
34	2081/06/02	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.24	30.4	14	12	0.1	0.02	6	1.7	0	Satisfactory
35	2081/06/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.39	31.9	14	12	0.1	0.02	6	0.71	0	Satisfactory
36	2081/06/02	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.31	31.6	14	12	0.1	0.02	6	1.55	0	Satisfactory
37	2081/06/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.06	33.1	12	12	0.1	0.02	6	3.23	0	Satisfactory
38	2081/06/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	7.2	30.9	14	12	0.1	0.02	6	2.27	0	Satisfactory
39	2081/06/02	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.24	<5	6.71	31.4	12	12	0.1	0.02	6	2.28	0	Satisfactory
40	2081/06/02	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.11	31.1	12	12	0.1	0.02	6	1.12	0	Satisfactory
41	2081/06/03	13:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.06	54.1	22	12	0.1	0.02	8	0.77	0	Satisfactory
42	2081/06/03	11:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.38	<5	7.40	35	12	12	0.1	0.02	6	0.87	0	Satisfactory
43	2081/06/03	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	7.44	37	14	14	0.1	0.02	6	1.04	0	Satisfactory
44	2081/06/03	15:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.43	37	14	14	0.1	0.02	6	1.02	0	Satisfactory
45	2081/06/03	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.09	<5	6.99	346	90	66	0.3	1.5	12	0.2	0	Satisfactory

46	2081/06/03	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.17	31.5	12	12	0.1	0.02	6	1.86	0	Satisfactory
47	2081/06/03	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.15	30.1	12	12	0.1	0.02	6	1.44	0	Satisfactory
48	2081/06/03	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.24	30.4	14	12	0.1	0.02	6	1.01	0	Satisfactory
49	2081/06/03	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.22	31.9	12	12	0.1	0.02	6	1.36	0	Satisfactory
50	2081/06/03	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.19	30.9	12	12	0.1	0.02	6	0.97	0	Satisfactory
51	2081/06/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.22	31.2	12	12	0.1	0.02	6	0.63	0	Satisfactory
52	2081/06/03	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.23	31.4	12	12	0.1	0.02	6	1.49	0	Satisfactory
53	2081/06/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.24	33.2	14	12	0.1	0.02	6	2.32	0	Satisfactory
54	2081/06/03	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.01	32.9	12	12	0.1	0.02	6	1.24	0	Satisfactory
55	2081/06/04	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.06	<5	7.96	394	102	124	0.1	0.02	10	0.83	0	Satisfactory
56	2081/06/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.15	54.8	22	12	0.1	0.02	8	0.9	0	Satisfactory
57	2081/06/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.08	50.4	22	12	0.1	0.02	8	0.38	0	Satisfactory
58	2081/06/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.4	52.2	24	12	0.1	0.02	8	0.39	0	Satisfactory
59	2081/06/04	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	7.5	75.4	26	22	0.1	0.02	6	1.27	0	Satisfactory
60	2081/06/04	13:25	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.5	84.7	26	22	0.1	0.02	8	0.45	0	Satisfactory
61	2081/06/04	12:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.44	72.8	24	18	0.1	0.02	6	0.86	0	Satisfactory
62	2081/06/04	11:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.46	80.8	26	16	0.1	0.02	6	0.42	0	Satisfactory
63	2081/06/04	14:00	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.67	74.4	28	22	0.1	0.02	8	0.46	0	Satisfactory
64	2081/06/04	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.41	36	12	12	0.1	0.02	6	0.97	0	Satisfactory
65	2081/06/04	14:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.42	37	14	14	0.1	0.02	6	1.03	0	Satisfactory
66	2081/06/04	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.31	<5	6.92	362	106	68	0.3	1.5	12	0.2	0	Satisfactory
67	2081/06/04	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.03	<5	6.91	377	92	70	0.3	1.5	20	0.61	0	Satisfactory
68	2081/06/04	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.98	<5	6.9	381	92	72	0.3	1.5	20	0.68	0	Satisfactory
69	2081/06/04	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7	33.4	12	12	0.1	0.02	6	2.01	0	Satisfactory
70	2081/06/04	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.28	34.3	14	12	0.1	0.02	6	2.29	0	Satisfactory
71	2081/06/04	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.2	32.6	12	12	0.1	0.02	6	1.83	0	Satisfactory
72	2081/06/04	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.21	32	12	12	0.1	0.02	6	1.9	0	Satisfactory

73	2081/06/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.28	31.5	14	12	0.1	0.02	6	1.44	0	Satisfactory
74	2081/06/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.04	29	12	12	0.1	0.02	6	1.14	0	Satisfactory
75	2081/06/04	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.05	31.3	12	12	0.1	0.02	6	1.22	0	Satisfactory
76	2081/06/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	6.83	31.9	12	12	0.1	0.02	6	1.54	0	Satisfactory
77	2081/06/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	6.96	31.3	12	12	0.1	0.02	6	1.24	0	Satisfactory
78	2081/06/04	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	7.03	34.1	12	12	0.1	0.02	6	1.77	0	Satisfactory
79	2081/06/05	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.78	53.2	30	12	0.1	0.02	8	0.45	0	Satisfactory
80	2081/06/05	7:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.95	80.7	30	28	0.1	0.02	6	1.05	0	Satisfactory
81	2081/06/05	9:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.85	72.3	30	18	0.1	0.02	6	0.85	0	Satisfactory
82	2081/06/05	8:25	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	8.15	81.7	32	18	0.1	0.02	6	0.88	0	Satisfactory
83	2081/06/05	6:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.68	71.2	28	16	0.1	0.02	6	1.12	0	Satisfactory
84	2081/06/05	11:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.44	35	12	12	0.1	0.02	6	0.90	0	Satisfactory
85	2081/06/05	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.37	36	12	12	0.1	0.02	6	0.92	0	Satisfactory
86	2081/06/05	15:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.41	36	12	12	0.1	0.02	6	0.94	0	Satisfactory
87	2081/06/05	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.17	<5	6.96	375	92	70	0.3	1.5	16	0.36	0	Satisfactory
88	2081/06/05	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.29	33.8	12	12	0.1	0.02	6	1.97	0	Satisfactory
89	2081/06/05	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.31	35.6	14	12	0.1	0.02	6	1.54	0	Satisfactory
90	2081/06/05	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.29	34.8	14	12	0.1	0.02	6	0.93	0	Satisfactory
91	2081/06/05	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.32	33.8	14	12	0.1	0.02	6	1.29	0	Satisfactory
92	2081/06/05	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.29	33.1	14	12	0.1	0.02	6	1.16	0	Satisfactory
93	2081/06/05	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.32	33.5	14	12	0.1	0.02	6	1.58	0	Satisfactory
94	2081/06/05	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	7.22	34.4	12	12	0.1	0.02	6	2.06	0	Satisfactory
95	2081/06/05	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.21	<5	7.17	34.6	12	12	0.1	0.02	6	1.99	0	Satisfactory
96	2081/06/05	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.24	33.9	14	12	0.1	0.02	6	1.82	0	Satisfactory
97	2081/06/05	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.08	33.7	12	12	0.1	0.02	6	1.81	0	Satisfactory
98	2081/06/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.74	<5	8.04	390	104	120	0.1	0.02	8	0.76	0	Satisfactory
99	2081/06/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.57	36.6	16	12	0.1	0.02	8	0.76	0	Satisfactory

100	2081/06/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.49	36.5	16	12	0.1	0.02	8	0.63	0	Satisfactory
101	2081/06/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.18	<5	7.48	35.3	16	12	0.1	0.02	8	0.53	0	Satisfactory
102	2081/06/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	6.78	33.5	10	12	0.1	0.02	8	0.67	0	Satisfactory
103	2081/06/06	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.40	33	12	12	0.1	0.02	6	0.86	0	Satisfactory
104	2081/06/06	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.38	34	12	12	0.1	0.02	6	0.94	0	Satisfactory
105	2081/06/06	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.41	34	12	12	0.1	0.02	6	0.92	0	Satisfactory
106	2081/06/06	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.9	<5	7.12	382	106	68	0.3	1.5	16	0.42	0	Satisfactory
107	2081/06/06	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.89	<5	6.99	377	98	68	0.3	1.5	16	0.31	0	Satisfactory
108	2081/06/06	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.42	<5	6.92	370	92	68	0.3	1.5	20	0.96	0	Satisfactory
109	2081/06/06	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.12	33.9	12	12	0.1	0.02	6	2.36	0	Satisfactory
110	2081/06/06	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.24	33.8	12	12	0.1	0.02	6	1.69	0	Satisfactory
111	2081/06/06	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.31	35.5	14	12	0.1	0.02	6	1.38	0	Satisfactory
112	2081/06/06	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.19	33.5	12	12	0.1	0.02	6	1.55	0	Satisfactory
113	2081/06/06	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.22	33.3	12	12	0.1	0.02	6	1.56	0	Satisfactory
114	2081/06/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.32	34.7	14	12	0.1	0.02	6	1.23	0	Satisfactory
115	2081/06/06	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.5	33.9	14	12	0.1	0.02	6	1.1	0	Satisfactory
116	2081/06/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.1	35.7	12	12	0.1	0.02	6	2.81	0	Satisfactory
117	2081/06/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.31	32.3	14	12	0.1	0.02	6	1.61	0	Satisfactory
118	2081/06/06	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.36	34.2	14	12	0.1	0.02	6	1.52	0	Satisfactory
119	2081/06/06	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.26	<5	7.09	33.1	12	12	0.1	0.02	6	1.62	0	Satisfactory
120	2081/06/07	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.12	<5	8.22	404	108	128	0.1	0.02	10	0.3	0	Satisfactory
121	2081/06/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	6.5	26.01	10	12	0.1	0.02	8	0.4	0	Satisfactory
122	2081/06/07	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.57	29.13	14	12	0.1	0.02	8	0.48	0	Satisfactory
123	2081/06/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	6.5	29.06	8	12	0.1	0.02	8	0.4	0	Satisfactory
124	2081/06/07	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.12	29.72	12	12	0.1	0.02	8	0.27	0	Satisfactory
125	2081/06/07	12:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.2	<5	6.85	40.5	10	18	0.1	0.02	6	1.05	0	Satisfactory
126	2081/06/07	11:20	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.15	45.3	12	18	0.1	0.02	6	1.09	0	Satisfactory

127	2081/06/07	11:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	6.65	38.7	8	16	0.1	0.02	6	1.2	0	Satisfactory
128	2081/06/07	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.36	32	12	12	0.1	0.02	6	0.67	0	Satisfactory
129	2081/06/07	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.44	33	12	12	0.1	0.02	6	1.04	0	Satisfactory
130	2081/06/07	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.42	34	12	12	0.1	0.02	6	1.01	0	Satisfactory
131	2081/06/07	10:20	Madhyapur Thimi	Bode WTP	Treated	Clear	1.85	<5	6.88	374	90	72	0.3	1.5	22	1.1	0	Satisfactory
132	2081/06/07	12:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.11	<5	6.9	366	88	70	0.3	1.5	18	0.4	0	Satisfactory
133	2081/06/07	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.92	<5	6.88	393	100	74	0.3	1.5	24	1.14	0	Satisfactory
134	2081/06/07	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	7.07	33.7	12	12	0.1	0.02	6	1.91	0	Satisfactory
135	2081/06/07	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.08	33.9	12	12	0.1	0.02	6	2.11	0	Satisfactory
136	2081/06/07	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.06	34.1	12	12	0.1	0.02	6	1.95	0	Satisfactory
137	2081/06/07	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.05	34.4	12	12	0.1	0.02	6	2.22	0	Satisfactory
138	2081/06/07	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.31	32.7	14	12	0.1	0.02	6	1.57	0	Satisfactory
139	2081/06/07	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.26	<5	7.03	32.5	12	12	0.1	0.02	6	0.56	0	Satisfactory
140	2081/06/07	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.22	<5	6.96	33.2	12	12	0.1	0.02	6	1.81	0	Satisfactory
141	2081/06/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	6.96	34.3	12	12	0.1	0.02	6	1.63	0	Satisfactory
142	2081/06/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.05	32.6	12	12	0.1	0.02	6	1.23	0	Satisfactory
143	2081/06/07	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.1	32.9	12	12	0.1	0.02	6	1.27	0	Satisfactory
144	2081/06/07	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.09	32.7	12	12	0.1	0.02	6	0.95	0	Satisfactory
145	2081/06/08	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.05	395	104	122	0.1	0.02	8	0.51	0	Satisfactory
146	2081/06/08	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.4	<5	7	29.15	10	12	0.1	0.02	8	0.29	0	Satisfactory
147	2081/06/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.19	37.5	12	12	0.1	0.02	8	0.54	0	Satisfactory
148	2081/06/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	6.96	36.6	10	12	0.1	0.02	8	0.46	0	Satisfactory
149	2081/06/08	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.03	37.4	10	12	0.1	0.02	8	0.26	0	Satisfactory
150	2081/06/08	10:00	Maharajgunj	Balaju SRT	Treated	Clear	1.1	<5	7.35	61.2	24	18	0.1	0.02	8	1.11	0	Satisfactory
151	2081/06/08	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.07	46.7	12	22	0.1	0.02	8	0.3	0	Satisfactory
152	2081/06/08	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.26	<5	7.42	33	12	12	0.1	0.02	6	0.86	0	Satisfactory
153	2081/06/08	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.44	34	12	12	0.1	0.02	6	0.94	0	Satisfactory

154	2081/06/08	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.37	35	12	12	0.1	0.02	6	0.92	0	Satisfactory
155	2081/06/08	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.21	<5	6.92	388	96	70	0.3	1.5	20	0.81	0	Satisfactory
156	2081/06/08	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.61	<5	6.89	377	94	70	0.3	1.5	22	0.37	0	Satisfactory
157	2081/06/08	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.08	32.9	12	12	0.1	0.02	6	1.43	0	Satisfactory
158	2081/06/08	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.11	33.1	12	12	0.1	0.02	6	1.91	0	Satisfactory
159	2081/06/08	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.09	33.3	12	12	0.1	0.02	6	1.69	0	Satisfactory
160	2081/06/08	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.1	33.4	12	12	0.1	0.02	6	1.98	0	Satisfactory
161	2081/06/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.04	32.6	12	12	0.1	0.02	6	1.32	0	Satisfactory
162	2081/06/08	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.12	30.8	12	12	0.1	0.02	6	0.75	0	Satisfactory
163	2081/06/08	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.08	32.9	12	12	0.1	0.02	6	0.73	0	Satisfactory
164	2081/06/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.18	33.3	12	12	0.1	0.02	6	1.38	0	Satisfactory
165	2081/06/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.07	35.8	12	12	0.1	0.02	6	1.56	0	Satisfactory
166	2081/06/08	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	6.93	32	12	12	0.1	0.02	6	1.23	0	Satisfactory
167	2081/06/08	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.11	31	12	12	0.1	0.02	6	1.54	0	Satisfactory
168	2081/06/09	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.48	<5	7.97	401	108	128	0.1	0.02	10	0.85	0	Satisfactory
169	2081/06/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.06	33.2	12	12	0.1	0.02	8	0.2	0	Satisfactory
170	2081/06/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.25	34.5	14	12	0.1	0.02	8	0.4	0	Satisfactory
171	2081/06/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	7.2	54.5	12	12	0.1	0.02	8	0.34	0	Satisfactory
172	2081/06/09	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.28	54.8	14	12	0.1	0.02	8	0.3	0	Satisfactory
173	2081/06/09	11:05	Tripureshwar	Anamnagar SRT	Treated	Clear	1.7	<5	6.79	53	8	18	0.1	0.02	6	0.92	0	Satisfactory
174	2081/06/09	13:10	Maharajgunj	Balaju SRT	Treated	Clear	0.2	<5	7.05	67.8	12	20	0.1	0.02	8	0.8	0	Satisfactory
175	2081/06/09	11:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.2	<5	6.91	51.5	10	18	0.1	0.02	6	0.81	0	Satisfactory
176	2081/06/09	10:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	6.95	49.7	10	16	0.1	0.02	6	1.11	0	Satisfactory
177	2081/06/09	14:00	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.2	44.1	12	22	0.1	0.02	8	0.1	0	Satisfactory
178	2081/06/09	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.42	35	12	12	0.1	0.02	6	0.63	0	Satisfactory
179	2081/06/09	16:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.26	<5	7.42	35	12	12	0.1	0.02	6	1.02	0	Satisfactory
180	2081/06/09	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.40	35	12	12	0.1	0.02	6	0.96	0	Satisfactory

181	2081/06/09	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.47	<5	6.98	357	92	66	0.3	1.5	12	0.2	0	Satisfactory
182	2081/06/09	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.8	<5	6.95	366	92	70	0.3	1.5	16	0.2	0	Satisfactory
183	2081/06/09	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.08	31.6	12	12	0.1	0.02	6	1.99	0	Satisfactory
184	2081/06/09	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.06	31.9	12	12	0.1	0.02	6	1.83	0	Satisfactory
185	2081/06/09	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.03	31.4	12	12	0.1	0.02	6	1.6	0	Satisfactory
186	2081/06/09	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	6.98	31.1	12	12	0.1	0.02	6	1.7	0	Satisfactory
187	2081/06/09	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	6.92	30.8	12	12	0.1	0.02	6	1.75	0	Satisfactory
188	2081/06/09	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.07	30.5	12	12	0.1	0.02	6	1.43	0	Satisfactory
189	2081/06/09	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	6.92	31.1	12	12	0.1	0.02	6	2.41	0	Satisfactory
190	2081/06/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	7.12	31.1	12	12	0.1	0.02	6	1.75	0	Satisfactory
191	2081/06/09	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	6.64	34.7	12	12	0.1	0.02	6	2.42	0	Satisfactory
192	2081/06/09	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	6.75	31.9	12	12	0.1	0.02	6	1.77	0	Satisfactory
193	2081/06/09	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	6.88	30	12	12	0.1	0.02	6	1.58	0	Satisfactory
194	2081/06/10	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.08	<5	7.95	406	110	128	0.1	0.02	12	0.72	0	Satisfactory
195	2081/06/10	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.57	38.4	16	12	0.1	0.02	8	0.23	0	Satisfactory
196	2081/06/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.06	52.8	12	12	0.1	0.02	8	2.33	0	Satisfactory
197	2081/06/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.12	47.6	12	12	0.1	0.02	8	1.08	0	Satisfactory
198	2081/06/10	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.25	46.5	14	12	0.1	0.02	8	0.84	0	Satisfactory
199	2081/06/10	11:25	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	6.98	51.5	14	18	0.1	0.02	6	1.2	0	Satisfactory
200	2081/06/10	13:10	Maharajgunj	Balaju SRT	Treated	Clear	1.7	<5	7.15	75.2	22	22	0.1	0.02	8	1.44	0	Satisfactory
201	2081/06/10	12:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	6.93	48.2	12	18	0.1	0.02	6	0.89	0	Satisfactory
202	2081/06/10	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	1.1	<5	7.01	46.7	10	22	0.1	0.02	8	0.1	0	Satisfactory
203	2081/06/10	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.43	35	12	12	0.1	0.02	6	1.02	0	Satisfactory
204	2081/06/10	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.42	37	14	14	0.1	0.02	6	0.98	0	Satisfactory
205	2081/06/10	16:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.52	37	14	14	0.1	0.02	6	1.02	0	Satisfactory
206	2081/06/10	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	7.03	362	94	66	0.3	1.5	12	0.2	0	Satisfactory
207	2081/06/10	12:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.99	<5	6.96	369	94	70	0.3	1.5	14	0.34	0	Satisfactory

208	2081/06/10	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.42	<5	6.98	373	96	70	0.3	1.5	14	0.36	0	Satisfactory
209	2081/06/10	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.22	<5	6.85	30.9	12	12	0.1	0.02	6	1.93	0	Satisfactory
210	2081/06/10	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	6.89	31.4	12	12	0.1	0.02	6	2.01	0	Satisfactory
211	2081/06/10	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.28	<5	6.91	31.9	12	12	0.1	0.02	6	1.61	0	Satisfactory
212	2081/06/10	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.26	<5	6.94	32.3	12	12	0.1	0.02	6	1.73	0	Satisfactory
213	2081/06/10	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.3	<5	7.03	32.6	12	12	0.1	0.02	6	1.73	0	Satisfactory
214	2081/06/10	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.13	33.2	12	12	0.1	0.02	6	1.24	0	Satisfactory
215	2081/06/10	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	6.93	35	12	12	0.1	0.02	6	1.71	0	Satisfactory
216	2081/06/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	6.89	34.6	12	12	0.1	0.02	6	1.85	0	Satisfactory
217	2081/06/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.18	<5	6.94	35.1	12	12	0.1	0.02	6	1.87	0	Satisfactory
218	2081/06/10	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	6.75	33.5	12	12	0.1	0.02	6	1.57	0	Satisfactory
219	2081/06/10	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	6.97	34.2	12	12	0.1	0.02	6	2.16	0	Satisfactory
220	2081/06/11	10:30	Lalitpur	Sainbu WTP	Treated	Clear	4.06	<5	8.13	391	104	120	0.1	0.02	8	0.1	0	Satisfactory
221	2081/06/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.28	39.2	14	12	0.1	0.02	8	0.38	0	Satisfactory
222	2081/06/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.26	39.7	14	12	0.1	0.02	8	0.29	0	Satisfactory
223	2081/06/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	6.74	41.4	8	12	0.1	0.02	8	0.32	0	Satisfactory
224	2081/06/11	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.1	50.2	22	18	0.1	0.02	6	1.47	0	Satisfactory
225	2081/06/11	11:40	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.35	50.9	24	18	0.1	0.02	6	0.71	0	Satisfactory
226	2081/06/11	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	1	<5	7.45	55.9	26	18	0.1	0.02	6	0.6	0	Satisfactory
227	2081/06/11	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.41	51.3	24	16	0.1	0.02	6	1.06	0	Satisfactory
228	2081/06/11	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.73	<5	7.44	37	14	14	0.1	0.02	6	0.96	0	Satisfactory
229	2081/06/11	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.38	38	14	14	0.1	0.02	6	1.04	0	Satisfactory
230	2081/06/11	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.24	<5	8.5	376	100	68	0.3	1.5	16	0.48	0	Satisfactory
231	2081/06/11	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.99	<5	6.92	379	100	70	0.3	1.5	16	0.51	0	Satisfactory
232	2081/06/11	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	6.99	33.9	12	12	0.1	0.02	6	2.27	0	Satisfactory
233	2081/06/11	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	6.98	33.7	12	12	0.1	0.02	6	1.93	0	Satisfactory
234	2081/06/11	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.08	33.5	12	12	0.1	0.02	6	1.39	0	Satisfactory

235	2081/06/11	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.1	33.1	12	12	0.1	0.02	6	1.44	0	Satisfactory
236	2081/06/11	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	6.93	31.7	12	12	0.1	0.02	6	1.41	0	Satisfactory
237	2081/06/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.07	28.9	12	12	0.1	0.02	6	1.28	0	Satisfactory
238	2081/06/11	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.02	29	12	12	0.1	0.02	6	0.64	0	Satisfactory
239	2081/06/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	6.86	30.7	12	12	0.1	0.02	6	1.36	0	Satisfactory
240	2081/06/11	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	6.89	30.3	12	12	0.1	0.02	6	1.72	0	Satisfactory
241	2081/06/12		Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.5	51.6	26	12	0.1	0.02	8	0.66	0	Satisfactory
242	2081/06/12	7:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.5	52.6	26	18	0.1	0.02	6	1.74	0	Satisfactory
243	2081/06/12	9:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.3	52.2	24	18	0.1	0.02	6	1.24	0	Satisfactory
244	2081/06/12	7:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.4	50.9	24	16	0.1	0.02	6	1.79	0	Satisfactory
245	2081/06/12	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	4.53	<5	7.33	36	12	12	0.1	0.02	6	1.00	0	Satisfactory
246	2081/06/12	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.3	<5	6.8	31.6	12	12	0.1	0.02	6	1.94	0	Satisfactory
247	2081/06/12	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	6.83	31.9	12	12	0.1	0.02	6	1.87	0	Satisfactory
248	2081/06/12	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	6.89	34.7	12	12	0.1	0.02	6	1.99	0	Satisfactory
249	2081/06/12	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	6.93	37.9	12	12	0.1	0.02	6	2.92	0	Satisfactory
250	2081/06/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.73	<5	6.95	41.1	10	12	0.1	0.02	8	0.2	0	Satisfactory
251	2081/06/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.4	<5	7.1	41.5	12	12	0.1	0.02	8	0.2	0	Satisfactory
252	2081/06/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.5	40.8	16	12	0.1	0.02	8	0.2	0	Satisfactory
253	2081/06/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.3	<5	7.18	40.9	12	12	0.1	0.02	8	0.2	0	Satisfactory
254	2081/06/13	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.31	34	12	12	0.1	0.02	6	0.73	0	Satisfactory
255	2081/06/13	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.50	<5	7.18	32	12	12	0.1	0.02	6	1.01	0	Satisfactory
256	2081/06/13	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.66	<5	7.34	32	12	12	0.1	0.02	6	0.97	0	Satisfactory
257	2081/06/13	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.42	<5	7.02	363	96	68	0.3	1.5	14	0.24	0	Satisfactory
258	2081/06/13	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	6.95	380	100	72	0.3	1.5	20	0.71	0	Satisfactory
259	2081/06/13	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.03	<5	6.9	406	100	78	0.3	1.5	22	1.25	0	Satisfactory
260	2081/06/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.17	<5	7.38	34	14	12	0.1	0.02	6	0.14	0	Satisfactory
261	2081/06/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.02	33.6	12	12	0.1	0.02	6	0.61	0	Satisfactory

262	2081/06/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.35	37.7	14	12	0.1	0.02	6	2.29	0	Satisfactory
263	2081/06/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.06	49.2	12	12	0.1	0.02	6	2.44	0	Satisfactory
264	2081/06/13	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.1	39.2	12	12	0.1	0.02	6	2.24	0	Satisfactory
265	2081/06/13	18:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	6.56	38.6	12	12	0.1	0.02	6	1.89	0	Satisfactory
266	2081/06/13	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	6.77	36.9	12	12	0.1	0.02	6	1.35	0	Satisfactory
267	2081/06/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	6.83	45.8	8	12	0.1	0.02	8	0.2	0	Satisfactory
268	2081/06/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.5	44.4	16	12	0.1	0.02	8	0.2	0	Satisfactory
269	2081/06/14	13:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.47	56.9	26	18	0.1	0.02	6	1.53	0	Satisfactory
270	2081/06/14		Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.59	61.5	26	14	0.1	0.02	6	1.82	0	Satisfactory
271	2081/06/14		Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.1	59.2	22	18	0.1	0.02	6	2.19	0	Satisfactory
272	2081/06/14	13:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	6.99	72.3	12	12	0.1	0.02	6	0.92	0	Satisfactory
273	2081/06/14		Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.1	64.5	22	22	0.1	0.02	8	0.31	0	Satisfactory
274	2081/06/14	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.44	32	12	12	0.1	0.02	6	0.91	0	Satisfactory
275	2081/06/14	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.45	32	12	12	0.1	0.02	6	1.01	0	Satisfactory
276	2081/06/14	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.45	32	12	12	0.1	0.02	6	1.05	0	Satisfactory
277	2081/06/14	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.96	<5	6.95	366	94	72	0.3	1.5	18	0.46	0	Satisfactory
278	2081/06/14	16:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.1	<5	6.92	379	100	72	0.3	1.5	18	0.52	0	Satisfactory
279	2081/06/14	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.3	<5	6.79	38.9	12	12	0.1	0.02	6	1.79	0	Satisfactory
280	2081/06/14	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	6.84	42.9	12	12	0.1	0.02	6	2.03	0	Satisfactory
281	2081/06/14	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	6.9	46.6	12	12	0.1	0.02	6	1.83	0	Satisfactory
282	2081/06/14	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	6.92	47.2	12	12	0.1	0.02	6	2.18	0	Satisfactory
283	2081/06/14	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.09	43.7	12	12	0.1	0.02	6	1.08	0	Satisfactory
284	2081/06/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.14	48.3	12	12	0.1	0.02	6	1.94	0	Satisfactory
285	2081/06/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.06	43.4	12	12	0.1	0.02	6	1.94	0	Satisfactory
286	2081/06/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.19	43.5	12	12	0.1	0.02	6	2.53	0	Satisfactory
287	2081/06/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.03	42.2	12	12	0.1	0.02	6	2.46	0	Satisfactory
288	2081/06/14	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	6.87	41.8	12	12	0.1	0.02	6	2.27	0	Satisfactory

289	2081/06/14	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	6.97	41.1	12	12	0.1	0.02	6	2.11	0	Satisfactory
290	2081/06/15		Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.9	<5	7.3	45.7	14	12	0.1	0.02	8	0.2	0	Satisfactory
291	2081/06/15	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.32	64.1	24	22	0.1	0.02	6	1.71	0	Satisfactory
292	2081/06/15	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	6.95	66.2	10	22	0.1	0.02	6	1.26	0	Satisfactory
293	2081/06/15	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.43	79.7	24	22	0.1	0.02	6	1.09	0	Satisfactory
294	2081/06/15	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.34	63.8	24	22	0.1	0.02	6	1.17	0	Satisfactory
295	2081/06/15	10:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.48	<5	7.37	31	12	12	0.1	0.02	6	0.71	0	Satisfactory
296	2081/06/15	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.43	32	12	12	0.1	0.02	6	1.02	0	Satisfactory
297	2081/06/15	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.52	32	12	12	0.1	0.02	6	1.03	0	Satisfactory
298	2081/06/15	10:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.79	<5	7.11	390	104	72	0.3	1.5	16	0.39	0	Satisfactory
299	2081/06/15	15:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.02	<5	6.95	396	104	76	0.3	1.5	22	1.05	0	Satisfactory
300	2081/06/15	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	6.94	41.2	12	12	0.1	0.02	6	2.43	0	Satisfactory
301	2081/06/15	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	6.91	41.3	12	12	0.1	0.02	6	2.14	0	Satisfactory
302	2081/06/15	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.03	39.9	12	12	0.1	0.02	6	1.98	0	Satisfactory
303	2081/06/15	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.11	39	12	12	0.1	0.02	6	1.52	0	Satisfactory
304	2081/06/15	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	7.12	38.7	12	12	0.1	0.02	6	2.04	0	Satisfactory
305	2081/06/15	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.08	39.2	12	12	0.1	0.02	6	1.91	0	Satisfactory
306	2081/06/15	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.5	<5	7.3	45.8	14	12	0.1	0.02	6	1.25	0	Satisfactory
307	2081/06/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.47	<5	7.07	42.5	12	12	0.1	0.02	6	2.26	0	Satisfactory
308	2081/06/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.23	<5	7.14	38.6	12	12	0.1	0.02	6	1.41	0	Satisfactory
309	2081/06/15	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.28	39.4	14	12	0.1	0.02	6	2.12	0	Satisfactory
310	2081/06/15	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	6.97	40.5	12	12	0.1	0.02	6	1.93	0	Satisfactory
311	2081/06/16		Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	6.85	41.7	10	12	0.1	0.02	8	0.2	0	Satisfactory
312	2081/06/16	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.1	<5	6.97	67.1	20	22	0.1	0.02	6	1.5	0	Satisfactory
313	2081/06/16	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.8	<5	6.85	64.2	20	22	0.1	0.02	6	1.27	0	Satisfactory
314	2081/06/16	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.23	67.1	22	22	0.1	0.02	6	1.19	0	Satisfactory
315	2081/06/16	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.25	69.7	24	22	0.1	0.02	6	1.25	0	Satisfactory

316	2081/06/16	11:30	Lalitpur	Khumaltar SRT	Treated	Clear	1.1	<5	6.78	61.2	18	18	0.1	0.02	6	1.57	0	Satisfactory
317	2081/06/16	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.51	31	12	12	0.1	0.02	6	0.76	0	Satisfactory
318	2081/06/16	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.55	33	12	12	0.1	0.02	6	0.84	0	Satisfactory
319	2081/06/16	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.55	32	12	12	0.1	0.02	6	0.82	0	Satisfactory
320	2081/06/16	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.1	<5	7.03	409	108	74	0.3	1.5	18	0.48	0	Satisfactory
321	2081/06/16	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.01	<5	7.1	428	120	76	0.3	1.5	18	0.6	0	Satisfactory
322	2081/06/16	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.28	<5	7.05	418	110	78	0.3	1.5	20	0.65	0	Satisfactory
323	2081/06/16	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7	37	12	12	0.1	0.02	6	2.21	0	Satisfactory
324	2081/06/16	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.03	37.3	12	12	0.1	0.02	6	1.03	0	Satisfactory
325	2081/06/16	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.05	36.9	12	12	0.1	0.02	6	0.93	0	Satisfactory
326	2081/06/16	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.07	37	12	12	0.1	0.02	6	2.42	0	Satisfactory
327	2081/06/16	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.06	36.6	12	12	0.1	0.02	6	2.95	0	Satisfactory
328	2081/06/16	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	6.9	39.4	12	12	0.1	0.02	6	2.42	0	Satisfactory
329	2081/06/16	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.2	39.3	12	12	0.1	0.02	6	1.19	0	Satisfactory
330	2081/06/16	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.24	<5	7.16	39.1	12	12	0.1	0.02	6	2.75	0	Satisfactory
331	2081/06/16	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.2	<5	7.09	38.8	12	12	0.1	0.02	6	2.54	0	Satisfactory
332	2081/06/16	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7	38.5	12	12	0.1	0.02	6	2.21	0	Satisfactory
333	2081/06/16	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.19	<5	7.1	38.3	12	12	0.1	0.02	6	1.38	0	Satisfactory
334	2081/06/17		Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.13	<5	7.32	43.6	14	12	0.1	0.02	8	0.2	0	Satisfactory
335	2081/06/17	7:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.7	<5	7.32	67.5	24	22	0.1	0.02	6	1.25	0	Satisfactory
336	2081/06/17	11:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.96	<5	7.43	34	12	12	0.1	0.02	6	1.02	0	Satisfactory
337	2081/06/17	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.16	38.1	12	12	0.1	0.02	6	1.55	0	Satisfactory
338	2081/06/17	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.2	37.8	12	12	0.1	0.02	6	1.46	0	Satisfactory
339	2081/06/17	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.18	36.9	12	12	0.1	0.02	6	0.98	0	Satisfactory
340	2081/06/17	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.1	36.5	12	12	0.1	0.02	6	1.43	0	Satisfactory
341	2081/06/17	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.14	35.9	12	12	0.1	0.02	6	1.85	0	Satisfactory
342	2081/06/17	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.07	35.2	12	12	0.1	0.02	6	1.72	0	Satisfactory

343	2081/06/17	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.08	34.9	12	12	0.1	0.02	6	0.69	0	Satisfactory
344	2081/06/17	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7	36.9	12	12	0.1	0.02	6	1.52	0	Satisfactory
345	2081/06/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.07	39.1	12	12	0.1	0.02	6	2.08	0	Satisfactory
346	2081/06/17	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	6.67	39.9	12	12	0.1	0.02	6	1.94	0	Satisfactory
347	2081/06/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.34	39.1	14	12	0.1	0.02	8	0.2	0	Satisfactory
348	2081/06/18	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.7	<5	7.2	75.4	22	22	0.1	0.02	6	1.15	0	Satisfactory
349	2081/06/18	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.79	75.7	28	22	0.1	0.02	6	0.95	0	Satisfactory
350	2081/06/18	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	1	<5	7.7	73.3	28	22	0.1	0.02	6	1	0	Satisfactory
351	2081/06/18	11:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.14	72.4	22	18	0.1	0.02	6	0.43	0	Satisfactory
352	2081/06/18	11:40	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.75	83	28	18	0.1	0.02	6	0.79	0	Satisfactory
353	2081/06/18	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.43	37	14	14	0.1	0.02	6	0.73	0	Satisfactory
354	2081/06/18	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.34	33	12	12	0.1	0.02	6	0.90	0	Satisfactory
355	2081/06/18	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.08	<5	7.01	390	100	68	0.3	1.5	12	0.2	0	Satisfactory
356	2081/06/18	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.33	<5	6.99	382	96	66	0.3	1.5	12	0.2	0	Satisfactory
357	2081/06/18	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.25	<5	6.96	365	92	66	0.3	1.5	10	0.2	0	Satisfactory
358	2081/06/18	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	6.68	39.6	12	12	0.1	0.02	6	2.09	0	Satisfactory
359	2081/06/18	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	6.73	39.4	12	12	0.1	0.02	6	2.23	0	Satisfactory
360	2081/06/18	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	6.89	39.4	12	12	0.1	0.02	6	1.89	0	Satisfactory
361	2081/06/18	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	6.92	39	12	12	0.1	0.02	6	1.91	0	Satisfactory
362	2081/06/18	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	6.84	34.2	12	12	0.1	0.02	6	1.87	0	Satisfactory
363	2081/06/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	6.96	34.1	12	12	0.1	0.02	6	1.36	0	Satisfactory
364	2081/06/18	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.6	<5	6.86	36.4	12	12	0.1	0.02	6	1.76	0	Satisfactory
365	2081/06/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.33	42.1	12	12	0.1	0.02	6	1.44	0	Satisfactory
366	2081/06/18	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.3	41.6	12	12	0.1	0.02	6	1.32	0	Satisfactory
367	2081/06/18	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	6.57	35.6	12	12	0.1	0.02	6	2.39	0	Satisfactory
368	2081/06/18	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.32	<5	6.87	38.3	12	12	0.1	0.02	6	1.72	0	Satisfactory
369	2081/06/19	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.23	<5	7.35	45.8	14	12	0.1	0.02	8	0.2	0	Satisfactory

370	2081/06/19	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.12	<5	7.37	72.7	24	22	0.1	0.02	6	1.65	0	Satisfactory
371	2081/06/19	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.50	<5	7.54	38	14	14	0.1	0.02	6	1.05	0	Satisfactory
372	2081/06/19	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	6.89	38.9	12	12	0.1	0.02	6	2.13	0	Satisfactory
373	2081/06/19	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	6.94	37.4	12	12	0.1	0.02	6	1.97	0	Satisfactory
374	2081/06/19	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.03	36.9	12	12	0.1	0.02	6	1.54	0	Satisfactory
375	2081/06/19	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.11	36.6	12	12	0.1	0.02	6	1.82	0	Satisfactory
376	2081/06/19	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.049	<5	7.19	35.7	12	12	0.1	0.02	6	2.09	0	Satisfactory
377	2081/06/19	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.14	35.1	12	12	0.1	0.02	6	1.56	0	Satisfactory
378	2081/06/19	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.051	<5	7.16	35.8	12	12	0.1	0.02	6	0.78	0	Satisfactory
379	2081/06/19	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	6.93	36.2	12	12	0.1	0.02	6	0.73	0	Satisfactory
380	2081/06/19	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.13	37.2	12	12	0.1	0.02	6	1.8	0	Satisfactory
381	2081/06/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.92	<5	7.96	395	100	124	0.1	0.02	10	0.76	0	Satisfactory
382	2081/06/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.09	40.3	12	12	0.1	0.02	8	0.2	0	Satisfactory
383	2081/06/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.76	96.2	28	12	0.1	0.02	8	2.37	0	Satisfactory
384	2081/06/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	6.51	43.2	8	22	0.1	0.02	6	0.1	0	Satisfactory
385	2081/06/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	8.42	84.5	34	22	0.1	0.02	6	1.79	0	Satisfactory
386	2081/06/20	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.06	<5	7.52	32	12	12	0.1	0.02	6	0.70	0	Satisfactory
387	2081/06/20	13:50	Maharajgunj	Bansbari WTP	Treated	Clear	1.35	<5	7.31	35	12	12	0.1	0.02	6	1.02	0	Satisfactory
388	2081/06/20	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.93	<5	7.28	33	12	12	0.1	0.02	6	1.03	0	Satisfactory
389	2081/06/20	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	7.02	373	94	66	0.3	1.5	10	0.2	0	Satisfactory
390	2081/06/20	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.32	<5	6.99	376	94	68	0.3	1.5	10	0.2	0	Satisfactory
391	2081/06/20	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.84	<5	6.99	377	94	68	0.3	1.5	10	0.2	0	Satisfactory
392	2081/06/20	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.1	36.9	12	12	0.1	0.02	6	2.3	0	Satisfactory
393	2081/06/20	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.03	35.2	12	12	0.1	0.02	6	1.99	0	Satisfactory
394	2081/06/20	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	6.97	34.9	12	12	0.1	0.02	6	1.83	0	Satisfactory
395	2081/06/20	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	6.93	34.2	12	12	0.1	0.02	6	2.34	0	Satisfactory
396	2081/06/20	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.09	<5	7.22	33.4	12	12	0.1	0.02	6	1.28	0	Satisfactory

397	2081/06/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.5	<5	7.34	37.5	12	12	0.1	0.02	6	0.72	0	Satisfactory
398	2081/06/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.26	<5	6.96	34.6	12	12	0.1	0.02	6	2.12	0	Satisfactory
399	2081/06/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.28	<5	6.62	35.9	12	12	0.1	0.02	6	1.6	0	Satisfactory
400	2081/06/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.22	<5	6.77	36.6	12	12	0.1	0.02	6	1.73	0	Satisfactory
401	2081/06/20	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.99	<5	6.62	36.7	12	12	0.1	0.02	6	1.65	0	Satisfactory
402	2081/06/20	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.81	<5	6.86	35.3	12	12	0.1	0.02	6	1.36	0	Satisfactory
403	2081/06/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	8.01	43.8	20	12	0.1	0.02	8	0.2	0	Satisfactory
404	2081/06/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.57	48.7	16	12	0.1	0.02	8	1.31	0	Satisfactory
405	2081/06/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.39	59	24	12	0.1	0.02	8	0.91	0	Satisfactory
406	2081/06/21	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.3	<5	7.58	59.1	26	12	0.1	0.02	8	0.15	0	Satisfactory
407	2081/06/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	4.8	<5	7.92	46.1	20	22	0.1	0.02	6	0.1	0	Satisfactory
408	2081/06/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.58	45.2	16	22	0.1	0.02	6	0.75	0	Satisfactory
409	2081/06/21	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.37	53.9	24	22	0.1	0.02	6	0.41	0	Satisfactory
410	2081/06/21	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.9	<5	7.58	59.2	26	22	0.1	0.02	6	0.84	0	Satisfactory
411	2081/06/21	13:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.13	81.1	22	24	0.1	0.02	6	1.48	0	Satisfactory
412	2081/06/21	11:50	Maharajgunj	Balaju SRT	Treated	Clear	1	<5	7.1	88.6	22	22	0.1	0.02	8	0.98	0	Satisfactory
413	2081/06/21	12:55	Lalitpur	Khumaltar SRT	Treated	Clear	2.1	<5	6.96	85	10	18	0.1	0.02	6	0.72	0	Satisfactory
414	2081/06/21	10:50	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.36	57	24	22	0.1	0.02	8	0.32	0	Satisfactory
415	2081/06/21	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.33	32	12	12	0.1	0.02	6	0.62	0	Satisfactory
416	2081/06/21	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.37	35	12	12	0.1	0.02	6	1.04	0	Satisfactory
417	2081/06/21	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.40	32	12	12	0.1	0.02	6	1.01	0	Satisfactory
418	2081/06/21	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.35	<5	7.06	375	94	66	0.3	1.5	10	0.2	0	Satisfactory
419	2081/06/21	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.44	<5	7.25	472	130	104	0.3	1.5	24	1.85	0	Satisfactory
420	2081/06/21	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.41	<5	7.16	431	120	80	0.3	1.5	20	1.08	0	Satisfactory
421	2081/06/21	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.63	<5	6.89	35.9	12	12	0.1	0.02	6	0.43	0	Satisfactory
422	2081/06/21	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.24	<5	6.93	36.4	12	12	0.1	0.02	6	0.1	0	Satisfactory
423	2081/06/21	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.11	35.4	12	12	0.1	0.02	6	0.1	0	Satisfactory

424	2081/06/21	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.2	33	12	12	0.1	0.02	6	0.1	0	Satisfactory
425	2081/06/21	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.42	<5	7.34	32.5	12	12	0.1	0.02	6	0.1	0	Satisfactory
426	2081/06/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.8	<5	7.1	36.6	12	12	0.1	0.02	6	0.96	0	Satisfactory
427	2081/06/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.18	<5	7.27	34.6	14	12	0.1	0.02	6	1.48	0	Satisfactory
428	2081/06/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.04	<5	7.29	35.7	14	12	0.1	0.02	6	0.1	0	Satisfactory
429	2081/06/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	7.26	35.4	14	12	0.1	0.02	6	0.1	0	Satisfactory
430	2081/06/21	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	6.94	34.9	12	12	0.1	0.02	6	0.1	0	Satisfactory
431	2081/06/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	6.96	36.2	12	12	0.1	0.02	6	0.45	0	Satisfactory
432	2081/06/22	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.6	<5	6.82	49.2	10	12	0.1	0.02	8	0.2	0	Satisfactory
433	2081/06/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	6.97	49.5	10	12	0.1	0.02	8	0.77	0	Satisfactory
434	2081/06/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.28	44.5	14	12	0.1	0.02	8	0.45	0	Satisfactory
435	2081/06/22	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.35	46.5	14	12	0.1	0.02	8	0.37	0	Satisfactory
436	2081/06/22	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	6.93	45.5	10	22	0.1	0.02	6	0.1	0	Satisfactory
437	2081/06/22	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.06	44.5	12	22	0.1	0.02	6	0.1	0	Satisfactory
438	2081/06/22	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.3	48.7	14	22	0.1	0.02	6	0.1	0	Satisfactory
439	2081/06/22	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.37	50.3	14	22	0.1	0.02	6	0.52	0	Satisfactory
440	2081/06/22	11:45	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	6.95	71.5	20	20	0.1	0.02	6	0.1	0	Satisfactory
441	2081/06/22	12:15	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.08	131.3	22	26	0.1	0.02	12	0.1	0	Satisfactory
442	2081/06/22	10:51	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.32	76.9	24	18	0.1	0.02	6	0.2	0	Satisfactory
443	2081/06/22	12:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.09	61.5	22	22	0.1	0.02	8	0.46	0	Satisfactory
444	2081/06/22	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.48	35	12	12	0.1	0.02	6	0.93	0	Satisfactory
445	2081/06/22	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.45	37	14	14	0.1	0.02	6	1.03	0	Satisfactory
446	2081/06/22	16:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.53	39	14	14	0.1	0.02	6	1.05	0	Satisfactory
447	2081/06/22	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.23	<5	7.01	380	94	68	0.3	1.5	14	0.25	0	Satisfactory
448	2081/06/22	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.17	<5	7.03	375	92	68	0.3	1.5	14	0.11	0	Satisfactory
449	2081/06/22	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	6.99	36.7	12	12	0.1	0.02	6	0.83	0	Satisfactory
450	2081/06/22	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.01	36.9	12	12	0.1	0.02	6	1.97	0	Satisfactory

451	2081/06/22	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.08	37.3	12	12	0.1	0.02	6	1.39	0	Satisfactory
452	2081/06/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.12	37.6	12	12	0.1	0.02	6	1.74	0	Satisfactory
453	2081/06/22	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.24	34.9	12	12	0.1	0.02	6	0.94	0	Satisfactory
454	2081/06/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.41	36.6	14	12	0.1	0.02	6	1.73	0	Satisfactory
455	2081/06/22	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.3	36.7	14	12	0.1	0.02	6	1.4	0	Satisfactory
456	2081/06/22	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.17	<5	7.68	38	14	12	0.1	0.02	6	2.84	0	Satisfactory
457	2081/06/22	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.57	41.3	14	12	0.1	0.02	6	1.72	0	Satisfactory
458	2081/06/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	7.78	44.1	14	12	0.1	0.02	6	0.25	0	Satisfactory
459	2081/06/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	8.18	117.7	18	20	0.1	0.02	6	1.41	0	Satisfactory
460	2081/06/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.89	52.4	28	12	0.1	0.02	8	0.47	0	Satisfactory
461	2081/06/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.2	<5	8.16	56.4	30	12	0.1	0.02	8	0.46	0	Satisfactory
462	2081/06/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.5	<5	7.89	53.2	28	12	0.1	0.02	8	0.33	0	Satisfactory
463	2081/06/23	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.83	49	28	12	0.1	0.02	8	0.25	0	Satisfactory
464	2081/06/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	8.5	140.5	36	22	0.1	0.02	6	0.22	0	Satisfactory
465	2081/06/23	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.69	164.8	28	22	0.1	0.02	6	0.69	0	Satisfactory
466	2081/06/23	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.76	152.9	28	22	0.1	0.02	6	0.76	0	Satisfactory
467	2081/06/23	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.5	<5	7.84	139	28	22	0.1	0.02	6	0.8	0	Satisfactory
468	2081/06/23	11:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.85	103.1	30	44	0.1	0.02	6	0.32	0	Satisfactory
469	2081/06/23	14:05	Maharajgunj	Balaju SRT	Treated	Clear	3.7	<5	8.29	191.7	34	34	0.1	0.02	12	0.1	0	Satisfactory
470	2081/06/23	12:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	8.35	101.2	34	18	0.1	0.02	6	0.2	0	Satisfactory
471	2081/06/23	13:10	Kirtipur	Kirtipur SRT	Treated	Clear	1.1	<5	8.1	120.3	32	22	0.1	0.02	6	0.45	0	Satisfactory
472	2081/06/23	11:50	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	8.15	155.5	32	28	0.1	0.02	22	0.3	0	Satisfactory
473	2081/06/23	14:25	Maharajgunj	Panipokhari SRT	Treated	Clear	1	<5	7.95	58.5	30	22	0.1	0.02	8	0.19	0	Satisfactory
474	2081/06/23	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.42	35	12	12	0.1	0.02	6	0.86	0	Satisfactory
475	2081/06/23	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.53	37	14	14	0.1	0.02	6	0.94	0	Satisfactory
476	2081/06/23	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.48	37	14	14	0.1	0.02	6	0.92	0	Satisfactory
477	2081/06/23	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	4.28	<5	7.3	429	124	80	0.3	1.5	22	1.55	0	Satisfactory

478	2081/06/23	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.86	<5	7.22	403	110	76	0.3	1.5	22	0.95	0	Satisfactory
479	2081/06/23	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	8.35	135.6	18	24	0.1	0.02	6	1.62	0	Satisfactory
480	2081/06/23	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	8.39	127.2	18	24	0.1	0.02	6	1.12	0	Satisfactory
481	2081/06/23	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	8.36	126.8	18	24	0.1	0.02	6	0.79	0	Satisfactory
482	2081/06/23	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	8.39	129.8	16	24	0.1	0.02	6	0.53	0	Satisfactory
483	2081/06/23	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	8.12	123	16	22	0.1	0.02	6	0.56	0	Satisfactory
484	2081/06/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	8.32	120.6	16	20	0.1	0.02	6	1.55	0	Satisfactory
485	2081/06/23	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	8.5	120.1	18	20	0.1	0.02	6	1.76	0	Satisfactory
486	2081/06/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	8.5	107.2	18	18	0.1	0.02	6	1.41	0	Satisfactory
487	2081/06/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	8.5	109.3	18	18	0.1	0.02	6	1.36	0	Satisfactory
488	2081/06/23	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	8.2	108.9	16	18	0.1	0.02	6	1.04	0	Satisfactory
489	2081/06/24	13:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.2	<5	7.46	50.9	26	12	0.1	0.02	8	0.92	0	Satisfactory
490	2081/06/24	15:15	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.76	170.3	28	22	0.1	0.02	6	0.26	0	Satisfactory
491	2081/06/24	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.54	38	14	14	0.1	0.02	6	1.04	0	Satisfactory
492	2081/06/24	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.79	<5	6.98	369	92	66	0.3	1.5	14	0.2	0	Satisfactory
493	2081/06/24	8:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.83	<5	7.82	157	48	40	0.1	0.02	10	0.23	0	Satisfactory
494	2081/06/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.46	<5	8.44	94.2	16	16	0.1	0.02	6	1.14	0	Satisfactory
495	2081/06/24	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	8.26	96.3	16	18	0.1	0.02	6	1.13	0	Satisfactory
496	2081/06/24	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	8.01	90.4	14	18	0.1	0.02	6	0.42	0	Satisfactory
497	2081/06/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	8.27	97	16	20	0.1	0.02	6	0.22	0	Satisfactory
498	2081/06/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.22	<5	7.53	67.5	14	12	0.1	0.02	6	1.02	0	Satisfactory
499	2081/06/24	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	7.61	62.8	14	12	0.1	0.02	6	0.63	0	Satisfactory
500	2081/06/25	11:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.1	52.1	22	12	0.1	0.02	8	0.4	0	Satisfactory
501	2081/06/25	11:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.1	90	22	22	0.1	0.02	6	0.68	0	Satisfactory
502	2081/06/25	9:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.3	<5	7.48	97.3	26	34	0.1	0.02	6	0.74	0	Satisfactory
503	2081/06/25	8:35	Maharajgunj	Balaju SRT	Treated	Clear	0.9	<5	7.5	100.5	26	26	0.1	0.02	12	0.89	0	Satisfactory
504	2081/06/25	7:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.2	<5	7.4	100.8	24	18	0.1	0.02	6	0.94	0	Satisfactory

505	2081/06/25	8:15	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.45	130.4	26	20	0.1	0.02	6	0.59	0	Satisfactory
506	2081/06/25	9:40	Baneshwor	Minbhawan SRT	Treated	Clear	1	<5	7.49	98.1	26	18	0.1	0.02	8	0.54	0	Satisfactory
507	2081/06/25	9:00	Maharajgunj	Panipokhari SRT	Treated	Clear	0.03	<5	7.5	55.9	26	22	0.1	0.02	8	0.18	0	Satisfactory
508	2081/06/25	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.52	35	12	12	0.1	0.02	6	0.92	0	Satisfactory
509	2081/06/25	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.59	52	14	12	0.1	0.02	6	1.15	0	Satisfactory
510	2081/06/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.65	51.2	14	12	0.1	0.02	6	0.54	0	Satisfactory
511	2081/06/25	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	7.4	51.1	14	12	0.1	0.02	6	0.71	0	Satisfactory
512	2081/06/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.25	<5	7.44	52.1	14	12	0.1	0.02	6	0.79	0	Satisfactory
513	2081/06/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.22	<5	7.51	52	14	12	0.1	0.02	6	0.92	0	Satisfactory
514	2081/06/25	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.35	52.2	14	12	0.1	0.02	6	0.69	0	Satisfactory
515	2081/06/26	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.54	35	12	12	0.1	0.02	6	0.86	0	Satisfactory
516	2081/06/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.64	53.1	14	12	0.1	0.02	6	1.2	0	Satisfactory
517	2081/06/26	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.52	53.5	14	12	0.1	0.02	6	0.84	0	Satisfactory
518	2081/06/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.27	<5	7.5	53.1	14	12	0.1	0.02	6	0.91	0	Satisfactory
519	2081/06/26	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.29	52.9	14	12	0.1	0.02	6	0.89	0	Satisfactory
520	2081/06/27	13:10	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.63	53	16	12	0.1	0.02	8	0.62	0	Satisfactory
521	2081/06/27	13:10	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.65	95.5	28	22	0.1	0.02	6	0.82	0	Satisfactory
522	2081/06/27	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.55	35	12	12	0.1	0.02	6	1.01	0	Satisfactory
523	2081/06/27	11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.56	<5	7.2	390	102	70	0.3	1.5	14	0.12	0	Satisfactory
524	2081/06/27	11:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.22	<5	7.4	86.3	26	32	0.1	0.02	4	0.38	0	Satisfactory
525	2081/06/27	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.8	51.9	16	12	0.1	0.02	6	0.49	0	Satisfactory
526	2081/06/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.68	52.8	14	12	0.1	0.02	6	0.88	0	Satisfactory
527	2081/06/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.67	51.1	14	12	0.1	0.02	6	0.92	0	Satisfactory
528	2081/06/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.49	52.5	14	12	0.1	0.02	6	1.03	0	Satisfactory
529	2081/06/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.28	<5	7.59	53.1	14	12	0.1	0.02	6	0.67	0	Satisfactory
530	2081/06/27	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.75	53.6	16	12	0.1	0.02	6	1.61	0	Satisfactory
531	2081/06/28	13:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.59	48.9	16	12	0.1	0.02	8	0.13	0	Satisfactory

532	2081/06/28	13:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.62	96.6	26	22	0.1	0.02	6	0.97	0	Satisfactory
533	2081/06/28	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.62	36	14	14	0.1	0.02	6	0.91	0	Satisfactory
534	2081/06/28	11:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.76	<5	7.25	426	122	80	0.3	1.5	22	1.82	0	Satisfactory
535	2081/06/28	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	6.95	87.2	24	32	0.1	0.02	4	0.16	0	Satisfactory
536	2081/06/28	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.71	53.9	16	12	0.1	0.02	6	1.93	0	Satisfactory
537	2081/06/28	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.79	50.3	16	12	0.1	0.02	6	2.04	0	Satisfactory
538	2081/06/28	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.77	51.8	14	12	0.1	0.02	6	1.03	0	Satisfactory
539	2081/06/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.8	52.6	14	12	0.1	0.02	6	0.69	0	Satisfactory
540	2081/06/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	8.13	51.2	16	12	0.1	0.02	6	0.31	0	Satisfactory
541	2081/06/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.78	52.1	14	12	0.1	0.02	6	1.24	0	Satisfactory
542	2081/06/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.61	53	14	12	0.1	0.02	6	1.18	0	Satisfactory
543	2081/06/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.88	53.5	16	12	0.1	0.02	6	0.91	0	Satisfactory
544	2081/06/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.51	52.7	14	12	0.1	0.02	6	0.74	0	Satisfactory
545	2081/06/28	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.63	52.6	14	12	0.1	0.02	6	1.67	0	Satisfactory
546	2081/06/29	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.12	370	98	120	0.1	0.02	10	0.57	0	Satisfactory
547	2081/06/29	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.74	51.1	18	12	0.1	0.02	8	0.57	0	Satisfactory
548	2081/06/29	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.59	57.8	26	12	0.1	0.02	8	1.42	0	Satisfactory
549	2081/06/29	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.42	58.3	24	12	0.1	0.02	8	1.34	0	Satisfactory
550	2081/06/29	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.45	80.7	26	12	0.1	0.02	8	2.21	0	Satisfactory
551	2081/06/29	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.47	91.4	26	22	0.1	0.02	6	0.62	0	Satisfactory
552	2081/06/29	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.48	88.2	26	22	0.1	0.02	6	0.79	0	Satisfactory
553	2081/06/29	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.35	88.9	24	22	0.1	0.02	6	0.82	0	Satisfactory
554	2081/06/29	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.44	83.2	24	22	0.1	0.02	6	1.08	0	Satisfactory
555	2081/06/29	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.47	91.5	16	32	0.1	0.02	6	0.51	0	Satisfactory
556	2081/06/29	13:25	Maharajgunj	Balaju SRT	Treated	Clear	0.2	<5	7.5	97.4	16	24	0.1	0.02	12	0.88	0	Satisfactory
557	2081/06/29	12:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.52	105.2	16	18	0.1	0.02	6	0.3	0	Satisfactory
558	2081/06/29	12:50	Kirtipur	Kirtipur SRT	Treated	Clear	0.2	<5	7.57	99.2	16	18	0.1	0.02	6	0.78	0	Satisfactory

559	2081/06/29	11:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.48	97.2	16	18	0.1	0.02	8	0.6	0	Satisfactory
560	2081/06/29	14:00	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.48	86.7	16	22	0.1	0.02	8	0.37	0	Satisfactory
561	2081/06/29	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.50	34	12	12	0.1	0.02	6	0.72	0	Satisfactory
562	2081/06/29	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.43	36	14	14	0.1	0.02	6	1.03	0	Satisfactory
563	2081/06/29	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.40	36	12	12	0.1	0.02	6	0.97	0	Satisfactory
564	2081/06/29	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.31	<5	7.16	423	118	80	0.3	1.5	20	0.84	0	Satisfactory
565	2081/06/29	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.16	<5	7.1	384	98	70	0.3	1.5	18	0.34	0	Satisfactory
566	2081/06/29	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.06	<5	7.2	87.1	26	32	0.1	0.02	4	0.47	0	Satisfactory
567	2081/06/29	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.71	52.5	14	12	0.1	0.02	6	1.53	0	Satisfactory
568	2081/06/29	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	7.73	52.4	14	12	0.1	0.02	6	0.91	0	Satisfactory
569	2081/06/29	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.22	<5	7.83	52.8	16	12	0.1	0.02	6	0.55	0	Satisfactory
570	2081/06/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.25	<5	7.97	52.2	16	12	0.1	0.02	6	0.69	0	Satisfactory
571	2081/06/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	8.06	52.2	14	12	0.1	0.02	6	0.68	0	Satisfactory
572	2081/06/29	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.95	53	14	12	0.1	0.02	6	0.93	0	Satisfactory
573	2081/06/29	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	7.88	53.3	14	12	0.1	0.02	6	0.86	0	Satisfactory
574	2081/06/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.74	54.2	14	12	0.1	0.02	6	1.03	0	Satisfactory
575	2081/06/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.55	53.2	14	12	0.1	0.02	6	0.7	0	Satisfactory
576	2081/06/29	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	7.7	53.7	14	12	0.1	0.02	6	1.02	0	Satisfactory
577	2081/06/29	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	7.54	54.2	14	12	0.1	0.02	6	1.94	0	Satisfactory
578	2081/06/30	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.56	<5	7.97	376	100	122	0.1	0.02	10	0.81	0	Satisfactory
579	2081/06/30	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.4	51.5	14	12	0.1	0.02	8	0.55	0	Satisfactory
580	2081/06/30	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.21	39.8	12	12	0.1	0.02	8	0.73	0	Satisfactory
581	2081/06/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.65	41.2	18	12	0.1	0.02	8	0.97	0	Satisfactory
582	2081/06/30	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.62	42.5	16	12	0.1	0.02	8	0.72	0	Satisfactory
583	2081/06/30	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.25	62.5	24	22	0.1	0.02	6	0.52	0	Satisfactory
584	2081/06/30	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.3	63.3	24	22	0.1	0.02	6	0.62	0	Satisfactory
585	2081/06/30	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.57	61.3	16	22	0.1	0.02	6	0.49	0	Satisfactory

586	2081/06/30	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.77	63.5	28	22	0.1	0.02	6	0.73	0	Satisfactory
587	2081/06/30	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.32	70.4	24	22	0.1	0.02	6	0.89	0	Satisfactory
588	2081/06/30	13:30	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.33	77.5	24	22	0.1	0.02	10	1.15	0	Satisfactory
589	2081/06/30	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.4	76.2	24	18	0.1	0.02	6	0.3	0	Satisfactory
590	2081/06/30	12:25	Kirtipur	Kirtipur SRT	Treated	Clear	0.4	<5	7.42	76.9	24	20	0.1	0.02	6	0.81	0	Satisfactory
591	2081/06/30	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.34	72.8	24	14	0.1	0.02	8	0.56	0	Satisfactory
592	2081/06/30	14:00	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.38	65.5	24	22	0.1	0.02	8	0.48	0	Satisfactory
593	2081/06/30	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.40	37	14	14	0.1	0.02	6	0.90	0	Satisfactory
594	2081/06/30	14:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.53	36	14	14	0.1	0.02	6	0.97	0	Satisfactory
595	2081/06/30	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.50	35	12	12	0.1	0.02	6	0.87	0	Satisfactory
596	2081/06/30	11:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.32	<5	6.98	357	90	66	0.3	1.5	12	0.2	0	Satisfactory
597	2081/06/30	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.59	<5	6.99	387	98	70	0.3	1.5	14	0.2	0	Satisfactory
598	2081/06/30	11:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.1	89.3	26	32	0.1	0.02	4	0.63	0	Satisfactory
599	2081/06/30	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.59	54.5	14	12	0.1	0.02	6	2.26	0	Satisfactory
600	2081/06/30	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.61	54.9	14	12	0.1	0.02	6	1.43	0	Satisfactory
601	2081/06/30	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	8.03	52.7	14	12	0.1	0.02	6	0.91	0	Satisfactory
602	2081/06/30	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	8.09	52.3	14	12	0.1	0.02	6	0.81	0	Satisfactory
603	2081/06/30	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.89	53.4	14	12	0.1	0.02	6	1.21	0	Satisfactory
604	2081/06/30	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.96	53.1	14	12	0.1	0.02	6	0.72	0	Satisfactory
605	2081/06/30	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.93	56.6	14	12	0.1	0.02	6	0.91	0	Satisfactory
606	2081/06/30	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.2	<5	7.98	54.8	14	12	0.1	0.02	6	1.1	0	Satisfactory
607	2081/06/30	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.73	<5	7.82	54.3	14	12	0.1	0.02	6	0.43	0	Satisfactory
608	2081/06/30	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.62	<5	7.91	54.8	14	12	0.1	0.02	6	0.81	0	Satisfactory
609	2081/06/30	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.64	<5	7.55	55.2	14	12	0.1	0.02	6	1.68	0	Satisfactory