



**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water / Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Kartik 2081**

S. N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	p <sup>H</sup>	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
							(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100ml	
<b>National Drinking Water Quality Standard (NDWQS)</b>							<b>5</b>	<b>5</b>	<b>6.5-8.5</b>	<b>1500</b>		<b>500</b>	<b>0.3 (3)</b>	<b>1.5</b>	<b>250</b>	<b>0.1-0.5</b>	<b>0 in 95% Samples</b>	
1	2081/07/01	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.74	<5	8.11	62	94	120	0.1	0.02	8	0.67	0	Satisfactory
2	2081/07/01	11:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.52	<5	7.65	54.2	16	18	0.1	0.02	6	1.46	0	Satisfactory
3	2081/07/01	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.59	<5	7.5	53.7	16	18	0.1	0.02	6	0.97	0	Satisfactory
4	2081/07/01	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.63	<5	7.72	53.5	16	18	0.1	0.02	6	0.63	0	Satisfactory
5	2081/07/01	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.75	<5	7.88	53.1	16	18	0.1	0.02	6	0.94	0	Satisfactory
6	2081/07/01	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.24	<5	8.05	52.8	16	18	0.1	0.02	6	0.75	0	Satisfactory
7	2081/07/01	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	7.92	53.1	16	18	0.1	0.02	6	1.3	0	Satisfactory
8	2081/07/01	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.48	<5	7.73	54.3	16	18	0.1	0.02	6	1.03	0	Satisfactory
9	2081/07/01	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.26	54.3	16	18	0.1	0.02	6	0.92	0	Satisfactory
10	2081/07/01	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.22	55.6	16	18	0.1	0.02	6	1.15	0	Satisfactory
11	2081/07/01	6:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.14	<5	7.11	54.4	16	18	0.1	0.02	6	0.67	0	Satisfactory
12	2081/07/01	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.89	<5	7.25	55.6	16	18	0.1	0.02	6	2.07	0	Satisfactory
13	2081/07/01	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.9	74.7	14	22	0.1	0.02	6	0.27	0	Satisfactory
14	2081/07/01	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	8.1	76.3	14	22	0.1	0.02	6	0.24	0	Satisfactory
15	2081/07/01	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	8.12	75.8	16	22	0.1	0.02	6	0.65	0	Satisfactory
16	2081/07/01	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	8.1	41.4	10	12	0.1	0.02	6	0.26	0	Satisfactory
17	2081/07/01	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.8	38.3	10	12	0.1	0.02	6	0.4	0	Satisfactory
18	2081/07/01	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	8.3	39.8	10	12	0.1	0.02	6	0.85	0	Satisfactory

19	2081/07/01	10:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.50	34	12	12	0.1	0.02	6	0.87	0	Satisfactory
20	2081/07/01	2:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.54	36	14	14	0.1	0.02	6	0.94	0	Satisfactory
21	2081/07/01	3:45 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.53	36	14	14	0.1	0.02	6	0.90	0	Satisfactory
22	2081/07/02	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	1.12	<5	7.98	369	94	122	0.1	0.02	10	0.78	0	Satisfactory
23	2081/07/02	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.86	<5	7.31	54.9	16	18	0.1	0.02	6	2.32	0	Satisfactory
24	2081/07/02	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.8	<5	7.52	54.5	16	18	0.1	0.02	6	1.22	0	Satisfactory
25	2081/07/02	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.73	<5	7.69	54.3	16	18	0.1	0.02	6	0.51	0	Satisfactory
26	2081/07/02	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.66	<5	7.83	53.9	16	18	0.1	0.02	6	0.64	0	Satisfactory
27	2081/07/02	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.54	<5	7.71	55.5	16	18	0.1	0.02	6	1.62	0	Satisfactory
28	2081/07/02	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.16	<5	7.81	56.1	16	18	0.1	0.02	6	1.44	0	Satisfactory
29	2081/07/02	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.27	<5	7.5	53.6	16	18	0.1	0.02	6	1.07	0	Satisfactory
30	2081/07/02	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.13	<5	7.76	54.4	16	18	0.1	0.02	6	1.17	0	Satisfactory
31	2081/07/02	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.36	54.8	16	18	0.1	0.02	6	0.91	0	Satisfactory
32	2081/07/02	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.37	54.9	16	18	0.1	0.02	6	2.04	0	Satisfactory
33	2081/07/02	11:45 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	1.2	<5	7.72	77.1	14	20	0.1	0.02	6	0.8	0	Satisfactory
34	2081/07/02	11:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.73	76.2	14	20	0.1	0.02	6	0.5	0	Satisfactory
35	2081/07/02	10:30 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	7.67	80.2	14	20	0.1	0.02	6	0.81	0	Satisfactory
36	2081/07/02	11:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1.3	<5	7.74	74.8	14	20	0.1	0.02	6	0.28	0	Satisfactory
37	2081/07/02	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.46	79	14	22	0.1	0.02	6	0.95	0	Satisfactory
38	2081/07/02	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.3	<5	7.74	77.8	14	22	0.1	0.02	6	0.61	0	Satisfactory
39	2081/07/02	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.68	76.2	14	22	0.1	0.02	6	0.76	0	Satisfactory
40	2081/07/02	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.8	48.3	10	12	0.1	0.02	6		0	Satisfactory
41	2081/07/02	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	7.78	46.1	12	12	0.1	0.02	6	0.89	0	Satisfactory
42	2081/07/02	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.7	<5	7.67	48.3	10	12	0.1	0.02	6	0.55	0	Satisfactory
43	2081/07/02		Madhyapur Thimi	Bode WTP	Treated	Clear	1.5	<5	7.34	329	126	64	0.3	1.5	14	0.18	0	Satisfactory
44	2081/07/02	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.54	36	14	14	0.1	0.02	6	1.04	0	Satisfactory
45	2081/07/02	1:55 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.48	34	12	12	0.1	0.02	6	0.97	0	Satisfactory

46	2081/07/03	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.4	54.3	16	18	0.1	0.02	6	0.96	0	Satisfactory
47	2081/07/03	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.59	53.7	16	18	0.1	0.02	6	0.55	0	Satisfactory
48	2081/07/03	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	7.73	53.1	16	18	0.1	0.02	6	0.51	0	Satisfactory
49	2081/07/03	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.4	<5	7.79	52.1	16	18	0.1	0.02	6	0.64	0	Satisfactory
50	2081/07/03	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.7	53.4	16	18	0.1	0.02	6	0.87	0	Satisfactory
51	2081/07/03	11:30 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.1	<5	7.76	54.1	16	18	0.1	0.02	6	1.04	0	Satisfactory
52	2081/07/03	1:30 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.02	<5	7.82	53.6	16	18	0.1	0.02	6	0.72	0	Satisfactory
53	2081/07/03	3:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.76	52.1	16	18	0.1	0.02	6	1.06	0	Satisfactory
54	2081/07/03	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.54	<5	7.46	51.2	16	18	0.1	0.02	6	1.73	0	Satisfactory
55	2081/07/03	11:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.38	73.7	18	22	0.1	0.02	6	0.65	0	Satisfactory
56	2081/07/03	11:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.36	45.3	14	12	0.1	0.02	6	0.82	0	Satisfactory
57	2081/07/03	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.7	<5	7.01	393	102	70	0.3	1.5	14	0.4	0	Satisfactory
58	2081/07/03	12:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.74	<5	7.45	87.4	26	36	0.1	0.02	4	1.11	0	Satisfactory
59	2081/07/03	10:25 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.54	37	14	14	0.1	0.02	6	0.97	0	Satisfactory
60	2081/07/04	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.37	<5	7.97	372	98	122	0.1	0.02	10	0.63	0	Satisfactory
61	2081/07/04	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.59	<5	7.48	51.8	16	18	0.1	0.02	6	1.29	0	Satisfactory
62	2081/07/04	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	7.42	53.7	16	18	0.1	0.02	6	0.98	0	Satisfactory
63	2081/07/04	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.73	<5	7.59	50.9	16	18	0.1	0.02	6	0.83	0	Satisfactory
64	2081/07/04	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.92	<5	7.64	50.5	16	18	0.1	0.02	6	1.18	0	Satisfactory
65	2081/07/04	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.62	50.8	16	18	0.1	0.02	6	0.94	0	Satisfactory
66	2081/07/04	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.66	51.1	16	18	0.1	0.02	6	0.88	0	Satisfactory
67	2081/07/04	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.51	51.9	16	18	0.1	0.02	6	1.23	0	Satisfactory
68	2081/07/04	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	<5	7.5	51.7	16	18	0.1	0.02	6	1.12	0	Satisfactory
69	2081/07/04	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.21	52.1	16	18	0.1	0.02	6	1.31	0	Satisfactory
70	2081/07/04	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.47	51.5	16	18	0.1	0.02	6	0.76	0	Satisfactory
71	2081/07/04	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.14	<5	7.27	51.6	16	18	0.1	0.02	6	1.94	0	Satisfactory
72	2081/07/04	11:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.9	<5	7.89	70.9	18	20	0.1	0.02	6	0.86	0	Satisfactory

73	2081/07/04	1:50 AM	Maharajgunj	Balaju SRT	Treated	Clear	1	<5	7.79	69.2	18	22	0.1	0.02	6	0.2	0	Satisfactory
74	2081/07/04	11:40 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.92	72.3	18	20	0.1	0.02	6	0.41	0	Satisfactory
75	2081/07/04	1:15 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	7.92	76.5	18	20	0.1	0.02	6	0.68	0	Satisfactory
76	2081/07/04	11:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1	<5	7.95	70.5	18	20	0.1	0.02	6	0.35	0	Satisfactory
77	2081/07/04	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	1.8	<5	7.76	51.9	18	20	0.1	0.02	6	0.58	0	Satisfactory
78	2081/07/04	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.7	<5	7.75	71.5	14	22	0.1	0.02	6	0.5	0	Satisfactory
79	2081/07/04	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.1	<5	7.93	64.4	20	22	0.1	0.02	6	1.1	0	Satisfactory
80	2081/07/04	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.93	63.5	18	22	0.1	0.02	6	0.74	0	Satisfactory
81	2081/07/04	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.69	65.3	18	22	0.1	0.02	6	0.77	0	Satisfactory
82	2081/07/04	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.7	<5	7.86	44.9	12	12	0.1	0.02	6	0.76	0	Satisfactory
83	2081/07/04	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	8	44.7	16	12	0.1	0.02	6	1.05	0	Satisfactory
84	2081/07/04	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	8.1	49.2	18	12	0.1	0.02	6	0.68	0	Satisfactory
85	2081/07/04	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.78	46.2	14	12	0.1	0.02	6	0.88	0	Satisfactory
86	2081/07/04	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.7	<5	7.08	397	104	70	0.3	1.5	18	0.92	0	Satisfactory
87	2081/07/04	1:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.77	<5	7.08	406	108	68	0.3	1.5	14	0.38	0	Satisfactory
88	2081/07/04	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.64	33	12	12	0.1	0.02	6	0.91	0	Satisfactory
89	2081/07/04	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	35	14	14	0.1	0.02	6	1.02	0	Satisfactory
90	2081/07/04	3:55 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	36	14	14	0.1	0.02	6	1.05	0	Satisfactory
91	2081/07/05	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.42	<5	7.98	374	100	124	0.1	0.02	10	0.74	0	Satisfactory
92	2081/07/05	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.29	51.9	16	18	0.1	0.02	6	1.34	0	Satisfactory
93	2081/07/05	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.19	<5	7.4	50.3	16	18	0.1	0.02	6	0.88	0	Satisfactory
94	2081/07/05	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	7.63	50.6	16	18	0.1	0.02	6	0.62	0	Satisfactory
95	2081/07/05	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.22	<5	7.73	50.7	16	18	0.1	0.02	6	0.75	0	Satisfactory
96	2081/07/05	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.71	52	16	18	0.1	0.02	6	0.77	0	Satisfactory
97	2081/07/05	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.32	<5	7.57	53.7	16	18	0.1	0.02	6	1.89	0	Satisfactory
98	2081/07/05	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.47	52.9	16	18	0.1	0.02	6	1.49	0	Satisfactory
99	2081/07/05	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.41	52.6	16	18	0.1	0.02	6	1.6	0	Satisfactory

##	2081/07/05	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.41	51.4	16	18	0.1	0.02	6	0.82	0	Satisfactory
##	2081/07/05	6:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	6.98	52.3	16	18	0.1	0.02	6	1.32	0	Satisfactory
##	2081/07/05	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.16	52.8	16	18	0.1	0.02	6	2.05	0	Satisfactory
##	2081/07/05	12:20 PM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.9	<5	7.82	74.7	18	20	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/05	2:05 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.9	<5	7.78	71.7	18	22	0.1	0.02	6	0.21	0	Satisfactory
##	2081/07/05	1:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.9	<5	7.78	73.7	18	20	0.1	0.02	6	0.59	0	Satisfactory
##	2081/07/05	1:30 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.4	<5	7.85	76.5	18	20	0.1	0.02	6	0.68	0	Satisfactory
##	2081/07/05	12:30 PM	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.85	71.5	18	20	0.1	0.02	6	0.83	0	Satisfactory
##	2081/07/05	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.81	69.8	18	20	0.1	0.02	6	0.56	0	Satisfactory
##	2081/07/05	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	8.1	37.3	20	22	0.1	0.02	6	0.2	0	Satisfactory
##	2081/07/05	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.95	38.2	18	22	0.1	0.02	6	0.2	0	Satisfactory
##	2081/07/05	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.67	70.8	18	22	0.1	0.02	6	1.56	0	Satisfactory
##	2081/07/05	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.75	70.6	18	22	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/05	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	8	50.3	16	12	0.1	0.02	6	0.45	0	Satisfactory
##	2081/07/05	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.87	47.8	14	12	0.1	0.02	6	0.68	0	Satisfactory
##	2081/07/05	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.8	51.7	16	12	0.1	0.02	6	0.49	0	Satisfactory
##	2081/07/05	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.86	51.6	14	12	0.1	0.02	6	0.57	0	Satisfactory
##	2081/07/05	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.52	<5	7.35	449	126	84	0.3	1.5	22	1.23	0	Satisfactory
##	2081/07/05	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.4	<5	7.3	434	124	82	0.3	1.5	20	1.06	0	Satisfactory
##	2081/07/05	10:45 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.4	84.8	26	36	0.1	0.02	4	0.28	0	Satisfactory
##	2081/07/05	10:40 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.82	41	16	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/05	10:58 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.70	42	16	16	0.1	0.02	6	1.28	0	Satisfactory
##	2081/07/05	2:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.52	39	16	16	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/05	4:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.54	37	14	14	0.1	0.02	6	1.03	0	Satisfactory
##	2081/07/06	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.92	376	100	124	0.1	0.02	10	0.2	0	Satisfactory
##	2081/07/06	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.14	52.4	16	18	0.1	0.02	6	2.19	0	Satisfactory
##	2081/07/06	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.22	52.8	16	18	0.1	0.02	6	1.36	0	Satisfactory

##	2081/07/06	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.49	51.2	16	18	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/06	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.47	<5	7.61	50.9	16	18	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/06	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.6	51.8	16	18	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/06	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.48	53.4	16	18	0.1	0.02	6	1.38	0	Satisfactory
##	2081/07/06	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.42	52.1	16	18	0.1	0.02	6	0.99	0	Satisfactory
##	2081/07/06	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.4	52.1	16	18	0.1	0.02	6	1.46	0	Satisfactory
##	2081/07/06	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.54	51.2	16	18	0.1	0.02	6	0.83	0	Satisfactory
##	2081/07/06	6:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.48	51.5	16	18	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/06	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.43	<5	7.14	52.2	16	18	0.1	0.02	6	2.37	0	Satisfactory
##	2081/07/06	11:30 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.51	72.6	18	20	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/06	1:00 AM	Maharajgunj	Balaju SRT	Treated	Clear	1.3	<5	7.67	73	18	22	0.1	0.02	6	0.41	0	Satisfactory
##	2081/07/06	2:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.7	<5	7.33	78.4	18	20	0.1	0.02	6	0.65	0	Satisfactory
##	2081/07/06	11:45 AM	Baneshwor	Minbhawan SRT	Treated	Clear	1.2	<5	7.25	73.6	18	20	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/06	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.33	73.1	18	20	0.1	0.02	6	0.66	0	Satisfactory
##	2081/07/06	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.5	66.2	18	22	0.1	0.02	6	0.77	0	Satisfactory
##	2081/07/06	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	7.62	66.7	18	22	0.1	0.02	6	0.72	0	Satisfactory
##	2081/07/06	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.33	74.6	18	22	0.1	0.02	6	0.9	0	Satisfactory
##	2081/07/06	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.2	73.2	18	22	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/06	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.4	<5	7.4	50.5	14	12	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/06	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.9	<5	7.62	53.7	16	12	0.1	0.02	6	0.79	0	Satisfactory
##	2081/07/06	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.5	<5	7.48	48.4	12	12	0.1	0.02	6	0.99	0	Satisfactory
##	2081/07/06	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.2	<5	7.51	49	14	12	0.1	0.02	6	1.12	0	Satisfactory
##	2081/07/06	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.57	<5	7.22	419	118	80	0.3	1.5	20	0.99	0	Satisfactory
##	2081/07/06	1:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.13	<5	7.03	399	102	76	0.3	1.5	20	0.82	0	Satisfactory
##	2081/07/06	3:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.1	<5	7.14	402	102	76	0.3	1.5	18	0.71	0	Satisfactory
##	2081/07/06	3:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.02	<5	7.4	84.6	26	36	0.1	0.02	4	1.36	0	Satisfactory
##	2081/07/06	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.47	36	12	12	0.1	0.02	6	1.02	0	Satisfactory

##	2081/07/06	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.51	35	12	12	0.1	0.02	6	0.90	0	Satisfactory
##	2081/07/06	4:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.48	35	12	12	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/07	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.99	<5	7.91	379	100	126	0.1	0.02	10	0.71	0	Satisfactory
##	2081/07/07	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.39	<5	7.11	52.5	16	18	0.1	0.02	6	2.61	0	Satisfactory
##	2081/07/07	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.11	<5	7.18	52.3	16	18	0.1	0.02	6	1.37	0	Satisfactory
##	2081/07/07	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.39	<5	7.55	50.3	16	18	0.1	0.02	6	0.64	0	Satisfactory
##	2081/07/07	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.72	<5	7.7	50.5	16	18	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/07	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.49	<5	7.41	51.7	16	18	0.1	0.02	6	1.12	0	Satisfactory
##	2081/07/07	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.41	<5	7.46	52.5	16	18	0.1	0.02	6	1.72	0	Satisfactory
##	2081/07/07	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.51	50.9	16	18	0.1	0.02	6	1.48	0	Satisfactory
##	2081/07/07	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.43	52.3	16	18	0.1	0.02	6	1.45	0	Satisfactory
##	2081/07/07	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.43	52.7	16	18	0.1	0.02	6	1.07	0	Satisfactory
##	2081/07/07	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.44	53.6	16	18	0.1	0.02	6	1.11	0	Satisfactory
##	2081/07/07	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.11	54	16	18	0.1	0.02	6	2.18	0	Satisfactory
##	2081/07/07	11:00 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.24	76	20	20	0.1	0.02	6	0.9	0	Satisfactory
##	2081/07/07	1:00 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.1	74.2	20	22	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/07	12:20 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.9	<5	7.39	77.7	20	20	0.1	0.02	6	0.46	0	Satisfactory
##	2081/07/07	1:15 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.4	79.6	20	20	0.1	0.02	6	1.25	0	Satisfactory
##	2081/07/07	11:15 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.44	73.9	20	20	0.1	0.02	6	0.38	0	Satisfactory
##	2081/07/07	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.24	75.7	20	20	0.1	0.02	6	0.76	0	Satisfactory
##	2081/07/07	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.3	71.1	18	22	0.1	0.02	6	0.83	0	Satisfactory
##	2081/07/07	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.4	72.3	18	22	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/07	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.33	67.5	18	22	0.1	0.02	6	1.1	0	Satisfactory
##	2081/07/07	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.31	66.9	20	22	0.1	0.02	6	0.96	0	Satisfactory
##	2081/07/07	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.41	47.4	14	12	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/07	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.5	43.7	16	12	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/07	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.38	45.8	14	12	0.1	0.02	6	1.33	0	Satisfactory

##	2081/07/07	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.48	42.7	14	12	0.1	0.02	6	1.09	0	Satisfactory
##	2081/07/07	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.18	<5	7.1	385	100	70	0.3	1.5	14	0.31	0	Satisfactory
##	2081/07/07	3:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.7	<5	7.12	420	114	82	0.3	1.5	20	1.84	0	Satisfactory
##	2081/07/07	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.91	<5	7.52	82.5	28	36	0.1	0.02	4	0.25	0	Satisfactory
##	2081/07/07	10:40 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.47	36	14	14	0.1	0.02	6	0.96	0	Satisfactory
##	2081/07/07	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.55	38	14	14	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/07	4:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.54	37	14	14	0.1	0.02	6	1.01	0	Satisfactory
##	2081/07/08	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	7.98	371	98	122	0.1	0.02	10	0.64	0	Satisfactory
##	2081/07/08	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.09	53.3	16	18	0.1	0.02	6	2.31	0	Satisfactory
##	2081/07/08	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.13	52.8	16	18	0.1	0.02	6	1.29	0	Satisfactory
##	2081/07/08	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.5	51.3	16	18	0.1	0.02	6	0.79	0	Satisfactory
##	2081/07/08	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.43	<5	7.56	50.7	16	18	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/08	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.46	52	16	18	0.1	0.02	6	1.28	0	Satisfactory
##	2081/07/08	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.53	51.7	16	18	0.1	0.02	6	0.34	0	Satisfactory
##	2081/07/08	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.56	52	16	18	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/08	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.52	<5	7.5	58.6	16	18	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/08	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.24	<5	7.53	56.1	16	18	0.1	0.02	6	1.06	0	Satisfactory
##	2081/07/08	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.5	55.3	16	18	0.1	0.02	6	1.01	0	Satisfactory
##	2081/07/08	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.44	<5	7.5	55.6	16	18	0.1	0.02	6	1.94	0	Satisfactory
##	2081/07/08	1:15 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.9	<5	7.57	83.1	22	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/08	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.61	68.7	22	20	0.1	0.02	6	1.01	0	Satisfactory
##	2081/07/08	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.47	68.8	20	22	0.1	0.02	6	0.82	0	Satisfactory
##	2081/07/08	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.8	<5	7.35	70.5	20	22	0.1	0.02	6	0.82	0	Satisfactory
##	2081/07/08	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.56	72.2	22	22	0.1	0.02	6	0.56	0	Satisfactory
##	2081/07/08	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.56	73.4	20	22	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/08	2:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.31	77.6	22	22	0.1	0.02	6	1.16	0	Satisfactory
##	2081/07/08	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.58	43.7	14	12	0.1	0.02	6	0.47	0	Satisfactory



##	2081/07/08	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.9	<5	7.6	45.3	14	12	0.1	0.02	6	0.52	0	Satisfactory
##	2081/07/08	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	7.64	44.3	14	12	0.1	0.02	6	0.84	0	Satisfactory
##	2081/07/08	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.6	<5	7.63	44.5	14	12	0.1	0.02	6	0.7	0	Satisfactory
##	2081/07/08	12:55 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.5	80.9	18	12	0.1	0.02	6	0.77	0	Satisfactory
##	2081/07/08	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.06	<5	6.94	394	100	70	0.3	1.5	14	0.36	0	Satisfactory
##	2081/07/08	3:45 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.51	<5	7.06	427	114	80	0.3	1.5	20	0.76	0	Satisfactory
##	2081/07/08	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.98	<5	7.25	85.1	26	36	0.1	0.02	4	0.46	0	Satisfactory
##	2081/07/08	10:25 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	37	14	14	0.1	0.02	6	1.03	0	Satisfactory
##	2081/07/08	2:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.53	36	14	14	0.1	0.02	6	0.90	0	Satisfactory
##	2081/07/08	4:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.51	36	14	14	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/09	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.64	<5	7.94	371	98	124	0.1	0.02	10	0.86	0	Satisfactory
##	2081/07/09	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.32	<5	7.49	51.8	16	18	0.1	0.02	6	2.17	0	Satisfactory
##	2081/07/09	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	7.57	52.8	16	18	0.1	0.02	6	1.63	0	Satisfactory
##	2081/07/09	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.14	<5	7.71	52.9	16	18	0.1	0.02	6	0.52	0	Satisfactory
##	2081/07/09	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.84	52.6	16	18	0.1	0.02	6	0.34	0	Satisfactory
##	2081/07/09	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.8	51.8	16	18	0.1	0.02	6	1.04	0	Satisfactory
##	2081/07/09	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.79	52.6	16	18	0.1	0.02	6	1.66	0	Satisfactory
##	2081/07/09	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.52	51.4	16	18	0.1	0.02	6	0.66	0	Satisfactory
##	2081/07/09	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.73	54.1	16	18	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/09	3:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.4	54.4	16	18	0.1	0.02	6	0.9	0	Satisfactory
##	2081/07/09	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.57	52.1	16	18	0.1	0.02	6	0.84	0	Satisfactory
##	2081/07/09	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.46	<5	7.47	53.9	16	18	0.1	0.02	6	1.57	0	Satisfactory
##	2081/07/09	11:15 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.64	53.6	20	20	0.1	0.02	6	1.25	0	Satisfactory
##	2081/07/09	12:55 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	7.62	54	20	20	0.1	0.02	6	0.64	0	Satisfactory
##	2081/07/09	12:30 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.64	54.9	20	20	0.1	0.02	6	0.72	0	Satisfactory
##	2081/07/09	11:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.77	64.6	20	20	0.1	0.02	6	0.45	0	Satisfactory
##	2081/07/09	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.23	47.2	18	22	0.1	0.02	6	0.65	0	Satisfactory

##	2081/07/09	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.51	50.1	18	22	0.1	0.02	6	1.44	0	Satisfactory
##	2081/07/09	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.7	52.6	20	22	0.1	0.02	6	1.17	0	Satisfactory
##	2081/07/09	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.25	30.5	12	12	0.1	0.02	6	0.73	0	Satisfactory
##	2081/07/09	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.56	29.2	10	12	0.1	0.02	6	0.79	0	Satisfactory
##	2081/07/09	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.83	29.9	16	12	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/09	10:45 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.02	<5	7.1	436	120	86	0.3	1.5	22	1.35	0	Satisfactory
##	2081/07/09	2:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.91	<5	7.02	400	102	76	0.3	1.5	20	0.8	0	Satisfactory
##	2081/07/09	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.06	<5	7.2	87.4	28	36	0.1	0.02	4	0.23	0	Satisfactory
##	2081/07/09	10:45 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.55	37	14	14	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/09	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.67	38	14	14	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/10	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.39	<5	7.52	53.3	16	18	0.1	0.02	6	2.03	0	Satisfactory
##	2081/07/10	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.43	<5	7.5	52.8	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/10	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.19	<5	7.73	51.3	16	18	0.1	0.02	6	0.37	0	Satisfactory
##	2081/07/10	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.07	<5	7.88	50.9	16	18	0.1	0.02	6	0.41	0	Satisfactory
##	2081/07/10	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.81	52.4	16	18	0.1	0.02	6	0.99	0	Satisfactory
##	2081/07/10	11:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.84	50.8	16	18	0.1	0.02	6	0.59	0	Satisfactory
##	2081/07/10	1:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.8	52.6	16	18	0.1	0.02	6	1.45	0	Satisfactory
##	2081/07/10	3:30 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.71	53	16	18	0.1	0.02	6	1.67	0	Satisfactory
##	2081/07/10	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	7.55	53	16	18	0.1	0.02	6	1.67	0	Satisfactory
##	2081/07/10	7:45 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	7.27	53.8	22	20	0.1	0.02	6	1.81	0	Satisfactory
##	2081/07/10	8:30 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.51	53.7	22	22	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/10	9:35 AM	Lalitpur	Khumaltar SRT	Treated	Clear	1.39	<5	7.23	52.4	22	20	0.1	0.02	6	1.39	0	Satisfactory
##	2081/07/10	9:10 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.42	56.2	22	20	0.1	0.02	6	0.96	0	Satisfactory
##	2081/07/10	7:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.36	52.8	22	20	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/10	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.37	53.3	22	20	0.1	0.02	6	0.85	0	Satisfactory
##	2081/07/10	11:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.24	51.3	20	22	0.1	0.02	6	1.68	0	Satisfactory
##	2081/07/10	11:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.22	53.3	16	12	0.1	0.02	6	0.96	0	Satisfactory

##	2081/07/10	5:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.29	<5	7.02	404	104	70	0.3	1.5	20	0.95	0	Satisfactory
##	2081/07/10	5:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.14	<5	7.41	83.9	28	36	0.1	0.02	4	1.16	0	Satisfactory
##	2081/07/10	11:15 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	36	14	14	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/11	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	8.01	369	96	124	0.1	0.02	10	0.94	0	Satisfactory
##	2081/07/11	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.24	<5	7.59	53.8	16	18	0.1	0.02	6	1.98	0	Satisfactory
##	2081/07/11	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.53	52.5	16	18	0.1	0.02	6	1.12	0	Satisfactory
##	2081/07/11	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.29	<5	7.72	51.6	16	18	0.1	0.02	6	0.27	0	Satisfactory
##	2081/07/11	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.85	<5	7.88	51.8	16	18	0.1	0.02	6	0.32	0	Satisfactory
##	2081/07/11	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	7.75	52.9	16	18	0.1	0.02	6	1.06	0	Satisfactory
##	2081/07/11	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.02	<5	7.74	53.1	16	18	0.1	0.02	6	1.61	0	Satisfactory
##	2081/07/11	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.7	51.9	16	18	0.1	0.02	6	1.59	0	Satisfactory
##	2081/07/11	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1	<5	7.62	52.9	16	18	0.1	0.02	6	1.67	0	Satisfactory
##	2081/07/11	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.45	51.9	16	18	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/11	6:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.23	52.6	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/11	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.9	<5	7.41	52.7	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/11	11:05 AM	Tripreushwar	Anamnagar SRT	Treated	Clear	0.9	<5	7.82	80	22	20	0.1	0.02	6	0.65	0	Satisfactory
##	2081/07/11	12:05 PM	Lalitpur	Khumaltar SRT	Treated	Clear	1.1	<5	8.53	87.3	26	20	0.1	0.02	6	0.49	0	Satisfactory
##	2081/07/11	12:40 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	7.74	84.1	20	20	0.1	0.02	6	0.39	0	Satisfactory
##	2081/07/11	11:20 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.7	81.5	22	20	0.1	0.02	6	0.35	0	Satisfactory
##	2081/07/11	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.9	75.5	22	20	0.1	0.02	6	0.47	0	Satisfactory
##	2081/07/11	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.24	77.1	20	22	0.1	0.02	6	1.12	0	Satisfactory
##	2081/07/11	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.69	76.7	22	22	0.1	0.02	6	1.2	0	Satisfactory
##	2081/07/11	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	7.94	78.2	24	22	0.1	0.02	6	0.58	0	Satisfactory
##	2081/07/11	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.45	76.2	20	22	0.1	0.02	6	1	0	Satisfactory
##	2081/07/11	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.3	39.6	14	12	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/11	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.9	48.2	12	12	0.1	0.02	6	0.42	0	Satisfactory
##	2081/07/11	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.99	48.47	14	12	0.1	0.02	6	0.42	0	Satisfactory

##	2081/07/11	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.66	43.8	16	12	0.1	0.02	6	0.25	0	Satisfactory
##	2081/07/11	10:15 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.99	<5	6.9	370	90	66	0.3	1.5	10	0.2	0	Satisfactory
##	2081/07/11	12:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.6	<5	6.94	362	90	66	0.3	1.5	10	0.2	0	Satisfactory
##	2081/07/11	4:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.05	<5	6.91	355	90	64	0.3	1.5	10	0.2	0	Satisfactory
##	2081/07/11	4:30 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.19	<5	7.2	80.9	24	36	0.1	0.02	4	0.87	0	Satisfactory
##	2081/07/11	10:40 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	37	14	14	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/11	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	38	14	14	0.1	0.02	6	1.02	0	Satisfactory
##	2081/07/11	3:55 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	37	14	14	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/12	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	1.04	<5	7.87	367	94	120	0.1	0.02	8	0.69	0	Satisfactory
##	2081/07/12	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.51	52.3	16	18	0.1	0.02	6	1.93	0	Satisfactory
##	2081/07/12	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.55	52	16	18	0.1	0.02	6	0.98	0	Satisfactory
##	2081/07/12	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.77	51.7	16	18	0.1	0.02	6	0.24	0	Satisfactory
##	2081/07/12	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.8	51.6	16	18	0.1	0.02	6	0.39	0	Satisfactory
##	2081/07/12	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.86	51.4	16	18	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/12	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	7.62	54.5	16	18	0.1	0.02	6	1.31	0	Satisfactory
##	2081/07/12	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.38	<5	7.65	52.2	16	18	0.1	0.02	6	0.98	0	Satisfactory
##	2081/07/12	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.46	52.8	16	18	0.1	0.02	6	1.5	0	Satisfactory
##	2081/07/12	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.65	51.4	16	18	0.1	0.02	6	1.34	0	Satisfactory
##	2081/07/12	6:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.51	52.5	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/12	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.49	52.9	16	18	0.1	0.02	6	1.58	0	Satisfactory
##	2081/07/12	11:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.27	107.4	26	20	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/12	12:20 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	8.02	116.2	26	20	0.1	0.02	6	0.82	0	Satisfactory
##	2081/07/12	12:55 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.33	111.1	22	20	0.1	0.02	6	0.77	0	Satisfactory
##	2081/07/12	11:40 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.23	105.1	22	20	0.1	0.02	6	0.46	0	Satisfactory
##	2081/07/12	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.22	99.7	24	20	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/12	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.58	81.7	24	22	0.1	0.02	6	0.68	0	Satisfactory
##	2081/07/12	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	7.43	99.7	26	22	0.1	0.02	6	1.5	0	Satisfactory

##	2081/07/12	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.47	104.3	26	22	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/12	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.3	106.1	24	22	0.1	0.02	6	1.58	0	Satisfactory
##	2081/07/12	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.48	49.9	16	12	0.1	0.02	6	0.81	0	Satisfactory
##	2081/07/12	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.4	<5	7.65	65.9	18	12	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/12	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.58	66.9	18	12	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/12	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.31	112.4	22	12	0.1	0.02	6	2	0	Satisfactory
##	2081/07/12	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.04	<5	7.05	439	120	84	0.3	1.5	22	2.6	0	Satisfactory
##	2081/07/12	4:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.11	<5	7.02	392	100	74	0.3	1.5	10	0.29	0	Satisfactory
##	2081/07/12	4:40 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.06	<5	7.26	85.2	24	36	0.1	0.02	4	1.14	0	Satisfactory
##	2081/07/12	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	37	14	14	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/12	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.60	39	14	14	0.1	0.02	6	1.01	0	Satisfactory
##	2081/07/12	3:55 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	41	14	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/13	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.63	<5	8.07	379	100	126	0.1	0.02	10	0.82	0	Satisfactory
##	2081/07/13	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.5	52.7	16	18	0.1	0.02	6	2.03	0	Satisfactory
##	2081/07/13	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.57	52.3	16	18	0.1	0.02	6	1.33	0	Satisfactory
##	2081/07/13	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.39	<5	7.8	51.8	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/13	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.97	<5	7.84	51.6	16	18	0.1	0.02	6	0.37	0	Satisfactory
##	2081/07/13	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.62	53.3	16	18	0.1	0.02	6	1.5	0	Satisfactory
##	2081/07/13	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.09	<5	7.72	52.6	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/13	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.56	52	16	18	0.1	0.02	6	1.32	0	Satisfactory
##	2081/07/13	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.72	53.6	16	18	0.1	0.02	6	1.35	0	Satisfactory
##	2081/07/13	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.5	51.6	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/13	6:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.43	52.8	16	18	0.1	0.02	6	1.34	0	Satisfactory
##	2081/07/13	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.37	53.4	16	18	0.1	0.02	6	1.89	0	Satisfactory
##	2081/07/13	1:40 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.36	104.4	26	20	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/13	9:45 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.2	111.1	26	20	0.1	0.02	6	0.78	0	Satisfactory
##	2081/07/13	10:15 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.53	101.5	24	20	0.1	0.02	6	0.85	0	Satisfactory

##	2081/07/13	1:55 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.65	103	26	20	0.1	0.02	6	0.33	0	Satisfactory
##	2081/07/13	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.62	107.9	24	20	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/13	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.25	102.9	24	22	0.1	0.02	6	1.28	0	Satisfactory
##	2081/07/13	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.39	102.8	24	22	0.1	0.02	6	0.57	0	Satisfactory
##	2081/07/13	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.52	100.7	26	22	0.1	0.02	6	0.59	0	Satisfactory
##	2081/07/13	3:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.3	105.6	24	22	0.1	0.02	6	1.31	0	Satisfactory
##	2081/07/13	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.2	62.5	20	12	0.1	0.02	6	0.42	0	Satisfactory
##	2081/07/13	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.64	61.5	18	12	0.1	0.02	6	0.19	0	Satisfactory
##	2081/07/13	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.4	63.5	18	12	0.1	0.02	6	0.24	0	Satisfactory
##	2081/07/13	3:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.59	63	18	12	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/13	10:45 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.42	<5	7.05	408	104	74	0.3	1.5	18	0.76	0	Satisfactory
##	2081/07/13	2:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	7.14	426	118	80	0.3	1.5	18	1.54	0	Satisfactory
##	2081/07/13	10:15 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.3	85.7	24	36	0.1	0.02	4	0.24	0	Satisfactory
##	2081/07/13	10:45 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.64	41	14	16	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/13	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	37	14	14	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/13	3:55 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	36	14	14	0.1	0.02	6	0.96	0	Satisfactory
##	2081/07/14	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	8.08	369	94	122	0.1	0.02	8	0.54	0	Satisfactory
##	2081/07/14	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.99	<5	7.4	53	16	18	0.1	0.02	6	2.07	0	Satisfactory
##	2081/07/14	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.08	<5	7.42	52.5	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/14	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.49	<5	7.54	51.9	16	18	0.1	0.02	6	0.35	0	Satisfactory
##	2081/07/14	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.59	<5	7.76	52.6	16	18	0.1	0.02	6	0.38	0	Satisfactory
##	2081/07/14	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.75	53.2	16	18	0.1	0.02	6	1.25	0	Satisfactory
##	2081/07/14	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.75	52.3	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/14	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.68	52.6	16	18	0.1	0.02	6	1.31	0	Satisfactory
##	2081/07/14	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.75	53.1	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/14	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.78	53.1	16	18	0.1	0.02	6	1.2	0	Satisfactory
##	2081/07/14	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.43	53.7	16	18	0.1	0.02	6	2.02	0	Satisfactory

##	2081/07/14	12:00 PM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	7.81	104.5	26	20	0.1	0.02	6	1.13	0	Satisfactory
##	2081/07/14	9:30 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.93	110.5	26	20	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/14	10:00 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.73	105	26	20	0.1	0.02	6	1.16	0	Satisfactory
##	2081/07/14	12:10 PM	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	7.81	105.7	26	20	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/14	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.2	<5	7.74	105.1	24	20	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/14	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.5	105.3	24	22	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/14	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.64	108.9	24	22	0.1	0.02	6	1.54	0	Satisfactory
##	2081/07/14	1:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.8	103	26	22	0.1	0.02	6	0.65	0	Satisfactory
##	2081/07/14	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.2	<5	7.28	72.6	20	12	0.1	0.02	6	0.59	0	Satisfactory
##	2081/07/14	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.62	66.5	18	12	0.1	0.02	6	0.51	0	Satisfactory
##	2081/07/14	1:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.4	78.2	18	12	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/14	10:45 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	7.12	420	114	78	0.3	1.5	22	0.46	0	Satisfactory
##	2081/07/14	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.58	<5	7.1	422	114	78	0.3	1.5	22	0.54	0	Satisfactory
##	2081/07/14	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.75	<5	7.3	454	132	86	0.3	1.5	22	1.9	0	Satisfactory
##	2081/07/14	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.42	<5	7.4	87.8	26	36	0.1	0.02	4	0.27	0	Satisfactory
##	2081/07/14	10:45 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.62	40	14	16	0.1	0.02	6	0.90	0	Satisfactory
##	2081/07/14	2:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.57	38	14	14	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/14	3:55 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.53	38	14	14	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/15	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.44	53.5	16	18	0.1	0.02	6	2.13	0	Satisfactory
##	2081/07/15	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.69	52	16	18	0.1	0.02	6	1.54	0	Satisfactory
##	2081/07/15	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.21	<5	7.72	51.3	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/15	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.33	<5	7.77	51.9	16	18	0.1	0.02	6	0.33	0	Satisfactory
##	2081/07/15	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.72	53.1	16	18	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/15	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.8	53.8	16	18	0.1	0.02	6	0.23	0	Satisfactory
##	2081/07/15	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.79	53.5	16	18	0.1	0.02	6	1.61	0	Satisfactory
##	2081/07/15	4:30 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.75	54.7	16	18	0.1	0.02	6	1.65	0	Satisfactory
##	2081/07/15	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.36	54.1	16	18	0.1	0.02	6	1.74	0	Satisfactory

##	2081/07/15	1:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.67	104.5	24	22	0.1	0.02	6	1.08	0	Satisfactory
##	2081/07/15	1:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.7	90.6	20	12	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/15	12:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.99	<5	7.37	455	132	88	0.3	1.5	22	2.5	0	Satisfactory
##	2081/07/15	1:30 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.08	<5	7.6	88.3	28	36	0.1	0.02	4	1.19	0	Satisfactory
##	2081/07/15	10:45 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	37	14	14	0.1	0.02	6	0.90	0	Satisfactory
##	2081/07/15	2:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	39	14	14	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/15	3:50 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	37	14	14	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/16	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.41	53.9	16	18	0.1	0.02	6	2.03	0	Satisfactory
##	2081/07/16	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.07	<5	7.45	53.2	16	18	0.1	0.02	6	1.33	0	Satisfactory
##	2081/07/16	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.32	<5	7.79	52.3	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/16	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.43	<5	7.88	51.9	16	18	0.1	0.02	6	0.45	0	Satisfactory
##	2081/07/16	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.7	53.7	16	18	0.1	0.02	6	1.25	0	Satisfactory
##	2081/07/16	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.73	54.1	16	18	0.1	0.02	6	1.34	0	Satisfactory
##	2081/07/16	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.76	53.6	16	18	0.1	0.02	6	1.43	0	Satisfactory
##	2081/07/16	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.73	53.8	16	18	0.1	0.02	6	1.24	0	Satisfactory
##	2081/07/16	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.72	53.7	16	18	0.1	0.02	6	0.86	0	Satisfactory
##	2081/07/16	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.55	55.2	16	18	0.1	0.02	6	1.92	0	Satisfactory
##	2081/07/16	7:10 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.56	105.2	26	20	0.1	0.02	6	1.14	0	Satisfactory
##	2081/07/16	8:00 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.5	105.1	26	22	0.1	0.02	6	0.68	0	Satisfactory
##	2081/07/16	9:00 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.48	105.8	26	20	0.1	0.02	6	0.82	0	Satisfactory
##	2081/07/16	8:20 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.61	108.8	26	20	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/16	6:50 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.39	104.6	26	20	0.1	0.02	6	0.53	0	Satisfactory
##	2081/07/16	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	1.4	<5	7.33	99.7	24	20	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/16	12:00 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.28	103.6	24	22	0.1	0.02	6	1.87	0	Satisfactory
##	2081/07/16	12:00 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.36	59.2	18	12	0.1	0.02	6	0.79	0	Satisfactory
##	2081/07/16	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.92	<5	7.15	409	104	78	0.3	1.5	22	0.33	0	Satisfactory
##	2081/07/16	11:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.88	<5	7.18	85.6	24	34	0.1	0.02	4	0.3	0	Satisfactory



##	2081/07/16	10:00 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	40	14	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/16	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	39	14	14	0.1	0.02	6	1.02	0	Satisfactory
##	2081/07/17	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.59	54.9	16	18	0.1	0.02	6	2.11	0	Satisfactory
##	2081/07/17	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.63	54.3	16	18	0.1	0.02	6	1.63	0	Satisfactory
##	2081/07/17	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.79	52.3	16	18	0.1	0.02	6	0.22	0	Satisfactory
##	2081/07/17	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.15	<5	7.87	54.5	16	18	0.1	0.02	6	0.32	0	Satisfactory
##	2081/07/17	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.62	54.5	16	18	0.1	0.02	6	1.55	0	Satisfactory
##	2081/07/17	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.16	<5	6.99	53.2	16	18	0.1	0.02	6	1.79	0	Satisfactory
##	2081/07/17	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.07	<5	7.46	54.2	16	18	0.1	0.02	6	1.67	0	Satisfactory
##	2081/07/17	1:35 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.51	107	24	20	0.1	0.02	6	0.5	0	Satisfactory
##	2081/07/17	1:05 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.4	<5	7.41	106	26	22	0.1	0.02	6	0.57	0	Satisfactory
##	2081/07/17	12:15 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.2	<5	7.53	105.8	26	20	0.1	0.02	6	0.9	0	Satisfactory
##	2081/07/17	12:40 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.77	111.7	24	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/17	1:50 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.49	108.8	24	20	0.1	0.02	6	1.39	0	Satisfactory
##	2081/07/17	1:30 PM	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.32	101.4	24	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/17	1:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.33	103	24	22	0.1	0.02	6	0.67	0	Satisfactory
##	2081/07/17	1:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.4	<5	7.19	100	20	12	0.1	0.02	6	1.17	0	Satisfactory
##	2081/07/17	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.02	<5	7.1	399	104	74	0.3	1.5	20	0.62	0	Satisfactory
##	2081/07/17	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.15	<5	7.22	81.9	24	34	0.1	0.02	4	0.22	0	Satisfactory
##	2081/07/17	10:55 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.71	38	14	14	0.1	0.02	6	1.02	0	Satisfactory
##	2081/07/17	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.67	39	14	14	0.1	0.02	6	0.98	0	Satisfactory
##	2081/07/17	3:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	39	16	16	0.1	0.02	6	1.00	0	Satisfactory
##	2081/07/18	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.42	54	16	18	0.1	0.02	6	1.97	0	Satisfactory
##	2081/07/18	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	7.4	53.7	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/18	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.28	<5	7.43	53.3	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/18	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.27	<5	7.49	53	16	18	0.1	0.02	6	0.33	0	Satisfactory
##	2081/07/18	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.5	53.7	16	18	0.1	0.02	6	1.3	0	Satisfactory

##	2081/07/18	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.45	<5	7.54	54.3	16	18	0.1	0.02	6	1.43	0	Satisfactory
##	2081/07/18	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.08	<5	7.57	54.2	16	18	0.1	0.02	6	1.95	0	Satisfactory
##	2081/07/18	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.65	54.2	16	18	0.1	0.02	6	1.93	0	Satisfactory
##	2081/07/18	10:15 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	37	14	14	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/18	2:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.62	38	14	16	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/18	3:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	37	14	14	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/19	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.75	52.7	16	18	0.1	0.02	6	1.44	0	Satisfactory
##	2081/07/19	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.31	<5	7.2	51.8	16	18	0.1	0.02	6	1.69	0	Satisfactory
##	2081/07/19	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.74	54.8	16	18	0.1	0.02	6	1.71	0	Satisfactory
##	2081/07/19	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.56	53.2	16	18	0.1	0.02	6	1.5	0	Satisfactory
##	2081/07/19	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.57	53.5	16	18	0.1	0.02	6	1.52	0	Satisfactory
##	2081/07/19	3:00 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.6	<5	7.56	104.7	26	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/19	2:20 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.53	104	26	22	0.1	0.02	6	0.18	0	Satisfactory
##	2081/07/19	1:10 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.5	106.5	26	20	0.1	0.02	6	0.6	0	Satisfactory
##	2081/07/19	1:40 AM	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.62	110	26	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/19	3:20 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.45	<5	7.46	104.6	26	20	0.1	0.02	6	0.35	0	Satisfactory
##	2081/07/19		Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.5	94.2	22	22	0.1	0.02	6	0.73	0	Satisfactory
##	2081/07/19		Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.5	70	18	12	0.1	0.02	6	0.65	0	Satisfactory
##	2081/07/19	3:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	7.06	391	96	80	0.3	1.5	24	1.09	0	Satisfactory
##	2081/07/19	3:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.5	<5	7.3	84.1	24	34	0.1	0.02	4	1.24	0	Satisfactory
##	2081/07/19	10:50 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.60	39	16	16	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/19	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	37	14	14	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/19	3:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.65	39	14	14	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/20	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.58	<5	7.88	384	100	126	0.1	0.02	10	0.75	0	Satisfactory
##	2081/07/20	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.59	53.1	16	18	0.1	0.02	6	1.91	0	Satisfactory
##	2081/07/20	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.63	52.9	16	18	0.1	0.02	6	1.12	0	Satisfactory
##	2081/07/20	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.37	<5	7.85	52.4	16	18	0.1	0.02	6	0.39	0	Satisfactory

##	2081/07/20	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.77	<5	7.88	52.3	16	18	0.1	0.02	6	0.51	0	Satisfactory
##	2081/07/20	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.76	54.2	16	18	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/20	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.48	56.3	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/20	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.51	55.7	16	18	0.1	0.02	6	1.32	0	Satisfactory
##	2081/07/20	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.51	54.2	16	18	0.1	0.02	6	1.36	0	Satisfactory
##	2081/07/20	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.56	53.8	16	18	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/20	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.46	55.8	16	18	0.1	0.02	6	1.87	0	Satisfactory
##	2081/07/20	11:25 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.64	109.3	26	20	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/20	1:05 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.6	109.3	26	22	0.1	0.02	6	0.19	0	Satisfactory
##	2081/07/20	12:00 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	7.5	109.1	26	20	0.1	0.02	6	0.76	0	Satisfactory
##	2081/07/20	12:40 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	7.57	113.9	26	20	0.1	0.02	6	0.81	0	Satisfactory
##	2081/07/20	11:40 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.6	<5	7.56	107.1	26	20	0.1	0.02	6	0.55	0	Satisfactory
##	2081/07/20	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.52	106.8	24	22	0.1	0.02	6	1.37	0	Satisfactory
##	2081/07/20	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.42	111.5	26	22	0.1	0.02	6	1.04	0	Satisfactory
##	2081/07/20	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.23	105.1	24	22	0.1	0.02	6	0.58	0	Satisfactory
##	2081/07/20	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.6	<5	7.49	109.6	26	22	0.1	0.02	6	1.29	0	Satisfactory
##	2081/07/20	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.37	71.4	20	12	0.1	0.02	6	0.76	0	Satisfactory
##	2081/07/20	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.8	<5	7.29	71.2	16	12	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/20	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.23	105.1	18	12	0.1	0.02	6	0.58	0	Satisfactory
##	2081/07/20	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.1	<5	7.18	104.4	16	12	0.1	0.02	6	1.2	0	Satisfactory
##	2081/07/20	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.8	<5	7.15	390	98	78	0.3	1.5	24	0.92	0	Satisfactory
##	2081/07/20	2:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.11	<5	7.2	396	100	80	0.3	1.5	20	1.71	0	Satisfactory
##	2081/07/20	3:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.56	<5	7.2	395	100	80	0.3	1.5	20	1.4	0	Satisfactory
##	2081/07/20	12:30 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.37	<5	7.4	86.8	26	36	0.1	0.02	4		0	Satisfactory
##	2081/07/21	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	1.07	<5	7.96	388	100	126	0.1	0.02	10	0.97	0	Satisfactory
##	2081/07/21	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.42	54.6	16	18	0.1	0.02	6	2.09	0	Satisfactory
##	2081/07/21	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.58	53.5	16	18	0.1	0.02	6	1.29	0	Satisfactory

##	2081/07/21	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.68	53.6	16	18	0.1	0.02	6	0.32	0	Satisfactory
##	2081/07/21	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.77	53.6	16	18	0.1	0.02	6	0.52	0	Satisfactory
##	2081/07/21	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.62	54.6	16	18	0.1	0.02	6	1.33	0	Satisfactory
##	2081/07/21	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.65	54.2	16	18	0.1	0.02	6	1.31	0	Satisfactory
##	2081/07/21	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.71	53.1	16	18	0.1	0.02	6	1.58	0	Satisfactory
##	2081/07/21	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.62	53.4	16	18	0.1	0.02	6	1.29	0	Satisfactory
##	2081/07/21	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.71	52.6	16	18	0.1	0.02	6	1.1	0	Satisfactory
##	2081/07/21	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.29	<5	7.34	49.3	16	18	0.1	0.02	6	1.47	0	Satisfactory
##	2081/07/21	11:00 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.43	111.6	26	20	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/21	12:45 PM	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.5	111	26	22	0.1	0.02	6	0.82	0	Satisfactory
##	2081/07/21	11:35 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.59	111.5	26	20	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/21	12:05 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.2	<5	7.66	114.5	26	20	0.1	0.02	6	0.84	0	Satisfactory
##	2081/07/21	11:10 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.52	109.1	26	20	0.1	0.02	6	0.43	0	Satisfactory
##	2081/07/21	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.1	<5	7.1	107.6	24	22	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/21	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.1	<5	7.1	107.6	24	22	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/21	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.1	102	24	22	0.1	0.02	6	0.74	0	Satisfactory
##	2081/07/21	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.05	107	24	22	0.1	0.02	6	1.42	0	Satisfactory
##	2081/07/21	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	6.97	66.2	16	12	0.1	0.02	6	2.1	0	Satisfactory
##	2081/07/21	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.6	<5	6.97	68.5	20	12	0.1	0.02	6	1.15	0	Satisfactory
##	2081/07/21	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	7.04	68.3	18	12	0.1	0.02	6	0.74	0	Satisfactory
##	2081/07/21	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	6.97	79.1	16	12	0.1	0.02	6	0.86	0	Satisfactory
##	2081/07/21	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.48	<5	7.38	433	126	84	0.3	1.5	24	2.1	0	Satisfactory
##	2081/07/21	1:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.28	<5	7.3	450	130	88	0.3	1.5	24	3.86	0	Satisfactory
##	2081/07/21	3:20 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.58	<5	7.4	453	132	86	0.3	1.5	24	3.48	0	Satisfactory
##	2081/07/21	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.06	<5	7.26	85.1	26	36	0.1	0.02	4	0.2	0	Satisfactory
##	2081/07/21	10:40 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.54	37	14	14	0.1	0.02	6	0.66	0	Satisfactory
##	2081/07/21	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.51	39	14	16	0.1	0.02	6	0.94	0	Satisfactory

##	2081/07/21	3:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.47	39	16	16	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/22	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.98	<5	7.38	49.5	16	18	0.1	0.02	6	1.72	0	Satisfactory
##	2081/07/22	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	4.22	<5	7.69	51	16	18	0.1	0.02	6	1	0	Satisfactory
##	2081/07/22	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.93	<5	7.7	42.5	16	18	0.1	0.02	6	0.3	0	Satisfactory
##	2081/07/22	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.81	<5	7.72	42.7	16	18	0.1	0.02	6	0.36	0	Satisfactory
##	2081/07/22	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.6	43.2	16	18	0.1	0.02	6	1.1	0	Satisfactory
##	2081/07/22	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.9	<5	7.63	54	16	18	0.1	0.02	6	1.75	0	Satisfactory
##	2081/07/22	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.7	55.3	16	18	0.1	0.02	6	1.1	0	Satisfactory
##	2081/07/22	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.73	53.6	16	18	0.1	0.02	6	1.64	0	Satisfactory
##	2081/07/22	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.27	52	16	18	0.1	0.02	6	1.73	0	Satisfactory
##	2081/07/22	7:45 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.6	<5	7.45	116.2	24	20	0.1	0.02	6	2.16	0	Satisfactory
##	2081/07/22	8:15 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.4	<5	7.65	115.3	24	22	0.1	0.02	6	1.28	0	Satisfactory
##	2081/07/22	9:35 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.21	113	24	20	0.1	0.02	6	1.31	0	Satisfactory
##	2081/07/22	8:10 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.4	<5	7.21	117.2	24	20	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/22	7:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.55	113.3	24	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/22	9:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.2	<5	7.13	108	24	22	0.1	0.02	6	0.52	0	Satisfactory
##	2081/07/22	9:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.26	107.8	20	12	0.1	0.02	6	0.23	0	Satisfactory
##	2081/07/22	11:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.9	<5	7.1	380	98	68	0.3	1.5	12	0.2	0	Satisfactory
##	2081/07/22	10:30 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.32	<5	7.26	86.2	26	38	0.1	0.02	4	0.24	0	Satisfactory
##	2081/07/22	10:15 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.51	39	14	14	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/22	2:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.53	38	14	14	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/22	3:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.54	38	14	14	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/23	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.71	<5	8.06	370	96	124	0.1	0.02	10	0.2	0	Satisfactory
##	2081/07/23	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.33	<5	7.31	51.9	16	18	0.1	0.02	6	2.01	0	Satisfactory
##	2081/07/23	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.42	<5	7.3	51.7	16	18	0.1	0.02	6	1.32	0	Satisfactory
##	2081/07/23	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	7.69	51.3	16	18	0.1	0.02	6	0.27	0	Satisfactory
##	2081/07/23	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.75	50.9	16	18	0.1	0.02	6	0.58	0	Satisfactory

##	2081/07/23	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.05	<5	7.67	52.5	16	18	0.1	0.02	6	1.04	0	Satisfactory
##	2081/07/23	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.41	<5	7.6	55.3	16	18	0.1	0.02	6	1.46	0	Satisfactory
##	2081/07/23	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.2	<5	7.7	56.9	16	18	0.1	0.02	6	1.59	0	Satisfactory
##	2081/07/23	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.6	55.6	16	18	0.1	0.02	6	1.2	0	Satisfactory
##	2081/07/23	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.9	<5	7.46	51.5	16	18	0.1	0.02	6	1.3	0	Satisfactory
##	2081/07/23	1:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.26	64.4	22	20	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/23	12:25 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	7.9	65.7	22	20	0.1	0.02	6	0.66	0	Satisfactory
##	2081/07/23	1:30 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.66	70.6	22	20	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/23	1:00 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.16	64.5	22	20	0.1	0.02	6	1	0	Satisfactory
##	2081/07/23	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	6.98	63.9	22	22	0.1	0.02	6	1.44	0	Satisfactory
##	2081/07/23	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.36	65.4	22	22	0.1	0.02	6	1.17	0	Satisfactory
##	2081/07/23	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.27	35.8	14	12	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/23	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.34	40.1	16	12	0.1	0.02	6	0.69	0	Satisfactory
##	2081/07/23	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.26	55.5	16	12	0.1	0.02	6	1.27	0	Satisfactory
##	2081/07/23	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	7.2	455	130	88	0.3	1.5	24	2.13	0	Satisfactory
##	2081/07/23	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.58	<5	7.08	382	96	72	0.3	1.5	18	1.08	0	Satisfactory
##	2081/07/23	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.54	<5	7.24	86.9	26	38	0.1	0.02	4	0.2	0	Satisfactory
##	2081/07/23	10:40 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	40	16	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/23	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.65	38	14	16	0.1	0.02	6	0.97	0	Satisfactory
##	2081/07/24	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.97	<5	7.51	53.2	16	18	0.1	0.02	6	1.72	0	Satisfactory
##	2081/07/24	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.83	<5	7.69	52.7	16	18	0.1	0.02	6	1.01	0	Satisfactory
##	2081/07/24	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.63	51.8	16	18	0.1	0.02	6	0.35	0	Satisfactory
##	2081/07/24	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.59	51.7	16	18	0.1	0.02	6	0.66	0	Satisfactory
##	2081/07/24	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.56	52.3	16	18	0.1	0.02	6	0.88	0	Satisfactory
##	2081/07/24	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.67	53.2	16	18	0.1	0.02	6	1.06	0	Satisfactory
##	2081/07/24	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.68	52.9	16	18	0.1	0.02	6	1.36	0	Satisfactory
##	2081/07/24	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.64	53.1	16	18	0.1	0.02	6	1.21	0	Satisfactory

##	2081/07/24	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.33	53	16	18	0.1	0.02	6	1.16	0	Satisfactory
##	2081/07/24	7:40 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.51	66.6	20	20	0.1	0.02	6	0.6	0	Satisfactory
##	2081/07/24	8:30 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.57	68.5	20	22	0.1	0.02	6	0.83	0	Satisfactory
##	2081/07/24	9:30 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.63	66.8	20	20	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/24	9:10 AM	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.77	70.2	20	20	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/24	7:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.64	66.6	20	20	0.1	0.02	6	0.74	0	Satisfactory
##	2081/07/24	1:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.1	<5	7.43	61.2	20	22	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/24	1:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.45	36.5	14	12	0.1	0.02	6	1.08	0	Satisfactory
##	2081/07/24	10:55 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	41	16	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/24	2:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.62	37	14	14	0.1	0.02	6	0.97	0	Satisfactory
##	2081/07/24	3:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	36	14	14	0.1	0.02	6	1.03	0	Satisfactory
##	2081/07/25	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.47	<5	7.93	385	96	122	0.1	0.02	10	0.81	0	Satisfactory
##	2081/07/25	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.37	52.6	16	18	0.1	0.02	6	1.59	0	Satisfactory
##	2081/07/25	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.41	52.4	16	18	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/25	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.52	54.7	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/25	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.69	55.6	16	18	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/25	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.72	51.5	16	18	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/25	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.26	<5	7.72	55.3	16	18	0.1	0.02	6	0.77	0	Satisfactory
##	2081/07/25	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.65	55.3	16	18	0.1	0.02	6	1.7	0	Satisfactory
##	2081/07/25	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.35	55.9	16	18	0.1	0.02	6	1.52	0	Satisfactory
##	2081/07/25	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.25	52.6	16	18	0.1	0.02	6	1.24	0	Satisfactory
##	2081/07/25	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.3	51.2	16	18	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/25	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.19	50.9	16	18	0.1	0.02	6	2.04	0	Satisfactory
##	2081/07/25	11:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	2.1	<5	7.73	65.6	22	20	0.1	0.02	6	1.07	0	Satisfactory
##	2081/07/25	12:40 PM	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.55	72.7	22	22	0.1	0.02	6	0.25	0	Satisfactory
##	2081/07/25	12:25 PM	Lalitpur	Khumaltar SRT	Treated	Clear	2.8	<5	7.65	66.7	22	20	0.1	0.02	6	0.54	0	Satisfactory
##	2081/07/25	1:20 AM	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.72	68.5	22	20	0.1	0.02	6	0.76	0	Satisfactory

##	2081/07/25	2:50 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.69	65.7	22	20	0.1	0.02	6	0.69	0	Satisfactory
##	2081/07/25	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.3	62.6	20	22	0.1	0.02	6	0.36	0	Satisfactory
##	2081/07/25	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.39	66.2	20	22	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/25	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.59	64.3	22	22	0.1	0.02	6	1.55	0	Satisfactory
##	2081/07/25	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.62	65.3	20	22	0.1	0.02	6	1.43	0	Satisfactory
##	2081/07/25	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.37	35.3	14	12	0.1	0.02	6	0.42	0	Satisfactory
##	2081/07/25	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.37	41.6	16	12	0.1	0.02	6	1.54	0	Satisfactory
##	2081/07/25	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.75	42.7	18	12	0.1	0.02	6	1.29	0	Satisfactory
##	2081/07/25	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.68	42.7	16	12	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/25	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.92	<5	7.05	377	96	70	0.3	1.5	18	0.31	0	Satisfactory
##	2081/07/25	1:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.94	<5	7.05	387	96	70	0.3	1.5	18	0.3	0	Satisfactory
##	2081/07/25	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.22	<5	7.45	85.5	26	38	0.1	0.02	4	0.22	0	Satisfactory
##	2081/07/25	10:50 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.60	35	12	12	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/25	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	7.61	38	14	14	0.1	0.02	6	0.90	0	Satisfactory
##	2081/07/25	3:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.57	38	14	14	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/26	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	1.04	<5	8.01	377	96	122	0.1	0.02	8	0.74	0	Satisfactory
##	2081/07/26	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.22	50.8	16	18	0.1	0.02	6	2.29	0	Satisfactory
##	2081/07/26	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.29	50.5	16	18	0.1	0.02	6	1.57	0	Satisfactory
##	2081/07/26	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.63	50.2	16	18	0.1	0.02	6	0.32	0	Satisfactory
##	2081/07/26	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.75	54.2	16	18	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/26	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.6	51.8	16	18	0.1	0.02	6	1.42	0	Satisfactory
##	2081/07/26	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.67	53.1	16	18	0.1	0.02	6	1.26	0	Satisfactory
##	2081/07/26	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.65	53.5	16	18	0.1	0.02	6	1.2	0	Satisfactory
##	2081/07/26	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.78	54.3	16	18	0.1	0.02	6	1.53	0	Satisfactory
##	2081/07/26	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.56	53.3	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/26	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.73	52.8	16	18	0.1	0.02	6	1.35	0	Satisfactory
##	2081/07/26	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.37	51.4	16	18	0.1	0.02	6	1.84	0	Satisfactory



##	2081/07/26	1:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.6	<5	7.62	66.5	20	20	0.1	0.02	6	0.81	0	Satisfactory
##	2081/07/26	12:40 PM	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.73	67.2	20	22	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/26	12:25 PM	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.67	67.8	20	20	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/26	11:50 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.68	68.7	20	20	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/26	1:30 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.47	65.3	20	20	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/26	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.35	64.7	22	22	0.1	0.02	6	0.67	0	Satisfactory
##	2081/07/26	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.25	62.6	20	22	0.1	0.02	6	1.27	0	Satisfactory
##	2081/07/26	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.42	63.7	20	22	0.1	0.02	6	1.07	0	Satisfactory
##	2081/07/26	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.62	64.2	22	22	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/26	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.47	41.2	16	12	0.1	0.02	6	0.58	0	Satisfactory
##	2081/07/26	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.3	43.8	16	12	0.1	0.02	6	2.18	0	Satisfactory
##	2081/07/26	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.46	44.7	14	12	0.1	0.02	6	1.88	0	Satisfactory
##	2081/07/26	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.42	39.2	14	12	0.1	0.02	6	0.84	0	Satisfactory
##	2081/07/26	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	4.25	<5	7.2	419	114	80	0.3	1.5	22	2.2	0	Satisfactory
##	2081/07/26	1:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.85	<5	7.16	396	98	70	0.3	1.5	24	0.91	0	Satisfactory
##	2081/07/26	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	4.8	<5	7.2	432	120	78	0.3	1.5	24	1.31	0	Satisfactory
##	2081/07/26	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.26	<5	7.42	83.6	26	36	0.1	0.02	4	0.2	0	Satisfactory
##	2081/07/26	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	39	16	16	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/26	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.67	41	16	16	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/26	3:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	41	16	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/27	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	7.94	385	100	124	0.1	0.02	10	1.12	0	Satisfactory
##	2081/07/27	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.39	51.1	16	18	0.1	0.02	6	2.14	0	Satisfactory
##	2081/07/27	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.42	50.9	16	18	0.1	0.02	6	1.29	0	Satisfactory
##	2081/07/27	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.59	50	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/27	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.63	50.1	16	18	0.1	0.02	6	0.43	0	Satisfactory
##	2081/07/27	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.65	51.5	16	18	0.1	0.02	6	1.06	0	Satisfactory
##	2081/07/27	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.71	54.1	16	18	0.1	0.02	6	1.34	0	Satisfactory

##	2081/07/27	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.51	53.8	16	18	0.1	0.02	6	1.23	0	Satisfactory
##	2081/07/27	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.66	54.1	16	18	0.1	0.02	6	1.49	0	Satisfactory
##	2081/07/27	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.67	53	16	18	0.1	0.02	6	1.26	0	Satisfactory
##	2081/07/27	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.66	52.4	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/27	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.6	40.7	16	18	0.1	0.02	6	1.45	0	Satisfactory
##	2081/07/27	11:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.77	65.7	22	20	0.1	0.02	6	0.97	0	Satisfactory
##	2081/07/27	1:15 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.75	67.2	22	22	0.1	0.02	6	0.49	0	Satisfactory
##	2081/07/27	12:05 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.78	64.5	22	20	0.1	0.02	6	0.45	0	Satisfactory
##	2081/07/27	12:40 PM	Kirtipur	Kirtipur SRT	Treated	Clear	0.4	<5	7.79	68.9	22	20	0.1	0.02	6	0.87	0	Satisfactory
##	2081/07/27	11:35 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	7.79	66.7	22	20	0.1	0.02	6	0.62	0	Satisfactory
##	2081/07/27	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.65	65.3	22	22	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/27	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.77	63.9	22	22	0.1	0.02	6	1.28	0	Satisfactory
##	2081/07/27	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.78	64.5	24	22	0.1	0.02	6	0.86	0	Satisfactory
##	2081/07/27	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.82	65.8	22	22	0.1	0.02	6	1.19	0	Satisfactory
##	2081/07/27	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.7	37.2	14	12	0.1	0.02	6	0.67	0	Satisfactory
##	2081/07/27	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.4	<5	7.95	37.4	16	12	0.1	0.02	6	0.48	0	Satisfactory
##	2081/07/27	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.74	65.2	16	12	0.1	0.02	6	2.23	0	Satisfactory
##	2081/07/27	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.82	60.3	18	12	0.1	0.02	6	1.8	0	Satisfactory
##	2081/07/27	11:00 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.41	<5	7.2	425	114	80	0.3	1.5	24	2.6	0	Satisfactory
##	2081/07/27	1:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.48	<5	7.02	376	94	70	0.3	1.5	16	0.24	0	Satisfactory
##	2081/07/27	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.4	84.9	26	38	0.1	0.02	4	0.21	0	Satisfactory
##	2081/07/27	10:30 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.73	39	16	16	0.1	0.02	6	0.86	0	Satisfactory
##	2081/07/27	4:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	40	16	16	0.1	0.02	6	0.92	0	Satisfactory
##	2081/07/27	3:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.61	40	16	16	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/28	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	2.06	<5	7.85	378	96	120	0.1	0.02	10	0.86	0	Satisfactory
##	2081/07/28	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.63	50.5	16	18	0.1	0.02	6	1.92	0	Satisfactory
##	2081/07/28	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.67	50.3	16	18	0.1	0.02	6	1.03	0	Satisfactory

##	2081/07/28	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.72	50.9	16	18	0.1	0.02	6	0.39	0	Satisfactory
##	2081/07/28	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.85	49.9	16	18	0.1	0.02	6	0.68	0	Satisfactory
##	2081/07/28	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.83	51	16	18	0.1	0.02	6	1.02	0	Satisfactory
##	2081/07/28	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.89	52.4	16	18	0.1	0.02	6	1.01	0	Satisfactory
##	2081/07/28	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.65	70.1	16	18	0.1	0.02	6	1.21	0	Satisfactory
##	2081/07/28	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.81	70.6	16	18	0.1	0.02	6	1.41	0	Satisfactory
##	2081/07/28	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.55	67.8	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/28	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.59	65.4	16	18	0.1	0.02	6	1.02	0	Satisfactory
##	2081/07/28	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.5	73	16	18	0.1	0.02	6	1.84	0	Satisfactory
##	2081/07/28	11:20 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	7.51	66.7	24	20	0.1	0.02	6	0.5	0	Satisfactory
##	2081/07/28	2:05 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.2	<5	7.85	69.7	24	22	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/28	12:10 PM	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.98	74.4	24	20	0.1	0.02	6	0.7	0	Satisfactory
##	2081/07/28	1:10 AM	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.56	68.5	24	20	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/28	11:35 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	7.58	67.6	24	20	0.1	0.02	6	0.79	0	Satisfactory
##	2081/07/28	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.8	<5	7.25	66.3	22	22	0.1	0.02	6	1.3	0	Satisfactory
##	2081/07/28	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.48	67.5	24	22	0.1	0.02	6	1.11	0	Satisfactory
##	2081/07/28	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.72	66.5	22	22	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/28	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.2	65.8	24	22	0.1	0.02	6	0.8	0	Satisfactory
##	2081/07/28	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.3	42.3	16	12	0.1	0.02	6	0.48	0	Satisfactory
##	2081/07/28	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.55	43.5	18	12	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/28	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.45	43.7	16	12	0.1	0.02	6	0.75	0	Satisfactory
##	2081/07/28	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.72	41.2	18	12	0.1	0.02	6	0.6	0	Satisfactory
##	2081/07/28	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.08	<5	7.16	374	96	66	0.3	1.5	12	0.2	0	Satisfactory
##	2081/07/28	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	7.2	387	98	70	0.3	1.5	16	0.2	0	Satisfactory
##	2081/07/28	3:00 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.36	<5	7.2	412	112	72	0.3	1.5	16	0.26	0	Satisfactory
##	2081/07/28	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.2	<5	7.52	82.3	26	36	0.1	0.02	4	0.28	0	Satisfactory
##	2081/07/28	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.64	37	14	14	0.1	0.02	6	0.90	0	Satisfactory

##	2081/07/28	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.57	39	16	16	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/28	3:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	40	16	16	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/29	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	7.81	379	96	124	0.1	0.02	10	0.93	0	Satisfactory
##	2081/07/29	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.52	73.2	16	18	0.1	0.02	6	2.13	0	Satisfactory
##	2081/07/29	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.56	72.6	16	18	0.1	0.02	6	1.31	0	Satisfactory
##	2081/07/29	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.67	72.5	16	18	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/29	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.79	72.2	16	18	0.1	0.02	6	0.93	0	Satisfactory
##	2081/07/29	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.71	73.7	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/29	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.78	71.9	16	18	0.1	0.02	6	0.76	0	Satisfactory
##	2081/07/29	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.55	71.6	16	18	0.1	0.02	6	1.68	0	Satisfactory
##	2081/07/29	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.03	<5	7.6	68.5	16	18	0.1	0.02	6	1.2	0	Satisfactory
##	2081/07/29	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.64	68.4	16	18	0.1	0.02	6	1.4	0	Satisfactory
##	2081/07/29	5:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.52	68.3	16	18	0.1	0.02	6	1.45	0	Satisfactory
##	2081/07/29	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.71	72.6	16	18	0.1	0.02	6	1.02	0	Satisfactory
##	2081/07/29	11:25 AM	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	8.15	73.5	24	20	0.1	0.02	6	1.8	0	Satisfactory
##	2081/07/29	11:45 AM	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.99	68.5	24	22	0.1	0.02	6	0.29	0	Satisfactory
##	2081/07/29	11:55 AM	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	8.05	68.2	24	20	0.1	0.02	6	0.6	0	Satisfactory
##	2081/07/29	12:45 PM	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	8	70.5	24	20	0.1	0.02	6	0.81	0	Satisfactory
##	2081/07/29	11:35 AM	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.98	68.2	24	20	0.1	0.02	6	1.12	0	Satisfactory
##	2081/07/29	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.67	67.7	22	22	0.1	0.02	6	1.26	0	Satisfactory
##	2081/07/29	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.8	66.1	22	22	0.1	0.02	6	0.54	0	Satisfactory
##	2081/07/29	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.76	64.7	20	22	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/29	3:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.75	70.2	24	22	0.1	0.02	6	1.33	0	Satisfactory
##	2081/07/29	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.89	31.3	16	12	0.1	0.02	6	0.35	0	Satisfactory
##	2081/07/29	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.1	38.5	14	12	0.1	0.02	6	0.78	0	Satisfactory
##	2081/07/29	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.85	40.5	16	12	0.1	0.02	6	0.78	0	Satisfactory
##	2081/07/29	3:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	8.11	45.4	20	12	0.1	0.02	6	2	0	Satisfactory

##	2081/07/29	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	7.03	412	108	76	0.3	1.5	20	0.95	0	Satisfactory
##	2081/07/29	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	3.28	<5	7.4	445	132	86	0.3	1.5	24	1.72	0	Satisfactory
##	2081/07/29	3:15 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.2	<5	7.25	406	104	86	0.3	1.5	24	2.55	0	Satisfactory
##	2081/07/29	3:00 PM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.64	86.5	28	38	0.1	0.02	4	0.95	0	Satisfactory
##	2081/07/29	10:40 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	38	16	16	0.1	0.02	6	0.91	0	Satisfactory
##	2081/07/29	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	40	16	16	0.1	0.02	6	0.94	0	Satisfactory
##	2081/07/29	3:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	41	16	16	0.1	0.02	6	0.90	0	Satisfactory
##	2081/07/30	10:30 AM	Lalitpur	Sainbu WTP	Treated	Clear	1.02	<5	7.92	384	98	126	0.1	0.02	10	0.63	0	Satisfactory
##	2081/07/30	12:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.74	72.1	16	18	0.1	0.02	6	1.69	0	Satisfactory
##	2081/07/30	2:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.69	71.9	16	18	0.1	0.02	6	0.97	0	Satisfactory
##	2081/07/30	4:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.89	71.7	16	18	0.1	0.02	6	0.31	0	Satisfactory
##	2081/07/30	6:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.91	71.6	16	18	0.1	0.02	6	0.52	0	Satisfactory
##	2081/07/30	8:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.97	74	16	18	0.1	0.02	6	0.89	0	Satisfactory
##	2081/07/30	10:00 AM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.86	69.6	16	18	0.1	0.02	6	0.32	0	Satisfactory
##	2081/07/30	12:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.83	73.4	16	18	0.1	0.02	6	0.95	0	Satisfactory
##	2081/07/30	2:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.79	70.4	16	18	0.1	0.02	6	1.22	0	Satisfactory
##	2081/07/30	4:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.56	68.9	16	18	0.1	0.02	6	0.57	0	Satisfactory
##	2081/07/30	10:00 PM	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.75	73.3	16		0.1	0.02	6	0.38	0	Satisfactory
##	2081/07/30	10:30 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.66	66	24	22	0.1	0.02	6	0.78	0	Satisfactory
##	2081/07/30	12:30 PM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.67	62.6	22	22	0.1	0.02	6	0.85	0	Satisfactory
##	2081/07/30	2:00 AM	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.35	66.6	24	22	0.1	0.02	6	0.4	0	Satisfactory
##	2081/07/30	10:30 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.86	36.1	16	12	0.1	0.02	6	0.63	0	Satisfactory
##	2081/07/30	12:30 PM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.62	37.5	16	12	0.1	0.02	6	0.78	0	Satisfactory
##	2081/07/30	2:00 AM	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.38	36.9	18	12	0.1	0.02	6	0.65	0	Satisfactory
##	2081/07/30	10:30 AM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	7.1	410	104	80	0.3	1.5	24	1.9	0	Satisfactory
##	2081/07/30	12:30 PM	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	7.29	460	136	88	0.3	1.5	24	1.33	0	Satisfactory
##	2081/07/30	10:00 AM	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.6	84.2	28	38	0.1	0.02	4	0.22	0	Satisfactory

##	2081/07/30	10:25 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	37	14	14	0.1	0.02	6	0.72	0	Satisfactory
##	2081/07/30	12:10 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	38	16	16	0.1	0.02	6	0.74	0	Satisfactory
##	2081/07/30	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	39	16	16	0.1	0.02	6	0.71	0	Satisfactory
##	2081/07/20	10:35 AM	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.62	38	14	14	0.1	0.02	6	0.86	0	Satisfactory
##	2081/07/20	2:00 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.53	40	16	16	0.1	0.02	6	1.05	0	Satisfactory
##	2081/07/20	3:15 PM	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.54	40	16	16	0.1	0.02	6	1.03	0	Satisfactory

--

--