



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Mangsir 2081

S.N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	p ^H	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
							(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml	
National Drinking Water Quality Standard (NDWQS)							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2081/08/01	8:40	Maharajgunj	Balaju SRT	Treated	Clear	1.5	<5	7.98	69.2	22	18	0.1	0.02	6	0.78	0	Satisfactory
2	2081/08/01	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.6	38.2	12	12	0.1	0.02	4	1.22	0	Satisfactory
3	2081/08/01	7:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.6	<5	7.99	72.5	22	18	0.1	0.02	6	1.15	0	Satisfactory
4	2081/08/01	10:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.9	<5	7.88	79.5	22	22	0.1	0.02	6	0.64	0	Satisfactory
5	2081/08/01	9:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.9	<5	7.98	70.2	22	22	0.1	0.02	6	0.2	0	Satisfactory
6	2081/08/01	7:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.92	67.5	22	22	0.1	0.02	4	0.74	0	Satisfactory
7	2081/08/01		Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.5	62.5	22	24	0.1	0.02	4	0.72	0	Satisfactory
8	2081/08/01	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.72	67.2	22	18	0.1	0.02	6	1.29	0	Satisfactory
9	2081/08/01	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	< 5	7.77	72.1	22	22	0.1	0.02	4	0.87	0	Satisfactory
10	2081/08/01	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	< 5	7.73	71.9	22	22	0.1	0.02	4	1.09	0	Satisfactory
11	2081/08/01	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	< 5	7.87	69.2	20	22	0.1	0.02	4	0.27	0	Satisfactory
12	2081/08/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	< 5	7.9	69.7	20	22	0.1	0.02	4	0.55	0	Satisfactory
13	2081/08/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	< 5	7.9	70.9	20	22	0.1	0.02	4	0.86	0	Satisfactory
14	2081/08/01	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	< 5	7.81	70.5	20	22	0.1	0.02	4	0.4	0	Satisfactory
15	2081/08/01	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	< 5	7.89	67.7	20	22	0.1	0.02	4	1.15	0	Satisfactory
16	2081/08/01	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	< 5	7.84	68	20	22	0.1	0.02	4	0.99	0	Satisfactory
17	2081/08/01	16:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	< 5	7.78	65	20	22	0.1	0.02	4	0.29	0	Satisfactory
18	2081/08/01	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	< 5	7.68	70.6	20	22	0.1	0.02	4	1.66	0	Satisfactory

19	2081/08/01	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.71	<5	7.82	58	20	26	0.1	0.02	6	0.43	0	Satisfactory
20	2081/08/01	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	39	16	16	0.1	0.02	6	0.72	0	Satisfactory
21	2081/08/01	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	39	16	16	0.1	0.02	6	0.71	0	Satisfactory
22	2081/08/01	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	38	16	16	0.1	0.02	6	0.72	0	Satisfactory
23	2081/08/02	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.19	47	14	12	0.1	0.02	4	0.59	0	Satisfactory
24	2081/08/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.3	47.9	20	12	0.1	0.02	4	0.52	0	Satisfactory
25	2081/08/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.32	48.7	18	12	0.1	0.02	4	0.2	0	Satisfactory
26	2081/08/02	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.3	44.5	18	12	0.1	0.02	4	1.95	0	Satisfactory
27	2081/08/02	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.25	68	22	18	0.1	0.02	6	0.73	0	Satisfactory
28	2081/08/02	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.39	66.2	24	18	0.1	0.02	6	1.22	0	Satisfactory
29	2081/08/02	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.45	67.9	22	18	0.1	0.02	6	0.7	0	Satisfactory
30	2081/08/02	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.39	66.3	20	18	0.86	0.02	6	1.07	0	Satisfactory
31	2081/08/02	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	< 5	7.7	70.3	20	22	0.1	0.02	4	1.93	0	Satisfactory
32	2081/08/02	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	< 5	7.73	70.5	20	22	0.1	0.02	4	1.02	0	Satisfactory
33	2081/08/02	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	< 5	7.87	70.8	22	22	0.1	0.02	4	0.29	0	Satisfactory
34	2081/08/02	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	< 5	7.91	71.6	22	22	0.1	0.02	4	0.4	0	Satisfactory
35	2081/08/02	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	< 5	7.96	74	22	22	0.1	0.02	4	0.72	0	Satisfactory
36	2081/08/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	< 5	7.94	73	22	22	0.1	0.02	4	0.7	0	Satisfactory
37	2081/08/02	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	< 5	8.03	69.4	20	22	0.1	0.02	4	0.61	0	Satisfactory
38	2081/08/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	< 5	8	72.6	20	22	0.1	0.02	4	0.53	0	Satisfactory
39	2081/08/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.94	< 5	8.02	70.4	24	22	0.1	0.02	4	0.81	0	Satisfactory
40	2081/08/02	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	< 5	7.74	71.1	22	22	0.1	0.02	4	0.98	0	Satisfactory
41	2081/08/02	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	< 5	7.69	68.2	20	22	0.1	0.02	4	1.2	0	Satisfactory
42	2081/08/02	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.45	<5	7.7	87.9	28	22	0.1	0.02	4	0.18	0	Satisfactory
43	2081/08/02	10:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.73	<5	7.76	55	20	20	0.1	0.02	6	0.43	0	Satisfactory
44	2081/08/02	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	7.86	58	20	26	0.1	0.02	6	0.70	0	Satisfactory
45	2081/08/02	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	36	14	14	0.1	0.02	6	0.73	0	Satisfactory
46	2081/08/02	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.75	38	16	16	0.1	0.02	6	0.70	0	Satisfactory

47	2081/08/02	14:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	39	16	16	0.1	0.02	6	0.72	0	Satisfactory	
48	2081/08/02	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.73	<5	8.07	371	96	122	0.1	0.02	10	0.89	0	Satisfactory	
49	2081/08/02	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.85	<5	7.05	413	120	70	0.3	0.02	16	0.95	0	Satisfactory	
50		13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.91	<5	7.1	411	120	70	0.3	0.02	16	0.81	0	Satisfactory	
51	2081/08/02	15:15	Madhyapur Thimi	Bode WTP	Treated	Clear	3.05	<5	7.15	418	122	70	0.3	0.02	18	0.75	0	Satisfactory	
52	2081/08/03	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.98	45.3	18	12	0.1	0.02	4	0.45	0	Satisfactory	
53	2081/08/03	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1	<5	8.34	88.1	24	18	0.1	0.02	6	0.55	0	Satisfactory	
54	2081/08/03	8:30	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	8.2	69.3	22	22	0.1	0.02	6	0.2	0	Satisfactory	
55	2081/08/03	12:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.9	<5	8.32	71.4	24	20	0.1	0.02	4	0.56	0	Satisfactory	
56	2081/08/03	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	8	68.9	24	18	0.1	0.02	6	0.97	0	Satisfactory	
57	2081/08/03	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	< 5	7.67	71.7	22	22	0.1	0.02	4	1.61	0	Satisfactory	
58	2081/08/03	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	< 5	7.65	70.3	22	22	0.1	0.02		4	1.03	0	Satisfactory
59	2081/08/03	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	< 5	7.89	70.5	22	22	0.1	0.02		4	0.33	0	Satisfactory
60	2081/08/03	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	< 5	7.92	72.6	22	22	0.1	0.02		4	0.44	0	Satisfactory
61	2081/08/03	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	< 5	7.82	74.1	22	22	0.1	0.02		4	0.96	0	Satisfactory
62	2081/08/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	< 5	7.9	68.8	22	22	0.1	0.02		4	0.4	0	Satisfactory
63	2081/08/03	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	< 5	7.58	70.8	22	22	0.1	0.02		4	1.09	0	Satisfactory
64	2081/08/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	< 5	7.59	72.7	22	22	0.1	0.02		4	1.01	0	Satisfactory
65	2081/08/03	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	< 5	7.75	73.7	22	22	0.1	0.02		4	0.71	0	Satisfactory
66	2081/08/03	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	< 5	7.73	71.4	22	22	0.1	0.02	4	0.86	0	Satisfactory	
67	2081/08/03	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	7.92	55	20	24	0.1	0.02	6	0.44	0	Satisfactory	
68	2081/08/03	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	41	16	16	0.1	0.02	6	0.73	0	Satisfactory	
69	2081/08/03	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.75	42	16	16	0.1	0.02	6	0.68	0	Satisfactory	
70	2081/08/03	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	42	16	16	0.1	0.02	6	0.73	0	Satisfactory	
71	2081/08/03	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.8	<5	6.99	372	100	66	0.3	0.02	10	0.2	0	Satisfactory	
72			11:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.99	<5	6.95	375	100	66	0.3	0.02	10	0.2	0	Satisfactory
73	2081/08/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.43	47.5	16	12	0.1	0.02	4	1.22	0	Satisfactory	
74	2081/08/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.63	48.3	16	12	0.1	0.02	4	0.54	0	Satisfactory	

75	2081/08/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.51	42.6	16	12	0.1	0.02	4	0.64	0	Satisfactory
76	2081/08/04	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.74	43.5	18	12	0.1	0.02	4	0.47	0	Satisfactory
77	2081/08/04	11:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.36	68.7	24	18	0.1	0.02	6	2.07	0	Satisfactory
78	2081/08/04	14:05	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.97	69.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
79	2081/08/04	8:30	Bhaktapur	Katunje SRT	Treated	Clear	1	<5	7.25	68.2	22	22	0.1	0.02	6	0.58	0	Satisfactory
80	2081/08/04	12:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	8.11	71.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
81	2081/08/04	13:10	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.97	65.7	24	22	0.1	0.02	6	0.15	0	Satisfactory
82	2081/08/04	11:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	8.1	68.9	24	20	0.1	0.02	4	2.15	0	Satisfactory
83	2081/08/04		Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	8.2	86.2	24	24	0.1	0.02	4	0.35	0	Satisfactory
84	2081/08/04	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.3	68.9	22	18	0.1	0.02	6	0.2	0	Satisfactory
85	2081/08/04	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.39	70.5	22	18	0.1	0.02	6	0.87	0	Satisfactory
86	2081/08/04	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.68	69.1	14	18	0.1	0.02	6	0.97	0	Satisfactory
87	2081/08/04	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.79	66.9	24	18	0.1	0.02	6	2.15	0	Satisfactory
88	2081/08/04	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	< 5	7.73	71.1	22	22	0.1	0.02	4	1.29	0	Satisfactory
89	2081/08/04	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	< 5	7.75	71.5	22	22	0.1	0.02	4	0.85	0	Satisfactory
90	2081/08/04	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	< 5	7.79	71.7	22	22	0.1	0.02	4	0.28	0	Satisfactory
91	2081/08/04	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	< 5	7.9	72	22	22	0.1	0.02	4	0.43	0	Satisfactory
92	2081/08/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	< 5	7.71	75.7	22	22	0.1	0.02	4	1.19	0	Satisfactory
93	2081/08/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	< 5	7.48	73.3	22	22	0.1	0.02	4	1.16	0	Satisfactory
94	2081/08/04	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	< 5	7.97	71.1	22	22	0.1	0.02	4	0.8	0	Satisfactory
95	2081/08/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	< 5	7.94	72.1	22	22	0.1	0.02	4	0.88	0	Satisfactory
96	2081/08/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	< 5	7.87	74.2	22	22	0.1	0.02	4	0.85	0	Satisfactory
97	2081/08/04	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	< 5	7.74	74.6	22	22	0.1	0.02	4	1.26	0	Satisfactory
98	2081/08/04	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.35	<5	7.5	87.3	22	22	0.1	0.02	4	0.32	0	Satisfactory
99	2081/08/04	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.22	<5	7.86	59	20	26	0.1	0.02	6	0.40	0	Satisfactory
100	2081/08/04	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	41	16	16	0.1	0.02	6	0.90	0	Satisfactory
101	2081/08/04	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	41	16	16	0.1	0.02	6	1.02	0	Satisfactory
102	2081/08/04	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	39	16	16	0.1	0.02	6	0.97	0	Satisfactory
103	2081/08/04	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.98	<5	7.91	376	98	122	0.1	0.02	10	1.02	0	Satisfactory
104	2081/08/04	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.03	<5	7.22	402	116	72	0.3	0.02	24	2.5	0	Satisfactory
105	2081/08/04	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.45	<5	7.3	400	118	72	0.3	0.02	18	1.86	0	Satisfactory

106	2081/08/04	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.44	<5	7.1	423	122	70	0.3	0.02	20	0.88	0	Satisfactory
107	2081/08/05	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.5	<5	7.68	44.7	20	12	0.1	0.02	4	0.2	0	Satisfactory
108	2081/08/05	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.47	46.2	18	12	0.1	0.02	4	0.5	0	Satisfactory
109	2081/08/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.42	45.5	16	12	0.1	0.02	4	0.87	0	Satisfactory
110	2081/08/05	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.39	48.4	18	12	0.1	0.02	4	0.41	0	Satisfactory
111	2081/08/05	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.9	<5	8.19	70.3	24	18	0.1	0.02	6	0.19	0	Satisfactory
112	2081/08/05	12:25	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	8.13	68.9	24	18	0.1	0.02	6	0.98	0	Satisfactory
113	2081/08/05	8:30	Bhaktapur	Katunje SRT	Treated	Clear	0.4	<5	7.83	70.5	22	22	0.1	0.02	6	0.2	0	Satisfactory
114	2081/08/05	13:50	Lalitpur	Khumaltar SRT	Treated	Clear	2.1	<5	8.06	69.8	24	22	0.1	0.02	6	1.56	0	Satisfactory
115	2081/08/05	13:10	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.96	73.5	24	22	0.1	0.02	6	1.75	0	Satisfactory
116	2081/08/05	14:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	7.94	70.4	24	20	0.1	0.02	4	0.88	0	Satisfactory
117	2081/08/05		Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.93	68.1	24	22	0.1	0.02	4	0.26	0	Satisfactory
118	2081/08/05	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.69	69.6	22	18	0.1	0.02	6	0.73	0	Satisfactory
119	2081/08/05	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.4	67.3	22	18	0.1	0.02	6	0.68	0	Satisfactory
120	2081/08/05	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.5	68.7	22	18	0.1	0.02	6	0.78	0	Satisfactory
121	2081/08/05	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.43	68.4	24	18	0.1	0.02	6	0.76	0	Satisfactory
122	2081/08/05	0:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.44	< 5	7.77	74.1	22	22	0.1	0.02	4	1.59	0	Satisfactory
123	2081/08/05	2:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.48	< 5	7.72	73.8	22	22	0.1	0.02	4	0.83	0	Satisfactory
124	2081/08/05	4:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.45	< 5	7.93	73.7	22	22	0.1	0.02	4	0.25	0	Satisfactory
125	2081/08/05	6:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.43	< 5	8	73.6	22	22	0.1	0.02	4	0.62	0	Satisfactory
126	2081/08/05	8:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.47	< 5	7.85	75.6	22	22	0.1	0.02	4	0.99	0	Satisfactory
127	2081/08/05	10:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.45	< 5	7.43	74	22	22	0.1	0.02	4	0.57	0	Satisfactory
128	2081/08/05	12:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.63	< 5	7.9	74.1	22	22	0.1	0.02	4	0.7	0	Satisfactory
129	2081/08/05	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	< 5	7.97	75.4	22	22	0.1	0.02	4	0.84	0	Satisfactory
130	2081/08/05	16:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.52	< 5	7.86	74.9	22	22	0.1	0.02	4	0.82	0	Satisfactory
131	2081/08/05	17:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.5	< 5	7.5	75.3	22	22	0.1	0.02	4	1.15	0	Satisfactory
132	2081/08/05	22:00	Sundarijal WTP	New Sundarijal WTP	Treated	Clear	0.67	< 5	7.68	73.4	22	22	0.1	0.02	4	1.36	0	Satisfactory
133	2081/08/05	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.26	<5	7.5	86.3	22	22	0.1	0.02	4	0.3	0	Satisfactory
134	2081/08/05	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.13	<5	7.84	54	20	26	0.1	0.02	6	0.40	0	Satisfactory
135	2081/08/05	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.10	<5	7.62	56	20	26	0.1	0.02	6	1.08	0	Satisfactory
136	2081/08/05	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	47	18	18	0.1	0.02	6	0.66	0	Satisfactory
137	2081/08/05	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	42	16	16	0.1	0.02	6	1.03	0	Satisfactory
138	2081/08/05	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	41	16	16	0.1	0.02	6	1.01	0	Satisfactory
139	2081/08/05	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.55	<5	7.86	365	94	120	0.1	0.02	8	0.67	0	Satisfactory
140	2081/08/05	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.41	<5	7.2	414	120	70	0.3	0.02	22	2.2	0	Satisfactory
141	2081/08/05	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.61	<5	7.02	400	114	70	0.3	0.02	20	1.8	0	Satisfactory
142	2081/08/05	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.06	<5	7.05	396	114	70	0.3	0.02	20	1.49	0	Satisfactory
143	2081/08/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.39	44.5	16	12	0.1	0.02	4	0.88	0	Satisfactory

144	2081/08/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.48	47.6	16	12	0.1	0.02	4	0.2	0	Satisfactory
145	2081/08/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.29	47.6	16	12	0.1	0.02	4	0.2	0	Satisfactory
146	2081/08/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.45	47.2	18	12	0.1	0.02	4	0.2	0	Satisfactory
147	2081/08/06	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.2	70.9	24	18	0.1	0.02	6	0.2	0	Satisfactory
148	2081/08/06	13:40	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.37	69.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
149	2081/08/06	7:30	Bhaktapur	Katunje SRT	Treated	Clear	0.5	<5	6.68	66	22	22	0.1	0.02	6	0.2	0	Satisfactory
150	2081/08/06	13:50	Lalitpur	Khumaltar SRT	Treated	Clear	5	<5	7.49	65.4	24	22	0.1	0.02	6	0.2	0	Satisfactory
151	2081/08/06	12:35	Kirtipur	Kirtipur SRT	Treated	Clear	0.2	<5	7.52	70.4	24	22	0.1	0.02	6	0.2	0	Satisfactory
152	2081/08/06	11:20	Baneshwor	Minbhawan SRT	Treated	Clear	1.4	<5	7.59	68.9	24	20	0.1	0.02	4	0.2	0	Satisfactory
153	2081/08/06	14:35	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.3	66.7	24	20	0.1	0.02	4	0.2	0	Satisfactory
154	2081/08/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.3	68.5	22	18	0.1	0.02	6	0.75	0	Satisfactory
155	2081/08/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.4	69.7	22	18	0.1	0.02	6	0.2	0	Satisfactory
156	2081/08/06	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.18	68.6	22	18	0.1	0.02	6	0.2	0	Satisfactory
157	2081/08/06	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.2	66.3	24	18	0.1	0.02	6	0.2	0	Satisfactory
158	2081/08/06	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.71	73.1	22	22	0.1	0.02	4	1.49	0	Satisfactory
159	2081/08/06	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.77	72.6	22	22	0.1	0.02	4	0.83	0	Satisfactory
160	2081/08/06	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.87	70.3	22	22	0.1	0.02	4	0.29	0	Satisfactory
161	2081/08/06	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.99	73.4	22	22	0.1	0.02	4	0.47	0	Satisfactory
162	2081/08/06	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.82	75.9	22	22	0.1	0.02	4	0.97	0	Satisfactory
163	2081/08/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.71	73.2	22	22	0.1	0.02	4	0.63	0	Satisfactory
164	2081/08/06	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.7	70.4	22	22	0.1	0.02	4	0.88	0	Satisfactory
165	2081/08/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.77	73.2	22	22	0.1	0.02	4	0.67	0	Satisfactory
166	2081/08/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.74	74.3	22	22	0.1	0.02	4	0.61	0	Satisfactory
167	2081/08/06	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.32	74.2	22	22	0.1	0.02	4	1.21	0	Satisfactory
168	2081/08/06	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.59	72.9	22	22	0.1	0.02	4	0.97	0	Satisfactory
169	2081/08/06	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.37	<5	7.48	82.5	22	22	0.1	0.02	4	0.22	0	Satisfactory
170	2081/08/06	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.71	58	20	26	0.1	0.02	6	0.62	0	Satisfactory
171	2081/08/06	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	40	16	16	0.1	0.02	6	0.90	0	Satisfactory
172	2081/08/06	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.75	42	16	16	0.1	0.02	6	0.88	0	Satisfactory
173	2081/08/06	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	42	16	16	0.1	0.02	6	0.91	0	Satisfactory
174	2081/08/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.57	<5	8.11	419	104	130	0.1	0.02	12	0.74	0	Satisfactory
175	2081/08/06	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.49	<5	7.07	394	114	70	0.3	0.02	22	2.55	0	Satisfactory
176	2081/08/06	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.12	<5	7.01	391	114	70	0.3	0.02	20	1.05	0	Satisfactory

177	2081/08/06	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.53	<5	7.01	390	114	70	0.3	0.02	20	0.82	0	Satisfactory
178	2081/08/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.18	47.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
179	2081/08/07	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.15	43.3	16	12	0.1	0.02	4	0.2	0	Satisfactory
180	2081/08/07	17:20	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.79	46.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
181	2081/08/07	11:25	Tripureshwar	Anamnagar SRT	Treated	Clear	1.5	<5	7.09	67.7	24	16	0.1	0.02	6	0.2	0	Satisfactory
182	2081/08/07	8:20	Bhaktapur	Katunje SRT	Treated	Clear	0.4	<5	6.95	69.5	22	22	0.1	0.02	6	0.2	0	Satisfactory
183	2081/08/07	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	1.9	<5	7.83	68	24	22	0.1	0.02	6	0.2	0	Satisfactory
184	2081/08/07	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.76	69.9	24	22	0.1	0.02	6	0.2	0	Satisfactory
185	2081/08/07	11:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.8	67.9	24	20	0.1	0.02	4	0.2	0	Satisfactory
186	2081/08/07	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	6.87	64.5	22	18	0.1	0.02	6	0.2	0	Satisfactory
187	2081/08/07	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.18	66.7	22	18	0.1	0.02	6	0.2	0	Satisfactory
188	2081/08/07	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.67	68.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
189	2081/08/07	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.61	72.5	22	22	0.1	0.02	4	1.13	0	Satisfactory
190	2081/08/07	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.67	72.3	22	22	0.1	0.02	4	0.69	0	Satisfactory
191	2081/08/07	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.95	70.9	22	22	0.1	0.02	4	0.29	0	Satisfactory
192	2081/08/07	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.96	70.4	22	22	0.1	0.02	4	0.43	0	Satisfactory
193	2081/08/07	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.83	73.6	22	22	0.1	0.02	4	0.77	0	Satisfactory
194	2081/08/07	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.54	72.4	22	22	0.1	0.02	4	0.57	0	Satisfactory
195	2081/08/07	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.91	69.3	22	22	0.1	0.02	4	1.01	0	Satisfactory
196	2081/08/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	8.01	69.6	22	22	0.1	0.02	4	1.08	0	Satisfactory
197	2081/08/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.79	72.7	22	22	0.1	0.02	4	1.21	0	Satisfactory
198	2081/08/07	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.45	73.8	22	22	0.1	0.02	4	1.1	0	Satisfactory
199	2081/08/07	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.41	74.3	22	22	0.1	0.02	4	2.02	0	Satisfactory
200	2081/08/07	11:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.2	<5	7.6	85.8	22	22	0.1	0.02	4	0.56	0	Satisfactory
201	2081/08/07	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.33	<5	7.64	53	20	26	0.1	0.02	6	0.63	0	Satisfactory
202	2081/08/07	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	41	16	16	0.1	0.02	6	0.90	0	Satisfactory
203	2081/08/07	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.66	44	16	16	0.1	0.02	6	0.94	0	Satisfactory
204	2081/08/07	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.04	<5	8.17	401	102	130	0.1	0.02	12	0.81	0	Satisfactory
205	2081/08/07	10:20	Madhyapur Thimi	Bode WTP	Treated	Clear	3.2	<5	7.1	373	108	62	0.3	0.02	12	0.2	0	Satisfactory
206	2081/08/07	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.27	<5	7.25	400	122	80	0.3	0.02	24	2.81	0	Satisfactory
207	2081/08/08	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.78	49.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
208	2081/08/08	10:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.59	68.4	22	16	0.1	0.02	6	0.2	0	Satisfactory
209	2081/08/08	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.69	83.5	22	20	0.1	0.02	6	0.2	0	Satisfactory
210	2081/08/08	7:30	Bhaktapur	Katunje SRT	Treated	Clear	1	<5	7.23	75.3	24	22	0.1	0.02	6	0.2	0	Satisfactory

211	2081/08/08	9:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.98	72.3	22	22	0.1	0.02	6	0.2	0	Satisfactory
212	2081/08/08	10:35	Kirtipur	Kirtipur SRT	Treated	Clear	0.9	<5	7.65	68.2	22	22	0.1	0.02	6	0.2	0	Satisfactory
213	2081/08/08	10:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.79	67.5	22	20	0.1	0.02	4	0.2	0	Satisfactory
214	2081/08/08	12:00	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.67	69.2	22	24	0.1	0.02	4	0.2	0	Satisfactory
215	2081/08/08	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.65	66.2	22	18	0.1	0.02	6	0.2	0	Satisfactory
216	2081/08/08	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.48	73.9	22	22	0.1	0.02	4	2.24	0	Satisfactory
217	2081/08/08	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.5	71.9	22	22	0.1	0.02	4	1.51	0	Satisfactory
218	2081/08/08	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.81	73.4	22	22	0.1	0.02	4	0.83	0	Satisfactory
219	2081/08/08	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.79	73.9	22	22	0.1	0.02	4	1.1	0	Satisfactory
220	2081/08/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.64	75.6	22	22	0.1	0.02	4	1.05	0	Satisfactory
221	2081/08/08	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.72	74.1	22	22	0.1	0.02	4	1.16	0	Satisfactory
222	2081/08/08	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.82	75.3	22	22	0.1	0.02	4	1.21	0	Satisfactory
223	2081/08/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.78	74.8	22	22	0.1	0.02	4	1.12	0	Satisfactory
224	2081/08/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.83	75.6	22	22	0.1	0.02	4	1.22	0	Satisfactory
225	2081/08/08	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.45	73.6	22	22	0.1	0.02	4	1.5	0	Satisfactory
226	2081/08/08	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.63	53	20	26	0.1	0.02	6	0.52	0	Satisfactory
227	2081/08/08	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.66	41	16	16	0.1	0.02	6	0.67	0	Satisfactory
228	2081/08/08	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.73	41	16	16	0.1	0.02	6	0.74	0	Satisfactory
229	2081/08/08	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	39	16	16	0.1	0.02	6	0.72	0	Satisfactory
230	2081/08/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.49	51.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
231	2081/08/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.34	51.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
232	2081/08/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.24	49.1	14	12	0.1	0.02	4	0.2	0	Satisfactory
233	2081/08/09	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.44	48.1	16	12	0.1	0.02	4	0.2	0	Satisfactory
234	2081/08/09	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.99	76.1	24	20	0.1	0.02	6	0.2	0	Satisfactory
235	2081/08/09	13:08	Maharajgunj	Balaju SRT	Treated	Clear	0.7	<5	7.9	76.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
236	2081/08/09	7:40	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.2	76.3	22	22	0.1	0.02	6	0.2	0	Satisfactory
237	2081/08/09	14:35	Lalitpur	Khumaltar SRT	Treated	Clear	5	<5	7.74	73.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
238	2081/08/09	13:40	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.7	77.8	24	22	0.1	0.02	6	0.2	0	Satisfactory
239	2081/08/09	15:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.3	72.4	24	24	0.1	0.02	4	0.2	0	Satisfactory
240	2081/08/09		Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.16	71.2	24	20	0.1	0.02	4	0.2	0	Satisfactory
241	2081/08/09	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.43	74.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
242	2081/08/09	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.39	76.1	24	20	0.1	0.02	6	0.2	0	Satisfactory
243	2081/08/09	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.7	<5	7.35	75.1	24	18	0.1	0.02	6	0.2	0	Satisfactory

244	2081/08/09	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.7	<5	7.41	75.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
245	2081/08/09	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.49	73.3	22	22	0.1	0.02	4	1.97	0	Satisfactory
246	2081/08/09	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.52	73.2	22	22	0.1	0.02	4	1.29	0	Satisfactory
247	2081/08/09	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.5	72.8	22	22	0.1	0.02	4	0.73	0	Satisfactory
248	2081/08/09	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.92	73.2	22	22	0.1	0.02	4	0.11	0	Satisfactory
249	2081/08/09	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.8	75.3	22	22	0.1	0.02	4	0.92	0	Satisfactory
250	2081/08/09	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.65	73.6	22	22	0.1	0.02	4	1.02	0	Satisfactory
251	2081/08/09	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.83	74.3	22	22	0.1	0.02	4	1.15	0	Satisfactory
252	2081/08/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.96	74	22	22	0.1	0.02	4	0.79	0	Satisfactory
253	2081/08/09	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.27	74.2	22	22	0.1	0.02	4	1.2	0	Satisfactory
254	2081/08/09	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.21	73.9	22	22	0.1	0.02	4	1.19	0	Satisfactory
255	2081/08/09	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.46	74.4	22	22	0.1	0.02	4	1.74	0	Satisfactory
256	2081/08/09	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.52	82.5	22	22	0.1	0.02	4	0.29	0	Satisfactory
257	2081/08/09	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.17	<5	7.80	52	20	26	0.1	0.02	6	0.64	0	Satisfactory
258	2081/08/09	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.67	41	16	16	0.1	0.02	6	0.70	0	Satisfactory
259	2081/08/09	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	39	16	16	0.1	0.02	6	0.72	0	Satisfactory
260	2081/08/09	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	40	16	16	0.1	0.02	6	0.74	0	Satisfactory
261	2081/08/09	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.82	<5	7.84	381	100	126	0.1	0.02	10	0.84	0	Satisfactory
262	2081/08/09	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.62	<5	7.04	393	110	70	0.3	0.02	20	0.91	0	Satisfactory
263	2081/08/09	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.77	<5	7.24	421	126	76	0.3	0.02	22	2.18	0	Satisfactory
264	2081/08/09	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.74	<5	7.25	416	124	80	0.3	0.02	24	2.13	0	Satisfactory
265	2081/08/10	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.65	63.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
266	2081/08/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.2	64.3	16	12	0.1	0.02	4	0.2	0	Satisfactory
267	2081/08/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.18	64.7	18	12	0.1	0.02	4	0.2	0	Satisfactory
268	2081/08/10	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.2	63.5	18	12	0.1	0.02	4	0.2	0	Satisfactory
269	2081/08/10	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.67	103.5	26	24	0.1	0.02	6	0.2	0	Satisfactory
270	2081/08/10	11:55	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.89	137.9	26	26	0.1	0.02	6	0.2	0	Satisfactory
271	2081/08/10	7:40	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.15	104.8	26	22	0.1	0.02	6	0.2	0	Satisfactory

272	2081/08/10	13:05	Lalitpur	Khumaltar SRT	Treated	Clear	2.7	<5	7.78	101.5	26	26	0.1	0.02	6	0.2	0	Satisfactory
273	2081/08/10	12:35	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.75	105.3	26	22	0.1	0.02	6	0.2	0	Satisfactory
274	2081/08/10	13:35	Baneshwor	Minbhawan SRT	Treated	Clear	1.5	<5	7.83	103.4	26	26	0.1	0.02	4	0.2	0	Satisfactory
275	2081/08/10		Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.64	103.9	26	26	0.1	0.02	4	0.2	0	Satisfactory
276	2081/08/10	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.39	96.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
277	2081/08/10	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.25	94.7	22	22	0.1	0.02	6	0.2	0	Satisfactory
278	2081/08/10	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.15	96.3	26	22	0.1	0.02	6	0.2	0	Satisfactory
279	2081/08/10	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.23	97.6		22	0.1	0.02	6	0.2	0	Satisfactory
280	2081/08/10	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.48	74.1	22	22	0.1	0.02	4	2.24	0	Satisfactory
281	2081/08/10	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.45	73.9	22	22	0.1	0.02	4	1.32	0	Satisfactory
282	2081/08/10	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.68	72.1	22	22	0.1	0.02	4	0.63	0	Satisfactory
283	2081/08/10	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.87	71.2	22	22	0.1	0.02	4	0.97	0	Satisfactory
284	2081/08/10	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.82	75.7	22	22	0.1	0.02	4	1.01	0	Satisfactory
285	2081/08/10	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.8	76.7	22	22	0.1	0.02	4	1.38	0	Satisfactory
286	2081/08/10	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.77	74.8	22	22	0.1	0.02	4	0.98	0	Satisfactory
287	2081/08/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.74	75.5	22	22	0.1	0.02	4	1.47	0	Satisfactory
288	2081/08/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.57	74.4	22	22	0.1	0.02	4	1.59	0	Satisfactory
289	2081/08/10	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.42	75.9	22	22	0.1	0.02	4	1.69	0	Satisfactory
290	2081/08/10	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	7.46	74.3	22	22	0.1	0.02	4	1.82	0	Satisfactory
291	2081/08/10	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.22	<5	7.5	83.6	22	22	0.1	0.02	4	0.32	0	Satisfactory
292	2081/08/10	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.13	<5	7.63	56	20	26	0.1	0.02	6	0.62	0	Satisfactory
293	2081/08/10	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.67	42	16	16	0.1	0.02	6	0.72	0	Satisfactory
294	2081/08/10	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	43	16	18	0.1	0.02	6	0.74	0	Satisfactory
295	2081/08/10	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	41	16	16	0.1	0.02	6	0.70	0	Satisfactory
296	2081/08/10	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.06	<5	7.97	377	98	126	0.1	0.02	10	0.54	0	Satisfactory
297	2081/08/10	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	3.11	<5	7.16	410	118	78	0.3	0.02	24	2.66	0	Satisfactory
298	2081/08/10	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.92	<5	7.2	408	118	76	0.3	0.02	24	1.54	0	Satisfactory
299	2081/08/10	15:45	Madhyapur Thimi	Bode WTP	Treated	Clear	1.82	<5	7.24	467	136	78	0.3	0.02	20	1.13	0	Satisfactory

300	2081/08/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	8.06	64.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
301	2081/08/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.92	67.8	16	12	0.1	0.02	4	0.2	0	Satisfactory
302	2081/08/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.88	69.1	16	12	0.1	0.02	4	0.2	0	Satisfactory
303	2081/08/11	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.78	86.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
304	2081/08/11	10:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.89	113.2	26	24	0.1	0.02	6	0.2	0	Satisfactory
305	2081/08/11	8:30	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.9	110	26	22	0.1	0.02	6	0.2	0	Satisfactory
306	2081/08/11	10:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.9	<5	7.88	111.1	26	24	0.1	0.02	4	0.2	0	Satisfactory
307	2081/08/11		Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.94	110.6	26	24	0.1	0.02	4	0.2	0	Satisfactory
308	2081/08/11	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.8	97.6	26	22	0.1	0.02	6	0.2	0	Satisfactory
309	2081/08/11	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.76	98.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
310	2081/08/11	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.8	109.9	26	26	0.1	0.02	6	0.2	0	Satisfactory
311	2081/08/11	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.73	110.6	26	26	0.1	0.02	6	0.2	0	Satisfactory
312	2081/08/11	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.43	74	22	22	0.1	0.02	4	2.37	0	Satisfactory
313	2081/08/11	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.49	73.9	22	22	0.1	0.02	4	1.42	0	Satisfactory
314	2081/08/11	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.77	74	22	22	0.1	0.02	4	0.6	0	Satisfactory
315	2081/08/11	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.8	74.2	22	22	0.1	0.02	4	0.89	0	Satisfactory
316	2081/08/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.9	76.2	22	22	0.1	0.02	4	1.2	0	Satisfactory
317	2081/08/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.55	75.8	22	22	0.1	0.02	4	0.1	0	Satisfactory
318	2081/08/11	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.42	74.8	22	22	0.1	0.02	4	0.1	0	Satisfactory
319	2081/08/11	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.55	74.3	22	22	0.1	0.02	4	0.23	0	Satisfactory
320	2081/08/11	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.75	75.2	22	22	0.1	0.02	4	1.79	0	Satisfactory
321	2081/08/11	15:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.24	<5	7.35	89.5	22	22	0.1	0.02	4	1.45	0	Satisfactory
322	2081/08/11	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.18	<5	7.63	58	20	26	0.1	0.02	6	0.90	0	Satisfactory
323	2081/08/11	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	46	18	18	0.1	0.02	6	0.91	0	Satisfactory
324	2081/08/11	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.68	48	18	18	0.1	0.02	6	0.87	0	Satisfactory
325	2081/08/11	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	49	18	18	0.1	0.02	6	0.87	0	Satisfactory
326	2081/08/11	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	8.02	378	100	126	0.1	0.02	10	0.66	0	Satisfactory
327	2081/08/11	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.18	<5	6.98	373	104	66	0.3	0.02	14	0.32	0	Satisfactory

328	2081/08/11	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	7.1	375	106	70	0.3	0.02	20	0.45	0	Satisfactory
329	2081/08/11	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.4	<5	7.1	386	110	70	0.3	0.02	20	0.46	0	Satisfactory
330	2081/08/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.96	41.2	14	12	0.1	0.02	4	0.2	0	Satisfactory
331	2081/08/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.73	42.3	14	12	0.1	0.02	4	0.2	0	Satisfactory
332	2081/08/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.78	42.3	14	12	0.1	0.02	4	0.2	0	Satisfactory
333	2081/08/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.69	45.1	16	12	0.1	0.02	4	0.2	0	Satisfactory
334	2081/08/12	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.3	<5	7.75	78.7	24	20	0.1	0.02	6	0.2	0	Satisfactory
335	2081/08/12	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.2	<5	7.43	81.3	24	22	0.1	0.02	6	0.2	0	Satisfactory
336	2081/08/12	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.78	76.8	24	22	0.1	0.02	6	0.2	0	Satisfactory
337	2081/08/12	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.85	79.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
338	2081/08/12	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	0:00	<5	7.7	75.3	24	24	0.1	0.02	4	0.2	0	Satisfactory
339	2081/08/12		Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.78	76.3	24	24	0.1	0.02	4	0.2	0	Satisfactory
340	2081/08/12	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.89	73.4	24	18	0.1	0.02	6	0.2	0	Satisfactory
341	2081/08/12	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.45	75.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
342	2081/08/12	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.62	72.7	26	18	0.1	0.02	6	0.2	0	Satisfactory
343	2081/08/12	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.6	75.9	24	18	0.1	0.02	6	0.2	0	Satisfactory
344	2081/08/12	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.72	74.9	22	22	0.1	0.02	4	2.37	0	Satisfactory
345	2081/08/12	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.75	74.7	22	22	0.1	0.02	4	1.39	0	Satisfactory
346	2081/08/12	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.76	74.7	22	22	0.1	0.02	4	0.51	0	Satisfactory
347	2081/08/12	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.68	74.6	22	22	0.1	0.02	4	0.85	0	Satisfactory
348	2081/08/12	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.75	76.4	22	22	0.1	0.02	4	0.83	0	Satisfactory
349	2081/08/12	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.78	76.1	22	22	0.1	0.02	4	1.32	0	Satisfactory
350	2081/08/12	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.66	76.2	22	22	0.1	0.02	4	1.69	0	Satisfactory
351	2081/08/12	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.68	75.8	22	22	0.1	0.02	4	1.59	0	Satisfactory
352	2081/08/12	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.59	76.8	22	22	0.1	0.02	4	2.04	0	Satisfactory
353	2081/08/12	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.47	75.2	22	22	0.1	0.02	4	1.72	0	Satisfactory
354	2081/08/12	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.42	<5	7.43	86.6	22	22	0.1	0.02	4	0.38	0	Satisfactory
355	2081/08/12	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.35	<5	7.74	65	22	28	0.1	0.02	6	0.67	0	Satisfactory
356	2081/08/12	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.63	38	14	14	0.1	0.02	6	0.51	0	Satisfactory
357	2081/08/12	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.61	40	16	16	0.1	0.02	6	0.71	0	Satisfactory
358	2081/08/12	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.63	39	14	16	0.1	0.02	6	0.74	0	Satisfactory
359	2081/08/12	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.75	<5	8.04	374	98	124	0.1	0.02	10	0.2	0	Satisfactory
360	2081/08/12	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.1	<5	7.11	369	102	66	0.3	0.02	10	0.2	0	Satisfactory

361	2081/08/12	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.16	<5	7.2	383	110	74	0.3	0.02	20	1.23	0	Satisfactory
362	2081/08/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.63	44.9	16	12	0.1	0.02	4	0.2	0	Satisfactory
363	2081/08/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	7.55	48.2	18	12	0.1	0.02	4	0.2	0	Satisfactory
364	2081/08/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4	<5	7.31	65.3	14	12	0.1	0.02	4	0.2	0	Satisfactory
365	2081/08/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.3	56.7	14	12	0.1	0.02	4	0.2	0	Satisfactory
366	2081/08/13	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	2.2	<5	7.37	78.5	24	20	0.1	0.02	6	0.2	0	Satisfactory
367	2081/08/13		Bhaktapur	Katunje SRT	Treated	Clear	1.2	<5	7.65	76.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
368	2081/08/13	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	1.9	<5	7.68	77.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
369	2081/08/13	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	1.4	<5	7.75	79.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
370	2081/08/13	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	1.5	<5	7.4	74.8	24	24	0.1	0.02	4	0.2	0	Satisfactory
371	2081/08/13		Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	8.32	98.7	24	24	0.1	0.02	4	0.2	0	Satisfactory
372	2081/08/13	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.65	72.8	24	18	0.1	0.02	6	0.2	0	Satisfactory
373	2081/08/13	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.79	76.2	26	20	0.1	0.02	6	0.2	0	Satisfactory
374	2081/08/13	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.48	75.4	22	18	0.1	0.02	6	0.2	0	Satisfactory
375	2081/08/13	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.35	74.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
376	2081/08/13	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.49	75	22	22	0.1	0.02	4	2.09	0	Satisfactory
377	2081/08/13	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.53	74.9	22	22	0.1	0.02	4	1.19	0	Satisfactory
378	2081/08/13	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.61	74.3	22	22	0.1	0.02	4	0.43	0	Satisfactory
379	2081/08/13	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.68	74.5	22	22	0.1	0.02	4	0.73	0	Satisfactory
380	2081/08/13	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.64	76.4	22	22	0.1	0.02	4	1.27	0	Satisfactory
381	2081/08/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.7	78.8	22	22	0.1	0.02	4	1.24	0	Satisfactory
382	2081/08/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.68	77.3	22	22	0.1	0.02	4	1.38	0	Satisfactory
383	2081/08/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.6	76.9	22	22	0.1	0.02	4	1.42	0	Satisfactory
384	2081/08/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.92	75.5	22	22	0.1	0.02	4	1.54	0	Satisfactory
385	2081/08/13	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.44	76.5	22	22	0.1	0.02	4	1.46	0	Satisfactory
386	2081/08/13	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.51	75.7	22	22	0.1	0.02	4	2	0	Satisfactory
387	2081/08/13	15:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.82	<5	7.62	87.1	22	22	0.1	0.02	4	1.18	0	Satisfactory
388	2081/08/13	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.26	<5	7.64	66	22	26	0.1	0.02	6	1.07	0	Satisfactory
389	2081/08/13	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	2.54	<5	7.62	45	16	16	0.1	0.02	6	1.02	0	Satisfactory
390	2081/08/13	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	47	18	18	0.1	0.02	6	0.97	0	Satisfactory
391	2081/08/13	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	50	18	18	0.1	0.02	6	0.92	0	Satisfactory
392	2081/08/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	8.24	375	98	124	0.1	0.02	10	0.81	0	Satisfactory
393	2081/08/13	10:20	Madhyapur Thimi	Bode WTP	Treated	Clear	3.54	<5	7.2	427	122	80	0.3	0.02	24	2.06	0	Satisfactory

394	2081/08/13	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.53	<5	7.32	427	124	80	0.3	0.02	24	3.12	0	Satisfactory
395	2081/08/13	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.05	<5	7.18	396	116	76	0.3	0.02	24	2.22	0	Satisfactory
396	2081/08/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.4	48.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
397	2081/08/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.48	50.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
398	2081/08/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.52	46.6	16	12	0.1	0.02	4	0.2	0	Satisfactory
399	2081/08/14	11:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.78	74.7	22	18	0.1	0.02	6	0.2	0	Satisfactory
400	2081/08/14		Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.3	71.6	24	22	0.1	0.02	6	0.2	0	Satisfactory
401	2081/08/14	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	5	<5	7.83	75.1	22	22	0.1	0.02	6	0.2	0	Satisfactory
402	2081/08/14	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	7.8	79.9	22	22	0.1	0.02	6	0.2	0	Satisfactory
403	2081/08/14	11:45	Baneshwor	Minbhawan SRT	Treated	Clear	1.3	<5	7.8	75.6	22	24	0.1	0.02	4	0.2	0	Satisfactory
404	2081/08/14	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.38	71.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
405	2081/08/14	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.48	74.8	22	18	0.1	0.02	6	0.2	0	Satisfactory
406	2081/08/14	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.43	74.4	22	18	0.1	0.02	6	0.2	0	Satisfactory
407	2081/08/14	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.55	75.3	22	22	0.1	0.02	4	2.49	0	Satisfactory
408	2081/08/14	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.5	74.9	22	22	0.1	0.02	4	1.47	0	Satisfactory
409	2081/08/14	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.88	73.6	22	22	0.1	0.02	4	0.59	0	Satisfactory
410	2081/08/14	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.94	73.2	22	22	0.1	0.02	4	0.72	0	Satisfactory
411	2081/08/14	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.71	74.9	22	22	0.1	0.02	4	0.92	0	Satisfactory
412	2081/08/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.75	72.6	22	22	0.1	0.02	4	1.12	0	Satisfactory
413	2081/08/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.89	74	22	22	0.1	0.02	4	1.15	0	Satisfactory
414	2081/08/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.75	74.8	22	22	0.1	0.02	4	1.25	0	Satisfactory
415	2081/08/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.63	75.1	22	22	0.1	0.02	4	1.37	0	Satisfactory
416	2081/08/14	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.48	74.3	22	22	0.1	0.02	4	1.26	0	Satisfactory
417	2081/08/14	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.78	73.5	22	22	0.1	0.02	4	1.58	0	Satisfactory
418	2081/08/14	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.77	<5	6.45	86	22	22	0.1	0.02	4	0.3	0	Satisfactory
419	2081/08/14	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.77	58	20	26	0.1	0.02	6	0.82	0	Satisfactory
420	2081/08/14	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	47	16	16	0.1	0.02	6	0.86	0	Satisfactory
421	2081/08/14	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	48	18	18	0.1	0.02	6	1.04	0	Satisfactory
422	2081/08/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	8.02	383	100	126	0.1	0.02	10	0.73	0	Satisfactory
423	2081/08/14	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.69	<5	6.95	391	112	70	0.3	0.02	18	0.7	0	Satisfactory
424	2081/08/14	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.75	<5	7.16	422	120	76	0.3	0.02	22	2.17	0	Satisfactory
425	2081/08/15	13:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.62	44	16	12	0.1	0.02	4	0.2	0	Satisfactory
426	2081/08/15	13:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.53	71	26	18	0.1	0.02	6	0.2	0	Satisfactory

427	2081/08/15	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.8	73.2	22	22	0.1	0.02	4	2.03	0	Satisfactory
428	2081/08/15	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.82	73	22	22	0.1	0.02	4	1.3	0	Satisfactory
429	2081/08/15	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.9	72.8	22	22	0.1	0.02	4	0.63	0	Satisfactory
430	2081/08/15	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.91	72	22	22	0.1	0.02	4	1	0	Satisfactory
431	2081/08/15	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.02	<5	7.84	73.3	22	22	0.1	0.02	4	0.7	0	Satisfactory
432	2081/08/15	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.79	73.3	22	22	0.1	0.02	4	0.79	0	Satisfactory
433	2081/08/15	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.6	73.8	22	22	0.1	0.02	4	1.6	0	Satisfactory
434	2081/08/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.35	73.6	22	22	0.1	0.02	4	1.23	0	Satisfactory
435	2081/08/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.54	74.7	22	22	0.1	0.02	4	0.78	0	Satisfactory
436	2081/08/15	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.48	74.4	22	22	0.1	0.02	4	2.19	0	Satisfactory
437	2081/08/15	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.77	58	22	28	0.1	0.02	6	0.80	0	Satisfactory
438	2081/08/15	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.72	44	16	16	0.1	0.02	6	0.92	0	Satisfactory
439	2081/08/15	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.68	41	16	16	0.1	0.02	6	0.87	0	Satisfactory
440	2081/08/15	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.73	42	16	16	0.1	0.02	6	0.93	0	Satisfactory
441	2081/08/16	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.75	45.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
442	2081/08/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.47	43.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
443	2081/08/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.49	43	16	12	0.1	0.02	4	0.2	0	Satisfactory
444	2081/08/16	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	7.4	65.2	14	12	0.1	0.02	4	0.2	0	Satisfactory
445	2081/08/16	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.99	76.2	22	18	0.1	0.02	6	0.2	0	Satisfactory
446	2081/08/16	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.2	75.7	24	22	0.1	0.02	6	0.2	0	Satisfactory
447	2081/08/16	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.7	<5	7.89	75.7	22	22	0.1	0.02	6	0.2	0	Satisfactory
448	2081/08/16	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	1.12	<5	7.97	75.7	22	22	0.1	0.02	6	0.2	0	Satisfactory
449	2081/08/16	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.95	70.6	22	24	0.1	0.02	4	0.2	0	Satisfactory
450	2081/08/16		Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.85	74.2	22	24	0.1	0.02	4	0.2	0	Satisfactory
451	2081/08/16	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.55	72.3	22	18	0.1	0.02	6	0.2	0	Satisfactory
452	2081/08/16	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.37	69.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
453	2081/08/16	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.64	74.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
454	2081/08/16	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.48	73.3	22	18	0.1	0.02	6	0.2	0	Satisfactory
455	2081/08/16	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.5	74	22	22	0.1	0.02	4	2.49	0	Satisfactory
456	2081/08/16	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.68	73.9	22	22	0.1	0.02	4	1.57	0	Satisfactory
457	2081/08/16	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.77	72.9	22	22	0.1	0.02	4	0.51	0	Satisfactory

458	2081/08/16	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.85	72.5	22	22	0.1	0.02	4	0.89	0	Satisfactory
459	2081/08/16	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.63	73.5	22	22	0.1	0.02	4	0.97	0	Satisfactory
460	2081/08/16	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.81	73.5	22	22	0.1	0.02	4	1.59	0	Satisfactory
461	2081/08/16	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.88	70.6	22	22	0.1	0.02	4	1.32	0	Satisfactory
462	2081/08/16	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.77	75.9	22	22	0.1	0.02	4	1.43	0	Satisfactory
463	2081/08/16	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.76	76	22	22	0.1	0.02	4	1.22	0	Satisfactory
464	2081/08/16	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.17	75.9	22	22	0.1	0.02	4	1.38	0	Satisfactory
465	2081/08/16	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.62	76	22	22	0.1	0.02	4	2.04	0	Satisfactory
466	2081/08/16	14:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.83	<5	7.6	85	22	22	0.1	0.02	4	1.04	0	Satisfactory
467	2081/08/16	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.10	<5	7.73	63	22	28	0.1	0.02	6	0.86	0	Satisfactory
468	2081/08/16	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	47	16	16	0.1	0.02	6	0.94	0	Satisfactory
469	2081/08/16	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.58	46	16	16	0.1	0.02	6	0.87	0	Satisfactory
470	2081/08/16	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.56	44	16	16	0.1	0.02	6	0.86	0	Satisfactory
471	2081/08/16	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	7.87	381	100	126	0.1	0.02	10	0.74	0	Satisfactory
472	2081/08/16	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.17	<5	6.96	380	104	68	0.3	0.02	12	0.2	0	Satisfactory
473	2081/08/16	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.59	<5	7.02	374	104	68	0.3	0.02	12	0.2	0	Satisfactory
474	2081/08/16	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.52	<5	7.1	401	112	68	0.3	0.02	12	0.2	0	Satisfactory
475	2081/08/17	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.1	55.6	18	12	0.1	0.02	4	0.2	0	Satisfactory
476	2081/08/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.3	57.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
477	2081/08/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.12	58.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
478	2081/08/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.48	87.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
479	2081/08/17	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.43	74.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
480	2081/08/17	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.28	85.7	24	22	0.1	0.02	6	0.2	0	Satisfactory
481	2081/08/17	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.9	<5	7.4	72.7	24	24	0.1	0.02	4	0.2	0	Satisfactory
482	2081/08/17	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.1	<5	7.17	75.1	24	18	0.1	0.02	6	0.2	0	Satisfactory
483	2081/08/17	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.15	71.9	22	18	0.1	0.02	6	0.2	0	Satisfactory
484	2081/08/17	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.25	74.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
485	2081/08/17	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	5	<5	7.5	74.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
486	2081/08/17	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.65	75.8	22	22	0.1	0.02	4	2.44	0	Satisfactory
487	2081/08/17	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.69	75.7	22	22	0.1	0.02	4	1.49	0	Satisfactory
488	2081/08/17	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.88	74.6	22	22	0.1	0.02	4	0.47	0	Satisfactory
489	2081/08/17	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.01	<5	7.93	74.5	22	22	0.1	0.02	4	0.83	0	Satisfactory

490	2081/08/17	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.79	75.9	22	22	0.1	0.02	4	1.04	0	Satisfactory
491	2081/08/17	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.11	<5	7.98	74.2	22	22	0.1	0.02	4	1.2	0	Satisfactory
492	2081/08/17	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.92	75.9	22	22	0.1	0.02	4	1.28	0	Satisfactory
493	2081/08/17	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	7.52	75.7	22	22	0.1	0.02	4	1.31	0	Satisfactory
494	2081/08/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.14	<5	7.9	75.1	22	22	0.1	0.02	4	1.05	0	Satisfactory
495	2081/08/17	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.3	<5	7.88	74.4	22	22	0.1	0.02	4	0.47	0	Satisfactory
496	2081/08/17	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.69	75.2	22	22	0.1	0.02	4	1.52	0	Satisfactory
497	2081/08/17	14:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.97	<5	7.56	83.3	22	22	0.1	0.02	4	0.7	0	Satisfactory
498	2081/08/17	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.26	<5	7.72	61	20	26	0.1	0.02	6	0.83	0	Satisfactory
499	2081/08/17	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.66	40	16	16	0.1	0.02	6	0.86	0	Satisfactory
500	2081/08/17	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	39	14	16	0.1	0.02	6	0.71	0	Satisfactory
501	2081/08/17	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.62	38	14	14	0.1	0.02	6	0.66	0	Satisfactory
502	2081/08/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.52	<5	7.92	375	98	124	0.1	0.02	8	0.86	0	Satisfactory
503	2081/08/17	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.92	<5	7.01	369	100	66	0.3	0.02	12	0.2	0	Satisfactory
504	2081/08/17	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.25	<5	7.14	383	108	72	0.3	0.02	18	0.89	0	Satisfactory
505	2081/08/17	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.46	<5	7.18	391	114	68	0.3	0.02	16	0.32	0	Satisfactory
506	2081/08/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.6	<5	7.25	69.9	16	12	0.1	0.02	4	0.2	0	Satisfactory
507	2081/08/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.43	76.1	18	12	0.1	0.02	4	0.2	0	Satisfactory
508	2081/08/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.41	74.8	14	12	0.1	0.02	4	0.2	0	Satisfactory
509	2081/08/18	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3	<5	7.55	53	14	12	0.1	0.02	4	0.2	0	Satisfactory
510	2081/08/18	14:25	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.73	75.3	22	18	0.1	0.02	6	0.2	0	Satisfactory
511	2081/08/18	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	6.95	75.7	24	22	0.1	0.02	6	0.2	0	Satisfactory
512	2081/08/18	13:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.9	<5	7.38	73.8	22	22	0.1	0.02	6	0.2	0	Satisfactory
513	2081/08/18	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	1.6	<5	7.61	77.7	22	22	0.1	0.02	6	0.2	0	Satisfactory
514	2081/08/18	14:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.6	<5	7.73	76	22	24	0.1	0.02	4	0.2	0	Satisfactory
515	2081/08/18		Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.8	84.3	22	24	0.1	0.02	4	0.2	0	Satisfactory
516	2081/08/18	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.7	<5	7.28	75.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
517	2081/08/18	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.8	<5	7.44	75.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
518	2081/08/18	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.2	<5	7.48	75.9	22	18	0.1	0.02	6	0.2	0	Satisfactory
519	2081/08/18	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.48	75	22	18	0.1	0.02	6	0.2	0	Satisfactory
520	2081/08/18	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.73	75	22	22	0.1	0.02	4	1.87	0	Satisfactory
521	2081/08/18	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.71	74.8	22	22	0.1	0.02	4	1.1	0	Satisfactory
522	2081/08/18	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.77	75.8	22	22	0.1	0.02	4	0.31	0	Satisfactory

523	2081/08/18	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.84	76.6	22	22	0.1	0.02	4	0.66	0	Satisfactory
524	2081/08/18	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.71	77.3	22	22	0.1	0.02	4	0.97	0	Satisfactory
525	2081/08/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.8	77.4	22	22	0.1	0.02	4	0.65	0	Satisfactory
526	2081/08/18	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.97	76	22	22	0.1	0.02	4	0.58	0	Satisfactory
527	2081/08/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.87	76.5	22	22	0.1	0.02	4	1.54	0	Satisfactory
528	2081/08/18	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.88	76.7	22	22	0.1	0.02	4	1.34	0	Satisfactory
529	2081/08/18	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.85	76.1	22	22	0.1	0.02	4	1.14	0	Satisfactory
530	2081/08/18	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.79	76	22	22	0.1	0.02	4	1.62	0	Satisfactory
531	2081/08/18	14:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.69	<5	6.79	84.5	22	22	0.1	0.02	4	0.8	0	Satisfactory
532	2081/08/18	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.13	<5	7.73	58	20	26	0.1	0.02	6	0.86	0	Satisfactory
533	2081/08/18	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.70	38	16	16	0.1	0.02	6	0.51	0	Satisfactory
534	2081/08/18	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	42	16	16	0.1	0.02	6	0.71	0	Satisfactory
535	2081/08/18	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	42	16	16	0.1	0.02	6	0.73	0	Satisfactory
536	2081/08/18	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.08	<5	7.91	390	104	128	0.1	0.02	10	0.71	0	Satisfactory
537	2081/08/18	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.73	<5	6.89	375	102	66	0.3	0.02	10	0.2	0	Satisfactory
538	2081/08/18	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.98	<5	7.06	391	110	78	0.3	0.02	24	1.89	0	Satisfactory
539	2081/08/18	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.74	<5	7.18	387	110	74	0.3	0.02	20	0.92	0	Satisfactory
540	2081/08/19	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.58	54.9	16	12	0.1	0.02	4	0.2	0	Satisfactory
541	2081/08/19	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.72	55.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
542	2081/08/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.63	55.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
543	2081/08/19	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.3	<5	7.66	61.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
544	2081/08/19	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	1.2	<5	7.88	77.5	24	20	0.1	0.02	6	0.2	0	Satisfactory
545	2081/08/19	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.45	76.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
546	2081/08/19	10:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	7.82	74.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
547	2081/08/19	10:40	Kirtipur	Kirtipur SRT	Treated	Clear	1.6	<5	7.87	78.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
548	2081/08/19	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2	<5	7.48	69.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
549	2081/08/19	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.75	69.7	22	18	0.1	0.02	6	0.2	0	Satisfactory
550	2081/08/19	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.6	<5	7.6	74	22	18	0.1	0.02	6	0.2	0	Satisfactory
551	2081/08/19	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.9	<5	7.78	73.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
552	2081/08/19	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.77	75.9	22	22	0.1	0.02	4	1.89	0	Satisfactory
553	2081/08/19	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.7	75.6	22	22	0.1	0.02	4	1.06	0	Satisfactory
554	2081/08/19	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.89	74.8	22	22	0.1	0.02	4	0.44	0	Satisfactory

555	2081/08/19	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.93	74.5	22	22	0.1	0.02	4	0.81	0	Satisfactory
556	2081/08/19	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.9	76	22	22	0.1	0.02	4	1.15	0	Satisfactory
557	2081/08/19	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.9	77.7	22	22	0.1	0.02	4	1.06	0	Satisfactory
558	2081/08/19	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.89	76.4	22	22	0.1	0.02	4	0.8	0	Satisfactory
559	2081/08/19	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	8.06	71.1	22	22	0.1	0.02	4	1.14	0	Satisfactory
560	2081/08/19	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.84	76	22	22	0.1	0.02	4	1.1	0	Satisfactory
561	2081/08/19	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.34	74.6	22	22	0.1	0.02	4	1.43	0	Satisfactory
562	2081/08/19	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.5	84.2	22	22	0.1	0.02	4	0.28	0	Satisfactory
563	2081/08/19	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.33	<5	7.78	55	20	26	0.1	0.02	6	0.36	0	Satisfactory
564	2081/08/19	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.66	32	16	16	0.1	0.02	6	0.70	0	Satisfactory
565	2081/08/19	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	41	16	16	0.1	0.02	6	0.87	0	Satisfactory
566	2081/08/19	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	42	16	16	0.1	0.02	6	0.91	0	Satisfactory
567	2081/08/19	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.74	<5	7.97	377	98	126	0.1	0.02	10	0.84	0	Satisfactory
568	2081/08/19	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.12	<5	7.18	421	120	78	0.3	0.02	24	2.74	0	Satisfactory
569	2081/08/19	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.07	<5	7.14	428	124	78	0.3	0.02	24	1.8	0	Satisfactory
570	2081/08/19	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.8	<5	7.13	419	120	76	0.3	0.02	22	1.3	0	Satisfactory
571	2081/08/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.85	50.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
572	2081/08/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	8.1	50.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
573	2081/08/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.6	<5	7.6	47.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
574	2081/08/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.78	64.6	14	12	0.1	0.02	4	0.2	0	Satisfactory
575	2081/08/20	10:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	8.05	76.6	24	18	0.1	0.02	6	0.2	0	Satisfactory
576	2081/08/20	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.1	<5	7.7	78.7	22	22	0.1	0.02	6	0.2	0	Satisfactory
577	2081/08/20	10:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	8	78.4	24	22	0.1	0.02	6	0.2	0	Satisfactory
578	2081/08/20	10:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.9	<5	8.24	77.2	24	24	0.1	0.02	4	0.2	0	Satisfactory
579	2081/08/20		Maharajgunj	Panipokhari SRT	Treated	Clear	2.7	<5	7.97	75	24	24	0.1	0.02	4	0.2	0	Satisfactory
580	2081/08/20	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2	<5	7.7	74.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
581	2081/08/20	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.85	74.8	24	18	0.1	0.02	6	0.2	0	Satisfactory
582	2081/08/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.3	<5	7.58	72.9	24	18	0.1	0.02	6	0.2	0	Satisfactory
583	2081/08/20	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.79	72.9	24	18	0.1	0.02	6	0.2	0	Satisfactory
584	2081/08/20	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.37	74.8	22	22	0.1	0.02	4	1.8	0	Satisfactory
585	2081/08/20	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.39	74.3	22	22	0.1	0.02	4	1	0	Satisfactory
586	2081/08/20	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.81	75.6	22	22	0.1	0.02	4	0.52	0	Satisfactory
587	2081/08/20	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.97	75.2	22	22	0.1	0.02	4	1.09	0	Satisfactory

588	2081/08/20	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.75	77.8	22	22	0.1	0.02	4	1.36	0	Satisfactory
589	2081/08/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.73	76.3	22	22	0.1	0.02	4	1.63	0	Satisfactory
590	2081/08/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	8.14	75.4	22	22	0.1	0.02	4	1.13	0	Satisfactory
591	2081/08/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	8.07	77.5	22	22	0.1	0.02	4	1.05	0	Satisfactory
592	2081/08/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.98	76.7	22	22	0.1	0.02	4	1.07	0	Satisfactory
593	2081/08/20	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.57	75.8	22	22	0.1	0.02	4	1.1	0	Satisfactory
594	2081/08/20	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.5	<5	7.5	90.2	22	22	0.1	0.02	4	0.39	0	Satisfactory
595	2081/08/20	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.17	<5	7.73	62	20	26	0.1	0.02	6	1.01	0	Satisfactory
596	2081/08/20	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	47	18	18	0.1	0.02	6	1.04	0	Satisfactory
597	2081/08/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.31	<5	8.14	388	98	128	0.1	0.02	10	0.65	0	Satisfactory
598	2081/08/20	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	4.92	<5	7.1	417	118	72	0.3	0.02	18	0.48	0	Satisfactory
599	2081/08/20	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	5	<5	6.96	384	104	66	0.3	0.02	18	0.6	0	Satisfactory
600	2081/08/20	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	4.98	<5	6.95	382	104	68	0.3	0.02	16	0.52	0	Satisfactory
601	2081/08/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.88	47.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
602	2081/08/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.87	49.2	16	12	0.1	0.02	4	0.2	0	Satisfactory
603	2081/08/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	8.05	48.6	14	12	0.1	0.02	4	0.2	0	Satisfactory
604	2081/08/21	13:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	8.19	76.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
605	2081/08/21	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.77	76.3	24	22	0.1	0.02	6	0.2	0	Satisfactory
606	2081/08/21	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	8.05	78.7	24	22	0.1	0.02	6	0.2	0	Satisfactory
607	2081/08/21	13:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	8.27	77.2	24	24	0.1	0.02	4	0.2	0	Satisfactory
608	2081/08/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.2	<5	7.77	74.3	16	18	0.1	0.02	6	0.2	0	Satisfactory
609	2081/08/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.6	<5	7.87	73.2	22	18	0.1	0.02	6	0.2	0	Satisfactory
610	2081/08/21	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.92	70.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
611	2081/08/21	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.59	74.9	22	22	0.1	0.02	4	1.69	0	Satisfactory
612	2081/08/21	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.62	74.5	22	22	0.1	0.02	4	1.01	0	Satisfactory
613	2081/08/21	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.91	75.8	22	22	0.1	0.02	4	0.4	0	Satisfactory
614	2081/08/21	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.99	75.6	22	22	0.1	0.02	4	0.73	0	Satisfactory
615	2081/08/21	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.83	77	22	22	0.1	0.02	4	1.29	0	Satisfactory
616	2081/08/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.82	76.1	22	22	0.1	0.02	4	1.02	0	Satisfactory
617	2081/08/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.72	77.1	22	22	0.1	0.02	4	1.62	0	Satisfactory
618	2081/08/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.62	76.7	22	22	0.1	0.02	4	1.5	0	Satisfactory

619	2081/08/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.48	75.7	22	22	0.1	0.02	4	1.2	0	Satisfactory
620	2081/08/21	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.66	76.5	22	22	0.1	0.02	4	1.52	0	Satisfactory
621	2081/08/21	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.43	<5	7.5	86.8	22	22	0.1	0.02	4	0.2	0	Satisfactory
622	2081/08/21	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.73	<5	7.77	59	20	26	0.1	0.02	6	0.41	0	Satisfactory
623	2081/08/21	13:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.64	<5	7.52	62	20	26	0.1	0.02	6	0.37	0	Satisfactory
624	2081/08/21	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.50	<5	7.56	40	16	16	0.1	0.02	6	0.63	0	Satisfactory
625	2081/08/21	12:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.42	<5	7.53	41	16	16	0.1	0.02	6	0.72	0	Satisfactory
626	2081/08/21	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.91	<5	8.24	388	100	128	0.1	0.02	10	0.66	0	Satisfactory
627	2081/08/21	10:20	Madhyapur Thimi	Bode WTP	Treated	Clear	5	<5	7.04	384	106	68	0.3	0.02	18	0.54	0	Satisfactory
628	2081/08/22	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.69	76.3	22	22	0.1	0.02	4	1.89	0	Satisfactory
629	2081/08/22	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.73	76.4	22	22	0.1	0.02	4	1.09	0	Satisfactory
630	2081/08/22	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.8	75.8	22	22	0.1	0.02	4	0.41	0	Satisfactory
631	2081/08/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.82	75.5	22	22	0.1	0.02	4	0.64	0	Satisfactory
632	2081/08/22	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.8	77.7	22	22	0.1	0.02	4	1.43	0	Satisfactory
633	2081/08/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.93	76.7	22	22	0.1	0.02	4	1.43	0	Satisfactory
634	2081/08/22	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.96	77	22	22	0.1	0.02	4	1.41	0	Satisfactory
635	2081/08/22	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.96	75.6	22	22	0.1	0.02	4	1.11	0	Satisfactory
636	2081/08/22	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.92	75.9	22	22	0.1	0.02	4	1.33	0	Satisfactory
637	2081/08/22	11:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.22	<5	7.73	61	20	26	0.1	0.02	6	0.51	0	Satisfactory
638	2081/08/22	13:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.16	<5	7.71	64	20	28	0.1	0.02	6	1.46	0	Satisfactory
639	2081/08/22	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.64	42	16	16	0.1	0.02	6	0.70	0	Satisfactory
640	2081/08/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.9	45.4	16	12	0.1	0.02	4	0.2	0	Satisfactory
641	2081/08/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	8	47.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
642	2081/08/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.6	<5	8.14	52.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
643	2081/08/23	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.85	46.8	16	12	0.1	0.02	4	0.2	0	Satisfactory
644	2081/08/23	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	8.14	77.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
645	2081/08/23	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.4	<5	7.83	78.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
646	2081/08/23	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	5	<5	8.19	88.9	24	22	0.2	0.02	6	0.2	0	Satisfactory
647	2081/08/23	12:40	Kirtipur	Kirtipur SRT	Treated	Clear	1.4	<5	8.22	80.1	24	22	0.1	0.02	6	0.2	0	Satisfactory
648	2081/08/23	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	1.7	<5	8.14	80.1	24	24	0.1	0.02	4	0.2	0	Satisfactory
649	2081/08/23		Maharajgunj	Panipokhari SRT	Treated	Clear	3.1	<5	8.15	78	24	24	0.1	0.02	4	0.2	0	Satisfactory
650	2081/08/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.81	76.5	24	20	0.1	0.02	6	0.2	0	Satisfactory
651	2081/08/23	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.86	75	22	18	0.1	0.02	6	0.2	0	Satisfactory
652	2081/08/23	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.9	<5	8	76.3	24	18	0.1	0.02	6	0.2	0	Satisfactory

653	2081/08/23	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.83	75	24	18	0.1	0.02	6	0.2	0	Satisfactory
654	2081/08/23	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.95	75.6	22	22	0.1	0.02	4	1.47	0	Satisfactory
655	2081/08/23	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.99	75.3	22	22	0.1	0.02	4	0.81	0	Satisfactory
656	2081/08/23	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	8.02	75.2	22	22	0.1	0.02	4	0.3	0	Satisfactory
657	2081/08/23	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	8.05	75.4	22	22	0.1	0.02	4	0.63	0	Satisfactory
658	2081/08/23	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.86	78.2	22	22	0.1	0.02	4	1.41	0	Satisfactory
659	2081/08/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.87	79.8	22	22	0.1	0.02	4	1.36	0	Satisfactory
660	2081/08/23	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	8.02	76	22	22	0.1	0.02	4	1.2	0	Satisfactory
661	2081/08/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	8.04	76.7	22	22	0.1	0.02	4	1.18	0	Satisfactory
662	2081/08/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	8.06	77.1	22	22	0.1	0.02	4	1.24	0	Satisfactory
663	2081/08/23	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.76	76.6	22	22	0.1	0.02	4	1.6	0	Satisfactory
664	2081/08/23	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.73	76.7	22	22	0.1	0.02	4	1.69	0	Satisfactory
665	2081/08/23	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.47	<5	7.52	87	22	22	0.1	0.02	4	0.18	0	Satisfactory
666	2081/08/23	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.24	<5	7.72	59	20	26	0.1	0.02	6	0.44	0	Satisfactory
667	2081/08/23	14:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.32	<5	7.53	63	20	26	0.1	0.02	6	2.01	0	Satisfactory
668	2081/08/23	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.28	<5	7.64	40	16	16	0.1	0.02	6	0.86	0	Satisfactory
669	2081/08/23	14:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.62	44	18	18	0.1	0.02	6	0.91	0	Satisfactory
670	2081/08/23	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.54	<5	7.1	380	104	70	0.3	0.02	20	0.87	0	Satisfactory
671	2081/08/23	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	7.15	374	104	70	0.3	0.02	20	0.51	0	Satisfactory
672	2081/08/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	8.02	45.4	14	12	0.1	0.02	4	0.2	0	Satisfactory
673	2081/08/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.89	44.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
674	2081/08/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.96	50.8	16	12	0.1	0.02	4	0.2	0	Satisfactory
675	2081/08/24	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.93	43.6	16	12	0.1	0.02	4	0.2	0	Satisfactory
676	2081/08/24	11:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.84	76.6	22	18	0.1	0.02	6	0.2	0	Satisfactory
677	2081/08/24	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1	<5	7.28	76.9	22	22	0.1	0.02	6	0.2	0	Satisfactory
678	2081/08/24	12:15	Baneshwor	Minbhawan SRT	Treated	Clear	1.3	<5	7.85	75.9	22	24	0.1	0.02	4	0.2	0	Satisfactory
679	2081/08/24		Maharajgunj	Panipokhari SRT	Treated	Clear	1.5	<5	7.83	75.6	22	24	0.1	0.02	4	0.2	0	Satisfactory
680	2081/08/24	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.84	76.1	24	20	0.1	0.02	6	0.2	0	Satisfactory
681	2081/08/24	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	8	62.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
682	2081/08/24	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.9	64.3	24	16	0.1	0.02	6	0.2	0	Satisfactory
683	2081/08/24	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.8	61.6	22	16	0.1	0.02	6	0.2	0	Satisfactory

684	2081/08/24	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.71	76.3	22	22	0.1	0.02	4	1.73	0	Satisfactory
685	2081/08/24	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.74	76	22	22	0.1	0.02	4	1.01	0	Satisfactory
686	2081/08/24	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.79	75.9	22	22	0.1	0.02	4	0.39	0	Satisfactory
687	2081/08/24	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	8.02	76.9	22	22	0.1	0.02	4	1.19	0	Satisfactory
688	2081/08/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.87	77.5	22	22	0.1	0.02	4	1.44	0	Satisfactory
689	2081/08/24	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.93	75.1	22	22	0.1	0.02	4	0.86	0	Satisfactory
690	2081/08/24	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.73	77.4	22	22	0.1	0.02	4	1.79	0	Satisfactory
691	2081/08/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.84	77.1	22	22	0.1	0.02	4	1.56	0	Satisfactory
692	2081/08/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.22	77.1	22	22	0.1	0.02	4	1.45	0	Satisfactory
693	2081/08/24	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.78	77.3	22	22	0.1	0.02	4	1.65	0	Satisfactory
694	2081/08/24	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.87	75.7	22	22	0.1	0.02	4	1.15	0	Satisfactory
695	2081/08/24	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.5	<5	7.55	90.3	22	22	0.1	0.02	4	0.33	0	Satisfactory
696	2081/08/24	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.26	<5	7.74	64	22	28	0.1	0.02	6	0.41	0	Satisfactory
697	2081/08/24	14:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.82	66	22	28	0.1	0.02	6	1.01	0	Satisfactory
698	2081/08/24	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	39	16	16	0.1	0.02	6	0.90	0	Satisfactory
699	2081/08/24	13:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	38	16	16	0.1	0.02	6	0.71	0	Satisfactory
700	2081/08/24	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.60	41	16	16	0.1	0.02	6	0.74	0	Satisfactory
701	2081/08/24	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.41	<5	8.02	392	104	130	0.1	0.02	10	0.84	0	Satisfactory
702	2081/08/24	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.89	<5	1.16	367	102	66	0.3	0.02	12	0.2	0	Satisfactory
703	2081/08/24	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.84	<5	7.17	365	102	66	0.3	0.02	12	0.2	0	Satisfactory
704	2081/08/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.29	45.4	16	12	0.1	0.02	4	0.2	0	Satisfactory
705	2081/08/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3	<5	7.14	45.3	16	12	0.1	0.02	4	0.2	0	Satisfactory
706	2081/08/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.26	44	14	12	0.1	0.02	4	0.2	0	Satisfactory
707	2081/08/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.63	51.9	16	12	0.1	0.02	4	0.2	0	Satisfactory
708	2081/08/25	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.66	77.6	24	18	0.1	0.02	6	0.2	0	Satisfactory
709	2081/08/25	14:30	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.68	78.5	24	20	0.1	0.02	6	0.2	0	Satisfactory
710	2081/08/25	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.8	<5	7.3	78.1	24	22	0.1	0.02	6	0.2	0	Satisfactory
711	2081/08/25	12:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.77	75.9	24	24	0.1	0.02	6	0.2	0	Satisfactory
712	2081/08/25	12:55	Kirtipur	Kirtipur SRT	Treated	Clear	1.1	<5	7.72	79.4	24	22	0.1	0.02	6	0.2	0	Satisfactory
713	2081/08/25	11:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.71	75.6	24	24	0.1	0.02	4	0.2	0	Satisfactory
714	2081/08/25		Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.3	75	24	24	0.1	0.02	4	0.2	0	Satisfactory
715	2081/08/25	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.2	73	24	18	0.1	0.02	6	0.2	0	Satisfactory
716	2081/08/25	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.38	76.4	24	18	0.1	0.02	6	0.2	0	Satisfactory
717	2081/08/25	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.28	76.1	24	18	0.1	0.02	6	0.2	0	Satisfactory

718	2081/08/25	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.68	76.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
719	2081/08/25	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.82	75.4	22	22	0.1	0.02	4	1.56	0	Satisfactory
720	2081/08/25	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.01	77	22	22	0.1	0.02	4	0.91	0	Satisfactory
721	2081/08/25	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.46	77.8	22	22	0.1	0.02	4	0.33	0	Satisfactory
722	2081/08/25	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.51	78.7	22	22	0.1	0.02	4	0.63	0	Satisfactory
723	2081/08/25	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.68	77.9	22	22	0.1	0.02	4	0.88	0	Satisfactory
724	2081/08/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.57	78.4	22	22	0.1	0.02	4	1.3	0	Satisfactory
725	2081/08/25	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.77	77.8	22	22	0.1	0.02	4	1.59	0	Satisfactory
726	2081/08/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.67	77.2	22	22	0.1	0.02	4	1.2	0	Satisfactory
727	2081/08/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.62	76.4	22	22	0.1	0.02	4	1.17	0	Satisfactory
728	2081/08/25	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.87	77.1	22	22	0.1	0.02	4	1.52	0	Satisfactory
729	2081/08/25	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	8.1	76.3	22	22	0.1	0.02	4	1	0	Satisfactory
730	2081/08/25	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.82	<5	7.55	88.4	22	22	0.1	0.02	4	0.3	0	Satisfactory
731	2081/08/25	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.15	<5	7.81	64	20	28	0.1	0.02	6	0.51	0	Satisfactory
732	2081/08/25	13:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.10	<5	7.60	64	22	28	0.1	0.02	6	0.54	0	Satisfactory
733	2081/08/25	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.11	<5	7.77	65	22	28	0.1	0.02	6	0.64	0	Satisfactory
734	2081/08/25	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	38	16	16	0.1	0.02	6	0.94	0	Satisfactory
735	2081/08/25	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.65	39	16	16	0.1	0.02	6	0.92	0	Satisfactory
736	2081/08/25	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	40	16	16	0.1	0.02	6	0.95	0	Satisfactory
737	2081/08/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.72	<5	7.96	371	96	122	0.1	0.02	8	0.86	0	Satisfactory
738	2081/08/25	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.95	<5	7.1	357	100	66	0.3	0.02	12	0.2	0	Satisfactory
739	2081/08/25	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.04	<5	7.12	353	100	66	0.3	0.02	12	0.2	0	Satisfactory
740	2081/08/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.74	48.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
741	2081/08/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.69	50.9	14	12	0.1	0.02	4	0.2	0	Satisfactory
742	2081/08/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.7	51.4	14	12	0.1	0.02	4	0.2	0	Satisfactory
743	2081/08/26	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.9	52.8	16	12	0.1	0.02	4	0.2	0	Satisfactory
744	2081/08/26	14:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	8	77.4	22	18	0.1	0.02	6	0.2	0	Satisfactory
745	2081/08/26	8:30	Bhaktapur	Katunje SRT	Treated	Clear	0.3	<5	7.56	76.9	24	22	0.1	0.02	6	0.2	0	Satisfactory
746	2081/08/26	13:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.7	<5	8.21	79.9	22	22	0.1	0.02	6	0.2	0	Satisfactory
747	2081/08/26	12:55	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	8.02	75.5	22	22	0.1	0.02	6	0.2	0	Satisfactory
748	2081/08/26	14:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.89	75.7	22	24	0.1	0.02	4	0.2	0	Satisfactory
749	2081/08/26		Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.96	71.5	22	24	0.1	0.02	4	0.2	0	Satisfactory
750	2081/08/26	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.59	77.8	22	18	0.1	0.02	6	0.2	0	Satisfactory
751	2081/08/26	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.66	65.3	22	18	0.1	0.02	6	0.2	0	Satisfactory

752	2081/08/26	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.68	66.3	24	18	0.1	0.02	6	0.2	0	Satisfactory
753	2081/08/26	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.83	65	22	18	0.1	0.02	6	0.2	0	Satisfactory
754	2081/08/26	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	8.07	76	22	22	0.1	0.02	4	1.49	0	Satisfactory
755	2081/08/26	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.8	76.2	22	22	0.1	0.02	4	0.89	0	Satisfactory
756	2081/08/26	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.71	76.5	22	22	0.1	0.02	4	0.39	0	Satisfactory
757	2081/08/26	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.68	79.1	22	22	0.1	0.02	4	0.76	0	Satisfactory
758	2081/08/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.97	77.6	22	22	0.1	0.02	4	1.2	0	Satisfactory
759	2081/08/26	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.91	77.9	22	22	0.1	0.02	4	1.86	0	Satisfactory
760	2081/08/26	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.72	78	22	22	0.1	0.02	4	2.06	0	Satisfactory
761	2081/08/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.84	77.2	22	22	0.1	0.02	4	1.51	0	Satisfactory
762	2081/08/26	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.34	77.2	22	22	0.1	0.02	4	1.01	0	Satisfactory
763	2081/08/26	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.79	76.8	22	22	0.1	0.02	4	1.2	0	Satisfactory
764	2081/08/26	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.84	76.8	22	22	0.1	0.02	4	1.73	0	Satisfactory
765	2081/08/26	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.75	<5	7.56	78.2	22	22	0.1	0.02	4	0.38	0	Satisfactory
766	2081/08/26	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.70	<5	7.80	63	20	26	0.1	0.02	6	0.72	0	Satisfactory
767	2081/08/26	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.21	<5	7.73	61	20	26	0.1	0.02	6	0.63	0	Satisfactory
768	2081/08/26	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.64	40	16	16	0.1	0.02	6	0.91	0	Satisfactory
769	2081/08/26	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	41	16	16	0.1	0.02	6	0.80	0	Satisfactory
770	2081/08/26	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.71	42	16	16	0.1	0.02	6	0.74	0	Satisfactory
771	2081/08/26	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.84	<5	7.86	383	100	126	0.1	0.02	10	0.75	0	Satisfactory
772	2081/08/26	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.46	<5	7.01	311	94	60	0.3	0.02	12	0.2	0	Satisfactory
773	2081/08/26	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.36	<5	7.04	306	94	60	0.3	0.02	12	0.2	0	Satisfactory
774	2081/08/26	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	7.02	309	94	60	0.3	0.02	12	0.2	0	Satisfactory
775	2081/08/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.97	55.3	16	12	0.1	0.02	4	0.2	0	Satisfactory
776	2081/08/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	6.98	52.7	14	12	0.1	0.02	4	0.2	0	Satisfactory
777	2081/08/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.95	62.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
778	2081/08/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	6.45	63.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
779	2081/08/27	19:54	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	6.48	82.7	26	18	0.1	0.02	6	0.2	0	Satisfactory
780	2081/08/27	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	6.25	80.2	24	20	0.1	0.02	6	0.2	0	Satisfactory
781	2081/08/27	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.1	<5	7.85	76.3	24	22	0.1	0.02	6	0.2	0	Satisfactory
782	2081/08/27	13:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.7	<5	6.45	81.5	26	22	0.1	0.02	6	0.2	0	Satisfactory
783	2081/08/27	12:55	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	6.4	83.7	26	22	0.1	0.02	6	0.2	0	Satisfactory
784	2081/08/27	14:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	6.4	80	26	24	0.1	0.02	4	0.2	0	Satisfactory
785	2081/08/27		Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	6.4	82.4	26	24	0.1	0.02	4	0.2	0	Satisfactory

786	2081/08/27	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.83	76.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
787	2081/08/27	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	6.89	71.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
788	2081/08/27	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	6.88	78.2	24	20	0.1	0.02	6	0.2	0	Satisfactory
789	2081/08/27	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	6.49	80.7	26	20	0.1	0.02	6	0.2	0	Satisfactory
790	2081/08/27	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.87	76.9	22	22	0.1	0.02	4	2.09	0	Satisfactory
791	2081/08/27	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.91	76.5	22	22	0.1	0.02	4	1.39	0	Satisfactory
792	2081/08/27	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.81	76.8	22	22	0.1	0.02	4	0.58	0	Satisfactory
793	2081/08/27	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.55	76.8	22	22	0.1	0.02	4	1.19	0	Satisfactory
794	2081/08/27	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.83	78.1	22	22	0.1	0.02	4	1.12	0	Satisfactory
795	2081/08/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.88	78.5	22	22	0.1	0.02	4	1.09	0	Satisfactory
796	2081/08/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.45	77.7	22	22	0.1	0.02	4	1.47	0	Satisfactory
797	2081/08/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.22	77.8	22	22	0.1	0.02	4	1.59	0	Satisfactory
798	2081/08/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.84	78	22	22	0.1	0.02	4	1.54	0	Satisfactory
799	2081/08/27	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.56	78.3	22	22	0.1	0.02	4	1.51	0	Satisfactory
800	2081/08/27	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	8.08	76.8	22	22	0.1	0.02	4	0.78	0	Satisfactory
801	2081/08/27	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.05	<5	7.35	72.7	22	22	0.1	0.02	4	0.26	0	Satisfactory
802	2081/08/27	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.17	<5	7.80	57	20	26	0.1	0.02	6	0.43	0	Satisfactory
803	2081/08/27	13:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.74	63	20	26	0.1	0.02	6	0.61	0	Satisfactory
804	2081/08/27	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.22	<5	7.62	68	22	30	0.1	0.02	6	1.57	0	Satisfactory
805	2081/08/27	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	40	16	16	0.1	0.02	6	0.66	0	Satisfactory
806	2081/08/27	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.57	42	16	16	0.1	0.02	6	0.74	0	Satisfactory
807	2081/08/27	14:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.56	47	18	18	0.1	0.02	6	0.71	0	Satisfactory
808	2081/08/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.05	<5	7.91	376	98	124	0.1	0.02	8	0.82	0	Satisfactory
809	2081/08/27	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.02	<5	7.08	304	94	60	0.3	0.02	12	0.2	0	Satisfactory
810	2081/08/27	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.71	<5	7.04	300	94	60	0.3	0.02	12	0.2	0	Satisfactory
811	2081/08/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.3	<5	7.6	56.2	14	12	0.1	0.02	4	0.2	0	Satisfactory
812	2081/08/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.1	<5	7.4	49.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
813	2081/08/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.4	<5	7.65	54.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
814	2081/08/28	10:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.36	77.5	24	18	0.1	0.02	6	0.2	0	Satisfactory
815	2081/08/28	11:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.9	79.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
816	2081/08/28	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.9	<5	7.5	77.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
817	2081/08/28	11:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.5	75	24	24	0.1	0.02	4	0.2	0	Satisfactory
818	2081/08/28	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.5	67.2	22	18	0.1	0.02	6	0.2	0	Satisfactory

819	2081/08/28	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.32	71.5	22	18	0.1	0.02	6	0.2	0	Satisfactory
820	2081/08/28	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.58	75.3	24	18	0.1	0.02	6	0.2	0	Satisfactory
821	2081/08/28	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	8.05	76.2	22	22	0.1	0.02	4	1.14	0	Satisfactory
822	2081/08/28	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.91	76.9	22	22	0.1	0.02		0.81	0	Satisfactory
823	2081/08/28	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.81	77	22	22	0.1	0.02		0.63	0	Satisfactory
824	2081/08/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.67	77.3	22	22	0.1	0.02		0.76	0	Satisfactory
825	2081/08/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.85	78.7	22	22	0.1	0.02		1.03	0	Satisfactory
826	2081/08/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.75	78.6	22	22	0.1	0.02		1.23	0	Satisfactory
827	2081/08/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.92	77	22	22	0.1	0.02		1.32	0	Satisfactory
828	2081/08/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.59	79.4	22	22	0.1	0.02		1.89	0	Satisfactory
829	2081/08/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.74	76.1	22	22	0.1	0.02		2.03	0	Satisfactory
830	2081/08/28	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.14	76.7	22	22	0.1	0.02		1.49	0	Satisfactory
831	2081/08/28	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.72	76.4	22	22	0.1	0.02	1.8	0	Satisfactory	
832	2081/08/28	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.40	<5	7.78	68	22	30	0.1	0.02	6	0.2	0	Satisfactory
833	2081/08/28	13:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.36	<5	7.57	66	22	28	0.1	0.02	6	0.46	0	Satisfactory
834	2081/08/28	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	7.54	67	22	30	0.1	0.02	6	1.42	0	Satisfactory
835	2081/08/28	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.64	46	18	18	0.1	0.02	6	0.46	0	Satisfactory
836	2081/08/28	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.63	51	20	20	0.1	0.02	6	0.52	0	Satisfactory
837	2081/08/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.66	<5	7.92	391	104	128	0.1	0.02	10	0.79	0	Satisfactory
838	2081/08/28	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.4	<5	7.04	298	94	58	0.3	0.02	10	0.2	0	Satisfactory
839	2081/08/28	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.73	<5	6.99	299	94	60	0.3	0.02	10	0.2	0	Satisfactory
840	2081/08/29	13:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.78	59.5	16	12	0.1	0.02	4	0.2	0	Satisfactory
841	2081/08/29	10:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	8.04	81.7	24	18	0.1	0.02	6	0.2	0	Satisfactory
842	2081/08/29	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.7	<5	7.98	75.2	24	18	0.1	0.02	6	0.2	0	Satisfactory
843	2081/08/29	10:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.79	78.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
844	2081/08/29	13:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.95	78.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
845	2081/08/29	10:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.9	76.7	24	24	0.1	0.02	4	0.2	0	Satisfactory
846	2081/08/29		Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	8	78.5	24	24	0.1	0.02	4	0.2	0	Satisfactory
847	2081/08/29	13:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.8	76.7	24	20	0.1	0.02	6	0.2	0	Satisfactory
848	2081/08/29	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.81	76.3	22	22	0.1	0.02	4	2.03	0	Satisfactory
849	2081/08/29	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.8	76.5	22	22	0.1	0.02		1.54	0	Satisfactory
850	2081/08/29	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.74	76.4	22	22	0.1	0.02		0.49	0	Satisfactory
851	2081/08/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.77	76.7	22	22	0.1	0.02		0.76	0	Satisfactory

852	2081/08/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.86	77.9	22	22	0.1	0.02	4	0.91	0	Satisfactory
853	2081/08/29	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.73	77.9	22	22	0.1	0.02	4	1.42	0	Satisfactory
854	2081/08/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.3	78.4	22	22	0.1	0.02	4	1.54	0	Satisfactory
855	2081/08/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.71	77.7	22	22	0.1	0.02	4	1.36	0	Satisfactory
856	2081/08/29	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.82	77.4	22	22	0.1	0.02	4	1.56	0	Satisfactory
857	2081/08/29	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.32	<5	7.22	67	22	28	0.1	0.02	6	0.33	0	Satisfactory
858	2081/08/29	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.74	41	16	16	0.1	0.02	6	0.54	0	Satisfactory
859	2081/08/30	8:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.72	52.7	16	12	0.1	0.02	4	0.2	0	Satisfactory
860	2081/08/30	8:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.79	75.6	24	18	0.1	0.02	6	0.2	0	Satisfactory
861	2081/08/30	0:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.8	77.1	22	22	0.1	0.02	4	1.93	0	Satisfactory
862	2081/08/30	2:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.81	75.9	22	22	0.1	0.02	4	1.38	0	Satisfactory
863	2081/08/30	4:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.76	77.9	22	22	0.1	0.02	4	0.41	0	Satisfactory
864	2081/08/30	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.28	<5	7.66	78.8	22	22	0.1	0.02	4	0.68	0	Satisfactory
865	2081/08/30	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.62	77.6	22	22	0.1	0.02	4	1.07	0	Satisfactory
866	2081/08/30	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.75	77.6	22	22	0.1	0.02	4	1.73	0	Satisfactory
867	2081/08/30	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.88	76.6	22	22	0.1	0.02	4	2	0	Satisfactory
868	2081/08/30	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.8	79.3	22	22	0.1	0.02	4	1.78	0	Satisfactory
869	2081/08/30	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.82	78.4	22	22	0.1	0.02	4	2.23	0	Satisfactory
870	2081/08/30	22:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.91	75.6	22	22	0.1	0.02	4	1.27	0	Satisfactory
871	2081/08/30	11:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.76	<5	7.68	65	22	28	0.1	0.02	6	0.37	0	Satisfactory
872	2081/08/30	11:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.66	47	18	18	0.1	0.02	6	1.04	0	Satisfactory