



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Magh 2081

S.N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	p ^H	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
							(NTU)	(TCU)		µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml	
National Drinking Water Quality Standard (NDWQS)							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2081/10/01	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.27	57	20	20	0.1	0.02	6	0.86	0	Satisfactory
2	2081/10/01	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.37	<5	7.27	67	24	30	0.1	0.02	6	0.23	0	Satisfactory
3	2081/10/01	7:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	8.13	84.3	24	24	0.1	0.02	4	0.66	0	Satisfactory
4	2081/10/01	9:55	Maharajgunj	Balaju SRT	Treated	Clear	2	<5	8.19	85.5	24	24	0.1	0.02	4	0.55	0	Satisfactory
5	2081/10/01	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.92	78.7	24	22	0.1	0.02	6	0.4	0	Satisfactory
6	2081/10/01	8:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.86	79.3	24	22	0.1	0.02	6	0.68	0	Satisfactory
7	2081/10/01	8:40	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.83	80.9	24	22	0.1	0.02	6	0.64	0	Satisfactory
8	2081/10/01	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.73	79	24	22	0.1	0.02	6	1.06	0	Satisfactory
9	2081/10/01	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.76	63.1	12	8	0.1	0.02	4	1.81	0	Satisfactory
10	2081/10/01	7:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.92	79.2	24	22	0.1	0.02	6	0.76	0	Satisfactory
11	2081/10/01	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.89	80	24	24	0.1	0.02	6	0.67	0	Satisfactory
12	2081/10/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.97	82.2	24	22	0.1	0.02	6	0.8	0	Satisfactory
13	2081/10/01	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.62	79.9	24	22	0.1	0.02	6	0.85	0	Satisfactory
14	2081/10/01	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.64	80.4	24	22	0.1	0.02	6	1.37	0	Satisfactory
15	2081/10/01	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.54	80.8	24	22	0.1	0.02	6	1.23	0	Satisfactory
16	2081/10/01	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.52	80.6	24	22	0.1	0.02	6	1.53	0	Satisfactory
17	2081/10/02	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	51	20	20	0.1	0.02	6	0.70	0	Satisfactory
18	2081/10/02	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.18	53	20	22	0.1	0.02	6	0.71	0	Satisfactory

19	2081/10/02	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.24	56	22	24	0.1	0.02	6	0.93	0	Satisfactory
20	2081/10/02	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.31	<5	7.28	66	22	30	0.1	0.02	6	0.63	0	Satisfactory
21	2081/10/02	14:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.25	77.5	24	22	0.1	0.02	4	0.8	0	Satisfactory
22	2081/10/02	11:55	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.3	82.5	24	24	0.1	0.02	4	0.22	0	Satisfactory
23	2081/10/02	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.96	78.9	26	22	0.1	0.02	6	0.22	0	Satisfactory
24	2081/10/02	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.3	77.5	24	22	0.1	0.02	6	0.85	0	Satisfactory
25	2081/10/02	12:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.3	80.5	24	22	0.1	0.02	6	0.54	0	Satisfactory
26	2081/10/02	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.1	72.5	26	22	0.1	0.02	6	1.02	0	Satisfactory
27	2081/10/02	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.25	76.2	24	22	0.1	0.02	6	1.18	0	Satisfactory
28	2081/10/02	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.3	78.5	26	22	0.1	0.02	6	1.22	0	Satisfactory
29	2081/10/02	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.12	79	24	22	0.1	0.02	6	0.9	0	Satisfactory
30	2081/10/02	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	8.07	67.5	14	8	0.1	0.02	4	2.05	0	Satisfactory
31	2081/10/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.6	<5	7.4	78.2	16	12	0.1	0.02	4	3.09	0	Satisfactory
32	2081/10/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	7.32	72.7	14	12	0.1	0.02	4	2.27	0	Satisfactory
33	2081/10/02	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.25	58	14	8	0.1	0.02	4	1.32	0	Satisfactory
34	2081/10/02	13:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.3	78.2	24	22	0.1	0.02	6	0.61	0	Satisfactory
35	2081/10/02	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.5	70.5	24	24	0.1	0.02	6	0.34	0	Satisfactory
36	2081/10/02	10:15	Thimi	Bode WTP	Treated	Clear	1.76	<5	7.08	318	102	62	0.57	1.5	16	0.26	0	Satisfactory
37	2081/10/02	13:00	Thimi	Bode WTP	Treated	Clear	4.12	<5	7.02	324	104	68	0.57	1.5	20	0.62	0	Satisfactory
38	2081/10/02	9:50	Thimi	Tigani SRT	Treated	Clear	1.54	<5	7.72	75	28	36	0.1	0.02	4	0.4	0	Satisfactory
39	2081/10/02	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.41	<5	7.84	414	120	130	0.1	0.02	12	0.81	0	Satisfactory
40	2081/10/02	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.36	80.1	24	22	0.1	0.02	6	0.76	0	Satisfactory
41	2081/10/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.72	79.5	24	22	0.1	0.02	6	1.29	0	Satisfactory
42	2081/10/02	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.64	80.7	24	22	0.1	0.02	6	1.07	0	Satisfactory
43	2081/10/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.64	80.1	24	22	0.1	0.02	6	1.55	0	Satisfactory
44	2081/10/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.72	79.8	24	22	0.1	0.02	6	1.2	0	Satisfactory
45	2081/10/02	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.85	79.5	24	22	0.1	0.02	6	1.37	0	Satisfactory
46	2081/10/03	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	53	20	20	0.1	0.02	6	0.70	0	Satisfactory

47	2081/10/03	14:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.25	54	20	20	0.1	0.02	6	0.73	0	Satisfactory
48	2081/10/03	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.31	66	22	28	0.1	0.02	6	0.73	0	Satisfactory
49	2081/10/03	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.63	<5	7.26	70	24	30	0.1	0.02	6	0.56	0	Satisfactory
50	2081/10/03	11:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.28	79.2	26	22	0.1	0.02	4	0.35	0	Satisfactory
51	2081/10/03	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	7.48	67.5	24	20	0.1	0.02	6	0.4	0	Satisfactory
52	2081/10/03	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.36	75.9	26	22	0.1	0.02	6	0.28	0	Satisfactory
53	2081/10/03	13:50	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.2	80.7	26	22	0.1	0.02	6	0.35	0	Satisfactory
54	2081/10/03	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.45	77.5	26	22	0.1	0.02	6	0.56	0	Satisfactory
55	2081/10/03	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.25	78.5	24	22	0.1	0.02	6	1.77	0	Satisfactory
56	2081/10/03	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.43	79.5	24	22	0.1	0.02	6	1.52	0	Satisfactory
57	2081/10/03	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.52	75.7	26	22	0.1	0.02	6	1.65	0	Satisfactory
58	2081/10/03	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.5	66.7	14	8	0.1	0.02	4	1.22	0	Satisfactory
59	2081/10/03	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.31	65.2	16	10	0.1	0.02	4	2.34	0	Satisfactory
60	2081/10/03	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.48	65.9	16	10	0.1	0.02	4	1.3	0	Satisfactory
61	2081/10/03	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.5	66.3	16	10	0.1	0.02	4	1.35	0	Satisfactory
62	2081/10/03	12:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.23	78.2	26	22	0.1	0.02	6	0.24	0	Satisfactory
63	2081/10/03	10:30	Thimi	Bode WTP	Treated	Clear	1.68	<5	7.32	320	108	66	0.57	1.5	12	0.4	0	Satisfactory
64	2081/10/03	13:00	Thimi	Bode WTP	Treated	Clear	1.88	<5	7.33	343	116	72	0.57	1.5	22	1.02	0	Satisfactory
65	2081/10/03	9:45	Thimi	Tigani SRT	Treated	Clear	1.44	<5	7.7	74.5	28	36	0.1	0.02	4	0.4	0	Satisfactory
66	2081/10/03	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.75	<5	7.89	408	120	128	0.1	0.02	12	0.67	0	Satisfactory
67	2081/10/03	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.85	80.9	24	22	0.1	0.02	6	0.69	0	Satisfactory
68	2081/10/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.62	80.1	24	22	0.1	0.02	6	1.94	0	Satisfactory
69	2081/10/03	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.64	79.7	24	22	0.1	0.02	6	1.22	0	Satisfactory
70	2081/10/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.72	80.7	24	22	0.1	0.02	6	1.62	0	Satisfactory
71	2081/10/03	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.74	81	24	22	0.1	0.02	6	1.33	0	Satisfactory
72	2081/10/03	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.86	80.6	24	22	0.1	0.02	6	1.36	0	Satisfactory
73	2081/10/04	10:30	Thimi	Bode WTP	Treated	Clear	1.91	<5	7.2	336	110	68	0.57	1.5	18	0.37	0	Satisfactory
74	2081/10/04	13:00	Thimi	Bode WTP	Treated	Clear	2.27	<5	7.42	366	124	76	0.57	1.5	20	1.8	0	Satisfactory

75	2081/10/04	14:30	Thimi	Bode WTP	Treated	Clear	2.03	<5	7.35	363	124	74	0.57	1.5	20	1.41	0	Satisfactory
76	2081/10/04	11:00	Thimi	Tigani SRT	Treated	Clear	1.43	<5	7.75	78.3	30	36	0.1	0.02	4	0.6	0	Satisfactory
77	2081/10/04	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.18	56	22	24	0.1	0.02	6	0.70	0	Satisfactory
78	2081/10/04	13:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.16	59	24	26	0.1	0.02	6	0.72	0	Satisfactory
79	2081/10/04	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.16	<5	7.30	67	22	30	0.1	0.02	6	0.75	0	Satisfactory
80	2081/10/04	14:05	Maharajgunj	Bansbari SRT	Treated	Clear	0.22	<5	7.25	68	24	30	0.1	0.02	6	0.71	0	Satisfactory
81	2081/10/04	13:45	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.57	79.5	24	22	0.1	0.02	4	0.28	0	Satisfactory
82	2081/10/04	12:10	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.57	78.7	24	22	0.1	0.02	4	0.2	0	Satisfactory
83	2081/10/04	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.3	<5	7.45	78.5	26	22	0.1	0.02	6	0.28	0	Satisfactory
84	2081/10/04	12:55	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.52	81.2	24	22	0.1	0.02	6	1.01	0	Satisfactory
85	2081/10/04	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.47	78.5	26	22	0.1	0.02	6	1.79	0	Satisfactory
86	2081/10/04	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.49	75.7	26	22	0.1	0.02	6	1.25	0	Satisfactory
87	2081/10/04	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.7	79.7	24	22	0.1	0.02	6	0.98	0	Satisfactory
88	2081/10/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.6	62.5	16	10	0.1	0.02	4	0.89	0	Satisfactory
89	2081/10/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.63	65.3	14	10	0.1	0.02	4	0.87	0	Satisfactory
90	2081/10/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.8	63.5	16	10	0.1	0.02	4	1.07	0	Satisfactory
91	2081/10/04	13:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.48	80.7	24	24	0.1	0.02	6	0.3	0	Satisfactory
92	2081/10/04	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.48	79.7	24	24	0.1	0.02	6	0.55	0	Satisfactory
93	2081/10/04	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.02	<5	7.87	465	124	138	0.1	0.02	16	0.55	0	Satisfactory
94	2081/10/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.85	79.4	24	22	0.1	0.02	6	1.32	0	Satisfactory
95	2081/10/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.83	80.9	24	22	0.1	0.02	6	1.4	0	Satisfactory
96	2081/10/04	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.74	88.5	24	22	0.1	0.02	6	1.24	0	Satisfactory
97	2081/10/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.77	89.7	24	22	0.1	0.02	6	1.34	0	Satisfactory
98	2081/10/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.74	89.4	24	22	0.1	0.02	6	1.24	0	Satisfactory
99	2081/10/04	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.72	90	24	22	0.1	0.02	6	1.41	0	Satisfactory
100	2081/10/05	10:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.16	53	22	22	0.1	0.02	6	0.66	0	Satisfactory
101	2081/10/05	11:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.11	<5	7.30	68	22	30	0.1	0.02	6	0.43	0	Satisfactory
102	2081/10/05	11:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.7	82.7	26	24	0.1	0.02	4	0.65	0	Satisfactory
103	2081/10/05	10:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.76	81.5	26	22	0.1	0.02	6	0.55	0	Satisfactory

104	2081/10/05	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.78	75.4	26	22	0.1	0.02	6	0.85	0	Satisfactory
105	2081/10/05	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.68	67.2	16	10	0.1	0.02	4	0.75	0	Satisfactory
106	2081/10/05	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.75	79.5	26	22	0.1	0.02	6	0.6	0	Satisfactory
107	2081/10/05	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.72	80.7	26	24	0.1	0.02	6	0.38	0	Satisfactory
108	2081/10/05	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.23	79.6	24	22	0.1	0.02	6	1.31	0	Satisfactory
109	2081/10/05	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.3	79.8	24	22	0.1	0.02	6	1.2	0	Satisfactory
110	2081/10/05	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.81	90.6	24	22	0.1	0.02	6	1.37	0	Satisfactory
111	2081/10/06	10:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.23	67	24	28	0.1	0.02	6	1.05	0	Satisfactory
112	2081/10/06	14:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	65	22	28	0.1	0.02	6	0.97	0	Satisfactory
113	2081/10/06	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.13	<5	7.27	68	24	30	0.1	0.02	6	0.95	0	Satisfactory
114	2081/10/06	14:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.16	<5	7.24	68	24	30	0.1	0.02	6	0.87	0	Satisfactory
115	2081/10/06	14:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.89	95.7	26	24	0.1	0.02	4	0.5	0	Satisfactory
116	2081/10/06	11:00	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.8	82.6	26	24	0.1	0.02	4	0.37	0	Satisfactory
117	2081/10/06	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.56	79.5	24	22	0.1	0.02	6	0.53	0	Satisfactory
118	2081/10/06	13:40	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.9	95.7	26	24	0.1	0.02	6	0.87	0	Satisfactory
119	2081/10/06	12:55	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.48	84.4	26	22	0.1	0.02	6	0.86	0	Satisfactory
120	2081/10/06	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.92	78.7	26	22	0.1	0.02	6	0.26	0	Satisfactory
121	2081/10/06	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.3	79.6	24	22	0.1	0.02	6	1.24	0	Satisfactory
122	2081/10/06	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.38	81.8	24	24	0.1	0.02	6	1.34	0	Satisfactory
123	2081/10/06	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.69	81.7	26	24	0.1	0.02	6	1.28	0	Satisfactory
124	2081/10/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	8.2	57.5	14	8	0.1	0.02	4	0.98	0	Satisfactory
125	2081/10/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.3	57.5	14	8	0.1	0.02	4	0.64	0	Satisfactory
126	2081/10/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.37	76.5	16	10	0.1	0.02	4	1.57	0	Satisfactory
127	2081/10/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.76	75.7	16	10	0.1	0.02	4	1.6	0	Satisfactory
128	2081/10/06	14:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.83	82.7	26	24	0.1	0.02	6	1.15	0	Satisfactory
129	2081/10/06	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.65	84.7	26	24	0.1	0.02	6	0.5	0	Satisfactory
130	2081/10/06	10:30	Thimi	Bode WTP	Treated	Clear	1.59	<5	7.16	323	108	66	0.57	1.5	12	0.4	0	Satisfactory
131	2081/10/06	15:15	Thimi	Bode WTP	Treated	Clear	1.82	<5	7.23	361	122	74	0.57	1.5	20	0.81	0	Satisfactory
132	2081/10/06	9:45	Thimi	Tigani SRT	Treated	Clear	1.4	<5	7.7	76.4	28	36	0.1	0.02	4	0.2	0	Satisfactory
133	2081/10/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	7.98	447	122	132	0.1	0.02	18	0.72	0	Satisfactory
134	2081/10/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	8.13	90.3	24	22	0.1	0.02	6	1.37	0	Satisfactory
135	2081/10/06	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.71	89.4	24	22	0.1	0.02	6	1.26	0	Satisfactory
136	2081/10/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.64	86.4	24	22	0.1	0.02	6	1.32	0	Satisfactory
137	2081/10/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.71	88.8	24	22	0.1	0.02	6	1.32	0	Satisfactory
138	2081/10/06	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.64	89.4	24	22	0.1	0.02	6	1.25	0	Satisfactory
139	2081/10/07	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.17	63	22	28	0.1	0.02	6	0.67	0	Satisfactory
140	2081/10/07	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.22	55	22	26	0.1	0.02	6	0.97	0	Satisfactory

141	2081/10/07	10:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.40	<5	7.31	68	24	30	0.1	0.02	6	0.63	0	Satisfactory
142	2081/10/07	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.61	<5	7.14	72	26	32	0.1	0.02	6	0.71	0	Satisfactory
143	2081/10/07	10:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.5	79.7	26	22	0.1	0.02	4	0.5	0	Satisfactory
144	2081/10/07	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.35	81.7	26	22	0.1	0.02	6	0.24	0	Satisfactory
145	2081/10/07	11:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.77	83.9	26	22	0.1	0.02	6	0.52	0	Satisfactory
146	2081/10/07	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.35	80.7	26	24	0.1	0.02	6	0.6	0	Satisfactory
147	2081/10/07	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.82	83.3	26	24	0.1	0.02	6	1.53	0	Satisfactory
148	2081/10/07	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.79	81	26	24	0.1	0.02	6	1.6	0	Satisfactory
149	2081/10/07	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.87	80.5	26	24	0.1	0.02	6	1.6	0	Satisfactory
150	2081/10/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.36	73.9	16	10	0.1	0.02	4	2.27	0	Satisfactory
151	2081/10/07	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.93	69.8	14	10	0.1	0.02	4	2.71	0	Satisfactory
152	2081/10/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.83	79.9	16	12	0.1	0.02	4	2.45	0	Satisfactory
153	2081/10/07	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.9	79.1	16	12	0.1	0.02	4	2.53	0	Satisfactory
154	2081/10/07	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.68	81.7	26	24	0.1	0.02	6	0.58	0	Satisfactory
155	2081/10/07	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.87	82.5	26	24	0.1	0.02	6	0.67	0	Satisfactory
156	2081/10/07	10:30	Thimi	Bode WTP	Treated	Clear	2.37	<5	7.32	324	110	68	0.57	1.5	16	0.38	0	Satisfactory
157	2081/10/07	13:00	Thimi	Bode WTP	Treated	Clear	2.95	<5	7.54	365	130	70	0.57	1.5	20	2.26	0	Satisfactory
158	2081/10/07	15:00	Thimi	Bode WTP	Treated	Clear	2.43	<5	7.5	347	126	70	0.57	1.5	20	0.88	0	Satisfactory
159	2081/10/07	8:00	Thimi	Tigani SRT	Treated	Clear	1.68	<5	7.9	78.9	30	38	0.1	0.02	4	0.15	0	Satisfactory
160	2081/10/07	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.67	<5	7.86	459	124	130	0.1	0.02	16	0.82	0	Satisfactory
161	2081/10/07	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	8.13	89.3	24	22	0.1	0.02	6	1.4	0	Satisfactory
162	2081/10/07	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.66	89.7	24	22	0.1	0.02	6	1.23	0	Satisfactory
163	2081/10/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.6	90.9	24	22	0.1	0.02	6	1.32	0	Satisfactory
164	2081/10/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.7	91.2	24	22	0.1	0.02	6	1.36	0	Satisfactory
165	2081/10/07	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.62	90.5	24	22	0.1	0.02	6	1.24	0	Satisfactory
166	2081/10/08	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.35	<5	7.13	62	22	28	0.1	0.02	6	0.46	0	Satisfactory
167	2081/10/08	15:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.10	66	22	28	0.1	0.02	6	0.91	0	Satisfactory
168	2081/10/08	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.40	<5	7.22	70	24	32	0.1	0.02	6	1.08	0	Satisfactory
169	2081/10/08	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.30	<5	7.20	69	24	32	0.1	0.02	6	1.02	0	Satisfactory
170	2081/10/08	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.85	85.2	28	24	0.1	0.02	4	0.44	0	Satisfactory
171	2081/10/08	12:15	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.62	84.5	28	24	0.1	0.02	4	0.18	0	Satisfactory
172	2081/10/08	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.35	83.9	28	22	0.1	0.02	6	0.23	0	Satisfactory
173	2081/10/08	13:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.7	84.2	28	22	0.1	0.02	6	0.3	0	Satisfactory
174	2081/10/08	13:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	8.22	91.5	28	22	0.1	0.02	6	0.89	0	Satisfactory
175	2081/10/08	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.29	82	26	24	0.1	0.02	6	0.75	0	Satisfactory
176	2081/10/08	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.53	82	26	24	0.1	0.02	6	1.57	0	Satisfactory
177	2081/10/08	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.45	80.7	24	24	0.1	0.02	6	1.26	0	Satisfactory
178	2081/10/08	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.58	84.4	28	24	0.1	0.02	6	1.48	0	Satisfactory

179	2081/10/08	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.2	68	16	10	0.1	0.02	4	1.08	0	Satisfactory
180	2081/10/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.5	66.9	18	10	0.1	0.02	4	2.15	0	Satisfactory
181	2081/10/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.6	<5	7.38	81.5	16	14	0.1	0.02	4	2.03	0	Satisfactory
182	2081/10/08	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.56	81.1	18	14	0.1	0.02	4	2.02	0	Satisfactory
183	2081/10/08	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.86	108.5	28	26	0.1	0.02	6	0.87	0	Satisfactory
184	2081/10/08	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.63	85.7	28	24	0.1	0.02	6	0.68	0	Satisfactory
185	2081/10/08	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.07	<5	7.88	469	124	132	0.1	0.02	16	0.66	0	Satisfactory
186	2081/10/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.68	90.6	24	22	0.1	0.02	6	1.34	0	Satisfactory
187	2081/10/08	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.6	90.4	24	22	0.1	0.02	6	1.31	0	Satisfactory
188	2081/10/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	7.65	90.2	24	22	0.1	0.02	6	1.38	0	Satisfactory
189	2081/10/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.79	89	24	22	0.1	0.02	6	1.35	0	Satisfactory
190	2081/10/08	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.73	90.3	24	22	0.1	0.02	6	1.47	0	Satisfactory
191	2081/10/09	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.10	<5	7.15	69	24	30	0.1	0.02	6	0.86	0	Satisfactory
192	2081/10/09	15:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.12	64	30	30	0.1	0.02	6	0.70	0	Satisfactory
193	2081/10/09	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.10	<5	7.20	71	24	32	0.1	0.02	6	1.20	0	Satisfactory
194	2081/10/09	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.21	<5	7.16	68	30	30	0.1	0.02	6	0.84	0	Satisfactory
195	2081/10/09	12:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.1	79.2	26	22	0.1	0.02	4	0.59	0	Satisfactory
196	2081/10/09	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.37	85.5	26	22	0.1	0.02	6	0.4	0	Satisfactory
197	2081/10/09	11:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.45	89.2	26	22	0.1	0.02	6	0.81	0	Satisfactory
198	2081/10/09	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.48	84.5	26	24	0.1	0.02	6	0.7	0	Satisfactory
199	2081/10/09	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.31	80.1	26	24	0.1	0.02	6	1.2	0	Satisfactory
200	2081/10/09	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.35	82.3	26	24	0.1	0.02	6	1.22	0	Satisfactory
201	2081/10/09	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	83.5	26	24	0.1	0.02	6	1.2	0	Satisfactory
202	2081/10/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.5	63.5	16	12	0.1	0.02	4	1.21	0	Satisfactory
203	2081/10/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.6	68.4	14	12	0.1	0.02	4	2.69	0	Satisfactory
204	2081/10/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.5	59.2	16	12	0.1	0.02	4	1.18	0	Satisfactory
205	2081/10/09	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.65	65.7	16	12	0.1	0.02	4	1.32	0	Satisfactory
206	2081/10/09	12:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.6	<5	7.35	85.9	26	24	0.1	0.02	6	0.83	0	Satisfactory
207	2081/10/09	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.5	89.7	26	24	0.1	0.02	6	0.83	0	Satisfactory
208	2081/10/09	10:30	Thimi	Bode WTP	Treated	Clear	2.07	<5	7.2	342	114	70	0.57	1.5	20	0.91	0	Satisfactory
209	2081/10/09	13:00	Thimi	Bode WTP	Treated	Clear	2.36	<5	7.25	368	124	78	0.57	1.5	24	3.3	0	Satisfactory
210	2081/10/09	15:00	Thimi	Bode WTP	Treated	Clear	1.8	<5	7.18	373	124	78	0.57	1.5	22	1.7	0	Satisfactory
211	2081/10/09	14:45	Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.6	80.3	30	38	0.1	0.02	4	1.07	0	Satisfactory
212	2081/10/09	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.71	<5	7.92	462	120	130	0.1	0.02	10	0.81	0	Satisfactory
213	2081/10/09	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.71	91.6	24	22	0.1	0.02	6	1.18	0	Satisfactory
214	2081/10/09	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.73	89.2	24	22	0.1	0.02	6	1.3	0	Satisfactory

215	2081/10/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.67	91.2	24	22	0.1	0.02	6	1.28	0	Satisfactory
216	2081/10/09	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.37	91	24	22	0.1	0.02	6	1.54	0	Satisfactory
217	2081/10/09	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.48	91.3	24	22	0.1	0.02	6	1.3	0	Satisfactory
218	2081/10/10	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.13	64	28	28	0.1	0.02	6	1.22	0	Satisfactory
219	2081/10/10	14:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.14	66	30	30	0.1	0.02	6	0.74	0	Satisfactory
220	2081/10/10	11:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.15	<5	7.16	68	30	30	0.1	0.02	6	0.33	0	Satisfactory
221	2081/10/10	15:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.31	<5	7.22	69	30	30	0.1	0.02	6	0.91	0	Satisfactory
222	2081/10/10	14:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.4	86.7	24	24	0.1	0.02	4	0.47	0	Satisfactory
223	2081/10/10	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	7.78	99.5	24	24	0.1	0.02	4	0.38	0	Satisfactory
224	2081/10/10	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.25	84.5	26	22	0.1	0.02	6	0.44	0	Satisfactory
225	2081/10/10	13:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.2	<5	7.75	85.7	24	22	0.1	0.02	6	0.38	0	Satisfactory
226	2081/10/10	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	7.5	89.8	24	22	0.1	0.02	6	0.57	0	Satisfactory
227	2081/10/10	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.37	88.5	26	24	0.1	0.02	6	1.86	0	Satisfactory
228	2081/10/10	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.64	84.7	26	24	0.1	0.02	6	0.97	0	Satisfactory
229	2081/10/10	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.5	78.7	24	22	0.1	0.02	6	0.56	0	Satisfactory
230	2081/10/10	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.67	74.2	24	22	0.1	0.02	6	1.72	0	Satisfactory
231	2081/10/10	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.3	65.7	16	12	0.1	0.02	4	1.67	0	Satisfactory
232	2081/10/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.55	67.6	14	12	0.1	0.02	4	1.06	0	Satisfactory
233	2081/10/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.42	71	16	12	0.1	0.02	4	1.91	0	Satisfactory
234	2081/10/10	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.85	71.7	16	12	0.1	0.02	4	1.22	0	Satisfactory
235	2081/10/10	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.23	76.7	24	22	0.1	0.02	6	0.56	0	Satisfactory
236	2081/10/10	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.95	127.9	24	24	0.1	0.02	6	0.42	0	Satisfactory
237	2081/10/10	10:30	Thimi	Bode WTP	Treated	Clear	2.82	<5	7.22	368	124	78	0.57	1.5	22	2.07	0	Satisfactory
238	2081/10/10	13:00	Thimi	Bode WTP	Treated	Clear	2.6	<5	7.16	354	120	76	0.57	1.5	22	1.99	0	Satisfactory
239	2081/10/10	10:15	Thimi	Tigani SRT	Treated	Clear	1.42	<5	7.6	79.7	30	38	0.1	0.02	4	0.28	0	Satisfactory
240	2081/10/10	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.77	<5	7.95	474	120	130	0.1	0.02	12	0.76	0	Satisfactory
241	2081/10/10	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	8.03	90.4	24	22	0.1	0.02	6	1.13	0	Satisfactory
242	2081/10/10	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.63	89.2	24	22	0.1	0.02	6	1.21	0	Satisfactory
243	2081/10/10	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.51	91.4	24	22	0.1	0.02	6	1.32	0	Satisfactory
244	2081/10/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.61	90.7	24	22	0.1	0.02	6	1.25	0	Satisfactory
245	2081/10/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.43	91	24	22	0.1	0.02	6	1.53	0	Satisfactory

246	2081/10/10	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.51	92.4	24	22	0.1	0.02	6	1.37	0	Satisfactory
247	2081/10/11	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.12	57	26	26	0.1	0.02	6	0.52	0	Satisfactory
248	2081/10/11	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.25	<5	7.07	57	22	26	0.1	0.02	6	0.71	0	Satisfactory
249	2081/10/11	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.55	<5	7.17	69	30	30	0.1	0.02	6	0.56	0	Satisfactory
250	2081/10/11	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.12	70	24	32	0.1	0.02	6	0.32	0	Satisfactory
251	2081/10/11	13:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.45	93.5	28	24	0.1	0.02	4	1.02	0	Satisfactory
252	2081/10/11	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	8.1	90.5	28	24	0.1	0.02	4	0.27	0	Satisfactory
253	2081/10/11	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.1	<5	8.12	95.8	28	22	0.1	0.02	6	0.85	0	Satisfactory
254	2081/10/11	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.46	89.9	26	24	0.1	0.02	6	0.85	0	Satisfactory
255	2081/10/11	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	90.6	26	24	0.1	0.02	6	0.95	0	Satisfactory
256	2081/10/11	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.07	115.7	28	28	0.1	0.02	6	0.89	0	Satisfactory
257	2081/10/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.44	74	16	12	0.1	0.02	4	2.05	0	Satisfactory
258	2081/10/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.73	74.7	14	12	0.1	0.02	4	1.99	0	Satisfactory
259	2081/10/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	8.35	67.2	16	12	0.1	0.02	4	0.74	0	Satisfactory
260	2081/10/11	14:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.28	88.2	28	24	0.1	0.02	6	0.35	0	Satisfactory
261	2081/10/11	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	7.62	91.5	28	24	0.1	0.02	6	0.35	0	Satisfactory
262	2081/10/11	10:00	Thimi	Bode WTP	Treated	Clear	3.12	<5	7.12	331	118	68	0.57	1.5	12	0.4	0	Satisfactory
263	2081/10/11	13:00	Thimi	Bode WTP	Treated	Clear	2.92	<5	7.26	362	124	80	0.57	1.5	24	3.28	0	Satisfactory
264	2081/10/11	11:30	Thimi	Tigani SRT	Treated	Clear	2.53	<5	7.76	81.1	30	38	0.1	0.02	4	0.45	0	Satisfactory
265	2081/10/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.8	91.5	24	22	0.1	0.02	6	1.83	0	Satisfactory
266	2081/10/11	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.73	91	24	22	0.1	0.02	6	1.76	0	Satisfactory
267	2081/10/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.38	90.2	24	22	0.1	0.02	6	1.53	0	Satisfactory
268	2081/10/12	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.10	52	20	20	0.1	0.02	6	0.68	0	Satisfactory
269	2081/10/12	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.10	52	20	22	0.1	0.02	6	0.72	0	Satisfactory
270	2081/10/12	10:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.22	<5	7.32	68	24	32	0.1	0.02	6	0.23	0	Satisfactory
271	2081/10/12	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.28	68	24	32	0.1	0.02	6	0.53	0	Satisfactory
272	2081/10/12	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.72	85.6	26	24	0.1	0.02	6	0.92	0	Satisfactory
273	2081/10/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.78	75	14	12	0.1	0.02	4	1.42	0	Satisfactory

274	2081/10/12	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.64	90.1	24	22	0.1	0.02	6	1.2	0	Satisfactory
275	2081/10/12	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.6	90.6	24	22	0.1	0.02	6	1.13	0	Satisfactory
276	2081/10/12	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.71	91.2	24	22	0.1	0.02	6	1.16	0	Satisfactory
277	2081/10/12	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.62	90.2	24	22	0.1	0.02	6	1.21	0	Satisfactory
278	2081/10/13	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.85	<5	6.94	47	18	18	0.1	0.02	6	0.72	0	Satisfactory
279	2081/10/13	13:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.40	<5	6.90	57	22	24	0.1	0.02	6	0.74	0	Satisfactory
280	2081/10/13	15:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.28	<5	7.06	62	22	28	0.1	0.02	6	0.97	0	Satisfactory
281	2081/10/13	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.24	<5	7.10	69	24	32	0.1	0.02	6	0.12	0	Satisfactory
282	2081/10/13	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.34	<5	7.08	70	24	32	0.1	0.02	6	0.41	0	Satisfactory
283	2081/10/13	13:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	8.1	91.7	24	24	0.1	0.02	4	0.41	0	Satisfactory
284	2081/10/13	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.1	<5	8.15	92.5	24	24	0.1	0.02	4	0.4	0	Satisfactory
285	2081/10/13	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.82	91.5	26	24	0.1	0.02	6	0.4	0	Satisfactory
286	2081/10/13	12:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.97	87.5	24	22	0.1	0.02	6	0.27	0	Satisfactory
287	2081/10/13	12:05	Kirtipur	Kirtipur SRT	Treated	Clear	1	<5	8.05	94.5	24	22	0.1	0.02	6	0.63	0	Satisfactory
288	2081/10/13	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.95	94	26	24	0.1	0.02	6	0.93	0	Satisfactory
289	2081/10/13	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.04	92	26	24	0.1	0.02	6	1.18	0	Satisfactory
290	2081/10/13	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.09	92.5	26	24	0.1	0.02	6	0.99	0	Satisfactory
291	2081/10/13	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.99	89.2	24	24	0.1	0.02	6	0.99	0	Satisfactory
292	2081/10/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.01	65.4	16	12	0.1	0.02	4	1.01	0	Satisfactory
293	2081/10/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	8.15	69	16	12	0.1	0.02	4	1.02	0	Satisfactory
294	2081/10/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	8.18	63.1	14	12	0.1	0.02	4	1.23	0	Satisfactory
295	2081/10/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	8.1	65.7	16	12	0.1	0.02	4	1.16	0	Satisfactory
296	2081/10/13	15:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	8.12	91.8	24	26	0.1	0.02	6	0.56	0	Satisfactory
297	2081/10/13	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	8.2	94.7	24	24	0.1	0.02	6	0.89	0	Satisfactory
298	2081/10/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.67	<5	7.82	478	124	130	0.1	0.02	10	0.83	0	Satisfactory
299	2081/10/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.63	90.3	24	22	0.1	0.02	6	1.31	0	Satisfactory
300	2081/10/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.77	90.5	24	22	0.1	0.02	6	1.44	0	Satisfactory
301	2081/10/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.52	90.3	24	22	0.1	0.02	6	1.34	0	Satisfactory

302	2081/10/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.54	89.4	24	22	0.1	0.02	6	1.22	0	Satisfactory
303	2081/10/13	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.62	89.6	24	22	0.1	0.02	6	1.26	0	Satisfactory
304	2081/10/14	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.83	<5	7.93	51	22	24	0.1	0.02	6	0.66	0	Satisfactory
305	2081/10/14	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.91	<5	7.06	64	22	28	0.1	0.02	6	0.86	0	Satisfactory
306	2081/10/14	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	1.44	<5	7.18	68	24	32	0.1	0.02	6	0.52	0	Satisfactory
307	2081/10/14	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.82	<5	7.12	68	24	32	0.1	0.02	6	0.33	0	Satisfactory
308	2081/10/14	15:25	Tripureshwar	Anamnagar SRT	Treated	Clear	1.5	<5	7.85	105.2	26	26	0.1	0.02	4	0.57	0	Satisfactory
309	2081/10/14	11:30	Maharajgunj	Balaju SRT	Treated	Clear	2	<5	7.85	95.6	26	24	0.1	0.02	4	0.65	0	Satisfactory
310	2081/10/14	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	8.1	93.8	26	24	0.1	0.02	6	0.4	0	Satisfactory
311	2081/10/14	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.15	90.5	26	24	0.1	0.02	6	0.56	0	Satisfactory
312	2081/10/14	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.78	92.7	26	24	0.1	0.02	6	0.9	0	Satisfactory
313	2081/10/14	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.44	90.6	26	24	0.1	0.02	6	0.59	0	Satisfactory
314	2081/10/14	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.4	91.2	26	24	0.1	0.02	6	0.6	0	Satisfactory
315	2081/10/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	8.2	67.2	16	12	0.1	0.02	4	0.52	0	Satisfactory
316	2081/10/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.75	62.7	16	12	0.1	0.02	4	0.95	0	Satisfactory
317	2081/10/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.49	63.3	16	12	0.1	0.02	4	1.53	0	Satisfactory
318	2081/10/14	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.33	62.4	16	12	0.1	0.02	4	1.46	0	Satisfactory
319	2081/10/14	15:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.9	<5	7.94	104	26	26	0.1	0.02	6	0.44	0	Satisfactory
320	2081/10/14	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	1.3	<5	7.81	106.8	26	24	0.1	0.02	6	0.37	0	Satisfactory
321	2081/10/14	10:30	Thimi	Bode WTP	Treated	Clear	2.32	<5	7.23	344	120	70	0.57	1.5	18	0.94	0	Satisfactory
322	2081/10/14	13:30	Thimi	Bode WTP	Treated	Clear	3.2	<5	7.2	335	120	68	0.57	1.5	18	0.25	0	Satisfactory
323	2081/10/14	15:00	Thimi	Bode WTP	Treated	Clear	3.18	<5	7.2	331	118	68	0.57	1.5	14	0.22	0	Satisfactory
324	2081/10/14	9:30	Thimi	Tigani SRT	Treated	Clear	1.38	<5	7.7	90	32	40	0.1	0.02	4	0.1	0	Satisfactory
325	2081/10/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	7.85	458	122	132	0.1	0.02	10	0.86	0	Satisfactory
326	2081/10/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.69	89.1	24	22	0.1	0.02	6	1.2	0	Satisfactory
327	2081/10/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.68	91	24	22	0.1	0.02	6	1.02	0	Satisfactory
328	2081/10/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.64	90.2	24	22	0.1	0.02	6	1.18	0	Satisfactory

329	2081/10/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	7.59	90.2	24	22	0.1	0.02	6	1.23	0	Satisfactory
330	2081/10/15	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.06	54	22	26	0.1	0.02	6	0.91	0	Satisfactory
331	2081/10/15	14:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.06	55	22	26	0.1	0.02	6	0.90	0	Satisfactory
332	2081/10/15	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.52	<5	7.10	69	24	32	0.1	0.02	6	0.47	0	Satisfactory
333	2081/10/15	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	4.4	<5	7.58	93.5	24	24	0.1	0.02	4	0.18	0	Satisfactory
334	2081/10/15	13:20	Maharajgunj	Balaju SRT	Treated	Clear	3.5	<5	7.74	94.8	24	24	0.1	0.02	4	0.26	0	Satisfactory
335	2081/10/15	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.49	91.8	28	24	0.1	0.02	6	0.4	0	Satisfactory
336	2081/10/15	11:25	Lalitpur	Khumaltar SRT	Treated	Clear	3.4	<5	7.9	93.4	24	24	0.1	0.02	6	0.29	0	Satisfactory
337	2081/10/15	12:05	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	7.92	105.1	24	22	0.1	0.02	6	0.88	0	Satisfactory
338	2081/10/15	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.5	90.8	26	24	0.1	0.02	6	0.3	0	Satisfactory
339	2081/10/15	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.42	87.2	26	24	0.1	0.02	6	1.46	0	Satisfactory
340	2081/10/15	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.44	87.6	26	24	0.1	0.02	6	0.94	0	Satisfactory
341	2081/10/15	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.5	88.9	24	24	0.1	0.02	6	0.68	0	Satisfactory
342	2081/10/15	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.55	60.7	18	12	0.1	0.02	4	0.44	0	Satisfactory
343	2081/10/15	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.4	54.9	16	12	0.1	0.02	4	1.14	0	Satisfactory
344	2081/10/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.5	56.9	14	12	0.1	0.02	4	0.9	0	Satisfactory
345	2081/10/15	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.56	57.1	18	12	0.1	0.02	4	0.89	0	Satisfactory
346	2081/10/15	10:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.7	92.1	24	26	0.1	0.02	6	0.3	0	Satisfactory
347	2081/10/15	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	1.8	<5	7.9	92.3	24	24	0.1	0.02	6	0.57	0	Satisfactory
348	2081/10/15	10:30	Thimi	Bode WTP	Treated	Clear	2.57	<5	7.26	365	124	78	0.57	1.5	20	1.62	0	Satisfactory
349	2081/10/15	13:30	Thimi	Bode WTP	Treated	Clear	3.51	<5	7.3	361	124	78	0.57	1.5	20	1.82	0	Satisfactory
350	2081/10/15	15:00	Thimi	Bode WTP	Treated	Clear	3.34	<5	7.3	361	124	78	0.57	1.5	20	1.8	0	Satisfactory
351	2081/10/15	9:30	Thimi	Tigani SRT	Treated	Clear	2.19	<5	7.7	80.2	30	38	0.1	0.02	4	0.4	0	Satisfactory
352	2081/10/15	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.14	<5	7.81	463	124	138	0.1	0.02	14	0.97	0	Satisfactory
353	2081/10/15	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.28	<5	7.7	91.7	24	22	0.1	0.02	6	1.64	0	Satisfactory
354	2081/10/15	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.71	90.2	24	22	0.1	0.02	6	1.05	0	Satisfactory
355	2081/10/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.34	<5	7.41	91.1	24	22	0.1	0.02	6	1.13	0	Satisfactory
356	2081/10/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.39	89.1	24	22	0.1	0.02	6	1.02	0	Satisfactory
357	2081/10/16	9:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.56	<5	7.08	54	20	20	0.1	0.02	6	0.86	0	Satisfactory
358	2081/10/16	14:20	Maharajgunj	Bansbari WTP	Treated	Clear	2.24	<5	7.14	61	22	28	0.1	0.02	6	0.93	0	Satisfactory
359	2081/10/16	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	2.06	<5	7.24	69	24	32	0.1	0.02	6	0.57	0	Satisfactory
360	2081/10/16	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	3.10	<5	7.21	71	24	32	0.1	0.02	6	0.53	0	Satisfactory
361	2081/10/16	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	2.9	<5	7.79	93.3	28	24	0.1	0.02	4	0.54	0	Satisfactory
362	2081/10/16	12:20	Maharajgunj	Balaju SRT	Treated	Clear	5	<5	7.9	92.3	28	24	0.1	0.02	4	0.23	0	Satisfactory
363	2081/10/16	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.82	93.5	26	24	0.1	0.02	6	0.4	0	Satisfactory
364	2081/10/16	13:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.7	92.9	28	24	0.1	0.02	6	0.25	0	Satisfactory
365	2081/10/16	12:55	Kirtipur	Kirtipur SRT	Treated	Clear	3	<5	7.8	94.5	28	22	0.1	0.02	6	0.39	0	Satisfactory

366	2081/10/16	16:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.05	83	28	24	0.1	0.02	6	0.8	0	Satisfactory
367	2081/10/16	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.92	65.7	14	12	0.1	0.02	4	1.38	0	Satisfactory
368	2081/10/16	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.7	92.3	28	26	0.1	0.02	6	0.25	0	Satisfactory
369	2081/10/16	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	4.8	<5	7.37	92.4	28	24	0.1	0.02	6	0.13	0	Satisfactory
370	2081/10/16	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	7.35	91.8	24	22	0.1	0.02	6	1.22	0	Satisfactory
371	2081/10/16	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.76	90	24	22	0.1	0.02	6	0.85	0	Satisfactory
372	2081/10/16	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.61	91.2	24	22	0.1	0.02	6	0.96	0	Satisfactory
373	2081/10/16	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.45	89.1	24	22	0.1	0.02	6	1.07	0	Satisfactory
374	2081/10/17	10:20	Maharajgunj	Bansbari WTP	Treated	Clear	1.24	<5	7.10	60	22	28	0.1	0.02	6	0.72	0	Satisfactory
375	2081/10/17	14:10	Maharajgunj	Bansbari WTP	Treated	Clear	1.92	<5	6.92	59	22	28	0.1	0.02	6	0.70	0	Satisfactory
376	2081/10/17	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	4.51	<5	7.23	69	24	32	0.1	0.02	6	0.44	0	Satisfactory
377	2081/10/17	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	2.28	<5	7.08	69	24	32	0.1	0.02	6	0.74	0	Satisfactory
378	2081/10/17	8:55	Tripureshwar	Anamnagar SRT	Treated	Clear	4.8	<5	8	95.7	24	24	0.1	0.02	4	1.04	0	Satisfactory
379	2081/10/17	11:10	Maharajgunj	Balaju SRT	Treated	Clear	4.2	<5	8.03	91.9	24	24	0.1	0.02	4	0.1	0	Satisfactory
380	2081/10/17	6:30	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.9	90.7	112	24	0.1	0.02	6	0.4	0	Satisfactory
381	2081/10/17	9:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	8	92	24	24	0.1	0.02	6	0.58	0	Satisfactory
382	2081/10/17	9:10	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	8.1	95.5	24	22	0.1	0.02	6	0.48	0	Satisfactory
383	2081/10/17	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.68	90.4	24	24	0.1	0.02	6	0.95	0	Satisfactory
384	2081/10/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.92	62.3	16	12	0.1	0.02	4	1.75	0	Satisfactory
385	2081/10/17	8:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	8.1	100	24	28	0.1	0.02	6	0.39	0	Satisfactory
386	2081/10/17	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	1	<5	8.06	91.6	24	24	0.1	0.02	6	0.22	0	Satisfactory
387	2081/10/17	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.78	89.9	24	22	0.1	0.02	6	0.88	0	Satisfactory
388	2081/10/17	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.69	92	24	22	0.1	0.02	6	1.24	0	Satisfactory
389	2081/10/17	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.61	90.7	24	22	0.1	0.02	6	1.21	0	Satisfactory
390	2081/10/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.61	90.8	24	22	0.1	0.02	6	1.18	0	Satisfactory
391	2081/10/18	10:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.81	<5	7.32	62	22	28	0.1	0.02	6	0.92	0	Satisfactory
392	2081/10/18	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.76	<5	7.15	63	22	28	0.1	0.02	6	0.74	0	Satisfactory
393	2081/10/18	10:40	Maharajgunj	Bansbari SRT	Treated	Clear	2.24	<5	7.37	69	24	32	0.1	0.02	6	0.73	0	Satisfactory
394	2081/10/18	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.24	<5	7.18	70	24	32	0.1	0.02	6	0.85	0	Satisfactory
395	2081/10/18	12:40	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	8.1	124.5	24	26	0.1	0.02	4	0.28	0	Satisfactory
396	2081/10/18	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.89	90.7	28	24	0.1	0.02	6	0.4	0	Satisfactory
397	2081/10/18	11:00	Lalitpur	Khumaltar SRT	Treated	Clear	2.1	<5	8.1	93.5	24	24	0.1	0.02	6	0.26	0	Satisfactory
398	2081/10/18	11:40	Kirtipur	Kirtipur SRT	Treated	Clear	2.4	<5	8.1	95.9	24	22	0.1	0.02	6	0.37	0	Satisfactory
399	2081/10/18	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.83	90.5	26	24	0.1	0.02	6	1.29	0	Satisfactory
400	2081/10/18	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.78	91.7	24	24	0.1	0.02	6	1.32	0	Satisfactory
401	2081/10/18	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.79	92.5	24	24	0.1	0.02	6	0.95	0	Satisfactory

402	2081/10/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.85	67.5	16	12	0.1	0.02	4	0.97	0	Satisfactory
403	2081/10/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.83	66.7	16	12	0.1	0.02	4	1.25	0	Satisfactory
404	2081/10/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.85	65.2	16	12	0.1	0.02	4	1.2	0	Satisfactory
405	2081/10/18	12:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	8.1	93.5	24	24	0.1	0.02	6	0.12	0	Satisfactory
406	2081/10/18	10:30	Thimi	Bode WTP	Treated	Clear	3.04	<5	7.19	365	122	76	0.76	1.5	20	0.72	0	Satisfactory
407	2081/10/18	14:30	Thimi	Bode WTP	Treated	Clear	3.17	<5	7.22	370	124	78	0.76	1.5	20	1.18	0	Satisfactory
408	2081/10/18	8:00	Thimi	Tigani SRT	Treated	Clear	1.76	<5	7.64	90.2	30	40	0.1	0.02	4	0.4	0	Satisfactory
409	2081/10/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	7.77	93	24	22	0.1	0.02	6	1.4	0	Satisfactory
410	2081/10/18	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.68	90.6	24	22	0.1	0.02	6	1.26	0	Satisfactory
411	2081/10/18	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.72	88.6	24	22	0.1	0.02	6	1.02	0	Satisfactory
412	2081/10/19	10:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.84	<5	7.13	55	22	26	0.1	0.02	6	0.66	0	Satisfactory
413	2081/10/19	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.33	<5	7.41	58	22	28	0.1	0.02	6	0.74	0	Satisfactory
414	2081/10/19	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	3.34	<5	7.68	69	24	32	0.1	0.02	6	0.61	0	Satisfactory
415	2081/10/19	11:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	8.18	97.5	24	24	0.1	0.02	4	1.22	0	Satisfactory
416	2081/10/19	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	8.2	105.9	24	26	0.1	0.02	4	0.4	0	Satisfactory
417	2081/10/19	7:30	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.95	92.7	26	24	0.1	0.02	6	0.18	0	Satisfactory
418	2081/10/19	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.85	95.2	24	24	0.1	0.02	6	0.23	0	Satisfactory
419	2081/10/19	12:40	Kirtipur	Kirtipur SRT	Treated	Clear	1.6	<5	7.9	96.5	24	22	0.1	0.02	6	0.35	0	Satisfactory
420	2081/10/19	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.85	89.5	24	24	0.1	0.02	6	0.68	0	Satisfactory
421	2081/10/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.95	63.9	16	12	0.1	0.02	4	1	0	Satisfactory
422	2081/10/19	10:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	8.2	92.7	24	24	0.1	0.02	6	0.4	0	Satisfactory
423	2081/10/19	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	2.1	<5	7.95	95.7	26	24	0.1	0.02	6	0.38	0	Satisfactory
424	2081/10/19	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.72	91.2	24	22	0.1	0.02	6	0.87	0	Satisfactory
425	2081/10/19	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.31	<5	7.48	92	24	22	0.1	0.02	6	1.26	0	Satisfactory
426	2081/10/19	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.61	92.5	24	22	0.1	0.02	6	1.56	0	Satisfactory
427	2081/10/19	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.65	90.2	24	22	0.1	0.02	6	1.41	0	Satisfactory
428	2081/10/20	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.47	58	22	28	0.1	0.02	6	0.60	0	Satisfactory
429	2081/10/20	14:35	Maharajgunj	Bansbari WTP	Treated	Clear	1.15	<5	7.43	57	22	26	0.1	0.02	6	0.61	0	Satisfactory
430	2081/10/20	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.81	<5	7.83	69	24	32	0.1	0.02	6	0.37	0	Satisfactory
431	2081/10/20	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	2.93	<5	7.52	69	24	32	0.1	0.02	6	0.23	0	Satisfactory
432	2081/10/20	12:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	8.2	100.4	26	26	0.1	0.02	4	0.7	0	Satisfactory
433	2081/10/20	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.9	100.5	28	24	0.1	0.02	6	0.4	0	Satisfactory
434	2081/10/20	11:10	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	8.2	100.7	26	26	0.1	0.02	6	0.56	0	Satisfactory
435	2081/10/20	9:40	Kirtipur	Kirtipur SRT	Treated	Clear	3.3	<5	8.1	98.5	26	22	0.1	0.02	6	0.76	0	Satisfactory
436	2081/10/20	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.95	91.5	26	24	0.1	0.02	6	1.79	0	Satisfactory
437	2081/10/20	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.85	91.7	26	24	0.1	0.02	6	1.16	0	Satisfactory

438	2081/10/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.96	88.7	24	24	0.1	0.02	6	0.51	0	Satisfactory
439	2081/10/20	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.84	88.6	26	24	0.1	0.02	6	0.84	0	Satisfactory
440	2081/10/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	8.1	56.7	14	12	0.1	0.02	4	0.39	0	Satisfactory
441	2081/10/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.97	54.6	14	12	0.1	0.02	4	0.66	0	Satisfactory
442	2081/10/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.11	54.4	16	12	0.1	0.02	4	0.79	0	Satisfactory
443	2081/10/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.05	69	16	12	0.1	0.02	4	0.93	0	Satisfactory
444	2081/10/20	11:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	8.16	93.4	26	24	0.1	0.02	6	0.4	0	Satisfactory
445	2081/10/20	10:30	Thimi	Bode WTP	Treated	Clear	3.14	<5	7.13	350	120	72	0.57	1.5	14	0.19	0	Satisfactory
446	2081/10/20	13:00	Thimi	Bode WTP	Treated	Clear	3.1	<5	7.11	364	122	74	0.76	1.5	20	0.91	0	Satisfactory
447	2081/10/20	15:30	Thimi	Bode WTP	Treated	Clear	3.16	<5	7.12	353	120	74	0.76	1.5	20		0	Satisfactory
448	2081/10/20	9:30	Thimi	Tigani SRT	Treated	Clear	1.43	<5	7.6	82.4	30	38	0.1	0.02	4	0.2	0	Satisfactory
449	2081/10/20	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.75	<5	7.97	447	118	130	0.1	0.02	10	0.64	0	Satisfactory
450	2081/10/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.82	93.7	24	22	0.1	0.02	6	1.1	0	Satisfactory
451	2081/10/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.69	92.4	24	22	0.1	0.02	6	1.12	0	Satisfactory
452	2081/10/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.61	93.2	24	22	0.1	0.02	6	1.2	0	Satisfactory
453	2081/10/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.62	92.4	24	22	0.1	0.02	6	1.13	0	Satisfactory
454	2081/10/20	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.68	91	24	22	0.1	0.02	6	1.32	0	Satisfactory
455	2081/10/21	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.39	<5	7.44	53	20	20	0.1	0.02	6	0.66	0	Satisfactory
456	2081/10/21	14:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.64	<5	7.46	64	24	30	0.1	0.02	6	0.70	0	Satisfactory
457	2081/10/21	10:00	Maharajgunj	Bansbari SRT	Treated	Clear	2.10	<5	7.47	71	24	32	0.1	0.02	6	0.27	0	Satisfactory
458	2081/10/21	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	2.91	<5	7.51	71	24	32	0.1	0.02	6	0.46	0	Satisfactory
459	2081/10/21	11:40	Tripureshwar	Anamnagar SRT	Treated	Clear	4.5	<5	8.1	94.2	26	24	0.1	0.02	4	0.4	0	Satisfactory
460	2081/10/21	14:05	Maharajgunj	Balaju SRT	Treated	Clear	2	<5	8.37	95.2	26	24	0.1	0.02	4	0.54	0	Satisfactory
461	2081/10/21	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	8.05	93.7	26	24	0.1	0.02	6	0.4	0	Satisfactory
462	2081/10/21	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.98	95.7	26	22	0.1	0.02	6	0.4	0	Satisfactory
463	2081/10/21	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	8.48	98.2	26	22	0.1	0.02	6	0.24	0	Satisfactory
464	2081/10/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.1	89.5	28	24	0.1	0.02	6	0.45	0	Satisfactory
465	2081/10/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.07	91.7	28	24	0.1	0.02	6	0.96	0	Satisfactory
466	2081/10/21	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.1	87.2	26	24	0.1	0.02	6	0.39	0	Satisfactory
467	2081/10/21	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.05	96.6	26	24	0.1	0.02	6	0.5	0	Satisfactory
468	2081/10/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.3	54.2	16	12	0.1	0.02	4	0.93	0	Satisfactory
469	2081/10/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.2	65.4	16	12	0.1	0.02	4	1.1	0	Satisfactory
470	2081/10/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.23	62.5	16	12	0.1	0.02	4	2.41	0	Satisfactory

471	2081/10/21	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.25	65	16	12	0.1	0.02	4	1.39	0	Satisfactory
472	2081/10/21	11:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	8.5	110.7	26	28	0.1	0.02	6	0.4	0	Satisfactory
473	2081/10/21	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	0.1	<5	8.45	94.7	26	24	0.1	0.02	6	0.4	0	Satisfactory
474	2081/10/21	10:30	Thimi	Bode WTP	Treated	Clear	2.67	<5	7.19	363	122	76	0.57	1.5	20	0.92	0	Satisfactory
475	2081/10/21	13:00	Thimi	Bode WTP	Treated	Clear	2.83	<5	7.21	382	124	80	0.57	1.5	20	1.48	0	Satisfactory
476	2081/10/21	15:30	Thimi	Bode WTP	Treated	Clear	2.76	<5	7.2	366	124	72	0.57	1.5	20	0.51	0	Satisfactory
477	2081/10/21	2:00 noon	Thimi	Tigani SRT	Treated	Clear	1.5	<5	7.71	86.1	32	38	0.1	0.02	4	0.81	0	Satisfactory
478	2081/10/21	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.37	<5	7.85	462	130	130	0.1	0.02	10	0.79	0	Satisfactory
479	2081/10/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.62	89.7	24	22	0.1	0.02	6	1.09	0	Satisfactory
480	2081/10/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.84	90.4	24	22	0.1	0.02	6	1.04	0	Satisfactory
481	2081/10/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.74	92.4	24	22	0.1	0.02	6	1.13	0	Satisfactory
482	2081/10/21	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.65	93.5	24	22	0.1	0.02	6	1.21	0	Satisfactory
483	2081/10/22	10:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.06	<5	7.46	67	24	30	0.1	0.02	6	0.93	0	Satisfactory
484	2081/10/22	14:40	Maharajgunj	Bansbari WTP	Treated	Clear	2.56	<5	7.47	67	24	30	0.1	0.02	6	0.71	0	Satisfactory
485	2081/10/22	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.13	<5	7.51	69	24	32	0.1	0.02	6	1.04	0	Satisfactory
486	2081/10/22	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	2.21	<5	7.48	70	24	32	0.1	0.02	6	0.41	0	Satisfactory
487	2081/10/22	13:30	Tripureshwar	Anamnagar SRT	Treated	Clear	2.4	<5	7.71	99.1	26	24	0.1	0.02	4	0.61	0	Satisfactory
488	2081/10/22	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.2	90.5	26	24	0.1	0.02	6	0.79	0	Satisfactory
489	2081/10/22	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.1	90.5	26	24	0.1	0.02	6	0.86	0	Satisfactory
490	2081/10/22	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.65	88.2	24	24	0.1	0.02	6	1.07	0	Satisfactory
491	2081/10/22	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.82	93.4	26	24	0.1	0.02	6	0.61	0	Satisfactory
492	2081/10/22	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.91	93.7	26	24	0.1	0.02	6	0.45	0	Satisfactory
493	2081/10/22	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	8.15	63.9	16	12	0.1	0.02	4	0.94	0	Satisfactory
494	2081/10/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.69	67.5	16	12	0.1	0.02	4	1.86	0	Satisfactory
495	2081/10/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.84	89.8	16	12	0.1	0.02	4	2.47	0	Satisfactory
496	2081/10/22	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.85	89.8	16	12	0.1	0.02	4	2.59	0	Satisfactory
497	2081/10/22	13:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.67	93.1	26	24	0.1	0.02	6	0.54	0	Satisfactory
498	2081/10/22	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	2.9	<5	7.85	96.4	26	24	0.1	0.02	6	0.54	0	Satisfactory
499	2081/10/22	10:30	Thimi	Bode WTP	Treated	Clear	2.46	<5	7.14	380	126	80	0.76	1.5	20	1.16	0	Satisfactory
500	2081/10/22	13:00	Thimi	Bode WTP	Treated	Clear	2.54	<5	7.18	395	128	82	0.76	1.5	24	2.08	0	Satisfactory
501	2081/10/22	15:00	Thimi	Bode WTP	Treated	Clear	2.96	<5	7.1	381	126	80	0.76	1.5	20	1.61	0	Satisfactory
502	2081/10/22	9:30	Thimi	Tigani SRT	Treated	Clear	1.45	<5	7.7	88	32	38	0.1	0.02	4	0.2	0	Satisfactory
503	2081/10/22	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.34	<5	7.88	463	126	132	0.1	0.02	12	0.54	0	Satisfactory
504	2081/10/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.85	92.5	24	22	0.1	0.02	6	0.9	0	Satisfactory
505	2081/10/22	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.87	90.9	24	22	0.1	0.02	6	1.1	0	Satisfactory

506	2081/10/22	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.62	91.8	24	22	0.1	0.02	6	1.12	0	Satisfactory
507	2081/10/22	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.55	93.9	24	22	0.1	0.02	6	1.05	0	Satisfactory
508	2081/10/22	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.57	92.2	24	22	0.1	0.02	6	1.34	0	Satisfactory
509	2081/10/23	10:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.54	<5	7.50	53	22	22	0.1	0.02	6	0.74	0	Satisfactory
510	2081/10/23	14:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.46	55	22	24	0.1	0.02	6	0.50	0	Satisfactory
511	2081/10/23	10:30	Maharajgunj	Bansbari SRT	Treated	Clear	3.34	<5	7.42	71	24	32	0.1	0.02	6	0.31	0	Satisfactory
512	2081/10/23	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	4.52	<5	7.46	70	24	32	0.1	0.02	6	0.50	0	Satisfactory
513	2081/10/23	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.42	95.1	26	24	0.1	0.02	4	0.67	0	Satisfactory
514	2081/10/23	13:40	Maharajgunj	Balaju SRT	Treated	Clear	3.5	<5	7.85	95.3	26	24	0.1	0.02	4	0.4	0	Satisfactory
515	2081/10/23	8:00	Bhaktapur	Katunje SRT	Treated	Clear	3.5	<5	7.92	95.9	26	24	0.1	0.02	6	0.4	0	Satisfactory
516	2081/10/23	11:35	Lalitpur	Khumaltar SRT	Treated	Clear	0.2	<5	7.7	96.4	26	22	0.1	0.02	6	0.31	0	Satisfactory
517	2081/10/23	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	7.83	98.3	26	22	0.1	0.02	6	0.82	0	Satisfactory
518	2081/10/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	8.01	95.1	26	24	0.1	0.02	6	0.92	0	Satisfactory
519	2081/10/23	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.4	94.3	28	24	0.1	0.02	6	0.51	0	Satisfactory
520	2081/10/23	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.7	95	26	24	0.1	0.02	6	0.81	0	Satisfactory
521	2081/10/23	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.38	84.9	26	24	0.1	0.02	6	0.65	0	Satisfactory
522	2081/10/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.97	67.1	18	12	0.1	0.02	4	1.9	0	Satisfactory
523	2081/10/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.43	66.3	16	12	0.1	0.02	4	2.15	0	Satisfactory
524	2081/10/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.75	66.4	16	12	0.1	0.02	4	1.87	0	Satisfactory
525	2081/10/23	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.79	67.2	16	12	0.1	0.02	4	1.05	0	Satisfactory
526	2081/10/23	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.58	95	26	24	0.1	0.02	6	0.4	0	Satisfactory
527	2081/10/23	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	2	<5	8.26	96.2	26	24	0.1	0.02	6	0.55	0	Satisfactory
528	2081/10/23	10:30	Thimi	Bode WTP	Treated	Clear	3.33	<5	7.07	351	120	68	0.76	1.5	10	0.4	0	Satisfactory
529	2081/10/23	13:00	Thimi	Bode WTP	Treated	Clear	2.97	<5	7.14	393	128	80	0.76	1.5	20	2.16	0	Satisfactory
530	2081/10/23	15:15	Thimi	Bode WTP	Treated	Clear	3.16	<5	7.1	381	126	78	0.76	1.5	20	0.93	0	Satisfactory
531	2081/10/23	9:00	Thimi	Tigani SRT	Treated	Clear	1.57	<5	7.65	90.1	32	38	0.1	0.02	4	0.4	0	Satisfactory
532	2081/10/23	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.18	<5	7.93	465	126	132	0.1	0.02	14	0.71	0	Satisfactory
533	2081/10/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.74	91.8	24	22	0.1	0.02	6	1.02	0	Satisfactory
534	2081/10/23	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.6	92.6	24	22	0.1	0.02	6	1.2	0	Satisfactory
535	2081/10/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.59	92.4	24	22	0.1	0.02	6	1.24	0	Satisfactory
536	2081/10/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.53	92.2	24	22	0.1	0.02	6	1.1	0	Satisfactory
537	2081/10/23	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.68	90.2	24	22	0.1	0.02	6	1.37	0	Satisfactory
538	2081/10/24	10:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.47	58	22	28	0.1	0.02	6	0.52	0	Satisfactory
539	2081/10/24	14:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.45	<5	7.50	65	22	28	0.1	0.02	6	0.54	0	Satisfactory
540	2081/10/24	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.01	<5	7.51	71	24	32	0.1	0.02	6	0.67	0	Satisfactory

541	2081/10/24	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.92	<5	7.50	71	24	32	0.1	0.02	6	0.70	0	Satisfactory
542	2081/10/24	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	1.4	<5	7.85	95.8	26	24	0.1	0.02	4	0.75	0	Satisfactory
543	2081/10/24	13:10	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	8.32	104.7	26	26	0.1	0.02	4	0.27	0	Satisfactory
544	2081/10/24	7:00	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.69	97.6	24	24	0.1	0.02	6	0.6	0	Satisfactory
545	2081/10/24	11:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.99	96.9	26	22	0.1	0.02	6	0.48	0	Satisfactory
546	2081/10/24	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	8.03	223.8	102	22	0.1	0.02	6		0	Satisfactory
547	2081/10/24	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.69	85.7	26	24	0.1	0.02	6	0.78	0	Satisfactory
548	2081/10/24	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.68	95.7	28	24	0.1	0.02	6	0.55	0	Satisfactory
549	2081/10/24	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.65	93.7	24	24	0.1	0.02	6	0.72	0	Satisfactory
550	2081/10/24	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.9	92.5	26	24	0.1	0.02	6	0.75	0	Satisfactory
551	2081/10/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.75	62.3	16	12	0.1	0.02	4	0.54	0	Satisfactory
552	2081/10/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.69	60.5	16	12	0.1	0.02	4	0.61	0	Satisfactory
553	2081/10/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.42	58.7	16	12	0.1	0.02	4	0.96	0	Satisfactory
554	2081/10/24	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.78	57.5	16	12	0.1	0.02	4	1.15	0	Satisfactory
555	2081/10/24	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.86	95.2	26	24	0.1	0.02	6	0.4	0	Satisfactory
556	2081/10/24	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	2.4	<5	8.1	95.2	24	24	0.1	0.02	6	0.32	0	Satisfactory
557	2081/10/24	10:30	Thimi	Bode WTP	Treated	Clear	2.54	<5	7.2	380	126	78	0.76	1.5	18	0.58	0	Satisfactory
558	2081/10/24	13:00	Thimi	Bode WTP	Treated	Clear	2.77	<5	7.25	418	132	80	0.76	1.5	22	1.5	0	Satisfactory
559	2081/10/24	15:00	Thimi	Bode WTP	Treated	Clear	2.62	<5	7.24	403	132	76	0.76	1.5	18	0.8	0	Satisfactory
560	2081/10/24	9:40	Thimi	Tigani SRT	Treated	Clear	1.72	<5	7.75	85.4	32	38	0.1	0.02	4	0.4	0	Satisfactory
561	2081/10/24	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.18	<5	8.11	477	134	140	0.1	0.02	14	0.74	0	Satisfactory
562	2081/10/24	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.65	89.8	24	22	0.1	0.02	6	0.71	0	Satisfactory
563	2081/10/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.62	88.6	24	22	0.1	0.02	6	1.76	0	Satisfactory
564	2081/10/24	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.55	88.9	24	22	0.1	0.02	6	1.07	0	Satisfactory
565	2081/10/24	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.62	89.1	24	22	0.1	0.02	6	1.12	0	Satisfactory
566	2081/10/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.61	89.3	24	22	0.1	0.02	6	1.12	0	Satisfactory
567	2081/10/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.71	90	24	22	0.1	0.02	6	1.31	0	Satisfactory
568	2081/10/24	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.76	87.2	24	22	0.1	0.02	6	1.41	0	Satisfactory
569	2081/10/25	10:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.42	<5	7.50	66	22	30	0.1	0.02	6	0.53	0	Satisfactory
570	2081/10/25	13:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.86	<5	7.52	67	22	30	0.1	0.02	6	0.67	0	Satisfactory
571	2081/10/25	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.65	<5	7.55	70	24	32	0.1	0.02	6	0.70	0	Satisfactory
572	2081/10/25	14:05	Maharajgunj	Bansbari SRT	Treated	Clear	1.41	<5	7.42	71	24	32	0.1	0.02	6	0.52	0	Satisfactory
573	2081/10/25	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	1.8	<5	8.34	101.1	24	24	0.1	0.02	4	1.11	0	Satisfactory
574	2081/10/25	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.2	<5	8.45	103.4	28	26	0.1	0.02	6	0.4	0	Satisfactory
575	2081/10/25	11:40	Lalitpur	Khumaltar SRT	Treated	Clear	0.9	<5	8.27	99	24	22	0.1	0.02	6	0.56	0	Satisfactory
576	2081/10/25	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.5	<5	8.38	117.5	24	22	0.1	0.02	6	0.92	0	Satisfactory

577	2081/10/25	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.85	97.8	26	24	0.1	0.02	6	1	0	Satisfactory
578	2081/10/25	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.7	97.4	26	24	0.1	0.02	6	0.7	0	Satisfactory
579	2081/10/25	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	8.08	98.4	24	24	0.1	0.02	6	0.54	0	Satisfactory
580	2081/10/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.92	63.7	16	12	0.1	0.02	4	1.15	0	Satisfactory
581	2081/10/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.75	63.7	16	12	0.1	0.02	4	0.97	0	Satisfactory
582	2081/10/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	8.22	62.4	16	12	0.1	0.02	4	0.86	0	Satisfactory
583	2081/10/25	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	8.27	98.2	24	26	0.1	0.02	6	0.37	0	Satisfactory
584	2081/10/25	10:30	Thimi	Bode WTP	Treated	Clear	2.73	<5	7.2	385	126	78	0.76	1.5	20	0.67	0	Satisfactory
585	2081/10/25	14:30	Thimi	Bode WTP	Treated	Clear	2.63	<5	7.3	400	132	80	0.76	1.5	24	2.7	0	Satisfactory
586	2081/10/25	10:15	Thimi	Tigani SRT	Treated	Clear	0.87	<5	8.01	84.9	32	38	0.1	0.02	4	0.1	0	Satisfactory
587	2081/10/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.02	<5	8.02	448	120	130	0.1	0.02	10	0.63	0	Satisfactory
588	2081/10/25	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.62	85.7	24	22	0.1	0.02	6	0.81	0	Satisfactory
589	2081/10/25	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.6	86.1	24	22	0.1	0.02	6	1.22	0	Satisfactory
590	2081/10/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.46	86.8	24	22	0.1	0.02	6	1.07	0	Satisfactory
591	2081/10/25	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.68	85.8	24	22	0.1	0.02	6	1.11	0	Satisfactory
592	2081/10/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.47	86.7	24	22	0.1	0.02	6	0.95	0	Satisfactory
593	2081/10/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.71	87.2	24	22	0.1	0.02	6	1.24	0	Satisfactory
594	2081/10/26	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.63	<5	7.46	57	22	26	0.1	0.02	6	0.73	0	Satisfactory
595	2081/10/26	14:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.31	<5	7.34	63	22	28	0.1	0.02	6	0.66	0	Satisfactory
596	2081/10/26	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	2.04	<5	7.52	71	24	32	0.1	0.02	6	0.58	0	Satisfactory
597	2081/10/26	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	1.51	<5	7.46	72	24	32	0.1	0.02	6	0.46	0	Satisfactory
598	2081/10/26	14:20	Tripureshwar	Anamnagar SRT	Treated	Clear	3.3	<5	7.91	100.1	26	24	0.1	0.02	4	0.26	0	Satisfactory
599	2081/10/26	13:55	Maharajgunj	Balaju SRT	Treated	Clear	3.1	<5	8.02	102	26	26	0.1	0.02	4	1.43	0	Satisfactory
600	2081/10/26	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.2	<5	8.35	100	28	26	0.1	0.02	6	0.83	0	Satisfactory
601	2081/10/26	12:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	8.11	99.9	26	22	0.1	0.02	6	0.67	0	Satisfactory
602	2081/10/26	12:40	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	8.13	150.8	26	22	0.1	0.02	6	0.28	0	Satisfactory
603	2081/10/26	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.89	94.7	26	24	0.1	0.02	6	1.07	0	Satisfactory
604	2081/10/26	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.88	74.5	16	12	0.1	0.02	4	1.05	0	Satisfactory
605	2081/10/26	11:50	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	8.19	98.3	26	26	0.1	0.02	6	0.1	0	Satisfactory
606	2081/10/26	13:15	Maharajgunj	Panipokhari SRT	Treated	Clear	2.3	<5	7.66	101	28	24	0.1	0.02	6	0.63	0	Satisfactory
607	2081/10/26	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.63	85.3	24	22	0.1	0.02	6	0.92	0	Satisfactory
608	2081/10/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.61	86.2	24	22	0.1	0.02	6	1.2	0	Satisfactory
609	2081/10/26	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.52	86.3	24	22	0.1	0.02	6	1.35	0	Satisfactory

610	2081/10/26	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.78	85.9	24	22	0.1	0.02	6	1.24	0	Satisfactory
611	2081/10/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.67	88.4	24	22	0.1	0.02	6	1.25	0	Satisfactory
612	2081/10/27	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.62	<5	7.35	64	22	28	0.1	0.02	6	0.54	0	Satisfactory
613	2081/10/27	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.46	<5	7.30	65	22	30	0.1	0.02	6	0.46	0	Satisfactory
614	2081/10/27	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.41	<5	7.50	70	24	32	0.1	0.02	6	0.47	0	Satisfactory
615	2081/10/27	14:30	Maharajgunj	Bansbari SRT	Treated	Clear	2.86	<5	7.36	71	24	32	0.1	0.02	6	0.77	0	Satisfactory
616	2081/10/27	14:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	8.22	100	26	24	0.1	0.02	4	0.76	0	Satisfactory
617	2081/10/27	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.5	<5	8.35	98.4	26	24	0.1	0.02	6	0.4	0	Satisfactory
618	2081/10/27	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	8.11	97.9	26	22	0.1	0.02	6	0.57	0	Satisfactory
619	2081/10/27	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	2	<5	8.45	157.9	26	22	0.1	0.02	6	0.4	0	Satisfactory
620	2081/10/27	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	8.27	95.7	28	24	0.1	0.02	6	0.59	0	Satisfactory
621	2081/10/27	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	8.05	97.2	26	24	0.1	0.02	6	1.35	0	Satisfactory
622	2081/10/27	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	8.15	97.2	26	24	0.1	0.02	6	0.91	0	Satisfactory
623	2081/10/27	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	8.11	92.5	26	24	0.1	0.02	6	0.97	0	Satisfactory
624	2081/10/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	8.4	62.7	16	12	0.1	0.02	4	0.13	0	Satisfactory
625	2081/10/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	8.12	83.7	16	12	0.1	0.02	4	3.39	0	Satisfactory
626	2081/10/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	8.2	71.8	16	12	0.1	0.02	4	2.12	0	Satisfactory
627	2081/10/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	8.25	69	16	12	0.1	0.02	4	2.16	0	Satisfactory
628	2081/10/27	14:20	Baneshwor	Minbhawan SRT	Treated	Clear	1.5	<5	8.49	107.3	26	26	0.1	0.02	6	0.56	0	Satisfactory
629	2081/10/27	10:30	Thimi	Bode WTP	Treated	Clear	2.31	<5	7.2	365	122	78	0.76	1.5	22	1.43	0	Satisfactory
630	2081/10/27	13:30	Thimi	Bode WTP	Treated	Clear	1.4	<5	7.28	374	124	80	0.57	1.5	22	1.44	0	Satisfactory
631	2081/10/27	15:30	Thimi	Bode WTP	Treated	Clear	1.6	<5	7.3	370	124	80	0.57	1.5	22	1.27	0	Satisfactory
632	2081/10/27	11:00	Thimi	Tigani SRT	Treated	Clear	0.85	<5	7.67	86	32	38	0.1	0.02	4	0.64	0	Satisfactory
633	2081/10/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.42	<5	8.04	455	128	132	0.1	0.02	12	0.82	0	Satisfactory
634	2081/10/27	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.76	84.8	24	22	0.1	0.02	6	0.5	0	Satisfactory
635	2081/10/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.47	86.5	24	22	0.1	0.02	6	1.23	0	Satisfactory
636	2081/10/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.63	85.5	24	22	0.1	0.02	6	1.13	0	Satisfactory
637	2081/10/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.59	87.1	24	22	0.1	0.02	6	1.1	0	Satisfactory
638	2081/10/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.81	86.6	24	22	0.1	0.02	6	1.1	0	Satisfactory
639	2081/10/27	17:30	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.52	86.6	24	22	0.1	0.02	6	1.21	0	Satisfactory
640	2081/10/28	10:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.60	<5	7.50	55	22	24	0.1	0.02	6	0.41	0	Satisfactory
641	2081/10/28	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.13	<5	7.52	71	24	32	0.1	0.02	6	0.74	0	Satisfactory
642	2081/10/28	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	1.47	<5	7.43	71	24	32	0.1	0.02	6	1.06	0	Satisfactory
643	2081/10/28	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	8.1	100	26	26	0.1	0.02	6	0.4	0	Satisfactory

644	2081/10/28	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	8.15	90.5	26	24	0.1	0.02	6	0.72	0	Satisfactory
645	2081/10/28	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	8.15	99.2	28	24	0.1	0.02	6	1.12	0	Satisfactory
646	2081/10/28	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.47	82.6	26	24	0.1	0.02	6	1.03	0	Satisfactory
647	2081/10/28	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.35	80.5	26	24	0.1	0.02	6	1	0	Satisfactory
648	2081/10/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	8.23	67.2	16	12	0.1	0.02	4	0.52	0	Satisfactory
649	2081/10/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	8.35	61.5	16	12	0.1	0.02	4	0.77	0	Satisfactory
650	2081/10/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.53	46.9	14	12	0.1	0.02	4	0.71	0	Satisfactory
651	2081/10/28	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.35	65.7	16	12	0.1	0.02	4	1.31	0	Satisfactory
652	2081/10/28	10:00	Thimi	Bode WTP	Treated	Clear	1.47	<5	7.3	366	124	76	0.57	1.5	20	0.68	0	Satisfactory
653	2081/10/28	13:00	Thimi	Bode WTP	Treated	Clear	2.09	<5	7.28	377	124	78	0.76	1.5	20	0.84	0	Satisfactory
654	2081/10/28	15:00	Thimi	Bode WTP	Treated	Clear	2.13	<5	7.3	372	124	78	0.76	1.5	20	0.79	0	Satisfactory
655	2081/10/28	9:30	Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.62	86.6	32	38	0.1	0.02	4	0.12	0	Satisfactory
656	2081/10/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.87	<5	7.88	467	120	132	0.1	0.02	10	0.62	0	Satisfactory
657	2081/10/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.85	84.4	24	22	0.1	0.02	6	0.66	0	Satisfactory
658	2081/10/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.62	86	24	22	0.1	0.02	6	1.34	0	Satisfactory
659	2081/10/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.56	87.2	24	22	0.1	0.02	6	1.01	0	Satisfactory
660	2081/10/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.62	84.8	24	22	0.1	0.02	6	1.22	0	Satisfactory
661	2081/10/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.62	85.1	24	22	0.1	0.02	6	1.17	0	Satisfactory
662	2081/10/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.76	83.2	24	22	0.1	0.02	6	1.1	0	Satisfactory
663	2081/10/28	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.62	85.1	24	22	0.1	0.02	6	1.16	0	Satisfactory
664	2081/10/29	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.91	<5	7.33	56	22	26	0.1	0.02	6	0.73	0	Satisfactory
665	2081/10/29	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	3.93	<5	7.60	70	24	32	0.1	0.02	6	0.22	0	Satisfactory
666	2081/10/29	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	2.23	<5	7.51	71	24	32	0.1	0.02	6	0.51	0	Satisfactory
667	2081/10/29	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.55	72.7	26	22	0.1	0.02	6	2.58	0	Satisfactory
668	2081/10/29	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.36	112.8	26	28	0.1	0.02	6	1.26	0	Satisfactory
669	2081/10/29	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.45	108.5	28	28	0.1	0.02	6	0.98	0	Satisfactory
670	2081/10/29	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.32	108.7	28	28	0.1	0.02	6	1.13	0	Satisfactory
671	2081/10/29	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.52	76.5	16	12	0.1	0.02	4	3.07	0	Satisfactory
672	2081/10/29	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.55	80.8	16	12	0.1	0.02	4	1.88	0	Satisfactory
673	2081/10/29	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.24	89.2	16	12	0.1	0.02	4	2.1	0	Satisfactory

674	2081/10/29	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.35	90.7	16	12	0.1	0.02	4	1.68	0	Satisfactory
675	2081/10/29	10:30	Thimi	Bode WTP	Treated	Clear	2.7	<5	7.27	356	122	76	0.57	1.5	20	0.61	0	Satisfactory
676	2081/10/29	13:30	Thimi	Bode WTP	Treated	Clear	2.83	<5	7.29	394	132	82	0.57	1.5	20	2.18	0	Satisfactory
677	2081/10/29	15:30	Thimi	Bode WTP	Treated	Clear	2.56	<5	7.3	386	128	80	0.57	1.5	20	1.82	0	Satisfactory
678	2081/10/29	9:00	Thimi	Tigani SRT	Treated	Clear	0.84	<5	7.7	87.9	112	62	0.1	0.02	4	0.23	0	Satisfactory
679	2081/10/29	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.84	<5	8.03	458	122	136	0.1	0.02	10	0.71	0	Satisfactory
680	2081/10/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.58	85.3	24	22	0.1	0.02	6	0.64	0	Satisfactory
681	2081/10/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.61	85.8	24	22	0.1	0.02	6	1.14	0	Satisfactory
682	2081/10/29	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.51	87.6	24	22	0.1	0.02	6	1.3	0	Satisfactory
683	2081/10/29	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.75	84.7	24	22	0.1	0.02	6	1.07	0	Satisfactory
684	2081/10/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.53	87	24	22	0.1	0.02	6	1.2	0	Satisfactory
685	2081/10/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.45	86.4	24	22	0.1	0.02	6	1.14	0	Satisfactory
686	2081/10/29	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.68	85.8	24	22	0.1	0.02	6	1.38	0	Satisfactory
687	2081/10/30	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.74	<5	7.48	62	22	28	0.1	0.02	6	0.67	0	Satisfactory
688	2081/10/30	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.46	<5	7.51	71	24	32	0.1	0.02	6	0.90	0	Satisfactory
689	2081/10/30	14:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.2	112.7	26	26	0.1	0.02	4	0.54	0	Satisfactory
690	2081/10/30	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.25	106.5	28	28	0.1	0.02	6	0.4	0	Satisfactory
691	2081/10/30	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.73	110.8	28	28	0.1	0.02	6	1.05	0	Satisfactory
692	2081/10/30	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.2	116.5	28	28	0.1	0.02	6	1.24	0	Satisfactory
693	2081/10/30	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.4	117.2	26	28	0.1	0.02	6	1.1	0	Satisfactory
694	2081/10/30	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.3	70.5	16	12	0.1	0.02	4	0.51	0	Satisfactory
695	2081/10/30	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.6	<5	7.82	68.9	16	12	0.1	0.02	4	0.82	0	Satisfactory
696	2081/10/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.25	102.1	16	12	0.1	0.02	4	1.82	0	Satisfactory
697	2081/10/30	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.49	115.3	16	12	0.1	0.02	4	2.08	0	Satisfactory
698	2081/10/30	14:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	6.95	112.3	26	28	0.1	0.02	6	0.79	0	Satisfactory
699	2081/10/30	10:30	Thimi	Bode WTP	Treated	Clear	2.67	<5	7.16	361	120	78	0.57	1.5	20	0.73	0	Satisfactory
700	2081/10/30	13:30	Thimi	Bode WTP	Treated	Clear	2.94	<5	7.2	390	130	80	0.57	1.5	20	1.62	0	Satisfactory
701	2081/10/30	15:30	Thimi	Bode WTP	Treated	Clear	2.53	<5	7.2	383	130	76	0.57	1.5	20	1.49	0	Satisfactory
702	2081/10/30	11:00	Thimi	Tigani SRT	Treated	Clear	1.41	<5	7.62	84.2	32	38	0.1	0.02	4	0.82	0	Satisfactory
703	2081/10/30	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.98	<5	7.86	457	118	124	0.1	0.02	12	0.58	0	Satisfactory
704	2081/10/30	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.79	85.3	24	22	0.1	0.02	6	0.31	0	Satisfactory
705	2081/10/30	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.69	85.9	24	22	0.1	0.02	6	1.22	0	Satisfactory

706	2081/10/30	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.71	85.9	24	22	0.1	0.02	6	1.13	0	Satisfactory
707	2081/10/30	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.56	86.7	24	22	0.1	0.02	6	1.58	0	Satisfactory
708	2081/10/30	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.37	86	24	22	0.1	0.02	6	1.44	0	Satisfactory
709	2081/10/30	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.49	85.8	24	22	0.1	0.02	6	1.36	0	Satisfactory