



**KATHMANDU UPATYAKA KHANEPANI LIMITED**  
**Water/Waste Water Quality Assurance Division , Mahankalchaur**  
**Laboratory Record Of Chemical & Bacteriological Analysis Of Water**  
**Chaitra 2081**

SN	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	pH	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
<b>Units</b> →							(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100ml	
<b>National Drinking Water Quality Standard (NDWQS)</b> →							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2081/12/01	14:00	Tripureswor	Anamnagar SRT	Treated	Clear	0.2	<5	7.4	76.2	24	22	0.1	0.02	4	1	0	Satisfactory
2	2081/12/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.65	75.9	22	24	0.1	0.02	6	1.27	0	Satisfactory
3	2081/12/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.40	<5	7.58	76.9	22	24	0.1	0.02	6	1.16	0	Satisfactory
4	2081/12/01	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.35	75.9	22	24	0.1	0.02	6	1.57	0	Satisfactory
5	2081/12/01	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.29	75.6	22	24	0.1	0.02	6	1.27	0	Satisfactory
6	2081/12/01	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.80	<5	7.36	75.2	22	24	0.1	0.02	6	0.89	0	Satisfactory
7	2081/12/01	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.42	75.6	22	24	0.1	0.02	6	1.18	0	Satisfactory
8	2081/12/01	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.62	74.9	22	24	0.1	0.02	6	1.07	0	Satisfactory
9	2081/12/01	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.59	75.2	22	24	0.1	0.02	6	1.1	0	Satisfactory
10	2081/12/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.40	<5	7.75	74.0	22	24	0.1	0.02	6	0.45	0	Satisfactory
11	2081/12/01	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.5	79.4	26	24	0.1	0.02	6	0.1	0	Satisfactory
12	2081/12/01	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.4	76.5	24	24	0.1	0.02	6	0.65	0	Satisfactory
13	2081/12/01	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	7.48	75	24	24	0.1	0.02	6	0.66	0	Satisfactory
14	2081/12/01	13:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.5	77	24	24	0.1	0.02	6	1.22	0	Satisfactory

15	2081/12/01	13:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.75	78.2	24	24	0.1	0.02	6	0.92	0	Satisfactory
16	2081/12/01	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.4	77.1	22	24	0.1	0.02	6	0.86	0	Satisfactory
17	2081/12/01	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.24	83.6	24	24	0.1	0.02	6	1.18	0	Satisfactory
18	2081/12/01	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.5	76.7	24	24	0.1	0.02	6	0.45	0	Satisfactory
19	2081/12/01	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.4	58.5	14	22	0.1	0.02	6	0.1	0	Satisfactory
20	2081/12/01	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	8.3	112	14	22	0.1	0.02	6	2.09	0	Satisfactory
21	2081/12/01	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	8.2	112	18	22	0.1	0.02	6	1.79	0	Satisfactory
22	2081/12/01	10:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.57	<5	7.36	73	24	32	0.1	0.02	6	0.84	0	Satisfactory
23	2081/12/01	14:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.48	<5	7.34	75	24	32	0.1	0.02	6	1.48	0	Satisfactory
24	2081/12/01	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.46	<5	7.30	64	22	28	0.1	0.02	6	0.96	0	Satisfactory
25	2081/12/01	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.75	<5	7.81	489	132	116	0.1	0.02	10	0.64	0	Satisfactory
26	2081/12/01	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.32	<5	7.7	90.1	34	38	0.1	0.02	4	0.1	0	Satisfactory
27	2081/12/01	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.03	<5	7.3	428	134	86	0.95	1.5	18	0.43	0	Satisfactory
28	2081/12/01	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.75	<5	7.3	407	132	84	0.95	1.5	18	0.74	0	Satisfactory
29	2081/12/02	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.56	74.5	22	24	0.1	0.02	6	0.96	0	Satisfactory
30	2081/12/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.43	76.6	22	24	0.1	0.02	6	1.48	0	Satisfactory
31	2081/12/02	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.29	<5	7.38	75.7	22	24	0.1	0.02	6	1.46	0	Satisfactory
32	2081/12/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.50	76.1	22	24	0.1	0.02	6	2.06	0	Satisfactory
33	2081/12/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.47	74.7	22	24	0.1	0.02	6	1.45	0	Satisfactory
34	2081/12/02	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.66	75.2	22	24	0.1	0.02	6	1.63	0	Satisfactory
35	2081/12/02	11:10	Tripureswor	Anamnagar SRT	Treated	Clear	1.5	<5	7.89	85.5	26	22	0.1	0.02	4	1.05	0	Satisfactory
36	2081/12/02	13:20	Maharajgunj	Balaju SRT	Treated	Clear	2.3	<5	7.84	82.2	26	22	0.1	0.02	6	1.43	0	Satisfactory
37	2081/12/02	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.82	82.3	24	24	0.1	0.02	6	0.1	0	Satisfactory
38	2081/12/02	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.94	81.4	26	24	0.1	0.02	6	1.12	0	Satisfactory
39	2081/12/02	12:35	Kirtipur	Kirtipur SRT	Treated	Clear	2	<5	7.93	84.7	26	24	0.1	0.02	6	1.03	0	Satisfactory

40	2081/12/02	11:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.98	85.2	26	24	0.1	0.02	6	0.69	0	Satisfactory
41	2081/12/02	13:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.88	81.2	26	24	0.1	0.02	6	0.95	0	Satisfactory
42	2081/12/02	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.52	76.8	26	24	0.1	0.02	6	1.48	0	Satisfactory
43	2081/12/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.65	51.9	14	22	0.1	0.02	6	0.66	0	Satisfactory
44	2081/12/02	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.03	<5	7.47	75	24	32	0.1	0.02	6	0.11	0	Satisfactory
45	2081/12/02	16:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.74	<5	7.40	73	24	32	0.1	0.02	6	1.01	0	Satisfactory
46	2081/12/02	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.40	<5	7.27	71	24	32	0.1	0.02	6	1.02	0	Satisfactory
47	2081/12/03	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.61	76.3	22	24	0.1	0.02	6	1.13	0	Satisfactory
48	2081/12/03	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.58	77.4	22	24	0.1	0.02	6	1.49	0	Satisfactory
49	2081/12/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.33	75.0	22	24	0.1	0.02	6	1.4	0	Satisfactory
50	2081/12/03	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.30	74.4	22	24	0.1	0.02	6	1.73	0	Satisfactory
51	2081/12/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.22	75.3	22	24	0.1	0.02	6	1.57	0	Satisfactory
52	2081/12/03	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.83	<5	7.21	74.5	22	24	0.1	0.02	6	1.84	0	Satisfactory
53	2081/12/03	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.28	75.8	22	24	0.1	0.02	6	1.42	0	Satisfactory
54	2081/12/03	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.51	73.6	22	24	0.1	0.02	6	1.18	0	Satisfactory
55	2081/12/03	13:35	Tripureswor	Anamnagar SRT	Treated	Clear	0.5	<5	7.85	85.7	26	22	0.1	0.02	4	0.56	0	Satisfactory
56	2081/12/03	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.85	82.7	26	24	0.1	0.02	6	0.1	0	Satisfactory
57	2081/12/03	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	1.7	<5	7.75	97.2	26	24	0.1	0.02	6	0.1	0	Satisfactory
58	2081/12/03	13:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	8.15	91.5	26	24	0.1	0.02	6	1.14	0	Satisfactory
59	2081/12/03	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.72	76.2	24	24	0.1	0.02	6	1.34	0	Satisfactory
60	2081/12/03	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.75	78.2	24	24	0.1	0.02	6	1.02	0	Satisfactory
61	2081/12/03	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.78	76.2	26	24	0.1	0.02	6	1.41	0	Satisfactory
62	2081/12/03	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.8	77.2	24	24	0.1	0.02	6	1.33	0	Satisfactory

63	2081/12/03	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.85	54.2	16	22	0.1	0.02	6	0.45	0	Satisfactory
64	2081/12/03	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.87	57.2	14	22	0.1	0.02	6	0.6	0	Satisfactory
65	2081/12/03	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.87	56.7	14	22	0.1	0.02	6	0.68	0	Satisfactory
66	2081/12/03	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.75	61.7	14	22	0.1	0.02	6	1.16	0	Satisfactory
67	2081/12/03	15:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.82	<5	7.82	93	34	38	0.1	0.02	4	1.62	0	Satisfactory
68	2081/12/03	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	3.12	<5	7.2	372	126	70	0.95	1.5	10	0.1	0	Satisfactory
69	2081/12/03	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	7.22	383	128	72	0.95	1.5	12	0.16	0	Satisfactory
70	2081/12/03	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.9	<5	7.22	388	128	72	0.95	1.5	10	0.1	0	Satisfactory
71	2081/12/03	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.92	<5	7.48	74	24	32	0.1	0.02	6	1.02	0	Satisfactory
72	2081/12/03	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.67	<5	7.36	76	26	32	0.1	0.02	6	0.94	0	Satisfactory
73	2081/12/03	6:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	7.31	67	22	28	0.1	0.02	6	1.01	0	Satisfactory
74	2081/12/03	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	7.84	424	130	120	0.1	0.02	10	0.79	0	Satisfactory
75	2081/12/04	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.60	74.6	22	24	0.1	0.02	6	0.26	0	Satisfactory
76	2081/12/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.54	75.4	22	24	0.1	0.02	6	0.98	0	Satisfactory
77	2081/12/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.27	75.6	22	24	0.1	0.02	6	1.79	0	Satisfactory
78	2081/12/04	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.30	<5	7.32	76.1	22	24	0.1	0.02	6	1.92	0	Satisfactory
79	2081/12/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.39	75.0	22	24	0.1	0.02	6	1.95	0	Satisfactory
80	2081/12/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.40	74.4	22	24	0.1	0.02	6	0.87	0	Satisfactory
81	2081/12/04	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.42	74.9	22	24	0.1	0.02	6	1.13	0	Satisfactory
82	2081/12/04	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.49	74.6	22	24	0.1	0.02	6	1.2	0	Satisfactory
83	2081/12/04	13:40	Tripureswor	Anamnagar SRT	Treated	Clear	0.4	<5	7.58	86.7	26	22	0.1	0.02	4	0.99	0	Satisfactory
84	2081/12/04	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.7	<5	7.65	81.7	26	22	0.1	0.02	6	0.1	0	Satisfactory

85	2081/12/04	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.05	78.7	26	24	0.1	0.02	6	0.41	0	Satisfactory
86	2081/12/04	12:45	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.72	118.3	26	24	0.1	0.02	6	0.65	0	Satisfactory
87	2081/12/04	12:10	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	7.48	107.3	26	24	0.1	0.02	6	0.1	0	Satisfactory
88	2081/12/04	13:30	Baneshwor	Minbhawan SRT	Treated	Clear	1.6	<5	7.58	108.2	26	24	0.1	0.02	6	0.65	0	Satisfactory
89	2081/12/04	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.58	84.7	26	24	0.1	0.02	6	0.95	0	Satisfactory
90	2081/12/04	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.35	79.7	26	24	0.1	0.02	6	1.43	0	Satisfactory
91	2081/12/04	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.2	80.2	26	24	0.1	0.02	6	1.46	0	Satisfactory
92	2081/12/04	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.42	80.7	24	24	0.1	0.02	6	1.21	0	Satisfactory
93	2081/12/04	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.52	83.7	26	24	0.1	0.02	6	1.15	0	Satisfactory
94	2081/12/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.5	60.2	14	22	0.1	0.02	6	0.58	0	Satisfactory
95	2081/12/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.15	59.7	14	22	0.1	0.02	6	0.95	0	Satisfactory
96	2081/12/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.28	60.7	14	22	0.1	0.02	6	0.9	0	Satisfactory
97	2081/12/04	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.23	60.3	16	22	0.1	0.02	6	0.97	0	Satisfactory
98	2081/12/04	15:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.92	<5	7.7	93.3	34	38	0.1	0.02	4	1.57	0	Satisfactory
99	2081/12/04	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.61	<5	7.28	388	128	72	0.76	1.5	14	0.1	0	Satisfactory
100	2081/12/04	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.92	<5	7.25	404	130	86	0.76	1.5	20	0.66	0	Satisfactory
101	2081/12/04	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.9	<5	7.28	405	130	86	0.76	1.5	20	1.06	0	Satisfactory
102	2081/12/04	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.84	<5	7.24	73	24	32	0.1	0.02	6	0.41	0	Satisfactory
103	2081/12/04	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.05	<5	6.67	75	26	32	0.1	0.02	6	1.42	0	Satisfactory
104	2081/12/04	6:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.46	<5	7.30	67	22	28	0.1	0.02	6	0.96	0	Satisfactory
105	2081/12/04	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	7.84	463	130	120	0.1	0.02	10	0.54	0	Satisfactory
106	2081/12/05	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.62	76.7	22	24	0.1	0.02	6	0.87	0	Satisfactory
107	2081/12/05	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.60	75.9	22	24	0.1	0.02	6	1.31	0	Satisfactory
108	2081/12/05	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.49	75.4	22	24	0.1	0.02	6	1.42	0	Satisfactory
109	2081/12/05	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.51	74.9	22	24	0.1	0.02	6	1.5	0	Satisfactory

110	2081/12/05	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.55	74.7	22	24	0.1	0.02	6	1.06	0	Satisfactory
111	2081/12/05	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.51	75.7	22	24	0.1	0.02	6	1.36	0	Satisfactory
112	2081/12/05	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.48	75.6	22	24	0.1	0.02	6	1.41	0	Satisfactory
113	2081/12/05	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.60	74.1	22	24	0.1	0.02	6	1.16	0	Satisfactory
114	2081/12/05	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.55	81.2	26	24	0.1	0.02	6	0.1	0	Satisfactory
115	2081/12/05	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.68	76.7	24	24	0.1	0.02	6	0.93	0	Satisfactory
116	2081/12/05	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.69	78.9	22	24	0.1	0.02	6	1.03	0	Satisfactory
117	2081/12/05	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.79	83.7	24	24	0.1	0.02	6	0.98	0	Satisfactory
118	2081/12/05	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.82	82.7	26	24	0.1	0.02	6	0.97	0	Satisfactory
119	2081/12/05	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.88	52.7	14	22	0.1	0.02	6	0.33	0	Satisfactory
120	2081/12/05	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.85	56.2	14	22	0.1	0.02	6	1.06	0	Satisfactory
121	2081/12/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.77	57.7	14	22	0.1	0.02	6	0.99	0	Satisfactory
122	2081/12/05	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.72	62.7	14	22	0.1	0.02	6	0.87	0	Satisfactory
123	2081/12/05	10:00	Maharajgunj	Bansbari SRT	Treated	Clear	1.01	<5	7.30	75	26	32	0.1	0.02	6	0.34	0	Satisfactory
124	2081/12/05	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.82	<5	7.23	77	26	32	0.1	0.02	6	0.92	0	Satisfactory
125	2081/12/05	6:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.70	<5	7.27	63	22	26	0.1	0.02	6	0.97	0	Satisfactory
126	2081/12/05	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	7.91	445	128	138	0.1	0.02	10	0.62	0	Satisfactory
127	2081/12/06	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.57	76.1	22	24	0.1	0.02	6	1.03	0	Satisfactory
128	2081/12/06	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.51	74.8	22	24	0.1	0.02	6	1.75	0	Satisfactory
129	2081/12/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.54	74.3	22	24	0.1	0.02	6	1.58	0	Satisfactory
130	2081/12/06	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.43	75.6	22	24	0.1	0.02	6	1.56	0	Satisfactory

131	2081/12/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.58	76.4	22	24	0.1	0.02	6	1.9	0	Satisfactory
132	2081/12/06	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.56	75.1	22	24	0.1	0.02	6	0.1	0	Satisfactory
133	2081/12/06	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.55	75.3	22	24	0.1	0.02	6	0.1	0	Satisfactory
134	2081/12/06	14:20	Tripureswor	Anamnagar SRT	Treated	Clear	1.6	<5	7.8	87.2	26	22	0.1	0.02	4	0.56	0	Satisfactory
135	2081/12/06	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.68	86.7	26	22	0.1	0.02	6	0.1	0	Satisfactory
136	2081/12/06	8:45	Bhaktapur	Katunje SRT	Treated	Clear	5	<5	7.1	81.7	26	24	0.1	0.02	6	0.1	0	Satisfactory
137	2081/12/06	12:10	Kirtipur	Kirtipur SRT	Treated	Clear	2.5	<5	7.75	121.5	26	24	0.1	0.02	6	0.1	0	Satisfactory
138	2081/12/06	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.68	80.2	26	24	0.1	0.02	6	0.43	0	Satisfactory
139	2081/12/06	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.28	80.2	26	24	0.1	0.02	6	1.45	0	Satisfactory
140	2081/12/06	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.8	80.2	26	24	0.1	0.02	6	1.28	0	Satisfactory
141	2081/12/06	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.78	83.7	24	24	0.1	0.02	6	0.7	0	Satisfactory
142	2081/12/06	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.85	83.7	26	24	0.1	0.02	6	0.87	0	Satisfactory
143	2081/12/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.25	67.2	14	22	0.1	0.02	6	0.95	0	Satisfactory
144	2081/12/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.65	69.7	16	22	0.1	0.02	6	1.01	0	Satisfactory
145	2081/12/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.62	62.5	16	22	0.1	0.02	6	0.82	0	Satisfactory
146	2081/12/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.68	65.7	16	22	0.1	0.02	6	0.95	0	Satisfactory
147	2081/12/06	7:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.94	<5	7.7	83	32	36	0.1	0.02	4	0.1	0	Satisfactory
148	2081/12/06	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.3	<5	7.02	345	116	68	0.57	1.5	18	0.1	0	Satisfactory
149	2081/12/06	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	7.06	343	152	68	0.57	1.5	18	0.1	0	Satisfactory
150	2081/12/06	16:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.49	<5	7.01	339	116	66	0.57	1.5	16	0.1	0	Satisfactory
151	2081/12/06	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.56	<5	7.38	76	26	32	0.1	0.02	6	0.80	0	Satisfactory
152	2081/12/06	15:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.52	<5	7.22	67	26	34	0.1	0.02	6	0.90	0	Satisfactory
153	2081/12/06	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.42	<5	7.32	66	22	28	0.1	0.02	6	1.04	0	Satisfactory
154	2081/12/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.91	<5	7.84	470	132	138	0.1	0.02	10	0.74	0	Satisfactory
155	2081/12/07	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.81	74.1	22	24	0.1	0.02	6	0.1	0	Satisfactory



156	2081/12/07	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.85	74.2	22	24	0.1	0.02	6	0.1	0	Satisfactory
157	2081/12/07	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.66	74.6	22	24	0.1	0.02	6	0.1	0	Satisfactory
158	2081/12/07	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.61	75.0	22	24	0.1	0.02	6	0.1	0	Satisfactory
159	2081/12/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.61	74.2	22	24	0.1	0.02	6	0.1	0	Satisfactory
160	2081/12/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.82	<5	7.81	73.4	22	24	0.1	0.02	6	0.1	0	Satisfactory
161	2081/12/07	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.81	75.3	22	24	0.1	0.02	6	0.1	0	Satisfactory
162	2081/12/07	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.59	75.1	22	24	0.1	0.02	6	0.1	0	Satisfactory
163	2081/12/07	11:45	Tripureswor	Anamnagar SRT	Treated	Clear	0.7	<5	7.88	81.9	24	22	0.1	0.02	4	0.1	0	Satisfactory
164	2081/12/07	10:55	Maharajgunj	Balaju SRT	Treated	Clear	0.7	<5	7.74	81.7	24	22	0.1	0.02	6	0.1	0	Satisfactory
165	2081/12/07	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.8	<5	7.42	82.7	26	24	0.1	0.02	6	0.1	0	Satisfactory
166	2081/12/07	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	4	<5	7.6	98.1	24	24	0.1	0.02	6	0.1	0	Satisfactory
167	2081/12/07	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.64	96.6	24	24	0.1	0.02	6	0.1	0	Satisfactory
168	2081/12/07	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.83	80.4	24	24	0.1	0.02	6	0.65	0	Satisfactory
169	2081/12/07	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.57	81.2	24	24	0.1	0.02	6	0.1	0	Satisfactory
170	2081/12/07	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	3.9	<5	7.63	84.7	26	24	0.1	0.02	6	0.1	0	Satisfactory
171	2081/12/07	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	72.7	24	24	0.1	0.02	6	0.1	0	Satisfactory
172	2081/12/07	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.8	<5	7.77	81.2	26	24	0.1	0.02	6	0.1	0	Satisfactory
173	2081/12/07	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.67	63.7	14	22	0.1	0.02	6	1.2	0	Satisfactory
174	2081/12/07	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.49	61.9	14	22	0.1	0.02	6	2.1	0	Satisfactory
175	2081/12/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.65	62.7	14	22	0.1	0.02	6	1.21	0	Satisfactory
176	2081/12/07	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.61	61.5	14	22	0.1	0.02	6	1.76	0	Satisfactory
177	2081/12/07	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.04	<5	7.7	83.1	32	36	0.1	0.02	4	0.1	0	Satisfactory
178	2081/12/07	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.34	<5	7.12	361	122	70	0.57	1.5	20	0.19	0	Satisfactory



179	2081/12/07	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.66	<5	7.12	372	124	70	0.57	1.5	20	0.1	0	Satisfactory
180	2081/12/07	16:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.32	<5	7.18	342	116	68	0.57	1.5	20	0.41	0	Satisfactory
181	2081/12/07	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.73	<5	7.52	73	24	32	0.1	0.02	6	0.15	0	Satisfactory
182	2081/12/07	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.11	<5	7.44	74	24	32	0.1	0.02	6	0.1	0	Satisfactory
183	2081/12/07	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.32	66	24	28	0.1	0.02	6	0.92	0	Satisfactory
184	2081/12/07	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.16	<5	7.94	476	130	126	0.1	0.02	12	0.82	0	Satisfactory
185	2081/12/08	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.92	74.3	22	24	0.1	0.02	6	0.1	0	Satisfactory
186	2081/12/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.87	75.2	22	24	0.1	0.02	6	0.1	0	Satisfactory
187	2081/12/08	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.83	74.0	22	24	0.1	0.02	6	0.1	0	Satisfactory
188	2081/12/08	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.67	75.0	22	24	0.1	0.02	6	0.1	0	Satisfactory
189	2081/12/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.63	75.0	22	24	0.1	0.02	6	0.1	0	Satisfactory
190	2081/12/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.71	76.2	22	24	0.1	0.02	6	0.1	0	Satisfactory
191	2081/12/08	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.61	75.9	22	24	0.1	0.02	6	0.1	0	Satisfactory
192	2081/12/08	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.94	74.0	22	24	0.1	0.02	6	0.1	0	Satisfactory
193	2081/12/08	13:25	Tripureswor	Anamnagar SRT	Treated	Clear	0.3	<5	8.15	85.7	24	22	0.1	0.02	4	0.1	0	Satisfactory
194	2081/12/08	12:35	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.98	115.7	24	24	0.1	0.02	6	0.1	0	Satisfactory
195	2081/12/08	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.78	82.7	26	24	0.1	0.02	6	0.1	0	Satisfactory
196	2081/12/08	11:55	Kirtipur	Kirtipur SRT	Treated	Clear	1.7	<5	7.97	114.7	24	24	0.1	0.02	6	0.1	0	Satisfactory
197	2081/12/08	13:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	8.03	84.8	24	24	0.1	0.02	6	0.1	0	Satisfactory
198	2081/12/08	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	8.1	117.2	24	24	0.1	0.02	6	0.59	0	Satisfactory
199	2081/12/08	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.82	88.5	26	24	0.1	0.02	6	0.1	0	Satisfactory
200	2081/12/08	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.7	<5	7.69	86.3	26	24	0.1	0.02	6	0.1	0	Satisfactory
201	2081/12/08	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.78	82.4	24	24	0.1	0.02	6	0.1	0	Satisfactory
202	2081/12/08	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.77	71	14	22	0.1	0.02	6	0.34	0	Satisfactory

203	2081/12/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.56	60.1	14	22	0.1	0.02	6	1.81	0	Satisfactory
204	2081/12/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.72	62.9	14	22	0.1	0.02	6	2.06	0	Satisfactory
205	2081/12/08	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.1	<5	7.56	80.1	30	36	0.1	0.02	4	0.1	0	Satisfactory
206	2081/12/08	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.96	<5	7.4	378	126	68	0.76	1.5	18	0.45	0	Satisfactory
207	2081/12/08	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.07	<5	7.42	382	126	70	0.76	1.5	20	0.81	0	Satisfactory
208	2081/12/08	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.47	<5	7.71	74	24	30	0.1	0.02	6	0.1	0	Satisfactory
209	2081/12/08	14:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.40	73	24	30	0.1	0.02	6	0.1	0	Satisfactory
210	2081/12/08	6:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.07	<5	7.23	71	26	30	0.1	0.02	6	1.14	0	Satisfactory
211	2081/12/08	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.68	<5	7.86	484	132	130	0.1	0.02	10	0.53	0	Satisfactory
212	2081/12/09	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.87	74.6	22	24	0.1	0.02	6	0.1	0	Satisfactory
213	2081/12/09	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.84	75.3	22	24	0.1	0.02	6	0.19	0	Satisfactory
214	2081/12/09	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.72	75.1	22	24	0.1	0.02	6	1.25	0	Satisfactory
215	2081/12/09	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.62	75.3	22	24	0.1	0.02	6	1.43	0	Satisfactory
216	2081/12/09	8:00	Tripureswor	Anamnagar SRT	Treated	Clear	2.6	<5	7.93	94.1	26	24	0.1	0.02	4	0.6	0	Satisfactory
217	2081/12/09	12:50	Maharajgunj	Balaju SRT	Treated	Clear	1.8	<5	7.95	81	26	22	0.1	0.02	6	0.21	0	Satisfactory
218	2081/12/09	8:45	Bhaktapur	Katunje SRT	Treated	Clear	2.1	<5	7.73	85.2	26	24	0.1	0.02	6	0.1	0	Satisfactory
219	2081/12/09	12:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.1	<5	8.03	83.3	26	24	0.1	0.02	6	0.1	0	Satisfactory
220	2081/12/09	9:10	Kirtipur	Kirtipur SRT	Treated	Clear	4.7	<5	7.75	191.9	32	24	0.1	0.02	6	0.1	0	Satisfactory
221	2081/12/09	7:50	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.89	81.5	26	24	0.1	0.02	6	0.22	0	Satisfactory
222	2081/12/09	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.87	82.8	26	24	0.1	0.02	6	0.55	0	Satisfactory
223	2081/12/09	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2.4	<5	7.56	83.5	26	24	0.1	0.02	6	0.78	0	Satisfactory
224	2081/12/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.4	58.9	14	22	0.1	0.02	6	2.36	0	Satisfactory
225	2081/12/09	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.23	<5	7.37	74	24	32	0.1	0.02	6	0.1	0	Satisfactory
226	2081/12/09	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.36	<5	7.23	70	24	30	0.1	0.02	6	1.02	0	Satisfactory
227	2081/12/10	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.79	76.1	22	24	0.1	0.02	6	0.58	0	Satisfactory
228	2081/12/10	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.65	77.0	22	24	0.1	0.02	6	1.65	0	Satisfactory

229	2081/12/10	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.60	75.9	22	24	0.1	0.02	6	1.78	0	Satisfactory
230	2081/12/10	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.56	75.8	22	24	0.1	0.02	6	1.47	0	Satisfactory
231	2081/12/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.69	75.2	22	24	0.1	0.02	6	1.2	0	Satisfactory
232	2081/12/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.63	74.0	22	24	0.1	0.02	6	1.29	0	Satisfactory
233	2081/12/10	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.71	75.1	22	24	0.1	0.02	6	1.21	0	Satisfactory
234	2081/12/10	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.70	75.5	22	24	0.1	0.02	6	0.62	0	Satisfactory
235	2081/12/10	13:20	Tripureswor	Anamnagar SRT	Treated	Clear	0.5	<5	7.8	84.6	24	22	0.1	0.02	4	0.73	0	Satisfactory
236	2081/12/10	10:55	Maharajgunj	Balaju SRT	Treated	Clear	1.1	<5	7.77	85.9	24	22	0.1	0.02	6	0.1	0	Satisfactory
237	2081/12/10	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.54	89.7	26	24	0.1	0.02	6	0.96	0	Satisfactory
238	2081/12/10	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	7.6	134	24	24	0.1	0.02	6	0.1	0	Satisfactory
239	2081/12/10	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	1.6	<5	7.69	84.7	24	24	0.1	0.02	6	0.1	0	Satisfactory
240	2081/12/10	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.7	85.3	24	24	0.1	0.02	6	0.31	0	Satisfactory
241	2081/12/10	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.67	86.7	26	24	0.1	0.02	6	0.76	0	Satisfactory
242	2081/12/10	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.59	87.2	26	24	0.1	0.02	6	1.44	0	Satisfactory
243	2081/12/10	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.53	82.3	26	24	0.1	0.02	6	0.83	0	Satisfactory
244	2081/12/10	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.82	82.7	24	24	0.1	0.02	6	1.07	0	Satisfactory
245	2081/12/10	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.57	63.2	16	22	0.1	0.02	6	0.63	0	Satisfactory
246	2081/12/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.65	70.6	16	22	0.1	0.02	6	1.94	0	Satisfactory
247	2081/12/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.68	66.1	14	22	0.1	0.02	6	1.85	0	Satisfactory
248	2081/12/10	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.75	73.7	16	22	0.1	0.02	6	1.76	0	Satisfactory
249	2081/12/10	11:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.22	<5	7.78	81.4	30	36	0.1	0.02	4	1.3	0	Satisfactory
250	2081/12/10	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.68	<5	7.35	339	116	72	0.57	1.5	18	0.16	0	Satisfactory
251	2081/12/10	9:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.22	<5	7.57	75	26	32	0.1	0.02	6	0.40	0	Satisfactory
252	2081/12/10	14:35	Maharajgunj	Bansbari SRT	Treated	Clear	0.80	<5	7.51	75	26	32	0.1	0.02	6	0.86	0	Satisfactory

253	2081/12/10	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.33	72	24	30	0.1	0.02	6	1.13	0	Satisfactory
254	2081/12/10	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.34	<5	7.84	483	120	128	0.1	0.02	12	0.49	0	Satisfactory
255	2081/12/11	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.68	74.6	22	24	0.1	0.02	6	0.81	0	Satisfactory
256	2081/12/11	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.45	75.6	22	24	0.1	0.02	6	1.55	0	Satisfactory
257	2081/12/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.51	76.4	22	24	0.1	0.02	6	1.92	0	Satisfactory
258	2081/12/11	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.54	77.0	22	24	0.1	0.02	6	1.7	0	Satisfactory
259	2081/12/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.56	75.8	22	24	0.1	0.02	6	1.52	0	Satisfactory
260	2081/12/11	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.69	74.4	22	24	0.1	0.02	6	0.32	0	Satisfactory
261	2081/12/11	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.71	75.6	22	24	0.1	0.02	6	0.1	0	Satisfactory
262	2081/12/11	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.60	<5	7.88	74.4	22	24	0.1	0.02	6	0.18	0	Satisfactory
263	2081/12/11	11:50	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.5	77.2	24	22	0.1	0.02	6	0.36	0	Satisfactory
264	2081/12/11	11:45	Tripureswor	Anamagar SRT	Treated	Clear	1.8	<5	7.39	87.6	24	22	0.1	0.02	4	0.98	0	Satisfactory
265	2081/12/11	8:45	Bhaktapur	Katunje SRT	Treated	Clear	2.6	<5	7.45	88.8	24	24	0.1	0.02	6	0.9	0	Satisfactory
266	2081/12/11	11:55	Baneshwor	Minbhawan SRT	Treated	Clear	1.3	<5	7.43	91.3	24	24	0.1	0.02	6	0.91	0	Satisfactory
267	2081/12/11	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.28	78.7	26	24	0.1	0.02	6	1.06	0	Satisfactory
268	2081/12/11	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.38	86.3	26	24	0.1	0.02	6	1.78	0	Satisfactory
269	2081/12/11	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	2	<5	7.35	87.1	26	24	0.1	0.02	6	1.23	0	Satisfactory
270	2081/12/11	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.33	88.1	24	24	0.1	0.02	6	1.04	0	Satisfactory
271	2081/12/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.4	63.7	16	22	0.1	0.02	6	0.67	0	Satisfactory
272	2081/12/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.15	68.4	16	22	0.1	0.02	6	0.47	0	Satisfactory
273	2081/12/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.28	66.4	16	22	0.1	0.02	6	1.22	0	Satisfactory
274	2081/12/11	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.21	68.6	14	22	0.1	0.02	6	1.13	0	Satisfactory

275	2081/12/11	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.14	<5	7.7	83.4	30	36	0.1	0.02	4	1.01	0	Satisfactory
276	2081/12/11	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.7	<5	7.45	346	120	72	0.76	1.5	18	0.78	0	Satisfactory
277	2081/12/11	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.40	<5	7.48	76	26	32	0.1	0.02	6	1.04	0	Satisfactory
278	2081/12/11	14:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.86	<5	7.33	75	26	32	0.1	0.02	6	0.88	0	Satisfactory
279	2081/12/11	5:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	7.33	72	24	30	0.1	0.02	6	1.05	0	Satisfactory
280	2081/12/11	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.9	490.00	126	124	0.1	0.02	12	0.61	0	Satisfactory
281	2081/12/12	13:30	Tripureswor	Anamnagar SRT	Treated	Clear	1.2	<5	7.68	86.7	26	22	0.1	0.02	4	0.38	0	Satisfactory
282	2081/12/12	11:15	Maharajgunj	Balaju SRT	Treated	Clear	1.8	<5	7.42	83	26	22	0.1	0.02	6	0.1	0	Satisfactory
283	2081/12/12	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.45	87.2	26	24	0.1	0.02	6	0.15	0	Satisfactory
284	2081/12/12	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	2.1	<5	7.8	262.2	38	24	0.1	0.02	6	0.1	0	Satisfactory
285	2081/12/12	13:55	Baneshwor	Minbhawan SRT	Treated	Clear	1.6	<5	7.3	82.8	26	24	0.1	0.02	6	0.27	0	Satisfactory
286	2081/12/12	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1.2	<5	7.67	88.1	26	24	0.1	0.02	6	0.1	0	Satisfactory
287	2081/12/12	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.5	80.7	26	24	0.1	0.02	6	0.48	0	Satisfactory
288	2081/12/12	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.73	81.7	26	24	0.1	0.02	6	0.5	0	Satisfactory
289	2081/12/12	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.41	84	26	24	0.1	0.02	6	0.75	0	Satisfactory
290	2081/12/12	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.4	82.7	26	24	0.1	0.02	6	0.72	0	Satisfactory
291	2081/12/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.7	56.2	14	22	0.1	0.02	6	0.28	0	Satisfactory
292	2081/12/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.7	69.5	14	22	0.1	0.02	6	0.75	0	Satisfactory
293	2081/12/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.3	67.8	14	22	0.1	0.02	6	2.09	0	Satisfactory
294	2081/12/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.4	73.7	14	22	0.1	0.02	6	2.36	0	Satisfactory
295	2081/12/12	16:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.53	<5	7.72	80	30	36	0.1	0.02	4	0.63	0	Satisfactory
296	2081/12/12	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.79	<5	7.22	349	116	76	0.95	1.5	20	0.87	0	Satisfactory
297	2081/12/12	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.94	<5	7.25	358	118	76	0.76	1.5	20	0.6	0	Satisfactory
298	2081/12/12	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.41	<5	7.32	76	26	32	0.1	0.02	6	0.23	0	Satisfactory
299	2081/12/12	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	1.22	<5	7.32	77	26	34	0.1	0.02	6	0.44	0	Satisfactory
300	2081/12/12	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.26	71	24	28	0.1	0.02	6	1.03	0	Satisfactory
301	2081/12/12	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.64	75.3	22	24	0.1	0.02	6	0.71	0	Satisfactory
302	2081/12/12	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.16	<5	7.59	76.4	22	24	0.1	0.02	6	0.84	0	Satisfactory

303	2081/12/12	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.19	<5	7.40	76.6	22	24	0.1	0.02	6	0.72	0	Satisfactory
304	2081/12/12	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.08	<5	7.71	77.8	22	24	0.1	0.02	6	1.53	0	Satisfactory
305	2081/12/12	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.12	<5	7.63	76.3	22	24	0.1	0.02	6	0.68	0	Satisfactory
306	2081/12/12	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.90	<5	7.75	76.3	22	24	0.1	0.02	6	0.82	0	Satisfactory
307	2081/12/12	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.71	77.2	22	24	0.1	0.02	6	1.58	0	Satisfactory
308	2081/12/12	20:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.86	75.4	22	24	0.1	0.02	6	1.11	0	Satisfactory
309	2081/12/12	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.53	74.7	22	24	0.1	0.02	6	1.13	0	Satisfactory
310	2081/12/12	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.71	<5	7.94	487	136	132	0.1	0.02	12	0.77	0	Satisfactory
311	2081/12/13	13:35	Tripureswor	Anamnagar SRT	Treated	Clear	1.1	<5	7.7	88.2	26	22	0.1	0.02	4	0.68	0	Satisfactory
312	2081/12/13	11:15	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.82	83.5	26	22	0.1	0.02	6	0.1	0	Satisfactory
313	2081/12/13	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.45	94.9	26	24	0.1	0.02	6	0.27	0	Satisfactory
314	2081/12/13	12:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.9	<5	7.58	85.7	26	24	0.1	0.02	6	0.1	0	Satisfactory
315	2081/12/13	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.38	85.2	26	24	0.1	0.02	6	0.35	0	Satisfactory
316	2081/12/13	13:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.6	<5	7.66	87.3	26	24	0.1	0.02	6	0.78	0	Satisfactory
317	2081/12/13	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.7	89.3	26	24	0.1	0.02	6	0.28	0	Satisfactory
318	2081/12/13	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.78	84.7	26	24	0.1	0.02	6	0.7	0	Satisfactory
319	2081/12/13	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.58	92.5	26	24	0.1	0.02	6	1.23	0	Satisfactory
320	2081/12/13	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.73	87.1	26	24	0.1	0.02	6	1.36	0	Satisfactory
321	2081/12/13	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.66	82.6	26	24	0.1	0.02	6	0.97	0	Satisfactory
322	2081/12/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.65	77.2	16	22	0.1	0.02	6	1.4	0	Satisfactory
323	2081/12/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.55	66.1	14	22	0.1	0.02	6	1.51	0	Satisfactory
324	2081/12/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.73	62.9	14	22	0.1	0.02	6	1.38	0	Satisfactory
325	2081/12/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.64	61.6	14	22	0.1	0.02	6	0.81	0	Satisfactory

326	2081/12/13	7:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.37	<5	7.7	81.3	30	36	0.1	0.02	4	0.41	0	Satisfactory
327	2081/12/13	10:20	Madhyapur Thimi	Bode WTP	Treated	Clear	1.74	<5	7.24	336	116	72	0.76	1.5	16	0.1	0	Satisfactory
328	2081/12/13	12:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.99	<5	7.29	334	116	76	0.57	1.5	18	0.77	0	Satisfactory
329	2081/12/13	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.47	<5	7.31	330	116	76	0.76	1.5	18	0.3	0	Satisfactory
330	2081/12/13	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.46	<5	7.52	76	24	32	0.1	0.02	6	0.16	0	Satisfactory
331	2081/12/13	15:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.71	<5	7.38	77	26	34	0.1	0.02	6	0.92	0	Satisfactory
332	2081/12/13	6:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.43	<5	7.34	65	24	26	0.1	0.02	6	0.97	0	Satisfactory
333	2081/12/13	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.84	<5	7.86	494	136	132	0.1	0.02	10	0.82	0	Satisfactory
334	2081/12/13	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.50	<5	7.60	76.6	22	24	0.1	0.02	6	1.29	0	Satisfactory
335	2081/12/13	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.79	75.8	22	24	0.1	0.02	6	1.59	0	Satisfactory
336	2081/12/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.29	76.1	22	24	0.1	0.02	6	1.76	0	Satisfactory
337	2081/12/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.44	75.4	22	24	0.1	0.02	6	1.64	0	Satisfactory
338	2081/12/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.50	<5	7.69	75.9	22	24	0.1	0.02	6	1.37	0	Satisfactory
339	2081/12/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.38	74.6	22	24	0.1	0.02	6	1.12	0	Satisfactory
340	2081/12/13	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.36	75.3	22	24	0.1	0.02	6	1.2	0	Satisfactory
341	2081/12/13	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.82	75.1	22	24	0.1	0.02	6	1.1	0	Satisfactory
342	2081/12/14	14:00	Tripureswor	Anamnagar SRT	Treated	Clear	0.6	<5	7.85	110.4	26	24	0.1	0.02	4	0.73	0	Satisfactory
343	2081/12/14	12:25	Maharajgunj	Balaju SRT	Treated	Clear	0.2	<5	7.55	86.1	26	22	0.1	0.02	6	1.07	0	Satisfactory
344	2081/12/14	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.5	<5	7.52	89.2	26	24	0.1	0.02	6	1.42	0	Satisfactory
345	2081/12/14	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.1	<5	7.61	82	26	24	0.1	0.02	6	0.61	0	Satisfactory
346	2081/12/14	12:25	Kirtipur	Kirtipur SRT	Treated	Clear	0.2	<5	7.61	86.2	26	24	0.1	0.02	6	0.8	0	Satisfactory
347	2081/12/14	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.66	82	26	24	0.1	0.02	6	0.97	0	Satisfactory
348	2081/12/14	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.77	86.8	26	24	0.1	0.02	6	0.48	0	Satisfactory
349	2081/12/14	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.6	80.5	26	24	0.1	0.02	6	1.49	0	Satisfactory



350	2081/12/14	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.52	90.5	26	24	0.1	0.02	6	0.85	0	Satisfactory
351	2081/12/14	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.4	81.9	26	24	0.1	0.02	6	1.09	0	Satisfactory
352	2081/12/14	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.32	82	26	24	0.1	0.02	6	1.84	0	Satisfactory
353	2081/12/14	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.7	60.2	16	22	0.1	0.02	6	1.49	0	Satisfactory
354	2081/12/14	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.58	67.2	16	22	0.1	0.02	6	1.93	0	Satisfactory
355	2081/12/14	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.45	57.1	14	22	0.1	0.02	6	0.98	0	Satisfactory
356	2081/12/14	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.35	55.6	16	22	0.1	0.02	6	0.98	0	Satisfactory
357	2081/12/14	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.29	<5	7.7	81.4	30	36	0.1	0.02	4	0.95	0	Satisfactory
358	2081/12/14	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.32	<5	7.23	327	114	68	0.95	1.5	12	0.1	0	Satisfactory
359	2081/12/14	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.29	<5	6.99	324	112	68	0.95	1.5	12	0.1	0	Satisfactory
360	2081/12/14	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.46	<5	7.31	76	26	32	0.1	0.02	6	0.16	0	Satisfactory
361	2081/12/14	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.48	<5	7.31	77	26	34	0.1	0.02	6	1.21	0	Satisfactory
362	2081/12/14	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.26	72	24	28	0.1	0.02	6	1.04	0	Satisfactory
363	2081/12/14	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	7.83	470	136	132	0.1	0.02	10	0.94	0	Satisfactory
364	2081/12/14	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.60	<5	7.61	76.3	22	24	0.1	0.02	6	1.45	0	Satisfactory
365	2081/12/14	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.65	75.0	22	24	0.1	0.02	6	1.24	0	Satisfactory
366	2081/12/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.53	76.2	22	24	0.1	0.02	6	1.39	0	Satisfactory
367	2081/12/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.34	75.8	22	24	0.1	0.02	6	1.35	0	Satisfactory
368	2081/12/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.65	75.1	22	24	0.1	0.02	6	1.08	0	Satisfactory
369	2081/12/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.33	75.5	22	24	0.1	0.02	6	1.69	0	Satisfactory
370	2081/12/14	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.28	75.3	22	24	0.1	0.02	6	1.38	0	Satisfactory

371	2081/12/14	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.60	74.5	22	24	0.1	0.02	6	1.02	0	Satisfactory
372	2081/12/15	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.38	82.4	26	24	0.1	0.02	6	1.25	0	Satisfactory
373	2081/12/15	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.67	80.7	26	24	0.1	0.02	6	1.08	0	Satisfactory
374	2081/12/15	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.25	81.2	24	24	0.1	0.02	6	1.05	0	Satisfactory
375	2081/12/15	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.52	81.7	26	24	0.1	0.02	6	1.23	0	Satisfactory
376	2081/12/15	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.65	59.7	14	22	0.1	0.02	6	0.82	0	Satisfactory
377	2081/12/15	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.52	<5	7.38	73.1	16	22	0.1	0.02	6	0.8	0	Satisfactory
378	2081/12/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.4	83.8	16	22	0.1	0.02	6	1.79	0	Satisfactory
379	2081/12/15	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.79	<5	7.55	82.4	30	36	0.1	0.02	4	1.01	0	Satisfactory
380	2081/12/15	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.3	<5	7.07	343	114	78	0.76	1.5	20	0.87	0	Satisfactory
381	2081/12/15	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.45	<5	7.07	339	114	76	0.76	1.5	18	0.51	0	Satisfactory
382	2081/12/15	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.16	<5	7.33	75	24	32	0.1	0.02	6	0.80	0	Satisfactory
383	2081/12/15	14:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.14	<5	7.28	77	26	34	0.1	0.02	6	1.17	0	Satisfactory
384	2081/12/15	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.22	64	24	28	0.1	0.02	6	1.02	0	Satisfactory
385	2081/12/15	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.97	465	134	122	0.1	0.02	10	0.83	0	Satisfactory
386	2081/12/15	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.74	74.6	22	24	0.1	0.02	6	0.88	0	Satisfactory
387	2081/12/15	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.56	75.4	22	24	0.1	0.02	6	1.35	0	Satisfactory
388	2081/12/15	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.35	76.7	22	24	0.1	0.02	6	1.95	0	Satisfactory
389	2081/12/15	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.64	76.9	22	24	0.1	0.02	6	1.94	0	Satisfactory
390	2081/12/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.50	76.5	22	24	0.1	0.02	6	1.32	0	Satisfactory
391	2081/12/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.62	75.7	22	24	0.1	0.02	6	1.1	0	Satisfactory
392	2081/12/15	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.60	75.0	22	24	0.1	0.02	6	1.02	0	Satisfactory

393	2081/12/15	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.58	75.3	22	24	0.1	0.02	6	0.91	0	Satisfactory
394	2081/12/16	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.3	<5	7.48	82.3	26	24	0.1	0.02	6	0.35	0	Satisfactory
395	2081/12/16	8:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	80.7	26	24	0.1	0.02	6	0.53	0	Satisfactory
396	2081/12/16	8:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.65	63.5	16	22	0.1	0.02	6	0.83	0	Satisfactory
397	2081/12/16	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.38	75	24	32	0.1	0.02	6	0.86	0	Satisfactory
398	2081/12/16	6:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.36	<5	7.28	70	24	30	0.1	0.02	6	1.04	0	Satisfactory
399	2081/12/16	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.70	75.2	22	24	0.1	0.02	6	0.97	0	Satisfactory
400	2081/12/16	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.80	<5	7.44	75.8	22	24	0.1	0.02	6	1.2	0	Satisfactory
401	2081/12/16	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.60	74.8	22	24	0.1	0.02	6	1.48	0	Satisfactory
402	2081/12/16	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.59	76.3	22	24	0.1	0.02	6	1.67	0	Satisfactory
403	2081/12/16	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.60	<5	7.60	75.8	22	24	0.1	0.02	6	1.86	0	Satisfactory
404	2081/12/16	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.70	<5	7.49	75.7	22	24	0.1	0.02	6	1.83	0	Satisfactory
405	2081/12/16	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.71	74.8	22	24	0.1	0.02	6	1.03	0	Satisfactory
406	2081/12/17	14:00	Tripureswor	Anamnagar SRT	Treated	Clear	0.3	<5	7.17	81.2	26	22	0.1	0.02	4	0.52	0	Satisfactory
407	2081/12/17	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	7.45	81.7	26	24	0.1	0.02	6	0.27	0	Satisfactory
408	2081/12/17	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.61	87.7	26	24	0.1	0.02	6	0.97	0	Satisfactory
409	2081/12/17	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.67	85.1	26	24	0.1	0.02	6	0.82	0	Satisfactory
410	2081/12/17	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.24	80.1	26	24	0.1	0.02	6	0.52	0	Satisfactory
411	2081/12/17	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.38	82.7	26	24	0.1	0.02	6	0.99	0	Satisfactory
412	2081/12/17	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.4	80.9	26	24	0.1	0.02	6	1.19	0	Satisfactory
413	2081/12/17	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.31	80	26	24	0.1	0.02	6	1.29	0	Satisfactory
414	2081/12/17	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.26	80.1	26	24	0.1	0.02	6	1.27	0	Satisfactory
415	2081/12/17	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.42	78.7	16	22	0.1	0.02	6	2.12	0	Satisfactory

416	2081/12/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.26	73.7	16	22	0.1	0.02	6	2.05	0	Satisfactory
417	2081/12/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.37	68.4	16	22	0.1	0.02	6	1.16	0	Satisfactory
418	2081/12/17	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.25	69	16	22	0.1	0.02	6	0.78	0	Satisfactory
419	2081/12/17	11:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.03	<5	7.4	80.7	30	36	0.1	0.02	4	1.45	0	Satisfactory
420	2081/12/17	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	1.45	<5	7.01	338	112	76	0.76	1.5	16	0.33	0	Satisfactory
421	2081/12/17	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.73	<5	7.1	335	112	76	0.76	1.5	16	0.1	0	Satisfactory
422	2081/12/17	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.31	<5	7.1	337	112	76	0.76	1.5	16	0.12	0	Satisfactory
423	2081/12/17	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.53	<5	7.26	76	26	34	0.1	0.02	6	0.86	0	Satisfactory
424	2081/12/17	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.76	<5	7.21	76	26	34	0.1	0.02	6	1.53	0	Satisfactory
425	2081/12/17	5:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.45	<5	7.21	65	24	28	0.1	0.02	6	1.02	0	Satisfactory
426	2081/12/17	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.61	<5	7.98	478	136	132	0.1	0.02	12	0.68	0	Satisfactory
427	2081/12/17	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.63	76.5	22	24	0.1	0.02	6	1.15	0	Satisfactory
428	2081/12/17	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.42	76.5	22	24	0.1	0.02	6	1.29	0	Satisfactory
429	2081/12/17	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.38	75.3	22	24	0.1	0.02	6	1.33	0	Satisfactory
430	2081/12/17	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.58	74.1	22	24	0.1	0.02	6	1.28	0	Satisfactory
431	2081/12/17	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.58	73.1	22	24	0.1	0.02	6	0.71	0	Satisfactory
432	2081/12/17	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.41	73.9	22	24	0.1	0.02	6	1.41	0	Satisfactory
433	2081/12/17	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.50	74.3	22	24	0.1	0.02	6	1.23	0	Satisfactory
434	2081/12/17	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.48	75.1	22	24	0.1	0.02	6	1.38	0	Satisfactory
435	2081/12/18	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.8	<5	7.35	85.7	26	24	0.1	0.02	6	0.47	0	Satisfactory
436	2081/12/18	11:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.26	79.8	26	24	0.1	0.02	6	1.33	0	Satisfactory
437	2081/12/18	11:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.22	74.2	16	22	0.1	0.02	6	1.06	0	Satisfactory

438	2081/12/18	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.32	74	24	30	0.1	0.02	6	0.77	0	Satisfactory
439	2081/12/18	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.60	<5	7.41	75	24	32	0.1	0.02	6	1.02	0	Satisfactory
440	2081/12/18	5:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.26	72	24	28	0.1	0.02	6	1.05	0	Satisfactory
441	2081/12/18	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.62	76.0	22	24	0.1	0.02	6	1.04	0	Satisfactory
442	2081/12/18	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.60	74.8	22	24	0.1	0.02	6	1.28	0	Satisfactory
443	2081/12/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.54	75.4	22	24	0.1	0.02	6	1.6	0	Satisfactory
444	2081/12/18	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.51	75.5	22	24	0.1	0.02	6	1.57	0	Satisfactory
445	2081/12/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.43	75.1	22	24	0.1	0.02	6	1.24	0	Satisfactory
446	2081/12/18	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.76	75.3	22	24	0.1	0.02	6	1.34	0	Satisfactory
447	2081/12/18	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.65	74.3	22	24	0.1	0.02	6	1.05	0	Satisfactory
448	2081/12/18	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.62	74.6	22	24	0.1	0.02	6	1.32	0	Satisfactory
449	2081/12/19	14:25	Tripureswor	Anamnagar SRT	Treated	Clear	0.4	<5	7.83	103.5	26	24	0.1	0.02	4	0.58	0	Satisfactory
450	2081/12/19	12:00	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	8.05	109	26	24	0.1	0.02	6	0.98	0	Satisfactory
451	2081/12/19	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.4	<5	7.28	84.8	26	24	0.1	0.02	6	0.56	0	Satisfactory
452	2081/12/19	13:35	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.89	84.7	26	24	0.1	0.02	6	0.45	0	Satisfactory
453	2081/12/19	12:35	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	7.78	87.9	26	24	0.1	0.02	6	0.89	0	Satisfactory
454	2081/12/19	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.6	94.7	26	24	0.1	0.02	6	1.05	0	Satisfactory
455	2081/12/19	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.87	82.2	26	24	0.1	0.02	6	0.87	0	Satisfactory
456	2081/12/19	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.3	82.5	26	24	0.1	0.02	6	1.4	0	Satisfactory
457	2081/12/19	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.32	82.7	26	24	0.1	0.02	6	0.81	0	Satisfactory
458	2081/12/19	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.35	81	26	24	0.1	0.02	6	0.91	0	Satisfactory
459	2081/12/19	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.48	81.4	26	24	0.1	0.02	6	1.25	0	Satisfactory
460	2081/12/19	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.25	80.2	14	22	0.1	0.02	6	2.09	0	Satisfactory
461	2081/12/19	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.4	82.7	16	22	0.1	0.02	6	2.1	0	Satisfactory

462	2081/12/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	6.9	74.8	14	22	0.1	0.02	6	1.2	0	Satisfactory
463	2081/12/19	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.54	65.4	14	22	0.1	0.02	6	0.85	0	Satisfactory
464	2081/12/19	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.73	<5	7.36	76	24	32	0.1	0.02	6	0.28	0	Satisfactory
465	2081/12/19	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.83	<5	7.16	76	26	34	0.1	0.02	6	1.47	0	Satisfactory
466	2081/12/19	6:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.35	<5	7.33	71	24	28	0.1	0.02	6	0.96	0	Satisfactory
467	2081/12/19	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.58	76.7	22	24	0.1	0.02	6	1.24	0	Satisfactory
468	2081/12/19	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.51	75.9	22	24	0.1	0.02	6	1.33	0	Satisfactory
469	2081/12/19	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.47	75.6	22	24	0.1	0.02	6	1.75	0	Satisfactory
470	2081/12/19	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.47	76.2	22	24	0.1	0.02	6	1.65	0	Satisfactory
471	2081/12/19	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.74	76.0	22	24	0.1	0.02	6	1.72	0	Satisfactory
472	2081/12/19	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.51	76.3	22	24	0.1	0.02	6	1.61	0	Satisfactory
473	2081/12/19	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.48	76.2	22	24	0.1	0.02	6	1.21	0	Satisfactory
474	2081/12/19	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.60	<5	7.53	75.4	22	24	0.1	0.02	6	1.26	0	Satisfactory
475	2081/12/20	11:25	Tripureswor	Anamnagar SRT	Treated	Clear	1	<5	7.43	84.3	26	22	0.1	0.02	4	1.35	0	Satisfactory
476	2081/12/20	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.3	<5	7.45	86.7	26	24	0.1	0.02	6	0.79	0	Satisfactory
477	2081/12/20	13:30	Lalitpur	Khumaltar SRT	Treated	Clear	4.8	<5	7.52	84.6	26	24	0.1	0.02	6	0.1	0	Satisfactory
478	2081/12/20	12:35	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.89	114.6	26	24	0.1	0.02	6	0.79	0	Satisfactory
479	2081/12/20	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.9	116.4	26	24	0.1	0.02	6	0.55	0	Satisfactory
480	2081/12/20	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1	<5	7.66	81.1	26	24	0.1	0.02	6	0.23	0	Satisfactory
481	2081/12/20	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.68	81.7	26	24	0.1	0.02	6	1.77	0	Satisfactory
482	2081/12/20	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.53	84.7	26	24	0.1	0.02	6	1.14	0	Satisfactory
483	2081/12/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.46	81.8	24	24	0.1	0.02	6	1.55	0	Satisfactory
484	2081/12/20	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.5	84.3	26	24	0.1	0.02	6	1.22	0	Satisfactory

485	2081/12/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.75	67.2	14	22	0.1	0.02	6	1.82	0	Satisfactory
486	2081/12/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.77	70.3	16	22	0.1	0.02	6	1.77	0	Satisfactory
487	2081/12/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.45	62.2	16	22	0.1	0.02	6	1.87	0	Satisfactory
488	2081/12/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.68	65.4	14	22	0.1	0.02	6	1.64	0	Satisfactory
489	2081/12/20	16:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.19	<5	7.54	84.2	30	36	0.1	0.02	4	1.4	0	Satisfactory
490	2081/12/20	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.11	<5	7.3	374	130	78	0.76	1.5	16	0.8	0	Satisfactory
491	2081/12/20	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.2	<5	7.31	341	116	76	0.76	1.5	16	0.1	0	Satisfactory
492	2081/12/20	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.03	<5	7.27	342	116	76	0.76	1.5	20	0.71	0	Satisfactory
493	2081/12/20	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.61	<5	7.18	75	24	32	0.1	0.02	6	0.16	0	Satisfactory
494	2081/12/20	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.56	<5	7.13	78	26	34	0.1	0.02	6	1.13	0	Satisfactory
495	2081/12/20	6:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.43	<5	7.33	72	24	30	0.1	0.02	6	1.03	0	Satisfactory
496	2081/12/20	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.68	76.4	22	24	0.1	0.02	6	0.94	0	Satisfactory
497	2081/12/20	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.63	75.2	22	24	0.1	0.02	6	1.4	0	Satisfactory
498	2081/12/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.41	75.9	22	24	0.1	0.02	6	1.87	0	Satisfactory
499	2081/12/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.61	76.3	22	24	0.1	0.02	6	1.98	0	Satisfactory
500	2081/12/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.66	75.2	22	24	0.1	0.02	6	1.45	0	Satisfactory
501	2081/12/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.52	75.3	22	24	0.1	0.02	6	1.39	0	Satisfactory
502	2081/12/20	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.54	75.3	22	24	0.1	0.02	6	1.22	0	Satisfactory
503	2081/12/20	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.58	74.8	22	24	0.1	0.02	6	1.05	0	Satisfactory
504	2081/12/21	13:40	Tripureswor	Anamnagar SRT	Treated	Clear	0.5	<5	7.57	82.7	26	22	0.1	0.02	4	0.9	0	Satisfactory
505	2081/12/21	11:40	Maharajgunj	Balaju SRT	Treated	Clear	0.4	<5	7.8	85.7	26	22	0.1	0.02	6	0.68	0	Satisfactory
506	2081/12/21	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	7.38	88.4	26	24	0.1	0.02	6	0.4	0	Satisfactory



507	2081/12/21	12:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.75	126.2	26	24	0.1	0.02	6	0.82	0	Satisfactory
508	2081/12/21	13:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.8	125.7	26	24	0.1	0.02	6	0.96	0	Satisfactory
509	2081/12/21	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.68	81.2	26	24	0.1	0.02	6	0.91	0	Satisfactory
510	2081/12/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.57	79.4	26	24	0.1	0.02	6	1.79	0	Satisfactory
511	2081/12/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.52	79.2	26	24	0.1	0.02	6	1.62	0	Satisfactory
512	2081/12/21	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.6	81.7	24	24	0.1	0.02	6	1.82	0	Satisfactory
513	2081/12/21	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.57	82.7	26	24	0.1	0.02	6	1.95	0	Satisfactory
514	2081/12/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.7	63.7	16	22	0.1	0.02	6	0.82	0	Satisfactory
515	2081/12/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.6	64.7	14	22	0.1	0.02	6	0.91	0	Satisfactory
516	2081/12/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.75	79.7	16	22	0.1	0.02	6	1.83	0	Satisfactory
517	2081/12/21	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.63	79.6	16	22	0.1	0.02	6	1.85	0	Satisfactory
518	2081/12/21	16:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.39	<5	7.6	83.8	30	36	0.1	0.02	4	1.79	0	Satisfactory
519	2081/12/21	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	1.92	<5	7.22	351	116	76	0.76	1.5	20	0.29	0	Satisfactory
520	2081/12/21	12:00	Madhyapur Thimi	Bode WTP	Treated	Clear	0.83	<5	7.25	347	116	76	0.57	1.5	20	0.33	0	Satisfactory
521	2081/12/21	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.01	<5	7.28	340	116	76	0.57	1.5	20	0.3	0	Satisfactory
522	2081/12/21	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.50	<5	7.41	74	24	32	0.1	0.02	6	1.04	0	Satisfactory
523	2081/12/21	15:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.43	<5	7.30	77	26	34	0.1	0.02	6	1.36	0	Satisfactory
524	2081/12/21	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.46	<5	7.07	66	24	28	0.1	0.02	6	1.01	0	Satisfactory
525	2081/12/21	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.59	76.6	22	24	0.1	0.02	6	1.59	0	Satisfactory
526	2081/12/21	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.70	<5	7.41	76.8	22	24	0.1	0.02	6	1.54	0	Satisfactory
527	2081/12/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.45	76.7	22	24	0.1	0.02	6	2.03	0	Satisfactory
528	2081/12/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.43	77.5	22	24	0.1	0.02	6	2.02	0	Satisfactory
529	2081/12/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.57	74.4	22	24	0.1	0.02	6	1.69	0	Satisfactory

530	2081/12/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.47	76.0	22	24	0.1	0.02	6	0.76	0	Satisfactory
531	2081/12/21	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.58	76.6	22	24	0.1	0.02	6	1.37	0	Satisfactory
532	2081/12/21	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.51	75.1	22	24	0.1	0.02	6	1	0	Satisfactory
533	2081/12/22	13:40	Tripureswor	Anamnagar SRT	Treated	Clear	0.5	<5	7.54	89.9	24	22	0.1	0.02	4	0.59	0	Satisfactory
534	2081/12/22	13:20	Maharajgunj	Balaju SRT	Treated	Clear	0.4	<5	7.8	88.4	26	22	0.1	0.02	6	0.49	0	Satisfactory
535	2081/12/22	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.4	87.5	26	24	0.1	0.02	6	1	0	Satisfactory
536	2081/12/22	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	1	<5	7.77	91.7	24	24	0.1	0.02	6	1.01	0	Satisfactory
537	2081/12/22	13:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.7	87.4	24	24	0.1	0.02	6	1	0	Satisfactory
538	2081/12/22	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.5	<5	7.87	89.7	24	24	0.1	0.02	6	0.87	0	Satisfactory
539	2081/12/22	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.79	83.7	26	24	0.1	0.02	6	1.75	0	Satisfactory
540	2081/12/22	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.47	84.1	26	24	0.1	0.02	6	1.36	0	Satisfactory
541	2081/12/22	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.33	87.5	24	24	0.1	0.02	6	1.65	0	Satisfactory
542	2081/12/22	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.72	88.7	14	22	0.1	0.02	6	2.03	0	Satisfactory
543	2081/12/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.61	83.2	16	22	0.1	0.02	6	1.15	0	Satisfactory
544	2081/12/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.31	79.5	16	22	0.1	0.02	6	0.45	0	Satisfactory
545	2081/12/22	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.47	<5	7.65	80.7	30	36	0.1	0.02	4	0.1	0	Satisfactory
546	2081/12/22	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.79	<5	7.3	337	116	72	0.57	1.5	16	0.25	0	Satisfactory
547	2081/12/22	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.84	<5	7.28	333	116	72	0.57	1.5	16	0.28	0	Satisfactory
548	2081/12/22	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.95	<5	7.28	330	116	72	0.57	1.5	16	0.26	0	Satisfactory
549	2081/12/22	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.36	<5	7.41	76	26	34	0.1	0.02	6	1.16	0	Satisfactory
550	2081/12/22	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.30	77	26	34	0.1	0.02	6	1.07	0	Satisfactory
551	2081/12/22	6:05	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	7.22	76	26	32	0.1	0.02	6	1.52	0	Satisfactory
552	2081/12/22	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	7.93	496	138	128	0.1	0.02	14	0.74	0	Satisfactory
553	2081/12/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.70	76.7	22	24	0.1	0.02	6	1.14	0	Satisfactory
554	2081/12/22	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.40	77.1	22	24	0.1	0.02	6	1.51	0	Satisfactory

555	2081/12/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.40	<5	7.57	76.0	22	24	0.1	0.02	6	2.05	0	Satisfactory
556	2081/12/22	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.47	77.6	22	24	0.1	0.02	6	1.93	0	Satisfactory
557	2081/12/22	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.66	77.0	22	24	0.1	0.02	6	2.2	0	Satisfactory
558	2081/12/22	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.72	78.1	22	24	0.1	0.02	6	1.81	0	Satisfactory
559	2081/12/22	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.75	75.2	22	24	0.1	0.02	6	0.63	0	Satisfactory
560	2081/12/22	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.58	75.9	22	24	0.1	0.02	6	1.02	0	Satisfactory
561	2081/12/23	6:30	Tripureswor	Anamnagar SRT	Treated	Clear	0.2	<5	7.73	68.2	26	20	0.1	0.02	4	0.73	0	Satisfactory
562	2081/12/23	9:00	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.46	81.7	26	22	0.1	0.02	6	0.72	0	Satisfactory
563	2081/12/23	8:45	Bhaktapur	Katunje SRT	Treated	Clear	2.6	<5	7.23	101.2	26	24	0.1	0.02	6	0.1	0	Satisfactory
564	2081/12/23	7:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.67	63.7	26	24	0.1	0.02	6	0.59	0	Satisfactory
565	2081/12/23	8:20	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.71	88.2	26	24	0.1	0.02	6	0.53	0	Satisfactory
566	2081/12/23	7:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.78	67.2	26	24	0.1	0.02	6	0.63	0	Satisfactory
567	2081/12/23	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.2	<5	7.65	81.5	26	24	0.1	0.02	6	0.45	0	Satisfactory
568	2081/12/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.69	82.7	26	24	0.1	0.02	6	0.62	0	Satisfactory
569	2081/12/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.65	62.8	14	22	0.1	0.02	6	0.89	0	Satisfactory
570	2081/12/23	9:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.36	<5	7.21	76	26	32	0.1	0.02	6	1.51	0	Satisfactory
571	2081/12/23	5:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.14	73	24	30	0.1	0.02	6	1.32	0	Satisfactory
572	2081/12/23	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.57	77.3	22	24	0.1	0.02	6	1.39	0	Satisfactory
573	2081/12/23	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.59	76.8	22	24	0.1	0.02	6	1.65	0	Satisfactory
574	2081/12/23	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.48	76.2	22	24	0.1	0.02	6	1.23	0	Satisfactory
575	2081/12/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.69	77.2	22	24	0.1	0.02	6	1.8	0	Satisfactory
576	2081/12/23	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.38	76.0	22	24	0.1	0.02	6	0.92	0	Satisfactory

577	2081/12/23	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.57	76.6	22	24	0.1	0.02	6	1.2	0	Satisfactory
578	2081/12/23	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.39	77.5	22	24	0.1	0.02	6	1.64	0	Satisfactory
579	2081/12/24	10:30	Tripureswor	Anamnagar SRT	Treated	Clear	0.3	<5	7.75	73.7	26	22	0.1	0.02	4	0.73	0	Satisfactory
580	2081/12/24	11:35	Maharajgunj	Balaju SRT	Treated	Clear	0.2	<5	7.72	81.3	26	22	0.1	0.02	6	0.62	0	Satisfactory
581	2081/12/24	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.1	<5	7.35	93.8	26	24	0.1	0.02	6	0.91	0	Satisfactory
582	2081/12/24	11:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.75	65.7	26	24	0.1	0.02	6	0.6	0	Satisfactory
583	2081/12/24	13:30	Kirtipur	Kirtipur SRT	Treated	Clear	1	<5	7.76	89.7	26	24	0.1	0.02	6	0.6	0	Satisfactory
584	2081/12/24	11:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.2	<5	7.72	69.7	26	24	0.1	0.02	6	0.7	0	Satisfactory
585	2081/12/24	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.75	82.5	26	24	0.1	0.02	6	0.63	0	Satisfactory
586	2081/12/24	13:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.76	82.5	26	24	0.1	0.02	6	0.75	0	Satisfactory
587	2081/12/24	13:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.72	76.7	16	22	0.1	0.02	6	1.23	0	Satisfactory
588	2081/12/24	9:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.23	<5	7.26	75	26	32	0.1	0.02	6	1.03	0	Satisfactory
589	2081/12/24	5:40	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.10	72	24	30	0.1	0.02	6	1.07	0	Satisfactory
590	2081/12/24	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.47	77.1	22	24	0.1	0.02	6	1.51	0	Satisfactory
591	2081/12/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.52	77.1	22	24	0.1	0.02	6	1.3	0	Satisfactory
592	2081/12/24	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.56	77.2	22	24	0.1	0.02	6	1.12	0	Satisfactory
593	2081/12/24	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.36	78.3	22	24	0.1	0.02	6	1.1	0	Satisfactory
594	2081/12/24	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.72	76.9	22	24	0.1	0.02	6	1.88	0	Satisfactory
595	2081/12/25	8:45	Bhaktapur	Katunje SRT	Treated	Clear	2.7	<5	7.26	91.8	26	24	0.1	0.02	6	0.1	0	Satisfactory
596	2081/12/25	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.25	94	26	24	0.1	0.02	6	1.6	0	Satisfactory
597	2081/12/25	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.57	81.5	26	24	0.1	0.02	6	1.36	0	Satisfactory
598	2081/12/25	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.75	83.7	26	24	0.1	0.02	6	1.23	0	Satisfactory
599	2081/12/25	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.7	81.2	26	24	0.1	0.02	6	0.65	0	Satisfactory
600	2081/12/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.29	85.2	16	22	0.1	0.02	6	1.4	0	Satisfactory

601	2081/12/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.55	80.2	16	22	0.1	0.02	6	1.58	0	Satisfactory
602	2081/12/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.63	63.7	14	22	0.1	0.02	6	1.64	0	Satisfactory
603	2081/12/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.57	76.7	16	22	0.1	0.02	6	1.15	0	Satisfactory
604	2081/12/25	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.26	<5	7.7	81.6	30	36	0.1	0.02	4	0.24	0	Satisfactory
605	2081/12/25	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.82	<5	7.21	351	118	70	0.57	1.5	16	0.28	0	Satisfactory
606	2081/12/25	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.13	<5	7.26	347	120	74	0.57	1.5	16	0.32	0	Satisfactory
607	2081/12/25	16:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.83	<5	7.25	343	102	60	0.57	1.5	16	0.25	0	Satisfactory
608	2081/12/25	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.40	<5	7.14	75	26	32	0.1	0.02	6	1.28	0	Satisfactory
609	2081/12/25	15:40	Maharajgunj	Bansbari SRT	Treated	Clear	0.50	<5	7.30	78	26	34	0.1	0.02	6	1.30	0	Satisfactory
610	2081/12/25	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.30	<5	7.10	73	24	30	0.1	0.02	6	1.23	0	Satisfactory
611	2081/12/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.88	<5	7.98	505	142	128	0.1	0.02	14	0.58	0	Satisfactory
612	2081/12/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.38	77.9	22	24	0.1	0.02	6	2.09	0	Satisfactory
613	2081/12/25	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.70	76.7	22	24	0.1	0.02	6	0.77	0	Satisfactory
614	2081/12/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.50	<5	7.63	77.2	22	24	0.1	0.02	6	1.5	0	Satisfactory
615	2081/12/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.70	76.7	22	24	0.1	0.02	6	1.81	0	Satisfactory
616	2081/12/25	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.73	77.1	22	24	0.1	0.02	6	1.21	0	Satisfactory
617	2081/12/25	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.59	76.7	22	24	0.1	0.02	6	0.96	0	Satisfactory
618	2081/12/26	10:40	Tripureswor	Anamnagar SRT	Treated	Clear	1.5	<5	7.65	88.2	26	22	0.1	0.02	4	0.97	0	Satisfactory
619	2081/12/26	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.6	<5	7.23	88.7	26	24	0.1	0.02	6	0.38	0	Satisfactory
620	2081/12/26	11:55	Lalitpur	Khumaltar SRT	Treated	Clear	1.2	<5	7.62	85.7	26	24	0.1	0.02	6	0.94	0	Satisfactory
621	2081/12/26	13:30	Baneshwor	Minbhawan SRT	Treated	Clear	1	<5	7.57	84.2	26	24	0.1	0.02	6	1.06	0	Satisfactory
622	2081/12/26	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.8	<5	7.61	90.1	26	24	0.1	0.02	6	1.53	0	Satisfactory
623	2081/12/26	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.35	82.3	26	24	0.1	0.02	6	0.76	0	Satisfactory
624	2081/12/26	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.69	83.4	26	24	0.1	0.02	6	1.41	0	Satisfactory

625	2081/12/26	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.72	85.3	26	24	0.1	0.02	6	1.32	0	Satisfactory
626	2081/12/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.69	78.1	16	22	0.1	0.02	6	0.67	0	Satisfactory
627	2081/12/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.44	68.5	16	22	0.1	0.02	6	0.87	0	Satisfactory
628	2081/12/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	8.23	75.1	16	22	0.1	0.02	6	1.06	0	Satisfactory
629	2081/12/26	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.65	74.7	16	22	0.1	0.02	6	1.55	0	Satisfactory
630	2081/12/26	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.08	<5	7.7	80.2	30	36	0.1	0.02	4	0.4	0	Satisfactory
631	2081/12/26	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.02	<5	7.41	350	154	68	0.57	1.5	20	0.98	0	Satisfactory
632	2081/12/26	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.97	<5	7.36	346	120	74	0.57	1.5	20	0.84	0	Satisfactory
633	2081/12/26	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.60	<5	7.32	76	26	32	0.1	0.02	6	1.21	0	Satisfactory
634	2081/12/26	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.31	<5	7.15	77	26	34	0.1	0.02	6	1.31	0	Satisfactory
635	2081/12/26	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.07	74	24	30	0.1	0.02	6	1.14	0	Satisfactory
636	2081/12/26	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.67	<5	7.89	501	138	132	0.1	0.02	14	0.76	0	Satisfactory
637	2081/12/26	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.45	77.5	22	24	0.1	0.02	6	1.53	0	Satisfactory
638	2081/12/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.48	77.3	22	24	0.1	0.02	6	1.55	0	Satisfactory
639	2081/12/26	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.59	76.3	22	24	0.1	0.02	6	1.26	0	Satisfactory
640	2081/12/26	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.65	76.9	22	24	0.1	0.02	6	1.84	0	Satisfactory
641	2081/12/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.72	77.4	22	24	0.1	0.02	6	1.34	0	Satisfactory
642	2081/12/26	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.64	75.8	22	24	0.1	0.02	6	1.13	0	Satisfactory
643	2081/12/26	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.62	77.5	22	24	0.1	0.02	6	1.18	0	Satisfactory
644	2081/12/27	11:55	Maharajgunj	Balaju SRT	Treated	Clear	0.2	<5	7.56	86.9	26	22	0.1	0.02	6	1.18	0	Satisfactory
645	2081/12/27	8:45	Bhaktapur	Katunje SRT	Treated	Clear	0.5	<5	7.53	85.3	26	24	0.1	0.02	6	0.49	0	Satisfactory
646	2081/12/27	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	1	<5	7.58	85.5	26	24	0.1	0.02	6	0.55	0	Satisfactory
647	2081/12/27	13:30	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.95	110.9	26	24	0.1	0.02	6	1.08	0	Satisfactory
648	2081/12/27	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.55	84.6	26	24	0.1	0.02	6	0.8	0	Satisfactory

649	2081/12/27	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.72	84.7	26	24	0.1	0.02	6	1.45	0	Satisfactory
650	2081/12/27	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.3	<5	7.47	84.2	26	24	0.1	0.02	6	1.3	0	Satisfactory
651	2081/12/27	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.53	84.3	26	24	0.1	0.02	6	1.3	0	Satisfactory
652	2081/12/27	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.33	84.3	26	24	0.1	0.02	6	1.21	0	Satisfactory
653	2081/12/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.65	75.7	16	22	0.1	0.02	6	0.95	0	Satisfactory
654	2081/12/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.52	70.7	16	22	0.1	0.02	6	0.89	0	Satisfactory
655	2081/12/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.65	79.2	16	22	0.1	0.02	6	0.55	0	Satisfactory
656	2081/12/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.51	73.7	14	22	0.1	0.02	6	0.9	0	Satisfactory
657	2081/12/27	16:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.23	<5	7.72	82.6	30	36	0.1	0.02	4	1.54	0	Satisfactory
658	2081/12/27	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.52	<5	7.25	340	118	74	0.57	1.5	20	0.43	0	Satisfactory
659	2081/12/27	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.47	<5	7.28	346	120	74	0.57	1.5	20	0.4	0	Satisfactory
660	2081/12/27	16:15	Madhyapur Thimi	Bode WTP	Treated	Clear	1.88	<5	7.28	344	118	74	0.57	1.5	20	0.26	0	Satisfactory
661	2081/12/27	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.31	<5	7.16	75	24	32	0.1	0.02	6	0.97	0	Satisfactory
662	2081/12/27	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.25	<5	7.18	78	26	34	0.1	0.02	6	0.97	0	Satisfactory
663	2081/12/27	5:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.12	<5	7.13	73	24	30	0.1	0.02	6	1.13	0	Satisfactory
664	2081/12/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.04	<5	7.94	508	138	132	0.1	0.02	14	0.55	0	Satisfactory
665	2081/12/27	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.42	78.2	22	24	0.1	0.02	6	2.03	0	Satisfactory
666	2081/12/27	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.49	77.5	22	24	0.1	0.02	6	1.15	0	Satisfactory
667	2081/12/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.47	78.3	22	24	0.1	0.02	6	1.79	0	Satisfactory
668	2081/12/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.37	79.8	22	24	0.1	0.02	6	1.41	0	Satisfactory
669	2081/12/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.54	77.8	22	24	0.1	0.02	6	1.31	0	Satisfactory
670	2081/12/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.56	77.5	22	24	0.1	0.02	6	1.56	0	Satisfactory



671	2081/12/27	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.61	76.6	22	24	0.1	0.02	6	1.27	0	Satisfactory
672	2081/12/27	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.43	76.4	22	24	0.1	0.02	6	1	0	Satisfactory
673	2081/12/28	11:25	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	8.01	114.7	26	24	0.1	0.02	6	0.37	0	Satisfactory
674	2081/12/28	8:45	Bhaktapur	Katunje SRT	Treated	Clear	5	<5	7.37	90	26	24	0.1	0.02	6	0.65	0	Satisfactory
675	2081/12/28	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.52	83.7	26	24	0.1	0.02	6	0.45	0	Satisfactory
676	2081/12/28	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	7.59	88.4	26	24	0.1	0.02	6	0.95	0	Satisfactory
677	2081/12/28	14:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.9	<5	7.9	117.4	26	24	0.1	0.02	6	1.1	0	Satisfactory
678	2081/12/28	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1	<5	7.4	86.9	26	24	0.1	0.02	6	1.09	0	Satisfactory
679	2081/12/28	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.44	84.9	26	24	0.1	0.02	6	0.97	0	Satisfactory
680	2081/12/28	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.62	82.3	26	24	0.1	0.02	6	0.95	0	Satisfactory
681	2081/12/28	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.3	81.9	26	24	0.1	0.02	6	1.08	0	Satisfactory
682	2081/12/28	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.72	82.3	26	24	0.1	0.02	6	1.15	0	Satisfactory
683	2081/12/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.49	64.9	16	22	0.1	0.02	6	0.81	0	Satisfactory
684	2081/12/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.68	59.7	16	22	0.1	0.02	6	1	0	Satisfactory
685	2081/12/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.43	65.2	16	22	0.1	0.02	6	0.56	0	Satisfactory
686	2081/12/28	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.65	64.7	16	22	0.1	0.02	6	0.87	0	Satisfactory
687	2081/12/28	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.27	<5	7.27	75	24	32	0.1	0.02	6	1.03	0	Satisfactory
688	2081/12/28	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.40	<5	7.30	76	26	32	0.1	0.02	6	1.41	0	Satisfactory
689	2081/12/28	6:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.10	73	24	30	0.1	0.02	6	1.37	0	Satisfactory
690	2081/12/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.99	472	136	130	0.1	0.02	12	0.71	0	Satisfactory
691	2081/12/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.55	76.1	22	24	0.1	0.02	6	0.64	0	Satisfactory
692	2081/12/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.56	76.4	22	24	0.1	0.02	6	1.11	0	Satisfactory
693	2081/12/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.60	<5	7.52	76.3	22	24	0.1	0.02	6	1.41	0	Satisfactory
694	2081/12/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.42	77.4	22	24	0.1	0.02	6	1.6	0	Satisfactory

695	2081/12/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.57	76.2	22	24	0.1	0.02	6	1.05	0	Satisfactory
696	2081/12/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.50	76.7	22	24	0.1	0.02	6	1.68	0	Satisfactory
697	2081/12/28	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.58	77.0	22	24	0.1	0.02	6	1.19	0	Satisfactory
698	2081/12/28	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.51	77.4	22	24	0.1	0.02	6	1.3	0	Satisfactory
699	2081/12/29	10:50	Tripureswor	Anamnagar SRT	Treated	Clear	0.6	<5	7.61	89	26	22	0.1	0.02	4	1.08	0	Satisfactory
700	2081/12/29	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1	<5	7.42	87.5	26	24	0.1	0.02	6	0.55	0	Satisfactory
701	2081/12/29	11:35	Lalitpur	Khumaltar SRT	Treated	Clear	1	<5	7.56	90.4	26	24	0.1	0.02	6	0.65	0	Satisfactory
702	2081/12/29	12:20	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.86	88.5	26	24	0.1	0.02	6	0.81	0	Satisfactory
703	2081/12/29	11:10	Baneshwor	Minbhawan SRT	Treated	Clear	5	<5	7.56	87	26	24	0.1	0.02	6	0.66	0	Satisfactory
704	2081/12/29	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.3	<5	7.89	92.1	26	24	0.1	0.02	6	0.89	0	Satisfactory
705	2081/12/29	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.4	<5	7.68	85.7	26	24	0.1	0.02	6	0.92	0	Satisfactory
706	2081/12/29	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.12	85.7	26	24	0.1	0.02	6	0.89	0	Satisfactory
707	2081/12/29	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.72	72.7	16	22	0.1	0.02	6	1.25	0	Satisfactory
708	2081/12/29	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.45	67.5	16	22	0.1	0.02	6	1.82	0	Satisfactory
709	2081/12/29	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2	<5	7.92	84	16	22	0.1	0.02	6	2.12	0	Satisfactory
710	2081/12/29	13:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.32	<5	7.75	84.3	30	36	0.1	0.02	4	1.1	0	Satisfactory
711	2081/12/29	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.73	<5	7.3	347	10	74	0.57	1.5	18	0.41	0	Satisfactory
712	2081/12/29	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.17	<5	7.25	362	12	76	0.57	1.5	18	0.45	0	Satisfactory
713	2081/12/29	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.2	<5	7.28	339	118	72	0.57	1.5	16	0.3	0	Satisfactory
714	2081/12/29	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	3.40	<5	7.31	76	26	32	0.1	0.02	6	1.10	0	Satisfactory
715	2081/12/29	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	4.37	<5	7.22	77	26	34	0.1	0.02	6	0.83	0	Satisfactory
716	2081/12/29	6:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.10	69	24	30	0.1	0.02	6	1.03	0	Satisfactory
717	2081/12/29	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.03	<5	7.85	501	140	140	0.1	0.02	16	0.85	0	Satisfactory
718	2081/12/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.61	<5	7.39	79.3	22	24	0.1	0.02	6	0.7	0	Satisfactory
719	2081/12/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	3.09	<5	7.22	78.1	22	24	0.1	0.02	6	0.94	0	Satisfactory

720	2081/12/29	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	4.57	<5	7.27	78.0	22	24	0.1	0.02	6	0.85	0	Satisfactory
721	2081/12/29	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.94	<5	7.30	79.4	22	24	0.1	0.02	6	1.74	0	Satisfactory
722	2081/12/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.22	<5	7.38	79.2	22	24	0.1	0.02	6	1.62	0	Satisfactory
723	2081/12/29	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.17	<5	7.58	78.0	22	24	0.1	0.02	6	1.91	0	Satisfactory
724	2081/12/29	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.06	<5	7.61	76.1	22	24	0.1	0.02	6	0.95	0	Satisfactory
725	2081/12/29	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.48	77.5	22	24	0.1	0.02	6	1.06	0	Satisfactory
726	2081/12/30	7:45	Tripureswor	Anamnagar SRT	Treated	Clear	1.7	<5	7.83	86.5	26	22	0.1	0.02	4	1.22	0	Satisfactory
727	2081/12/30	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.2	<5	7.86	91.3	26	24	0.1	0.02	6	0.59	0	Satisfactory
728	2081/12/30	8:10	Lalitpur	Khumaltar SRT	Treated	Clear	2.4	<5	7.76	86.1	26	24	0.1	0.02	6	1.04	0	Satisfactory
729	2081/12/30	9:15	Kirtipur	Kirtipur SRT	Treated	Clear	5	<5	7.99	88.2	26	24	0.1	0.02	6	0.22	0	Satisfactory
730	2081/12/30	7:35	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.9	83.3	26	24	0.1	0.02	6	0.63	0	Satisfactory
731	2081/12/30	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1	<5	7.77	84.1	26	24	0.1	0.02	6	1.25	0	Satisfactory
732	2081/12/30	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.81	82.9	26	24	0.1	0.02	6	1.71	0	Satisfactory
733	2081/12/30	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.85	68.9	16	22	0.1	0.02	6	0.59	0	Satisfactory
734	2081/12/30	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.28	<5	7.17	76	26	34	0.1	0.02	6	0.86	0	Satisfactory
735	2081/12/30	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	1.04	<5	7.14	76	26	32	0.1	0.02	6	1.17	0	Satisfactory
736	2081/12/30	11:25	Maharajgunj	Balaju SRT	Treated	Clear	0.7	<5	7.89	84.7	26	22	0.1	0.02	6	1.92	0	Satisfactory
737	2081/12/30	11:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	8.05	86.5	26	24	0.1	0.02	6	0.73	0	Satisfactory
738	2081/12/30	10:30	Baneshwor	Minbhawan SRT	Treated	Clear	1	<5	7.78	89.7	26	24	0.1	0.02	6	1.19	0	Satisfactory
739	2081/12/30	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.92	82.7	26	24	0.1	0.02	6	1.3	0	Satisfactory
740	2081/12/30	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.95	83.7	26	24	0.1	0.02	6	1.2	0	Satisfactory
741	2081/12/30	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.96	76.2	16	22	0.1	0.02	6	1.44	0	Satisfactory
742	2081/12/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.96	77.8	16	22	0.1	0.02	6	1.62	0	Satisfactory
743	2081/12/30	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.44	<5	7.18	78	26	34	0.1	0.02	6	1.24	0	Satisfactory
744	2081/12/30	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.57	77.7	22	24	0.1	0.02	6	0.75	0	Satisfactory

745	2081/12/30	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.47	77.3	22	24	0.1	0.02	6	0.62	0	Satisfactory
746	2081/12/30	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.13	<5	7.38	79.2	22	24	0.1	0.02	6	1.67	0	Satisfactory
747	2081/12/30	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.57	<5	7.59	79.3	22	24	0.1	0.02	6	0.98	0	Satisfactory
748	2081/12/30	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.46	<5	7.45	78.2	22	24	0.1	0.02	6	0.28	0	Satisfactory
749	2081/12/30	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.92	<5	7.39	77.2	22	24	0.1	0.02	6	0.55	0	Satisfactory
750	2081/12/30	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.46	77.2	22	24	0.1	0.02	6	1.22	0	Satisfactory
751	2081/12/31	10:40	Tripureswor	Anamnagar SRT	Treated	Clear	0.6	<5	7.95	86.7	26	22	0.1	0.02	4	0.96	0	Satisfactory
752	2081/12/31	8:45	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.91	88.2	26	24	0.1	0.02	6	0.99	0	Satisfactory
753	2081/12/31	12:05	Kirtipur	Kirtipur SRT	Treated	Clear	1	<5	7.98	85.3	26	24	0.1	0.02	6	0.73	0	Satisfactory
754	2081/12/31	11:10	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.98	86.2	26	24	0.1	0.02	6	0.66	0	Satisfactory
755	2081/12/31	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.8	83.4	26	24	0.1	0.02	6	0.63	0	Satisfactory
756	2081/12/31	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.72	78.2	26	24	0.1	0.02	6	1.03	0	Satisfactory
757	2081/12/31	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.78	77.2	16	22	0.1	0.02	6	1.62	0	Satisfactory
758	2081/12/31	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.66	84.2	16	22	0.1	0.02	6	0.91	0	Satisfactory
759	2081/12/31	5:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.13	78	26	34	0.1	0.02	6	1.03	0	Satisfactory
760	2081/12/31	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.51	78.4	22	24	0.1	0.02	6	0.95	0	Satisfactory
761	2081/12/31	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.48	78.6	22	24	0.1	0.02	6	1.53	0	Satisfactory
762	2081/12/31	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.63	76.2	22	24	0.1	0.02	6	0.65	0	Satisfactory
763	2081/12/31	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.35	78.3	22	24	0.1	0.02	6	1.77	0	Satisfactory
764	2081/12/31	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.55	77.6	22	24	0.1	0.02	6	1.68	0	Satisfactory

765	2081/12/31	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.54	76.8	22	24	0.1	0.02	6	1.64	0	Satisfactory
766	2081/12/31	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.75	<5	7.61	76.1	22	24	0.1	0.02	6	1.14	0	Satisfactory
767	2081/12/31	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.80	<5	7.62	76.3	22	24	0.1	0.02	6	1.1	0	Satisfactory