



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Falgun 2081

S.N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	p ^H	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
							(NTU)	(TCU)		µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml	
National Drinking Water Quality Standard (NDWQS)							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2081/11/01	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	8.15	65.7	16	18	0.1	0.02	4	0.95	0	Satisfactory
2	2081/11/01	16:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	8.1	65.7	24	22	0.1	0.02	6	0.95	0	Satisfactory
3	2081/11/01	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.51	<5	7.46	64	22	28	0.1	0.02	6	1.05	0	Satisfactory
4	2081/11/01	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.16	<5	7.47	72	24	32	0.1	0.02	6	1.16	0	Satisfactory
5	2081/11/01	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.16	120.9	24	22	0.1	0.02	6	0.61	0	Satisfactory
6	2081/11/01	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.35	<5	8.02	481	122	138	0.1	0.02	12	0.81	0	Satisfactory
7	2081/11/01	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.72	85.1	22	18	0.1	0.02	4	0.28	0	Satisfactory
8	2081/11/01	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.69	86.9	22	18	0.1	0.02	4	0.91	0	Satisfactory
9	2081/11/01	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.55	87.4	22	18	0.1	0.02	4	1.59	0	Satisfactory
10	2081/11/01	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.38	87.5	22	18	0.1	0.02	4	1.41	0	Satisfactory
11	2081/11/01	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.41	87.1	22	18	0.1	0.02	4	1.42	0	Satisfactory
12	2081/11/01	18:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.57	87.1	22	18	0.1	0.02	4	1.2	0	Satisfactory
13	2081/11/02	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.4	64.2	14	18	0.1	0.02	4	1.6	0	Satisfactory
14	2081/11/02	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.72	98.2	18	18	0.1	0.02	4	1.82	0	Satisfactory
15	2081/11/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.67	71.5	14	18	0.1	0.02	4	1.85	0	Satisfactory
16	2081/11/02	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.5	86.2	26	22	0.1	0.02	6	0.85	0	Satisfactory
17	2081/11/02	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.6	118.2	26	22	0.1	0.02	6	0.78	0	Satisfactory
18	2081/11/02	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.32	80.5	24	22	0.1	0.02	6	0.8	0	Satisfactory
19	2081/11/02	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.40	<5	7.46	57	22	26	0.1	0.02	6	1.03	0	Satisfactory

20	2081/11/02	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.92	<5	7.50	71	24	32	0.1	0.02	6	0.72	0	Satisfactory
21	2081/11/02	14:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.71	<5	7.42	72	24	32	0.1	0.02	6	0.66	0	Satisfactory
22	2081/11/02	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.58	<5	7.16	364	120	78	0.57	7.2	20	0.59	0	Satisfactory
23	2081/11/02	14:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.43	<5	7.2	380	130	80	0.57	7.2	20	1.36	0	Satisfactory
24	2081/11/02	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.94	<5	7.6	87.4	32	38	0.1	0.02	4	0.1	0	Satisfactory
25	2081/11/02	13:35	Tripureshwar	Anamnagar SRT	Treated	Clear	0.2	<5	7.92	90.1	24	22	0.1	0.02	6	1.25	0	Satisfactory
26	2081/11/02	11:20	Maharajgunj	Balaju SRT	Treated	Clear	0.4	<5	8.15	92.5	24	24	0.1	0.02	6	0.2	0	Satisfactory
27	2081/11/02	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.15	115.9	26	22	0.1	0.02	6	0.38	0	Satisfactory
28	2081/11/02	12:55	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	7.78	80.1	24	22	0.1	0.02	6	0.3	0	Satisfactory
29	2081/11/02	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	7.6	101.5	24	26	0.1	0.02	8	1.62	0	Satisfactory
30	2081/11/02	13:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.61	79	24	22	0.1	0.02	6	0.62	0	Satisfactory
31	2081/11/02	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	1.5	<5	7.93	77.4	24	22	0.1	0.02	6	0.4	0	Satisfactory
32	2081/11/02	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	7.89	459	118	130	0.1	0.02	10	0.63	0	Satisfactory
33	2081/11/02	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.78	85.1	22	18	0.1	0.02	4	0.3	0	Satisfactory
34	2081/11/02	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.62	87	22	18	0.1	0.02	4	1.3	0	Satisfactory
35	2081/11/02	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.73	86.6	22	18	0.1	0.02	4	1.42	0	Satisfactory
36	2081/11/02	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.8	87.5	22	18	0.1	0.02	4	1.36	0	Satisfactory
37	2081/11/02	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.53	86.1	22	18	0.1	0.02	4	1.32	0	Satisfactory
38	2081/11/02	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.68	87.4	22	18	0.1	0.02	4	1.07	0	Satisfactory
39	2081/11/03	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.72	64.5	14	18	0.1	0.02	4	0.95	0	Satisfactory
40	2081/11/03	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.82	82.7	24	22	0.1	0.02	6	0.86	0	Satisfactory
41	2081/11/03	6:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.48	61	22	28	0.1	0.02	6	0.97	0	Satisfactory
42	2081/11/03	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.70	<5	7.46	70	24	32	0.1	0.02	6	0.37	0	Satisfactory
43	2081/11/03	14:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.83	<5	7.51	71	24	32	0.1	0.02	6	0.73	0	Satisfactory
44	2081/11/03	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.66	77.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
45	2081/11/03	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.79	86.1	22	18	0.1	0.02	4	0.42	0	Satisfactory
46	2081/11/03	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.58	86.3	22	18	0.1	0.02	4	1.17	0	Satisfactory
47	2081/11/03	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.56	86.6	22	18	0.1	0.02	4	1.12	0	Satisfactory

48	2081/11/03	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.53	87	22	18	0.1	0.02	4	1.44	0	Satisfactory
49	2081/11/03	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.48	86.2	22	18	0.1	0.02	4	1.48	0	Satisfactory
50	2081/11/04	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.3	<5	7.73	58.1	14	18	0.1	0.02	4	0.62	0	Satisfactory
51	2081/11/04	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.8	58.1	14	18	0.1	0.02	4	1.74	0	Satisfactory
52	2081/11/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.83	58	16	18	0.1	0.02	4	1.6	0	Satisfactory
53	2081/11/04	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.8	58.8	14	18	0.1	0.02	4	1.88	0	Satisfactory
54	2081/11/04	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.33	80	24	22	0.1	0.02	6	0.69	0	Satisfactory
55	2081/11/04	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.66	78.5	24	22	0.1	0.02	6	1.33	0	Satisfactory
56	2081/11/04	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.75	78.6	26	22	0.1	0.02	6	0.89	0	Satisfactory
57	2081/11/04	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.75	79	26	22	0.1	0.02	6	0.88	0	Satisfactory
58	2081/11/04	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.50	62	22	28	0.1	0.02	6	1.03	0	Satisfactory
59	2081/11/04	12:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.90	<5	7.46	68	24	32	0.1	0.02	6	0.82	0	Satisfactory
60	2081/11/04	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.47	<5	7.42	70	24	32	0.1	0.02	6	0.36	0	Satisfactory
61	2081/11/04	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	2.71	<5	7.22	367	122	78	0.57	7.2	20	0.95	0	Satisfactory
62	2081/11/04	14:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.82	<5	7.24	383	130	80	0.57	7.2	20	1.36	0	Satisfactory
63	2081/11/04	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.9	<5	7.7	88.3	32	38	0.1	0.02	4	0.1	0	Satisfactory
64	2081/11/04	13:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.89	80.8	26	22	0.1	0.02	6	1	0	Satisfactory
65	2081/11/04	11:30	Maharajgunj	Balaju SRT	Treated	Clear	1	<5	8.2	85.6	26	22	0.1	0.02	6	0.2	0	Satisfactory
66	2081/11/04	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.3	<5	7.55	79.3	26	22	0.1	0.02	6	0.2	0	Satisfactory
67	2081/11/04	13:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.9	77.9	26	22	0.1	0.02	6	0.34	0	Satisfactory
68	2081/11/04	12:50	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	8.1	95	26	22	0.1	0.02	8	0.93	0	Satisfactory
69	2081/11/04	14:00	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.63	76.6	26	22	0.1	0.02	6	0.5	0	Satisfactory
70	2081/11/04	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	8.17	79.3	26	22	0.1	0.02	6	0.41	0	Satisfactory
71	2081/11/04	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.54	<5	7.94	457	120	120	0.1	0.02	12	0.84	0	Satisfactory
72	2081/11/04	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.81	84.5	22	18	0.1	0.02	4	0.18	0	Satisfactory
73	2081/11/04	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.4	<5	7.68	87	22	18	0.1	0.02	4	0.98	0	Satisfactory
74	2081/11/04	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.48	88.4	22	18	0.1	0.02	4	1.42	0	Satisfactory
75	2081/11/04	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.56	86.3	22	18	0.1	0.02	4	1.1	0	Satisfactory

76	2081/11/04	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.45	85.6	22	18	0.1	0.02	4	1.27	0	Satisfactory
77	2081/11/04	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.61	87.1	22	18	0.1	0.02	4	1.42	0	Satisfactory
78	2081/11/04	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.54	86.2	22	18	0.1	0.02	4	1.24	0	Satisfactory
79	2081/11/05	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.72	76.2	16	18	0.1	0.02	4	1.54	0	Satisfactory
80	2081/11/05	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.25	78.5	14	18	0.1	0.02	4	2.36	0	Satisfactory
81	2081/11/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.2	71.5	16	18	0.1	0.02	4	1.45	0	Satisfactory
82	2081/11/05	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.38	72.8	16	18	0.1	0.02	4	0.82	0	Satisfactory
83	2081/11/05	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.5	79.5	26	22	0.1	0.02	6	1.41	0	Satisfactory
84	2081/11/05	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.35	82.5	24	22	0.1	0.02	6	1.57	0	Satisfactory
85	2081/11/05	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.3	81.5	26	22	0.1	0.02	6	0.66	0	Satisfactory
86	2081/11/05	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.4	85.7	24	22	0.1	0.02	6	0.82	0	Satisfactory
87	2081/11/05	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.42	<5	7.47	64	22	28	0.1	0.02	6	1.05	0	Satisfactory
88	2081/11/05	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.86	<5	7.41	69	24	32	0.1	0.02	6	0.72	0	Satisfactory
89	2081/11/05	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.60	<5	7.37	71	24	32	0.1	0.02	6	0.62	0	Satisfactory
90	2081/11/05	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.36	<5	7.28	372	124	78	0.76	7.2	20	1.22	0	Satisfactory
91	2081/11/05	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	7.4	493	148	94	0.76	5.6	24	3.86	0	Satisfactory
92	2081/11/05	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.91	<5	7.33	411	136	86	0.76	6.4	24	1.88	0	Satisfactory
93	2081/11/05	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.76	<5	7.8	84.8	34	38	0.1	0.02	4	0.24	0	Satisfactory
94	2081/11/05	14:05	Tripureshwar	Anamnagar SRT	Treated	Clear	0.8	<5	7.72	85.7	24	22	0.1	0.02	6	0.66	0	Satisfactory
95	2081/11/05	11:15	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.3	81.7	24	22	0.1	0.02	6	0.2	0	Satisfactory
96	2081/11/05	7:00	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.5	80.2	24	22	0.1	0.02	6	0.63	0	Satisfactory
97	2081/11/05	13:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.74	82.5	24	22	0.1	0.02	6	0.29	0	Satisfactory
98	2081/11/05	12:25	Kirtipur	Kirtipur SRT	Treated	Clear	0.6	<5	7.65	173.2	24	34	0.1	0.02	12	0.2	0	Satisfactory
99	2081/11/05	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	1	<5	7.89	100.7	24	22	0.1	0.02	6	0.5	0	Satisfactory
100	2081/11/05	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.85	84.7	24	22	0.1	0.02	6	0.29	0	Satisfactory
101	2081/11/05	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.71	<5	7.87	460	120	116	0.1	0.02	12	0.75	0	Satisfactory
102	2081/11/05	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.54	87.5	22	18	0.1	0.02	4	0.69	0	Satisfactory
103	2081/11/05	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.58	86.8	22	18	0.1	0.02	4	1.57	0	Satisfactory
104	2081/11/05	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.47	86.2	22	18	0.1	0.02	4	1.77	0	Satisfactory
105	2081/11/05	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.51	86.6	22	18	0.1	0.02	4	1.25	0	Satisfactory
106	2081/11/05	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.48	86.3	22	18	0.1	0.02	4	1.07	0	Satisfactory
107	2081/11/05	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.52	86.4	22	18	0.1	0.02	4	1.5	0	Satisfactory

108	2081/11/05	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.56	87.6	22	18	0.1	0.02	4	1.36	0	Satisfactory
109	2081/11/06	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.28	63.2	16	18	0.1	0.02	4	1.26	0	Satisfactory
110	2081/11/06	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.45	69.5	18	18	0.1	0.02	4	1.48	0	Satisfactory
111	2081/11/06	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.5	68.7	16	18	0.1	0.02	4	1.2	0	Satisfactory
112	2081/11/06	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.25	68.2	16	18	0.1	0.02	4	1	0	Satisfactory
113	2081/11/06	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.35	81.5	26	22	0.1	0.02	6	0.81	0	Satisfactory
114	2081/11/06	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1.5	<5	7.3	90.2	26	22	0.1	0.02	6	0.84	0	Satisfactory
115	2081/11/06	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	1	<5	7.4	91.7	26	22	0.1	0.02	6	0.91	0	Satisfactory
116	2081/11/06	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.35	92.7	26	22	0.1	0.02	6	0.77	0	Satisfactory
117	2081/11/06	6:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.31	62	22	28	0.1	0.02	6	1.05	0	Satisfactory
118	2081/11/06	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.44	<5	7.42	72	24	32	0.1	0.02	6	0.97	0	Satisfactory
119	2081/11/06	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.67	<5	7.35	71	24	32	0.1	0.02	6	0.87	0	Satisfactory
120	2081/11/06	10:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.59	<5	7.35	405	130	90	0.57	7	20	0.66	0	Satisfactory
121	2081/11/06	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.06	<5	7.33	384	128	88	0.57	7	24	0.93	0	Satisfactory
122	2081/11/06	16:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.83	<5	7.75	83.2	34	38	0.1	0.02	4	1.02	0	Satisfactory
123	2081/11/06	14:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.6	<5	7.1	89.7	26	22	0.1	0.02	6	0.75	0	Satisfactory
124	2081/11/06	11:45	Maharajgunj	Balaju SRT	Treated	Clear	0.4	<5	7.3	92.3	26	22	0.1	0.02	6	0.22	0	Satisfactory
125	2081/11/06	7:30	Bhaktapur	Katunje SRT	Treated	Clear	1.7	<5	7.19	96.2	28	22	0.1	0.02	6	1.08	0	Satisfactory
126	2081/11/06	13:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.72	84.7	26	22	0.1	0.02	6	0.25	0	Satisfactory
127	2081/11/06	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	2.9	<5	7.68	157.2	28	34	0.1	0.02	12	0.2	0	Satisfactory
128	2081/11/06	13:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.6	116.7	26	22	0.1	0.02	6	0.48	0	Satisfactory
129	2081/11/06	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.65	94.7	26	22	0.1	0.02	6	0.69	0	Satisfactory
130	2081/11/06	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.74	<5	7.87	467	120	114	0.1	0.02	10	0.64	0	Satisfactory
131	2081/11/06	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.04	<5	7.5	87.6	22	18	0.1	0.02	4	0.18	0	Satisfactory
132	2081/11/06	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.98	<5	7.53	87.6	22	18	0.1	0.02	4	0.77	0	Satisfactory
133	2081/11/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.74	88.3	22	18	0.1	0.02	4	1.36	0	Satisfactory
134	2081/11/06	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.97	<5	7.44	90	22	18	0.1	0.02	4	1.27	0	Satisfactory
135	2081/11/06	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.69	89.2	22	18	0.1	0.02	4	1.01	0	Satisfactory
136	2081/11/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.61	88.9	22	18	0.1	0.02	4	1.09	0	Satisfactory
137	2081/11/06	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.54	87.4	22	18	0.1	0.02	4	1.48	0	Satisfactory
138	2081/11/07	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.72	69.5	16	18	0.1	0.02	4	0.8	0	Satisfactory
139	2081/11/07	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.78	86.7	26	22	0.1	0.02	6	0.65	0	Satisfactory
140	2081/11/07	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.46	<5	7.27	60	22	26	0.1	0.02	6	1.03	0	Satisfactory
141	2081/11/07	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.80	<5	7.44	73	24	32	0.1	0.02	6	1.20	0	Satisfactory
142	2081/11/07	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.71	<5	7.38	71	24	32	0.1	0.02	6	0.57	0	Satisfactory

143	2081/11/07	12:15	Tripureshwar	Anamnagar SRT	Treated	Clear	1.3	<5	7.62	96.7	26	22	0.1	0.02	6	0.46	0	Satisfactory
144	2081/11/07	13:30	Maharajgunj	Balaju SRT	Treated	Clear	1.2	<5	7.8	91.8	26	22	0.1	0.02	6	0.2	0	Satisfactory
145	2081/11/07	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.55	98.5	26	22	0.1	0.02	6	0.2	0	Satisfactory
146	2081/11/07	11:00	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.72	96.7	26	24	0.1	0.02	6	0.85	0	Satisfactory
147	2081/11/07	11:00	Kirtipur	Kirtipur SRT	Treated	Clear	2	<5	7.68	133.5	26	32	0.1	0.02	14	0.3	0	Satisfactory
148	2081/11/07	12:00	Baneshwor	Minbhawan SRT	Treated	Clear	1.3	<5	7.67	97.2	26	22	0.1	0.02	6	0.33	0	Satisfactory
149	2081/11/07	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	2	<5	8.17	100	26	24	0.1	0.02	6		0	Satisfactory
150	2081/11/07	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.71	85.7	22	18	0.1	0.02	4	0.2	0	Satisfactory
151	2081/11/07	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.57	87.9	22	18	0.1	0.02	4	1.3	0	Satisfactory
152	2081/11/07	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.38	86.6	22	18	0.1	0.02	4	0.66	0	Satisfactory
153	2081/11/07	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.43	88.5	22	18	0.1	0.02	4	1.21	0	Satisfactory
154	2081/11/07	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.24	87.4	22	18	0.1	0.02	4	1.3	0	Satisfactory
155	2081/11/07	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.35	<5	7.25	87.8	22	18	0.1	0.02	4	1.56	0	Satisfactory
156	2081/11/08	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.7	71.2	16	18	0.1	0.02	4	0.62	0	Satisfactory
157	2081/11/08	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.35	74.5	16	18	0.1	0.02	4	1.12	0	Satisfactory
158	2081/11/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.4	76.2	14	18	0.1	0.02	4	1.27	0	Satisfactory
159	2081/11/08	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.48	77.2	16	18	0.1	0.02	4	1.2	0	Satisfactory
160	2081/11/08	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.52	91.2	26	22	0.1	0.02	6	0.76	0	Satisfactory
161	2081/11/08	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.4	90.7	26	22	0.1	0.02	6	1.22	0	Satisfactory
162	2081/11/08	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.7	<5	7.34	86.7	26	22	0.1	0.02	6	1.42	0	Satisfactory
163	2081/11/08	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.42	90.2	24	22	0.1	0.02	6	1.02	0	Satisfactory
164	2081/11/08	6:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.30	62	22	26	0.1	0.02	6	1.01	0	Satisfactory
165	2081/11/08	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.86	<5	7.43	73	24	32	0.1	0.02	6	0.94	0	Satisfactory
166	2081/11/08	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.62	<5	7.44	74	24	32	0.1	0.02	6	0.85	0	Satisfactory
167	2081/11/08	15:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.73	95.8	24	22	0.1	0.02	6	0.68	0	Satisfactory
168	2081/11/08	11:25	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.65	102.9	24	26	0.1	0.02	6	0.54	0	Satisfactory
169	2081/11/08	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1	<5	7.45	97.5	24	22	0.1	0.02	6	1.26	0	Satisfactory
170	2081/11/08	12:45	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.85	114.7	24	26	0.1	0.02	6	0.77	0	Satisfactory
171	2081/11/08	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	2	<5	7.65	97.7	24	22	0.1	0.02	8	0.2	0	Satisfactory
172	2081/11/08	14:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.3	<5	7.68	94.2	24	22	0.1	0.02	6	0.81	0	Satisfactory
173	2081/11/08	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.68	95.2	24	22	0.1	0.02	6	0.52	0	Satisfactory
174	2081/11/08	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.77	<5	7.81	455	120	116	0.1	0.02	10	0.71	0	Satisfactory
175	2081/11/08	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.6	86.9	22	18	0.1	0.02	4	0.12	0	Satisfactory
176	2081/11/08	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.6	87	22	18	0.1	0.02	4	0.77	0	Satisfactory
177	2081/11/08	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.51	86.9	22	18	0.1	0.02	4	1.14	0	Satisfactory
178	2081/11/08	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.43	87.7	22	18	0.1	0.02	4	1.1	0	Satisfactory

179	2081/11/08	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.48	87.2	22	18	0.1	0.02	4	1.27	0	Satisfactory
180	2081/11/08	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.54	87.8	22	18	0.1	0.02	4	1.47	0	Satisfactory
181	2081/11/08	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.42	87.7	22	18	0.1	0.02	4	1.4	0	Satisfactory
182	2081/11/09	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.1	64.7	16	18	0.1	0.02	4	1.24	0	Satisfactory
183	2081/11/09	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.35	67.5	18	18	0.1	0.02	4	1.1	0	Satisfactory
184	2081/11/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.68	60.2	14	18	0.1	0.02	4	0.68	0	Satisfactory
185	2081/11/09	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.7	92.7	26	22	0.1	0.02	6	0.54	0	Satisfactory
186	2081/11/09	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.72	95.7	26	22	0.1	0.02	6	0.65	0	Satisfactory
187	2081/11/09	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.52	91.7	24	22	0.1	0.02	6	0.7	0	Satisfactory
188	2081/11/09	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.45	<5	7.33	64	22	28	0.1	0.02	6	1.05	0	Satisfactory
189	2081/11/09	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.73	<5	7.51	71	24	32	0.1	0.02	6	0.45	0	Satisfactory
190	2081/11/09	13:50	Maharajgunj	Bansbari SRT	Treated	Clear	3.13	<5	7.48	73	24	32	0.1	0.02	6	0.28	0	Satisfactory
191	2081/11/09	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.84	<5	7.2	365	122	76	0.76	7.5	18	0.78	0	Satisfactory
192	2081/11/09	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.88	<5	7.62	86.6	32	38	0.1	0.02	4	0.35	0	Satisfactory
193	2081/11/09	13:15	Tripureshwar	Anamnagar SRT	Treated	Clear	0.9	<5	7.75	97.2	24	22	0.1	0.02	6	0.59	0	Satisfactory
194	2081/11/09	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.78	98.5	24	22	0.1	0.02	6	0.44	0	Satisfactory
195	2081/11/09	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.7	<5	6.55	93.1	24	22	0.1	0.02	6	0.28	0	Satisfactory
196	2081/11/09	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.78	97.8	24	24	0.1	0.02	6	0.88	0	Satisfactory
197	2081/11/09	11:50	Kirtipur	Kirtipur SRT	Treated	Clear	2.3	<5	7.72	111.2	24	26	0.1	0.02	12	0.28	0	Satisfactory
198	2081/11/09	13:05	Baneshwor	Minbhawan SRT	Treated	Clear	2.7	<5	7.85	110.2	24	22	0.1	0.02	6	0.2	0	Satisfactory
199	2081/11/09	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.68	96.5	24	22	0.1	0.02	6	0.75	0	Satisfactory
200	2081/11/09	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	7.97	486	128	120	0.1	0.02	12	0.54	0	Satisfactory
201	2081/11/09	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.38	<5	7.7	88.5	22	18	0.1	0.02	4	0.21	0	Satisfactory
202	2081/11/09	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.36	<5	7.5	90.4	22	18	0.1	0.02	4	0.78	0	Satisfactory
203	2081/11/09	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.25	<5	7.31	90.7	22	18	0.1	0.02	4	0.87	0	Satisfactory
204	2081/11/09	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	2.21	<5	7.42	91.8	22	18	0.1	0.02	4	1.2	0	Satisfactory
205	2081/11/09	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	1.52	<5	7.58	89.7	22	18	0.1	0.02	4	1.5	0	Satisfactory
206	2081/11/09	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.58	89.8	22	18	0.1	0.02	4	1.36	0	Satisfactory
207	2081/11/10	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.6	63.5	16	18	0.1	0.02	4	0.73	0	Satisfactory
208	2081/11/10	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.79	86.7	24	22	0.1	0.02	6	0.62	0	Satisfactory
209	2081/11/10	6:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	7.31	57	22	28	0.1	0.02	6	1.02	0	Satisfactory
210	2081/11/10	10:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.84	<5	7.46	72	24	32	0.1	0.02	6	0.96	0	Satisfactory
211	2081/11/10	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	1.14	<5	7.54	72	24	32	0.1	0.02	6	0.50	0	Satisfactory
212	2081/11/10	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.73	87.2	22	18	0.1	0.02	4	1.14	0	Satisfactory
213	2081/11/10	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.96	<5	7.53	86.3	22	18	0.1	0.02	4	1.2	0	Satisfactory

214	2081/11/10	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.73	91.3	22	18	0.1	0.02	4	0.4	0	Satisfactory
215	2081/11/11	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.57	64.7	16	18	0.1	0.02	4	0.6	0	Satisfactory
216	2081/11/11	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.3	54.7	16	18	0.1	0.02	4	1.21	0	Satisfactory
217	2081/11/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.9	<5	7.52	55.3	14	18	0.1	0.02	4	1.06	0	Satisfactory
218	2081/11/11	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	7.4	53.7	14	18	0.1	0.02	4	1.23	0	Satisfactory
219	2081/11/11	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.45	91.7	26	22	0.1	0.02	6	0.28	0	Satisfactory
220	2081/11/11	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.26	76.7	26	22	0.1	0.02	6	0.35	0	Satisfactory
221	2081/11/11	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.55	74.7	16	22	0.1	0.02	6	0.4	0	Satisfactory
222	2081/11/11	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.38	76.7	26	22	0.1	0.02	6	0.98	0	Satisfactory
223	2081/11/11	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.33	<5	7.34	64	22	28	0.1	0.02	6	1.04	0	Satisfactory
224	2081/11/11	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.67	<5	7.48	72	24	32	0.1	0.02	6	0.70	0	Satisfactory
225	2081/11/11	15:00	Maharajgunj	Bansbari SRT	Treated	Clear	0.53	<5	7.36	72	24	32	0.1	0.02	6	0.51	0	Satisfactory
226	2081/11/11	11:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.37	<5	7.3	460	144	94	1.14	7.5	22	3.57	0	Satisfactory
227	2081/11/11	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.96	<5	7.28	418	132	88	1.14	7.5	22	1.69	0	Satisfactory
228	2081/11/11	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	7.25	398	132	80	1.14	7.5	22	1.12	0	Satisfactory
229	2081/11/11	10:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.08	<5	7.7	89.9	34	38	0.1	0.02	4	0.41	0	Satisfactory
230	2081/11/11	15:10	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.75	81.2	26	22	0.1	0.02	6	0.79	0	Satisfactory
231	2081/11/11	11:25	Maharajgunj	Balaju SRT	Treated	Clear	1.2	<5	7.35	76.5	26	22	0.1	0.02	6	0.35	0	Satisfactory
232	2081/11/11	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	7.25	96.5	26	22	0.1	0.02	6	0.6	0	Satisfactory
233	2081/11/11	13:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.75	81.5	26	22	0.1	0.02	6	0.63	0	Satisfactory
234	2081/11/11	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.8	<5	7.73	87.2	26	22	0.1	0.02	8	0.2	0	Satisfactory
235	2081/11/11	13:25	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.68	82.3	26	22	0.1	0.02	6	0.63	0	Satisfactory
236	2081/11/11	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.75	79.5	26	22	0.1	0.02	6	0.8	0	Satisfactory
237	2081/11/11	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	8.05	451	120	116	0.1	0.02	12	0.63	0	Satisfactory
238	2081/11/11	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.67	87.2	22	18	0.1	0.02	4	0.28	0	Satisfactory
239	2081/11/11	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.63	87.5	22	18	0.1	0.02	4	0.86	0	Satisfactory
240	2081/11/11	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.45	89.1	22	18	0.1	0.02	4	1.24	0	Satisfactory
241	2081/11/11	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.58	89.3	22	18	0.1	0.02	4	1.18	0	Satisfactory
242	2081/11/11	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.42	87.4	22	18	0.1	0.02	4	1.17	0	Satisfactory
243	2081/11/11	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.35	89.6	22	18	0.1	0.02	4	1.01	0	Satisfactory
244	2081/11/11	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.41	88.7	22	18	0.1	0.02	4	1.31	0	Satisfactory
245	2081/11/12	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.68	56.7	16	18	0.1	0.02	4	0.99	0	Satisfactory
246	2081/11/12	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.65	53.8	16	18	0.1	0.02	4	1.79	0	Satisfactory

247	2081/11/12	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.45	53.7	16	18	0.1	0.02	4	1.4	0	Satisfactory
248	2081/11/12	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.25	54.7	16	18	0.1	0.02	4	1.3	0	Satisfactory
249	2081/11/12	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.53	77.8	24	22	0.1	0.02	6	0.62	0	Satisfactory
250	2081/11/12	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.57	69.2	24	22	0.1	0.02	6	0.56	0	Satisfactory
251	2081/11/12	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.5	76.2	24	22	0.1	0.02	6	0.65	0	Satisfactory
252	2081/11/12	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.13	64.7	22	22	0.1	0.02	6	0.68	0	Satisfactory
253	2081/11/12	6:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.31	<5	7.31	65	22	28	0.1	0.02	6	1.02	0	Satisfactory
254	2081/11/12	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.42	<5	7.34	72	24	32	0.1	0.02	6	1.06	0	Satisfactory
255	2081/11/12	14:50	Maharajgunj	Bansbari SRT	Treated	Clear	0.27	<5	7.28	71	24	32	0.1	0.02	6	0.50	0	Satisfactory
256	2081/11/12	10:45	Madhyapur Thimi	Bode WTP	Treated	Clear	3.37	<5	7.32	403	130	88	1.14	7.5	22	1.9	0	Satisfactory
257	2081/11/12	14:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.85	<5	7.3	409	130	88	1.14	7.5	22	0.75	0	Satisfactory
258	2081/11/12	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.81	<5	7.28	399	132	80	0.95	7.5	20	0.72	0	Satisfactory
259	2081/11/12	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.33	<5	7.76	90.5	34	40	0.1	0.02	4	0.34	0	Satisfactory
260	2081/11/12	12:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.62	90.2	24	22	0.1	0.02	6	1.03	0	Satisfactory
261	2081/11/12	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.3	<5	7.48	80.2	24	22	0.1	0.02	6	0.63	0	Satisfactory
262	2081/11/12	11:40	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.25	156.2	24	32	0.1	0.02	12	0.2	0	Satisfactory
263	2081/11/12	12:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.58	71.7	24	22	0.1	0.02	6	0.45	0	Satisfactory
264	2081/11/12	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	7.1	77.2	24	22	0.1	0.02	6	0.65	0	Satisfactory
265	2081/11/12	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.74	86.4	22	18	0.1	0.02	4	0.33	0	Satisfactory
266	2081/11/12	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.56	87.2	22	18	0.1	0.02	4	0.83	0	Satisfactory
267	2081/11/12	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.4	88.7	22	18	0.1	0.02	4	1.23	0	Satisfactory
268	2081/11/12	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.51	87.9	22	18	0.1	0.02	4	1.3	0	Satisfactory
269	2081/11/12	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.43	88.8	22	18	0.1	0.02	4	0.74	0	Satisfactory
270	2081/11/12	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.57	<5	7.51	90.1	22	18	0.1	0.02	4	1.36	0	Satisfactory
271	2081/11/12	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.51	87.8	22	18	0.1	0.02	4	1.27	0	Satisfactory
272	2081/11/13	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.52	59.2	16	18	0.1	0.02	4	2.44	0	Satisfactory
273	2081/11/13	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.45	51.7	14	18	0.1	0.02	4	0.65	0	Satisfactory
274	2081/11/13	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.3	69.2	16	18	0.1	0.02	4	0.85	0	Satisfactory

275	2081/11/13	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.5	67.2	14	18	0.1	0.02	4	1.9	0	Satisfactory
276	2081/11/13	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.42	78.7	24	22	0.1	0.02	6	0.34	0	Satisfactory
277	2081/11/13	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.45	77.2	24	22	0.1	0.02	6	0.47	0	Satisfactory
278	2081/11/13	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.48	78.2	24	22	0.1	0.02	6	0.62	0	Satisfactory
279	2081/11/13	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.62	78.7	26	22	0.1	0.02	6	0.95	0	Satisfactory
280	2081/11/13	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.33	66	22	28	0.1	0.02	6	1.05	0	Satisfactory
281	2081/11/13	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.23	<5	7.50	73	24	32	0.1	0.02	6	1.04	0	Satisfactory
282	2081/11/13	15:25	Maharajgunj	Bansbari SRT	Treated	Clear	0.16	<5	7.33	71	24	32	0.1	0.02	6	0.60	0	Satisfactory
283	2081/11/13	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	7.2	378	126	74	0.95	7.5	12	0.2	0	Satisfactory
284	2081/11/13	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.32	<5	7.7	90.8	34	38	0.1	0.02	4	0.3	0	Satisfactory
285	2081/11/13	14:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.4	<5	7.75	81.2	26	22	0.1	0.02	6	1.05	0	Satisfactory
286	2081/11/13	11:30	Maharajgunj	Balaju SRT	Treated	Clear	1	<5	7.45	86.2	26	22	0.1	0.02	6	0.48	0	Satisfactory
287	2081/11/13	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.7	<5	7.3	82.7	26	22	0.1	0.02	6	0.75	0	Satisfactory
288	2081/11/13	12:50	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.5	102.3	26	24	0.1	0.02	6	0.42	0	Satisfactory
289	2081/11/13	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	0.8	<5	7.95	123.2	26	28	0.1	0.02	12	0.2	0	Satisfactory
290	2081/11/13	13:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.9	116.2	26	22	0.1	0.02	6	0.55	0	Satisfactory
291	2081/11/13	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.95	85.7	26	22	0.1	0.02	6	0.75	0	Satisfactory
292	2081/11/13	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.57	87.2	22	18	0.1	0.02	4	0.71	0	Satisfactory
293	2081/11/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.54	87	22	18	0.1	0.02	4	1.21	0	Satisfactory
294	2081/11/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.03	89.6	22	18	0.1	0.02	4	1.37	0	Satisfactory
295	2081/11/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.32	<5	6.93	90.4	22	18	0.1	0.02	4	1.31	0	Satisfactory
296	2081/11/13	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.34	90.4	22	18	0.1	0.02	4	1.43	0	Satisfactory
297	2081/11/13	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.42	<5	7.48	89.2	22	18	0.1	0.02	4	1.29	0	Satisfactory
298	2081/11/14	9:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.6	<5	7.68	65.7	16	18	0.1	0.02	4	0.94	0	Satisfactory
299	2081/11/14	9:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.79	85.7	24	22	0.1	0.02	6	0.63	0	Satisfactory
300	2081/11/14	6:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.27	57	22	26	0.1	0.02	6	1.02	0	Satisfactory
301	2081/11/14	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.13	<5	7.32	73	24	32	0.1	0.02	6	1.34	0	Satisfactory
302	2081/11/14	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.17	<5	7.33	73	24	32	0.1	0.02	6	0.62	0	Satisfactory

303	2081/11/14	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.48	85.2	24	22	0.1	0.02	6	0.22	0	Satisfactory
304	2081/11/14	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.54	88.2	22	18	0.1	0.02	4	0.18	0	Satisfactory
305	2081/11/14	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.56	88.7	22	18	0.1	0.02	4	0.81	0	Satisfactory
306	2081/11/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.28	90.5	22	18	0.1	0.02	4	1.76	0	Satisfactory
307	2081/11/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.31	89.6	22	18	0.1	0.02	4	1.46	0	Satisfactory
308	2081/11/14	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.33	<5	7.24	89.5	22	18	0.1	0.02	4	1.35	0	Satisfactory
309	2081/11/15	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.68	61.7	16	18	0.1	0.02	4	0.65	0	Satisfactory
310	2081/11/15	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.53	62.5	18	18	0.1	0.02	4	0.65	0	Satisfactory
311	2081/11/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.52	65.7	16	18	0.1	0.02	4	0.78	0	Satisfactory
312	2081/11/15	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.86	65.3	16	18	0.1	0.02	4	0.87	0	Satisfactory
313	2081/11/15	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.68	78.5	26	22	0.1	0.02	6	0.2	0	Satisfactory
314	2081/11/15	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.58	78.2	26	22	0.1	0.02	6	1.08	0	Satisfactory
315	2081/11/15	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.69	78.7	24	22	0.1	0.02	6	0.82	0	Satisfactory
316	2081/11/15	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.79	77.8	24	22	0.1	0.02	6	0.65	0	Satisfactory
317	2081/11/15	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.26	65	22	28	0.1	0.02	6	1.13	0	Satisfactory
318	2081/11/15	10:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.20	<5	7.36	72	24	32	0.1	0.02	6	1.08	0	Satisfactory
319	2081/11/15	15:45	Maharajgunj	Bansbari SRT	Treated	Clear	0.31	<5	7.34	73	24	32	0.1	0.02	6	1.04	0	Satisfactory
320	2081/11/15	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.76	<5	7.14	400	126	86	0.95	7.5	20	0.73	0	Satisfactory
321	2081/11/15	14:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.8	<5	7.22	371	126	76	0.95	7.5	20	0.45	0	Satisfactory
322	2081/11/15	9:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.43	<5	7.7	91.7	34	38	0.1	0.02	4	0.11	0	Satisfactory
323	2081/11/15	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.95	96.2	24	24	0.1	0.02	6	0.91	0	Satisfactory
324	2081/11/15	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.45	81.2	26	22	0.1	0.02	6	0.52	0	Satisfactory
325	2081/11/15	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.87	230.8	24	38	0.1	0.02	18	0.2	0	Satisfactory
326	2081/11/15	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.48	76.2	24	22	0.1	0.02	6	0.62	0	Satisfactory
327	2081/11/15	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.6	86.2	22	18	0.1	0.02	4	0.26	0	Satisfactory
328	2081/11/15	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.46	<5	7.54	86.4	22	18	0.1	0.02	4	0.71	0	Satisfactory
329	2081/11/15	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.32	88.4	22	18	0.1	0.02	4	1.53	0	Satisfactory
330	2081/11/15	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.39	90.4	22	18	0.1	0.02	4	1.91	0	Satisfactory

331	2081/11/15	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.47	<5	7.59	88.8	22	18	0.1	0.02	4	1.3	0	Satisfactory
332	2081/11/15	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.5	88.9	22	18	0.1	0.02	4	1.2	0	Satisfactory
333	2081/11/15	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.37	<5	7.48	88.9	22	18	0.1	0.02	4	1.07	0	Satisfactory
334	2081/11/15	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.36	<5	7.35	87.9	22	18	0.1	0.02	4	0.91	0	Satisfactory
335	2081/11/16	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	7.74	55	16	18	0.1	0.02	4	1.41	0	Satisfactory
336	2081/11/16	15:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.72	73.6	24	22	0.1	0.02	6	0.92	0	Satisfactory
337	2081/11/16	6:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.26	<5	7.26	60	22	28	0.1	0.02	6	0.96	0	Satisfactory
338	2081/11/16	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.71	<5	7.41	72	24	32	0.1	0.02	6	1.24	0	Satisfactory
339	2081/11/16	15:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.47	<5	7.36	71	24	32	0.1	0.02	6	0.85	0	Satisfactory
340	2081/11/16	8:20	Tripureshwar	Anamnagar SRT	Treated	Clear	0.9	<5	8.07	81.2	24	22	0.1	0.02	6	1.04	0	Satisfactory
341	2081/11/16	10:05	Maharajgunj	Balaju SRT	Treated	Clear	1.6	<5	7.93	78.6	24	22	0.1	0.02	6	0.61	0	Satisfactory
342	2081/11/16	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.85	80.2	26	22	0.1	0.02	6	0.2	0	Satisfactory
343	2081/11/16	12:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.97	84.7	24	22	0.1	0.02	6	1.28	0	Satisfactory
344	2081/11/16	9:25	Kirtipur	Kirtipur SRT	Treated	Clear	1.2	<5	8.17	96	24	22	0.1	0.02	8	0.7	0	Satisfactory
345	2081/11/16	8:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.95	79.4	24	22	0.1	0.02	6	1.14	0	Satisfactory
346	2081/11/16	10:45	Maharajgunj	Panipokhari SRT	Treated	Clear	1.4	<5	7.97	79.7	24	22	0.1	0.02	6	0.85	0	Satisfactory
347	2081/11/16	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.48	86.4	22	18	0.1	0.02	4	0.7	0	Satisfactory
348	2081/11/16	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.6	88	22	18	0.1	0.02	4	0.89	0	Satisfactory
349	2081/11/16	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.48	88.2	22	18	0.1	0.02	4	0.81	0	Satisfactory
350	2081/11/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.86	55.5	14	18	0.1	0.02	4	0.57	0	Satisfactory
351	2081/11/17	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.75	75	26	22	0.1	0.02	6	1.11	0	Satisfactory
352	2081/11/17	6:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.31	62	22	28	0.1	0.02	6	1.04	0	Satisfactory
353	2081/11/17	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.16	<5	7.53	71	24	32	0.1	0.02	6	0.83	0	Satisfactory
354	2081/11/17	15:30	Maharajgunj	Bansbari SRT	Treated	Clear	0.43	<5	7.57	72	24	32	0.1	0.02	6	0.90	0	Satisfactory
355	2081/11/17	11:00	Tripureshwar	Anamnagar SRT	Treated	Clear	1.3	<5	8.03	81.3	26	22	0.1	0.02	6	1.03	0	Satisfactory
356	2081/11/17	12:40	Maharajgunj	Balaju SRT	Treated	Clear	1.3	<5	8.13	78.1	26	22	0.1	0.02	6	0.47	0	Satisfactory
357	2081/11/17	8:00	Bhaktapur	Katunje SRT	Treated	Clear	1.2	<5	7.89	80.2	26	22	0.1	0.02	6	0.49	0	Satisfactory
358	2081/11/17	11:35	Lalitpur	Khumaltar SRT	Treated	Clear	1.8	<5	8.09	79	26	22	0.1	0.02	6	0.49	0	Satisfactory
359	2081/11/17	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.9	<5	7.96	110	26	24	0.1	0.02	12	0.81	0	Satisfactory
360	2081/11/17	10:00	Baneshwor	Minbhawan SRT	Treated	Clear	1	<5	7.8	77.6	26	22	0.1	0.02	6	0.76	0	Satisfactory
361	2081/11/17	13:10	Maharajgunj	Panipokhari SRT	Treated	Clear	1.4	<5	8.16	80.8	26	22	0.1	0.02	6	0.95	0	Satisfactory
362	2081/11/17	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.69	86.2	22	18	0.1	0.02	4	0.48	0	Satisfactory
363	2081/11/17	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.53	87	22	18	0.1	0.02	4	0.9	0	Satisfactory
364	2081/11/17	11:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.3	87.3	22	18	0.1	0.02	4	1.46	0	Satisfactory
365	2081/11/17	13:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.37	86.8	22	18	0.1	0.02	4	1.41	0	Satisfactory
366	2081/11/17	15:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.49	87.4	22	18	0.1	0.02	4	1.34	0	Satisfactory

367	2081/11/17	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.46	86.8	22	18	0.1	0.02	4	0.96	0	Satisfactory
368	2081/11/17	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.58	85.4	22	18	0.1	0.02	4	0.63	0	Satisfactory
369	2081/11/18	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.85	63.7	16	18	0.1	0.02	4	0.39	0	Satisfactory
370	2081/11/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.89	68.2	16	18	0.1	0.02	4	0.75	0	Satisfactory
371	2081/11/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.89	66.2	16	18	0.1	0.02	4	0.65	0	Satisfactory
372	2081/11/18	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.76	64.2	18	18	0.1	0.02	4	0.88	0	Satisfactory
373	2081/11/18	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.78	81.5	26	22	0.1	0.02	6	0.84	0	Satisfactory
374	2081/11/18	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.87	80.7	26	22	0.1	0.02	6	0.75	0	Satisfactory
375	2081/11/18	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.89	80.2	26	22	0.1	0.02	6	0.82	0	Satisfactory
376	2081/11/18	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.85	80.5	26	22	0.1	0.02	6	0.8	0	Satisfactory
377	2081/11/18	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.28	55	20	22	0.1	0.02	6	1.02	0	Satisfactory
378	2081/11/18	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	1.30	<5	7.34	71	24	32	0.1	0.02	6	0.71	0	Satisfactory
379	2081/11/18	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	1.04	<5	7.30	73	24	32	0.1	0.02	6	0.76	0	Satisfactory
380	2081/11/18	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.44	<5	7.26	407	128	90	0.95	6.5	24	1.7	0	Satisfactory
381	2081/11/18	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.74	<5	7.28	387	126	78	0.95	7.5	14	0.27	0	Satisfactory
382	2081/11/18	10:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.12	<5	7.58	90.2	32	38	0.1	0.02	4	0.71	0	Satisfactory
383	2081/11/18	15:55	Tripureshwar	Anamnagar SRT	Treated	Clear	1.7	<5	7.85	81.7	26	22	0.1	0.02	6	0.98	0	Satisfactory
384	2081/11/18	12:20	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	8.1	98.5	26	22	0.1	0.02	6	0.47	0	Satisfactory
385	2081/11/18	8:00	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.88	80.2	26	22	0.1	0.02	6	0.44	0	Satisfactory
386	2081/11/18	14:05	Lalitpur	Khumaltar SRT	Treated	Clear	1.5	<5	7.87	79.7	26	22	0.1	0.02	6	0.89	0	Satisfactory
387	2081/11/18	13:05	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.9	91.5	26	22	0.1	0.02	8	0.2	0	Satisfactory
388	2081/11/18	15:40	Baneshwor	Minbhawan SRT	Treated	Clear	1.7	<5	7.88	79.2	26	22	0.1	0.02	6	1.1	0	Satisfactory
389	2081/11/18	10:40	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	8.4	95.7	26	22	0.1	0.02	6	0.81	0	Satisfactory
390	2081/11/18	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.81	<5	7.89	458	122	118	0.1	0.02	12	0.76	0	Satisfactory
391	2081/11/18	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.58	85.9	22	18	0.1	0.02	4	0.53	0	Satisfactory
392	2081/11/18	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.53	86.3	22	18	0.1	0.02	4	0.64	0	Satisfactory
393	2081/11/18	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.52	87.2	22	18	0.1	0.02	4	1.34	0	Satisfactory
394	2081/11/18	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.48	88.6	22	18	0.1	0.02	4	1.12	0	Satisfactory
395	2081/11/18	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.38	89.7	22	18	0.1	0.02	4	1.2	0	Satisfactory
396	2081/11/18	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.33	86.6	22	18	0.1	0.02	4	1.52	0	Satisfactory
397	2081/11/18	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.38	88.9	22	18	0.1	0.02	4	1.1	0	Satisfactory
398	2081/11/18	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.36	87.4	22	18	0.1	0.02	4	0.91	0	Satisfactory
399	2081/11/19	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.99	56.2	14	18	0.1	0.02	4	0.6	0	Satisfactory

400	2081/11/19	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.47	60	14	18	0.1	0.02	4	0.85	0	Satisfactory
401	2081/11/19	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.28	62.7	14	18	0.1	0.02	4	0.61	0	Satisfactory
402	2081/11/19	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.4	65.7	14	18	0.1	0.02	4	0.87	0	Satisfactory
403	2081/11/19	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.85	78.9	26	22	0.1	0.02	6	1.3	0	Satisfactory
404	2081/11/19	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.9	<5	7.47	78.8	26	22	0.1	0.02	6	1	0	Satisfactory
405	2081/11/19	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.5	76.2	26	22	0.1	0.02	6	0.78	0	Satisfactory
406	2081/11/19	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.57	78.5	24	22	0.1	0.02	6	0.69	0	Satisfactory
407	2081/11/19	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.41	<5	7.26	65	22	28	0.1	0.02	6	1.05	0	Satisfactory
408	2081/11/19	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.74	<5	7.31	72	24	32	0.1	0.02	6	1.21	0	Satisfactory
409	2081/11/19	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.46	<5	7.26	74	24	32	0.1	0.02	6	1.31	0	Satisfactory
410	2081/11/19	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.82	<5	7.25	391	126	84	0.95	7.5	20	0.79	0	Satisfactory
411	2081/11/19	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	7.3	413	132	90	0.95	7.5	24	3.54	0	Satisfactory
412	2081/11/19	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.86	<5	7.3	405	130	90	0.95	7.5	24	3.06	0	Satisfactory
413	2081/11/19	9:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.6	91.3	34	38	0.1	0.02	4	0.36	0	Satisfactory
414	2081/11/19	15:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.25	78.5	24	22	0.1	0.02	6	0.68	0	Satisfactory
415	2081/11/19	11:30	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	7.55	88.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
416	2081/11/19	9:15	Bhaktapur	Katunje SRT	Treated	Clear	1.7	<5	7.12	79.2	26	22	0.1	0.02	6	0.49	0	Satisfactory
417	2081/11/19	13:05	Lalitpur	Khumaltar SRT	Treated	Clear	0.7	<5	7.3	78.7	24	22	0.1	0.02	6	0.67	0	Satisfactory
418	2081/11/19	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	0.5	<5	7.75	86.2	24	22	0.1	0.02	8	0.58	0	Satisfactory
419	2081/11/19	14:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.3	79.4	24	22	0.1	0.02	6	0.95	0	Satisfactory
420	2081/11/19	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.7	<5	7.89	85.7	24	22	0.1	0.02	6	0.64	0	Satisfactory
421	2081/11/19	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.79	<5	7.52	89.3	22	18	0.1	0.02	4	0.8	0	Satisfactory
422	2081/11/19	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.31	89.6	22	18	0.1	0.02	4	1.41	0	Satisfactory
423	2081/11/19	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.43	<5	7.15	88.6	22	18	0.1	0.02	4	1.2	0	Satisfactory
424	2081/11/19	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.5	88.5	22	18	0.1	0.02	4	1.23	0	Satisfactory
425	2081/11/19	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.95	<5	7.52	89.3	22	18	0.1	0.02	4	1.2	0	Satisfactory
426	2081/11/19	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.5	88	22	18	0.1	0.02	4	1.1	0	Satisfactory
427	2081/11/19	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.91	<5	7.54	88.9	22	18	0.1	0.02	4	1.4	0	Satisfactory
428	2081/11/19	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.54	85.8	22	18	0.1	0.02	4	0.48	0	Satisfactory
429	2081/11/20	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.87	59.2	16	18	0.1	0.02	4	0.94	0	Satisfactory
430	2081/11/20	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	7.62	56.7	16	18	0.1	0.02	4	0.68	0	Satisfactory
431	2081/11/20	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.68	58.7	16	18	0.1	0.02	4	0.65	0	Satisfactory
432	2081/11/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	7.89	67.2	16	18	0.1	0.02	4	0.65	0	Satisfactory

433	2081/11/20	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.76	73.7	24	22	0.1	0.02	6	0.65	0	Satisfactory
434	2081/11/20	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.52	79.2	24	22	0.1	0.02	6	0.84	0	Satisfactory
435	2081/11/20	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.58	78.2	26	22	0.1	0.02	6	0.7	0	Satisfactory
436	2081/11/20	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.89	80.2	26	22	0.1	0.02	6	0.82	0	Satisfactory
437	2081/11/20	6:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.81	<5	7.30	65	22	28	0.1	0.02	6	1.02	0	Satisfactory
438	2081/11/20	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	1.24	<5	7.28	73	24	32	0.1	0.02	6	1.18	0	Satisfactory
439	2081/11/20	15:20	Maharajgunj	Bansbari SRT	Treated	Clear	0.93	<5	7.26	73	24	32	0.1	0.02	6	1.42	0	Satisfactory
440	2081/11/20	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3	<5	7.25	428	130	86	1.14	7.5	22	1.46	0	Satisfactory
441	2081/11/20	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.13	<5	7.27	435	132	86	1.14	7.5	22	0.78	0	Satisfactory
442	2081/11/20	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.2	<5	7.29	427	130	86	1.14	7.5	22	0.71	0	Satisfactory
443	2081/11/20	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.47	<5	7.6	91.1	32	38	0.1	0.02	4	0.31	0	Satisfactory
444	2081/11/20	9:15	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.35	72.7	26	22	0.1	0.02	6	0.55	0	Satisfactory
445	2081/11/20	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.54	88	22	18	0.1	0.02	4	0.79	0	Satisfactory
446	2081/11/20	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.36	86.5	22	18	0.1	0.02	4	1.09	0	Satisfactory
447	2081/11/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.42	88.2	22	18	0.1	0.02	4	1.73	0	Satisfactory
448	2081/11/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.53	88.5	22	18	0.1	0.02	4	1.68	0	Satisfactory
449	2081/11/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.54	87	22	18	0.1	0.02	4	1.61	0	Satisfactory
450	2081/11/20	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.23	86.8	22	18	0.1	0.02	4	1.43	0	Satisfactory
451	2081/11/20	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.28	88.1	22	18	0.1	0.02	4	1.32	0	Satisfactory
452	2081/11/20	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.86	<5	7.63	87	22	18	0.1	0.02	4	0.63	0	Satisfactory
453	2081/11/21	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.57	57.2	16	18	0.1	0.02	4	0.61	0	Satisfactory
454	2081/11/21	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.6	57.3	16	18	0.1	0.02	4	0.72	0	Satisfactory
455	2081/11/21	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.89	72.6	16	18	0.1	0.02	4	0.8	0	Satisfactory
456	2081/11/21	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	7.73	65.8	16	18	0.1	0.02	4	0.75	0	Satisfactory
457	2081/11/21	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.52	78.2	26	22	0.1	0.02	6	0.82	0	Satisfactory
458	2081/11/21	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.52	78.5	24	22	0.1	0.02	6	0.65	0	Satisfactory
459	2081/11/21	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.75	86.2	26	22	0.1	0.02	6	0.6	0	Satisfactory
460	2081/11/21	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.77	86.7	24	22	0.1	0.02	6	0.59	0	Satisfactory
461	2081/11/21	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.42	<5	7.28	63	22	26	0.1	0.02	6	1.05	0	Satisfactory
462	2081/11/21	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.72	<5	7.41	72	24	32	0.1	0.02	6	0.35	0	Satisfactory
463	2081/11/21	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.61	<5	7.31	72	24	32	0.1	0.02	6	0.64	0	Satisfactory
464	2081/11/21	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.93	<5	7.2	37	124	70	1.14	7.5	12	0.2	0	Satisfactory
465	2081/11/21	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.47	<5	7.62	92.9	32	38	0.1	0.02	4	0.4	0	Satisfactory

466	2081/11/21	9:15	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	7.15	79.5	24	22	0.1	0.02	6	0.47	0	Satisfactory
467	2081/11/21	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.89	<5	7.48	88.4	22	18	0.1	0.02	4	1.27	0	Satisfactory
468	2081/11/21	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.93	<5	7.59	87.3	22	18	0.1	0.02	4	0.86	0	Satisfactory
469	2081/11/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.3	88.4	22	18	0.1	0.02	4	1.67	0	Satisfactory
470	2081/11/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.78	<5	7.56	88.1	22	18	0.1	0.02	4	1.44	0	Satisfactory
471	2081/11/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.44	89.1	22	18	0.1	0.02	4	1.69	0	Satisfactory
472	2081/11/21	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.88	<5	7.56	88.3	22	18	0.1	0.02	4	1.39	0	Satisfactory
473	2081/11/21	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.49	<5	7.51	89.7	22	18	0.1	0.02	4	1.12	0	Satisfactory
474	2081/11/21	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.68	85.8	22	18	0.1	0.02	4	0.41	0	Satisfactory
475	2081/11/22	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.67	64.7	16	18	0.1	0.02	4	1.07	0	Satisfactory
476	2081/11/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.75	61.7	16	18	0.1	0.02	4	1.16	0	Satisfactory
477	2081/11/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.74	62.5	16	18	0.1	0.02	4	1.22	0	Satisfactory
478	2081/11/22	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.78	60.7	16	18	0.1	0.02	4	1.1	0	Satisfactory
479	2081/11/22	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.65	79.2	26	22	0.1	0.02	6	1	0	Satisfactory
480	2081/11/22	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.6	<5	7.8	77.2	24	22	0.1	0.02	6	1.43	0	Satisfactory
481	2081/11/22	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.79	80.2	24	22	0.1	0.02	6	1.31	0	Satisfactory
482	2081/11/22	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.72	79.5	26	22	0.1	0.02	6	0.95	0	Satisfactory
483	2081/11/22	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.27	63	22	26	0.1	0.02	6	0.97	0	Satisfactory
484	2081/11/22	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.46	<5	7.40	73	24	32	0.1	0.02	6	0.26	0	Satisfactory
485	2081/11/22	15:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.30	<5	7.37	73	24	32	0.1	0.02	6	1.10	0	Satisfactory
486	2081/11/22	23:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	7.88	79.5	26	22	0.1	0.02	6	0.96	0	Satisfactory
487	2081/11/22	11:10	Maharajgunj	Balaju SRT	Treated	Clear	2.3	<5	8.21	94.2	26	22	0.1	0.02	6	0.2	0	Satisfactory
488	2081/11/22	9:15	Bhaktapur	Katunje SRT	Treated	Clear	1.7	<5	7.57	86.7	24	22	0.2	0.02	6	0.2	0	Satisfactory
489	2081/11/22	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	2.5	<5	8.3	144.7	26	26	0.1	0.02	14	0.2	0	Satisfactory
490	2081/11/22	12:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.78	78.2	26	22	0.1	0.02	6	0.8	0	Satisfactory
491	2081/11/22	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.8	<5	8.27	87.2	26	22	0.1	0.02	6	0.41	0	Satisfactory
492	2081/11/22	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.65	<5	7.68	89	22	18	0.1	0.02	4	0.96	0	Satisfactory
493	2081/11/22	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.8	<5	7.45	88.9	22	18	0.1	0.02	4	1.56	0	Satisfactory
494	2081/11/22	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.87	<5	7.32	89.4	22	18	0.1	0.02	4	2.1	0	Satisfactory
495	2081/11/22	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.59	<5	7.42	89	22	18	0.1	0.02	4	1.74	0	Satisfactory
496	2081/11/22	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.51	88.4	22	18	0.1	0.02	4	1.04	0	Satisfactory

497	2081/11/22	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.29	87.8	22	18	0.1	0.02	4	1.17	0	Satisfactory
498	2081/11/22	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.41	88.2	22	18	0.1	0.02	4	1.32	0	Satisfactory
499	2081/11/22	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.53	88.6	22	18	0.1	0.02	4	1.19	0	Satisfactory
500	2081/11/23	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	7.97	55.7	16	18	0.1	0.02	4	0.45	0	Satisfactory
501	2081/11/23	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.87	56.7	16	18	0.1	0.02	4	0.68	0	Satisfactory
502	2081/11/23	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.69	70.2	16	18	0.1	0.02	4	0.87	0	Satisfactory
503	2081/11/23	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.85	77.2	24	22	0.1	0.02	6	0.38	0	Satisfactory
504	2081/11/23	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	7.78	76.2	24	22	0.1	0.02	6	1.41	0	Satisfactory
505	2081/11/23	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.5	<5	8.12	82.2	26	22	0.1	0.02	6	0.98	0	Satisfactory
506	2081/11/23	6:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.21	<5	7.30	63	22	28	0.1	0.02	6	1.05	0	Satisfactory
507	2081/11/23	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.36	<5	7.47	73	24	32	0.1	0.02	6	1.07	0	Satisfactory
508	2081/11/23	13:55	Maharajgunj	Bansbari SRT	Treated	Clear	0.63	<5	7.31	75	26	34	0.1	0.02	6	0.37	0	Satisfactory
509	2081/11/23	10:50	Tripureshwar	Anamnagar SRT	Treated	Clear	0.5	<5	8.1	83.4	26	22	0.1	0.02	6	1.05	0	Satisfactory
510	2081/11/23	9:15	Bhaktapur	Katunje SRT	Treated	Clear	0.9	<5	7.17	85.2	26	22	0.1	0.02	6	0.53	0	Satisfactory
511	2081/11/23	11:35	Lalitpur	Khumaltar SRT	Treated	Clear	0.8	<5	8.45	91.2	26	22	0.1	0.02	6	0.8	0	Satisfactory
512	2081/11/23	12:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.7	<5	7.98	91.7	26	22	0.1	0.02	8	0.32	0	Satisfactory
513	2081/11/23	11:05	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	8.25	81.7	26	22	0.1	0.02	6	0.37	0	Satisfactory
514	2081/11/23	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.69	<5	7.68	88.1	22	18	0.1	0.02	4	0.5	0	Satisfactory
515	2081/11/23	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.56	89.1	22	18	0.1	0.02	4	1.39	0	Satisfactory
516	2081/11/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.27	89.6	22	18	0.1	0.02	4	2.14	0	Satisfactory
517	2081/11/23	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.28	88	22	18	0.1	0.02	4	1.46	0	Satisfactory
518	2081/11/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.85	<5	7.42	87.5	22	18	0.1	0.02	4	1.35	0	Satisfactory
519	2081/11/23	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.34	88.2	22	18	0.1	0.02	4	1.1	0	Satisfactory
520	2081/11/24	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.7	60.7	16	18	0.1	0.02	4	0.72	0	Satisfactory
521	2081/11/24	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.75	75.7	24	22	0.1	0.02	6	0.53	0	Satisfactory
522	2081/11/24	6:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.20	<5	7.30	54	20	24	0.1	0.02	6	1.02	0	Satisfactory
523	2081/11/24	7:55	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.73	68.7	24	18	0.1	0.02	6	0.65	0	Satisfactory
524	2081/11/24	9:30	Maharajgunj	Balaju SRT	Treated	Clear	1.8	<5	7.75	68.7	24	18	0.1	0.02	6	0.45	0	Satisfactory
525	2081/11/24	9:15	Bhaktapur	Katunje SRT	Treated	Clear	1.5	<5	7.9	85.3	24	22	0.1	0.02	6	0.26	0	Satisfactory
526	2081/11/24	9:00	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.78	66.2	24	20	0.1	0.02	8	0.2	0	Satisfactory
527	2081/11/24	7:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.7	<5	7.73	69.5	24	22	0.1	0.02	6	0.75	0	Satisfactory
528	2081/11/24	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.6	<5	7.75	62.7	24	22	0.1	0.02	6	0.53	0	Satisfactory
529	2081/11/24	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.64	<5	7.7	86.6	22	18	0.1	0.02	4	0.31	0	Satisfactory
530	2081/11/24	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.65	86.9	22	18	0.1	0.02	4	1.21	0	Satisfactory

531	2081/11/24	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.48	88.6	22	18	0.1	0.02	4	1.55	0	Satisfactory
532	2081/11/24	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.64	86.2	22	18	0.1	0.02	4	1.4	0	Satisfactory
533	2081/11/24	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.68	<5	7.62	86.3	22	18	0.1	0.02	4	0.31	0	Satisfactory
534	2081/11/24	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.56	<5	7.58	87.6	22	18	0.1	0.02	4	1.38	0	Satisfactory
535	2081/11/25	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.6	56.2	16	18	0.1	0.02	4	0.2	0	Satisfactory
536	2081/11/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.57	63.7	16	18	0.1	0.02	4	1.8	0	Satisfactory
537	2081/11/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.57	63.7	16	18	0.1	0.02	4	1.8	0	Satisfactory
538	2081/11/25	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.74	61.8	16	18	0.1	0.02	4	1.17	0	Satisfactory
539	2081/11/25	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.3	<5	7.98	78.5	24	22	0.1	0.02	6	0.2	0	Satisfactory
540	2081/11/25	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.8	<5	7.5	83.2	26	22	0.1	0.02	6		0	Satisfactory
541	2081/11/25	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.72	83.2	26	22	0.1	0.02	6	1.31	0	Satisfactory
542	2081/11/25	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.4	<5	7.8	77.8	26	22	0.1	0.02	6	1.32	0	Satisfactory
543	2081/11/25	6:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.27	61	22	26	0.1	0.02	6	1.05	0	Satisfactory
544	2081/11/25	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.6	<5	7.26	380	126	74	1.14	7.5	20	0.75	0	Satisfactory
545	2081/11/25	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.99	<5	7.19	368	124	72	1.14	7.5	16	0.2	0	Satisfactory
546	2081/11/25	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.87	<5	7.28	367	124	72	1.14	7.5	16	0.21	0	Satisfactory
547	2081/11/25	9:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.45	<5	7.6	90.1	32	38	0.1	0.02	4	0.35	0	Satisfactory
548	2081/11/25	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	7.3	79.8	26	22	0.1	0.02	6	1.1	0	Satisfactory
549	2081/11/25	9:15	Bhaktapur	Katunje SRT	Treated	Clear	0.7	<5	7.98	86.2	26	22	0.1	0.02	6	0.91	0	Satisfactory
550	2081/11/25	11:15	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.25	77.2	26	22	0.1	0.02	6	0.46	0	Satisfactory
551	2081/11/25	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.51	<5	7.86	460	122	120	0.1	0.02	12	0.81	0	Satisfactory
552	2081/11/25	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.73	<5	7.73	86.9	22	18	0.1	0.02	4	0.21	0	Satisfactory
553	2081/11/25	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.62	89.6	22	18	0.1	0.02	4	0.54	0	Satisfactory
554	2081/11/25	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.39	92	22	18	0.1	0.02	4	2.29	0	Satisfactory
555	2081/11/25	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.81	<5	7.52	88.5	22	18	0.1	0.02	4	0.83	0	Satisfactory
556	2081/11/25	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.44	88.3	22	18	0.1	0.02	4	1.29	0	Satisfactory
557	2081/11/25	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.84	<5	7.42	88.2	22	18	0.1	0.02	4	1.25	0	Satisfactory
558	2081/11/25	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.51	88	22	18	0.1	0.02	4	1.33	0	Satisfactory
559	2081/11/25	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.72	<5	7.58	88.3	22	18	0.1	0.02	4	0.94	0	Satisfactory
560	2081/11/26	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.72	58.7	14	18	0.1	0.02	4	1.02	0	Satisfactory
561	2081/11/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.52	69.2	16	18	0.1	0.02	4	1.35	0	Satisfactory

562	2081/11/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.72	57.3	16	18	0.1	0.02	4	1.23	0	Satisfactory
563	2081/11/26	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.68	57.2	16	18	0.1	0.02	4	1.57	0	Satisfactory
564	2081/11/26	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.62	80.2	26	22	0.1	0.02	6	1.53	0	Satisfactory
565	2081/11/26	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.5	79.2	26	22	0.1	0.02	6	1.38	0	Satisfactory
566	2081/11/26	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.2	<5	7.6	76.2	26	22	0.1	0.02	6	1.2	0	Satisfactory
567	2081/11/26	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.65	80.2	26	22	0.1	0.02	6	1.81	0	Satisfactory
568	2081/11/26	6:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.28	63	22	26	0.1	0.02	6	0.96	0	Satisfactory
569	2081/11/26	10:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.65	<5	7.28	396	126	88	1.14	7.5	20	1.71	0	Satisfactory
570	2081/11/26	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.8	<5	7.28	394	126	88	1.14	7.5	20	1.46	0	Satisfactory
571	2081/11/26	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.94	<5	7.22	392	124	86	1.14	7.5	20	0.55	0	Satisfactory
572	2081/11/26	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.57	<5	7.7	94	32	38	0.1	0.02	4	0.6	0	Satisfactory
573	2081/11/26	11:30	Tripureshwar	Anamnagar SRT	Treated	Clear	0.6	<5	7.72	83.7	26	22	0.1	0.02	6	0.74	0	Satisfactory
574	2081/11/26	9:15	Bhaktapur	Katunje SRT	Treated	Clear	1.6	<5	7.62	78.7	26	22	0.1	0.02	6	1.05	0	Satisfactory
575	2081/11/26	13:20	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.85	82.3	26	22	0.1	0.02	6	0.95	0	Satisfactory
576	2081/11/26	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	0.4	<5	7.79	81.5	26	22	0.1	0.02	8	0.82	0	Satisfactory
577	2081/11/26	11:55	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.85	80.2	26	22	0.1	0.02	6	0.2	0	Satisfactory
578	2081/11/26	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	7.72	77.8	26	22	0.1	0.02	6	0.93	0	Satisfactory
579	2081/11/26	10:30	Lalitpur	Sainbu WTP	Treated	Clear	1.01	<5	7.97	517	130	124	0.1	0.02	16	0.71	0	Satisfactory
580	2081/11/26	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.6	<5	7.75	87.7	22	18	0.1	0.02	4	0.28	0	Satisfactory
581	2081/11/26	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.52	<5	7.56	90.7	22	18	0.1	0.02	4	1.53	0	Satisfactory
582	2081/11/26	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.47	88.7	22	18	0.1	0.02	4	1.25	0	Satisfactory
583	2081/11/26	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.76	<5	7.34	76.3	22	18	0.1	0.02	4	1.85	0	Satisfactory
584	2081/11/26	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.63	<5	7.39	74.3	22	18	0.1	0.02	4	1.48	0	Satisfactory
585	2081/11/26	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.28	74.4	22	18	0.1	0.02	4	1.44	0	Satisfactory
586	2081/11/26	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.62	<5	7.36	77.1	22	18	0.1	0.02	4	0.83	0	Satisfactory
587	2081/11/26	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.59	74.1	22	18	0.1	0.02	4	0.57	0	Satisfactory
588	2081/11/27	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.76	59.7	16	18	0.1	0.02	4	0.57	0	Satisfactory
589	2081/11/27	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.78	67.2	16	18	0.1	0.02	4	1.03	0	Satisfactory
590	2081/11/27	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.5	69.2	16	18	0.1	0.02	4	1.29	0	Satisfactory
591	2081/11/27	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.55	69.7	16	18	0.1	0.02	4	0.98	0	Satisfactory
592	2081/11/27	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	81.2	26	22	0.1	0.02	6	0.78	0	Satisfactory
593	2081/11/27	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.78	79.5	26	22	0.1	0.02	6	1	0	Satisfactory

594	2081/11/27	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.57	80.2	26	22	0.1	0.02	6	1.38	0	Satisfactory
595	2081/11/27	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.07	80.5	26	22	0.1	0.02	6	0.92	0	Satisfactory
596	2081/11/27	6:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.34	66	22	28	0.1	0.02	6	1.05	0	Satisfactory
597	2081/11/27	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.56	<5	7.24	369	124	70	0.95	8	12	0.2	0	Satisfactory
598	2081/11/27	13:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2	<5	7.05	365	122	70	0.95	8	12	0.2	0	Satisfactory
599	2081/11/27	10:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.34	<5	7.7	93.3	34	38	0.1	0.02	4	0.1	0	Satisfactory
600	2081/11/27	14:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.1	<5	8.12	81.9	26	22	0.1	0.02	6	0.82	0	Satisfactory
601	2081/11/27	11:50	Maharajgunj	Balaju SRT	Treated	Clear	0.6	<5	8.2	87.2	26	22	0.1	0.02	6	1.16	0	Satisfactory
602	2081/11/27	9:15	Bhaktapur	Katunje SRT	Treated	Clear	0.6	<5	7.6	80.7	26	22	0.1	0.02	6	0.98	0	Satisfactory
603	2081/11/27	12:15	Kirtipur	Kirtipur SRT	Treated	Clear	1.5	<5	7.78	89.7	26	22	0.1	0.02	8	0.2	0	Satisfactory
604	2081/11/27	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.4	<5	8.39	131	26	28	0.1	0.02	6	0.93	0	Satisfactory
605	2081/11/27	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.38	<5	7.85	515	126	124	0.1	0.02	12	0.74	0	Satisfactory
606	2081/11/27	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.74	73.5	22	18	0.1	0.02	4	0.2	0	Satisfactory
607	2081/11/27	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.44	<5	7.73	74.6	22	18	0.1	0.02	4	0.89	0	Satisfactory
608	2081/11/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.41	75.5	22	18	0.1	0.02	4	1.76	0	Satisfactory
609	2081/11/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.39	<5	7.51	72.7	22	18	0.1	0.02	4	1.34	0	Satisfactory
610	2081/11/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.67	<5	7.3	74.1	22	18	0.1	0.02	4	1.41	0	Satisfactory
611	2081/11/27	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.77	<5	7.32	73.6	22	18	0.1	0.02	4	1.26	0	Satisfactory
612	2081/11/27	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.41	74.9	22	18	0.1	0.02	4	1.47	0	Satisfactory
613	2081/11/27	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.51	<5	7.52	74.6	22	18	0.1	0.02	4	1.38	0	Satisfactory
614	2081/11/28	10:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.99	63.7	16	18	0.1	0.02	4	1.2	0	Satisfactory
615	2081/11/28	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	8.05	61.7	16	18	0.1	0.02	4	1.95	0	Satisfactory
616	2081/11/28	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.86	56.2	16	18	0.1	0.02	4	1.1	0	Satisfactory
617	2081/11/28	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.65	62.7	16	18	0.1	0.02	4	1.12	0	Satisfactory
618	2081/11/28	10:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.89	78.7	26	22	0.1	0.02	6	1.37	0	Satisfactory
619	2081/11/28	12:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.93	77.8	26	22	0.1	0.02	6	1.33	0	Satisfactory
620	2081/11/28	14:00	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.7	76.5	26	22	0.1	0.02	6	1.4	0	Satisfactory
621	2081/11/28	15:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	80.2	26	22	0.1	0.02	6	1.3	0	Satisfactory
622	2081/11/28	6:30	Maharajgunj	Bansbari WTP	Treated	Clear	0.28	<5	7.31	71	22	30	0.1	0.02	6	1.03	0	Satisfactory
623	2081/11/28	10:15	Maharajgunj	Bansbari SRT	Treated	Clear	0.33	<5	7.44	75	24	32	0.1	0.02	6	0.54	0	Satisfactory
624	2081/11/28	16:10	Maharajgunj	Bansbari SRT	Treated	Clear	2.21	<5	7.38	73	24	32	0.1	0.02	6	0.81	0	Satisfactory
625	2081/11/28	10:15	Madhyapur Thimi	Bode WTP	Treated	Clear	2.76	<5	7.26	390	128	84	0.95	7.5	18	0.27	0	Satisfactory
626	2081/11/28	9:30	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.3	<5	7.7	90.7	32	38	0.1	0.02	12	0.66	0	Satisfactory
627	2081/11/28	14:00	Tripureshwar	Anamnagar SRT	Treated	Clear	0.7	<5	7.9	82.7	26	22	0.1	0.02	6	0.85	0	Satisfactory
628	2081/11/28	11:50	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.85	83.7	26	22	0.1	0.02	6	1.12	0	Satisfactory

629	2081/11/28	9:15	Bhaktapur	Katunje SRT	Treated	Clear	0.8	<5	7.95	88.7	26	22	0.1	0.02	6	0.2	0	Satisfactory
630	2081/11/28	12:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.8	<5	7.87	110.9	26	28	0.1	0.02	8	1.92	0	Satisfactory
631	2081/11/28	13:45	Baneshwor	Minbhawan SRT	Treated	Clear	0.5	<5	7.37	80.2	26	22	0.1	0.02	6	1.2	0	Satisfactory
632	2081/11/28	11:05	Maharajgunj	Panipokhari SRT	Treated	Clear	0.9	<5	7.85	85.2	26	22	0.1	0.02	6	0.73	0	Satisfactory
633	2081/11/28	10:30	Lalitpur	Sainbu WTP	Treated	Clear	0.97	<5	7.92	520	128	122	0.1	0.02	14	0.76	0	Satisfactory
634	2081/11/28	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.74	<5	7.7	74.5	22	18	0.1	0.02	4	0.68	0	Satisfactory
635	2081/11/28	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.66	<5	7.68	74.2	22	18	0.1	0.02	4	1	0	Satisfactory
636	2081/11/28	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.54	<5	7.33	75.1	22	18	0.1	0.02	4	1.8	0	Satisfactory
637	2081/11/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.01	75.1	22	18	0.1	0.02	4	1.87	0	Satisfactory
638	2081/11/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.71	<5	7.08	74.1	22	18	0.1	0.02	4	1.71	0	Satisfactory
639	2081/11/28	16:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.7	<5	7.1	74	22	18	0.1	0.02	4	1.3	0	Satisfactory
640	2081/11/28	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.38	<5	7.36	74.8	22	18	0.1	0.02	4	1.46	0	Satisfactory
641	2081/11/28	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.58	<5	7.6	74.1	22	18	0.1	0.02	4	1.15	0	Satisfactory
642	2081/11/29	7:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.64	62.7	16	18	0.1	0.02	4	0.63	0	Satisfactory
643	2081/11/29	7:30	Mahankalchaur	Mahankalchaur Melamchi inlet	Treated	Clear	0.1	<5	7.75	80.2	26	22	0.1	0.02	6	0.53	0	Satisfactory
644	2081/11/29	6:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.47	<5	7.34	70	24	30	0.1	0.02	6	1.05	0	Satisfactory
645	2081/11/29	10:10	Maharajgunj	Bansbari SRT	Treated	Clear	0.66	<5	7.47	73	24	32	0.1	0.02	6	0.83	0	Satisfactory
646	2081/11/29	16:40	Maharajgunj	Bansbari SRT	Treated	Clear	1.03	<5	7.44	73	24	32	0.1	0.02	6	0.64	0	Satisfactory
647	2081/11/29	6:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.53	<5	7.74	74.8	22	18	0.1	0.02	4	0.4	0	Satisfactory
648	2081/11/29	8:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.61	<5	7.72	73.3	22	18	0.1	0.02	4	1.19	0	Satisfactory
649	2081/11/29	10:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.55	<5	7.78	73.8	22	18	0.1	0.02	4	1.21	0	Satisfactory
650	2081/11/29	12:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.71	74.7	22	18	0.1	0.02	4	1.28	0	Satisfactory
651	2081/11/29	14:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.5	<5	7.91	77.8	22	18	0.1	0.02	4	1.26	0	Satisfactory
652	2081/11/29	17:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.48	<5	7.55	73.8	22	18	0.1	0.02	4	0.81	0	Satisfactory
653	2081/11/29	19:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.45	<5	7.61	74.6	22	18	0.1	0.02	4	1.21	0	Satisfactory
654	2081/11/29	21:00	Sundarijal WTP Section	New Sundarijal WTP	Treated	Clear	0.41	<5	7.49	74.1	22	18	0.1	0.02	4	1.08	0	Satisfactory